

ANNEXURE-I		
S. No.	REF: IR/TEESTA/001	Rev-00
1	Test Voltage	250V,500V,1000V,2500V,5000V
2	Test Voltage Accuracy	0 to 100kV AC
3	Insulation Resistance	10 Kilo Ohms to 5 Tera Ohms Analog display
		10 Kilo Ohms to 5 Tera Ohms Digital display
4	Accuracy	$\pm 5\%$ @ 1T Ohms
		Automatic Discharge of potential
5	Battery	Internal Rechargeable Battery
6	Test Certificate	Test & Calibration certificate from NABL accredited lab
7	Warranty	Two Years from date of dispatch
8	Operation & Maintenance Manual	To be provided
9	Mandatory Spares (if any)	To be provided
10	Delivery	FOR Rudrapur

अक्षर 20/07/17
(Rupesh Kumar)

ANNEXURE- IR/BHAVINI/001		Rev-00
1	Test Voltage	250V,500V,1000V,2500V,5000V
2	Test Voltage Accuracy	0 to 100kV AC
3	Insulation Resistance	10 Kilo Ohms to 5 Tera Ohms Analog display
		10 Kilo Ohms to 5 Tera Ohms Digital display
4	Accuracy	± 5% @ 1T Ohms
5		Automatic Discharge of potential
6	Battery	Internal Rechargeable Battery
7	Test Certificate	Test & Calibration certificate from NABL accredited lab
8	Warranty	Two Years from date of dispatch
9	Operation & Maintenance Manual	To be provided
10	Mandatory Spares (if any)	To be provided
11	Delivery	FOR Rudrapur

H. Xy - 4
 21/07/12