

Prequalification Requirements for Pneumatic Regulating Actuator vendors:-

- 1) Vendor should have supplied pneumatic regulating actuators with accessories (pneumatic positioner, linkage rods) of minimum torque 15kgm,
- 2) Customer reference details along with old POs/GA drawings/datasheets/quality plan supplied for nearest sizes to be submitted,
- 3) Vendor should have in-house testing facilities – photos to be submitted.