

Annexure-1 (Rev01)

Specifications for 6 KVA Online UPS

Description- 6KVA True Online UPS

Technology-IGBT based True on-line double conversion

Rating-6KVA

Phase-Single in single out

Cooling-Air cooled

Voltage In- 165v - 265v

Voltage out-220V

PF-0.8

No. of Battery required-16/18 (Max)

Battery Charging Current: 7A (Min)

Inbuilt Isolation transformer-Required

Generator compatibility-Required

Inbuilt static bypass-Required

Efficiency->90%

Make-Liebert/APC/Delta/Emerson (VERTIV)

Warranty-2 Year Onsite

Port: Ethernet port with TCP/IP communication card required.

Programmable auto ON/OFF- Required



श्याम सुन्दर पाल
उप प्रबंधक (अनु. / सिविल / डी.टी.बी.)
बी.एच.ई.एल. रुद्रपुर
उत्तराखण्ड - 263153

SHYAM SUNDER PAL
Dy. Mgr. (MNT. / CIVIL / DTG)
B.H.E.L., Rudrapur
Uttarakhand-263153