

ANNEXURE – I

Vendor Pre-Qualification Requirement.

S.N.	DESCRIPTION	VENDOR'S REMARKS(Y/N)
1.0	TECHNICAL:	
1.1	Should have tested material as per, IEC: 61061-3-2 grade T2R & T4R, at any NABL approved testing laboratory (owned or third party) (If Ring is manufactured in India) OR at Suppliers own/third party testing laboratory (If Ring is being imported). (One no. test report of Beech Wood complying to above has to be furnished. These reports shall not be older than 5 years from tender enquiry due date).	
1.2	Should have supplied Tangential beech Wood Top Ring as per IEC: 61061-3-2 to 400kV or above class Power Transformers to any two (2) of major Transformer manufacturers. (2 nos. valid un-priced PO copies of Tangential Ring for Power Transformer, one each from 2 different utilities (from above list), not older than 5 years from tender enquiry due date, to be submitted along with bid.)	
1.3	Performance Certificate OR Any document showing acceptance of material as per above PO copies furnished to be furnished along with bid.	
1.4	Should have capability to manufacture the Ring with the maximum OD of 2860 mm without any joint.(Documentary proof e.g. Machine/Press capacity etc. to be furnished with bid)	
2.0	COMMERCIAL:	
2.1	BHEL reserves the right to verify information and documents submitted by the vendor. In case the information is found to be false/ incorrect, the offer shall be rejected.	
2.2	Unregistered vendors must submit application for registration in Supplier Registration Format (SRF) to our Supplier Development Cell (SDC). Details of formalities and editable SRF, are available on vendor's Portal on our website www.bhel.com	
2.3	VQR shall be applicable for all suppliers.	
2.4	All documents must be in Hindi or English only.	

.....
Signature & Seal Vendor with date