



BHEL, BHOPAL

**TENDER No. HSE/AMC/2020-21/W4**  
**HEALTH SAFETY & ENVIRONMENT ENGINEERING**

Page 1 of 1

**ANNEXURE G**

**ADDRESSABLE TYPE DETECTION SYSTEM AT COMMUNICATION BUILDING**

**1.0** The annual maintenance contract covers

- Fire Detection System installed at Communication Building.

**1.1** Detector & Call Points Details:

System	No. of Zones	No of Detectors	No of Call Points	Cross-Zoning
Ground Floor	16	22	2	NA

**1.2** Alarm Signal/Hooter Details

Detection System	Location of Hooters/Sounders
Communication Building	Passage Ground Floor
	Store Room Ground Floor

**1.3** Panel Details

Location	Type of Panel
Ground Floor	Analogue Addressable Fire Panel (Cooper Make CF1200)
CISF Fire Station	Addressable Fire Alarm Repeater Panel (Cooper Make CF3000PR)

**1.4** Maintaining the system in proper operational condition by regular and systematic examination (once in every quarter).

**1.5** Checking of alarm signal to CISF/Fire control room.