


TENDER ENQUIRY-16E0061

ANNEXURE-A

Technical Specification of 3 phase 4 pole ACB 800Amps:-

Air Circuit Breaker EDO Emax Breaker 800A, 4P,50KA with PR122LSIG Release with metering Module having LCD Display, 20 trip history, Neutral Overload protection, Zone Selective Interlocking, Under/Over Voltage Protection, Under/Over Frequency Protection, Reverse Rower, Over temperature protection, Power/ Energy Measurement, Bargraph, Remote Trip Indication, Thermal Memory, Compatible to Bluetooth communication and facility of self diagnose of release, Fault Curve Recording and waveform recording.

Model No:- E1N800PR122/P-LSIGIn=800A4pWMP


स्कन्दशिव भारद्वाज
वरिष्ठ अभियंता (सामग्री प्रबन्धन)
बी.एच.ई.एल., रुद्रपुर
उत्तराखण्ड - 263153
SKANDSHIV BHARDWAJ
Sr. Engineer (M.M.)
B.H.E.L., Rudrapur
Uttarakhand-263153