

ANNEXURE-A

Liquid oxygen specification for the Indent No. D83090008

Supply of liquid oxygen (LOX) confirming to IS 309 (Latest revision) in supplier's tanker along with PDS , MSDS and T.C. confirming to it's specification for each supply. The liquid oxygen to be unloaded / transferred in to Lox tank of 13 KL located at BHEL /BAP / Ranipet-6. The specification of the filling joint of the tank is pipe size 42.2 OD X 2.77 TK, W.N.Flange (large groove face) 32 NB X 300#, Flange bore 36.66 mm. Supplier shall be suitably arrange the required end joint with gaskets or other suitable joint mating to LOX tank located in BHEL / BAP premises.

Guarantee

Lox supply be confirmed as per IS 309 latest with minimum purity of 99.5%

Measurement Criteria

The supply shall be in Kgs. Will be arrived from the weight difference between the incoming tanker and outgoing tanker. Payment will be made for actual Kgs unloaded in the LOX tank at BAP Ranipet.

Consumption

Approximate consumption per month is 25000 Kgs.

Delivery

Delivery shall be made in staggered manner as and when requested by BHEL with firm price with delivery period of Five working days from the date of purchase order. Delivery per load is as per request by BHEL, BAP, Ranipet. Minimum requirement per load is approximately 7500 Kgs. This may vary according to requirement. Supplier has to give their supply capacities per load in technical bid

Note:- This is a rate contract for a period of ONE year