

QUALIFYING REQUIREMENTS

Revision 00, Dated:29.03.2018

Enquiry Ref: **CSRL PIPES and FITTINGS-SPEC-25:Rev-00**

Item: Carbon steel rubber lined pipes and fittings for NTPC Bongaigaon Project (3x250MW).

The Bidder is required to meet the qualification requirement for Carbon steel rubber lined pipes and fittings as per criteria stipulated below:

Carbon steel rubber lined pipes and fittings for the Wet Limestone based Flue Gas Desulphurization (FGD) System offered by the bidder shall be only from such bidder(s) who have previous experience as supplier and executed / got executed Carbon steel rubber lined pipes and fittings as part of main supply to any thermal power plants/ Chemical plants or for similar applications, such that the supplied rubber lined pipes should have been in successful operation in at least one plant for a period not less than one year reckoned as on the date of bid opening.

The Bidder should provide reference list and performance certificates from End User along with bid.

Prepared By

Checked By

Approved By

(RAJU.P/DM,FGD)

(SK.DASH/DGM,FGD)

(R.LAKSHMANAN/AGM,FGD)