

Annexure-A

Specification sheet for Isolation Transformer

Description- Isolation transformer

Phase- Single Phase

Rating- 8KVA

Type of Isolation- Ultra Galvanic

Wound- Copper

Cooling- Air Cooled

Voltage-220-240V

Ratio- 1:1

Input power indication- Required

Warranty- 1 Year

Applicable IS-2026 (Test certificate required)

Make- (i) COSMOSTATE/BLUE BIRD/Kirloskar Electric/LE TRANSFORMERS INDIA/Danish Private Limited/Krykard

(ii) Make other than mentioned at (i) above shall also be acceptable subject to preior supply of 'Isolation transformer' pf such other make to BHEL/NTPC/Power Grid Corporation/SEBS (Bidder should enclose copy of P.O. with clear name, address & contact detail (Phone no. & email ID) and make of item in support of this requirement)

Shyam
7217120
श्याम सुन्दर पाल
उप प्रबंधक (अनु. विद्युत / डी.टी.जी.)
बी.एच.ई.एल. रुद्रपुर
उत्तराखण्ड - 263153

SHYAM SUNDER PAL
Dy. Mgr. (MNT. / CIVIL / DTG)
B.H.E.L., Rudrapur
Uttarakhand-263153

Bidder Signature *SH*

Anshuman

अंशुमान वर्मा

उप महा प्रबंधक (अनु. विद्युत / डी.टी.जी.)

बी.एच.ई.एल., रुद्रपुर

उत्तराखण्ड - 263153

Anshuman Verma

DGM (Maintenance / IT)

B.H.E.L., Rudrapur

Uttarakhand-263153