

SPECIAL CONTRACT REQUIREMENTS FOR POWER
OPERATED GATE

1. No Indian Standard Specification or Indian Standard materials shall be used for this project.
2. Pneumatic Actuators and associated accessories must be intrinsically safe in accordance with IEC 60079-11
3. All electrical, control and monitoring equipments shall be designed to comply with hazardous area requirements of IEC60079 (Zone 2). Explosion proof to Group IIA & IIB.