

Annexure-I
Pre-Qualification criteria for the Supply of HT VCB Panels

Sl. No	Description	Vendor to confirm
1	The bidder shall be HT Panel Manufacturer (OEM) or their authorized dealer/ channel partner. In case of dealer/ channel partner, necessary authorization document in support of above shall be submitted by vendor quoting the enquiry number. The offered equipment have to be designed, manufactured and tested as per relevant IS/IEC with latest amendments.	
2	Equipment offered shall have Type Test Certificates from accredited laboratory based on ISO/IEC Guide 25 / 17025 or EN 45001. Type test report shall be submitted along with the offer.	
3	Equipment proposed shall be of similar or higher rating and in service for a minimum period of one year and satisfactory performance certificate in respect of this is to be available and submitted.	
4	The bidder shall agree to supply, install and commission the panels that match with the existing HT Panel with ABB make Vmax VCB panel . The busbar chamber shall be matched with the existing switchboard for extension.	