


TECHNICAL REQUIREMENTS

1. 6 mm I/D x 8 mm O/D Crepe paper tubes 600 mm long made of Crepe paper Type-C as per CPS AA-21117 Rev-03 Amd-02. Only start and end of the paper is to be bonded. Materials including glue should be compatible with inhibited mineral insulating transformer oil as per IEC-60296. Conformance to the above is to be submitted with Part-I bid.
2. The supplier should submit test certificate for the offered crepe paper covering all tests as per CPS AA21117 for approval along with the Part-I bid.
3. Only reputed - proven makes of crepe paper are to be used. Make of the paper is to be disclosed with technical bid. Credentials for proof of supplies of the offered crepe paper / crepe paper tubes to any of the following transformer manufacturers are to be submitted with Part-I bid:-

M/s. ABB, M/s. Siemens, , M/s. Alstom, M/s. Crompton, M/s. BHEL, M/s. TELK, M/s. Transformers & Rectifiers, M/s. Bharat Bijlee, M/s. Kirloskar, M/s. EMCO, M/s. Scheneider.

Copies of atleast 02 purchase orders not older than 03 years are to be submitted against proof of supplies along with tax invoice.


15/11/16
(Neeraj Vanshney)