

	TITLE:	SPEC. NO.: PE-TS- 415 165-N001
	TECHNICAL SPECIFICATION	VOLUME: III
	COOLING TOWERS	SECTION:
	COMPLIANCE CERTIFICATE	REV. NO. 0 DATE 19.01.18
		SHEET 1 OF 1

COMPLIANCE CERTIFICATE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions with regard to same.
- b) There are no other deviations w.r.t. specification other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/ CUSTOMER approval & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc.
- d) All drawings/ data-sheets/ calculations etc. submitted along with the offer shall be considered for reference only, same shall be subject to BHEL/ CUSTOMER approval in the event of order.
- e) The offered materials shall be either equivalent or superior to those specified in the specification.

For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.
- f) The commissioning spares shall be supplied on 'As Required Basis' & prices for same included in the base price itself. Prices for special tools & tackles, if any, shall also be included in the base price.
- g) All sub vendors shall be subject to BHEL/ CUSTOMER approval in the event of order.
- h) The Performance guarantees shall stand valid till at least eighteen (18) months after full load commissioning of CT or as per commercial terms and conditions, whichever is later.
- i) Specifically confirm compliance with Cl. Nos. 6.0 and 11.0 and their sub clauses of Sec. C1 of Technical Specification specification.
- j) The hydrostatic testing of piping shall be carried out as specified i.e. at 1.5 times the design pressure.