

Bid Number: GEM/2020/B/878063 Dated: 16-11-2020

Additional Terms and Conditions

View(s)

- 1: Sodium Hypochlorite Solution (Grade 1) conforming to Indian Standard IS 11673(latest) : Yes
- 2: Available Chlorine percent by mass by volume : 9
- 3: Total Chlorine percent by volume(as Cl) : 9
- 4: Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification : Yes
- 5: Test Report to be Submitted to the Buyer on demand : Yes
- 6: Food and drug license available : No
- 7: Food and drug license to be submitted to the Buyer on demand : No
- 8: Packing Type : Air Tight Plastic Containers /cans
- 9: Marking(as per provisions made in clause 6 of IS 11673(latest) : Yes
- 10: Free Alkali (as NaOH) (Min)g/l : 1
- 11: Free Sodium Carbonate Na₂CO₃ (Max)g/l : 0.5
- 12: Iron(as Fe)(Max) ppm : 0.4
- 13: Sodium Chlorate : Traces
- 14: MATERIAL SHOULD BE DELIVERED WITH MATERIAL SAFETY DATA SHEET(MSDS)AT EQUALIZING RESERVOIR OF BHEL (LOCATED ON THE WEST SIDE OF THIRUVERAMBUR POLICE STATION) TRICHY-620014 TAMILNADU.
- 15: THE VENDOR HAS TO DELIVER THE MATERIAL THROUGH HIS TRANSPORT VEHICLE IN HIS CONTAINER FOR WHICH SOUNDNESS CERTIFICATE OF THE CONTAINER IS REQUIRED AND COLLECT EMPTY CONTAINERS THROUGH THE SAME VEHICLE FOR SUBSEQUENT STAGGERED DELIVERIES.
- 16: DELIVERY SHOULD BE STAGGERED IN 70 CONTAINERS PER WEEK OVER A PERIOD OF CONTRACT. PILOT SAMPLE OF 10 LITRES IS REQUIRED ON RECEIPT OF ORDER BEFORE EFFECTING BULK SUPPLY FOR OUR APPROVAL. SUPPLY SHOULD BE AS PER SAMPLE SUBMITTED BY YOU AND APPROVED BY US.
- 17: THE SUPPLIER SHOULD SUBMIT TEST REPORT FOR AVAILABLE /TOTAL CHLORINE AS PER SPECIFICATION FROM CENTRAL GOVT./NABL/ILAC ACCREDITED LAB. DURING FIRST DAY BULK SUPPLY AND ALSO ON DEMAND BY BHEL.
- 18: ADDITIONAL TESTING OF THE QUALITY OF THE SUPPLY WILL BE DONE AT BHEL PLANT LAB TO ENSURE AVAILABILITY OF 9% AVAILABLE CHLORINE PER LITRE OF SOLUTION.
- 19: ACCEPTANCE OF EACH STAGGERED SUPPLY WILL BE GIVEN ONLY AFTER RECEIPT OF THE TEST RESULTS FROM BHEL PLANT LAB AND IF THE SAMPLE PASSES THE REQUIREMENT THEN ONLY DC WILL BE SENT FOR GR CREATION.
- 20: IF ANY ADDITIONAL STAGGERED SUPPLY IS TO BE DONE BASED ON THE INCREASED DEMAND REQUIREMENT FROM THE EQ RESERVOIR IN-CHARGE AND IT IS WITHIN THE PO QTY THEN IT HAS TO BE SUPPLIED WITHIN 4 DAYS FROM THE DATE OF DEMAND GIVEN BY THE IN-CHARGE BY PHONE CALL OR SMS OR EMAIL TO THE SUPPLIER.
- 21: IN CASE OF SHORTAGE/NON SUPPLY OF ITEM IN TIME OR IF THE SUPPLIED ITEM IS NOT OF EXPECTED QUALITYTHE TOTAL CHARGES ON ACCOUNT OF ALTERNATIVE ARRANGEMENTS MADE BY US TO SUPPLY THE SAME SHALL SETTLED BY THE SUPPLIER TO BHEL BEFORE EFFECTING NEXT STAGGERED SUPPLY.
- 22: THE SUPPLIER SHOULD MAINTAIN A REGISTER FOR THE NUMBER CONTAINER

SUPPLIED EACH TIME AND GET THE SIGNATURE OF THE EQ RESERVOIR IN-CHARGE AND SUBMIT THE CONSOLIDATED LIST AT THE END OF EACH MONTH TO HEAD OF CIVIL TOWNSHIP/SERVICES SECTION FOR VERIFICATION.

23: THE RATES QUOTED SHALL BE VALID FROM THE DATE OF AWARDING THE CONTRACT AND THE PERIOD OF CONTRACT WILL BE FOR ONE YEAR FROM THE DATE OF COMMENCEMENT. FURTHER EXTENSION OF CONTRACT PERIOD OR ENHANCEMENT OF THE QUANTITY SHALL BE AS PER STANDARD OPTION CLAUSE OF GEM.

24: MATERIAL SHOULD BE SECURELY AND SUITABLY PACKED TO AVOID TRANSIT DAMAGED AND DAMAGED SUPPLY WILL NOT BE ACCEPTED.

25: THE TRUCK/DRIVER MUST POSSESS 1) VALID DRIVING LICENCE 2) VEHICLE INSURANCE 3) CERTIFICATE OF REGISTRATION 4) CERTIFICATE FROM POLLUTION CONTROL AUTHORITY FOR THE VEHICLE ETC.

26: THE SUPPLIER HAS TO ADHERE TO THE SECURITY POLICY AND NORMS OF BHEL FOR MOVEMENT OF VEHICLES AND MATERIALS. SUPPLIER SHOULD PRODUCE GATE ENTRY PROOF OF PREVIOUS SUPPLY BEFORE TAKING EMPTY CONTAINERS OF THE PREVIOUS SUPPLY.

27: BHEL WILL NOT BE LIABLE FOR ANY MEDICAL ATTENDANCE INJURY LOSS OF THE PERSONS ENGAGED BY THE CONTRACTOR IN THE PREPARATION OR TRANSPORTATION OF THE ITEM TO THE SAID AREAS.

28: ORIGINAL INVOICE SHOULD BE SENT TO
DY.MANAGER/PURCHASE/PSS MATERIALS MANAGEMENT 24 BUILDING 4TH
FLOOR BHEL TRICHY 14 BY THE SUPPLIER HIMSELF.

29: COPY OF THE INVOICE AND DC WITH SECURITY GATE ENTRY SEAL AND RECEIPT SIGNATURE OF THE SHIFT IN-CHARGE OF EQ RESERVOIR SHOULD BE SUBMITTED TO CIVIL TOWNSHIP STORES BY THE SUPPLIER HIMSELF.

Disclaimer: This corrigendum has been published by the Buyer after due approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of the above clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process owing to publication of such corrigendum due to modification of technical specification and / or terms and conditions governing the bid. Buyer has been allowed to publish this corrigendum for upfront information of prospective sellers so that bidder can respond to bid with matching catalog and conditions of bid (if modulated due to publication of the corrigendum on the GeM portal). However, it is to be noted that buyer organization is solely responsible for the corrigendum.