

1. For any technical clarification, please contact Mr. Manoj Santani, Manager (TBEM); Contact No. 0120-6748521; e-mail: manoj.santani@bhel.in
2. For any commercial clarification, please contact Smt. Archana Kumari, Dy. Manager (TBMM) / Sh. S K Jain, AGM (TBMM); Contact No. 0120-6748467 / 8137; e-mail: archanak@bhel.in / skjain@bhel.in
3. Bidder must ensure that their bid is submitted / dropped in the tender box on or before **14.00 Hrs. IST** on the due date of opening at the address as follows:

TENDER Box (Purchase)
Material Management Division
Transmission Business Group
Tower A, 5th Floor, BHEL, Advant Navis IT Business Park
Plot No 7, Sector - 142, Express way Noida
Noida -201305
DISTT- GAUTAM BUDH NAGAR, UP

Or by mail only to tenderbox@bhel.in

4. Proposed delivery plan is **AUG - 2018**. However, vendor has to quote their best possible delivery plan in activity schedule in activity schedule to meet the tender delivery requirement. In case, BHEL's delivery requirement is not met by vendor(s), then a chance may be given to all such vendors to review their quoted delivery schedule in line with BHEL's delivery requirement. However, if vendor fails to meet the requisite delivery plan, then BHEL reserves the right not to consider the offer of such vendor(s).
5. Integrity Pact ñ Not Applicable.
6. Permissible Technical Deviations: No permissible Technical Deviation has been envisaged.
7. Clause No. ñ 7 - If no option is specified, by default option ñ B shall be considered for confirmation.
8. **The link for Online Supplier registration Portal is <https://supplier.bhel.in/>.**
9. **Clause No. 33 for Reverse Auction of NIT shall be as follows:**

"BHEL reserves the right to go for Reverse Auction (RA) (Guidelines as available on www.bhel.com) instead of opening the sealed envelope price bid, submitted by the bidder. This will be decided after techno-commercial evaluation. Bidders to give their acceptance with the offer for participation in RA. Non-acceptance to participate in RA may result in non-consideration of their bids, in case BHEL decides to go for RA.

Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit 'Process compliance form' (to the designated service provider) as well as 'Online sealed bid' in the Reverse Auction. Non-submission of 'Process compliance form' or 'Online sealed bid' by the agreed bidder(s) will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines for suspension of business dealings with suppliers/ contractors (as available on www.bhel.com).

The bidders have to necessarily submit online sealed bid less than or equal to their envelope sealed price bid already submitted to BHEL along with the offer.

The envelope sealed price bid of successful L1 bidder in RA, if conducted, shall also be opened after RA and the order will be placed on lower of the two bids (RA

closing price & envelope sealed price) thus obtained. The bidder having submitted this offer specifically agrees to this condition and undertakes to execute the contract on thus awarded rates.

If it is found that L1 bidder has quoted higher in online sealed bid in comparison to envelope sealed bid for any item(s), the bidder will be issued a warning letter to this effect. However, if the same bidder again defaults on this count in any subsequent tender in the unit, it will be considered as fraud and will invite action by BHEL as per extant guidelines for suspension of business dealings with suppliers/ contractors (as available on www.bhel.com)."

As a reminder to the bidders, system will flash following message (in RED Color) during the course of online sealed bid

"Bidders to submit online sealed bid less than or equal to their envelope sealed bid already submitted to BHEL"

10. Vendors who are not approved with end customer, following credentials are required for customer approval before price bid opening;

- a) Credentials/Performance certificates along with PO copies of similar supplied material during past 3 years highlighting experience with SEBs/State utilities/NTPC/PGCIL.
- b) Audited annual financial turnover during the past 3 years (Encl. copy of 3 years audited balance sheet).
- c) Whether any of the proposed sub vendors have been blacklisted by any State/Central Govt. departments.
- d) If approved for TANGEDCO project then furnish details of approval for the same.

11. Rating wise evaluation for 624 kV and 198 / 216 kV shall be done and separate PO may be placed in case of different L-1 bidders. However evaluation will be done on combined basis for both North Chennai and Uppur, but separate POs will be placed.

12. Pre-Qualification Criteria- As per clause 3.0 of Section 1 of Technical Specification No. – TB- 316-393-002 Rev. 00.

The Bidder must ensure that they confirm the Pre-qualifying requirement.

BHEL Reserves the Right to reject any offer from Bidder in case of Non – Compliance to the Pre-qualifying criteria.

13. Packing Instruction: All boxes/containers are to be distinctly marked with boldly written "TBG" mark on it.

14. Vendor to quote as per specified price format of NIT, otherwise their offer shall be liable to be rejected.
Following confirmation to be provided by vendor:

"We confirm that we have quoted as per specified price format provided along with this tender".

Name:

Signature:

Stamp:

SCHEDULE OF PRICE (Part II) (FOR INDIAN VENDORS)

(BIDDER TO STRICTLY ENSURE SUBMITTING THE PRICE BIDS IN THIS FORMAT)

VENDOR NAME / OFFER REF:

ENQUIRY No. - 228G011 dated 26/04/2018

	S.No.	Description of Item	HSN Code	Unit	Quantity	Unit Price Ex-works (Rs.)	Total Ex-Works (Rs.)	GST @__on Ex Works	Unit Freight & Insurance	Total Freight & Insurance	GST @__on Freight & Insurance	TOTAL (FOR Destination) PRICE (Rs.)
		FOR NORTH CHENNAI										
	1	624 kV, Discharge current-20 kA, Class-V, Creepage-31mm/kV Surge Arrestor complete with all accessories like corona ring, terminal pad, surge counter, insulating base, fixing hardware etc.	85354010	Nos.	3							
	2	Rigid through type Terminal Connector for 624kV Surge Arrestor suitable for Quad Bull AAAC/ Quad Moose ACSR conductor with Horizontal approach	85359090	Nos.	3							
	3	216 kV, Discharge current-10 kA, Class-III, Creepage-31mm/kV Surge Arrestor complete with all accessories like corona ring, terminal pad, surge counter, insulating base, fixing hardware etc.	85354010	Nos.	3							
	4	Rigid through type Terminal Connector for 216kV Surge Arrestor suitable for Twin Bull AAAC/ Twin ACSR Moose conductor with Horizontal approach	85359090	Nos.	3							
	5	For 624 kV: Insulated connecting cable between Surge Arrestor & Surge Monitor along with Lugs (Single Length)	85446020	Mtr.	36							
	6	For 216 kV: Insulated connecting cable between Surge Arrestor & Surge Monitor along with Lugs (Single Length)	85446020	Mtr.	15							
		FOR UPPUR										
	1	624 kV, Discharge current-20 kA, Class-V, Creepage-31mm/kV Surge Arrestor complete with all accessories like corona ring, terminal pad, surge counter, insulating base, fixing hardware etc.	85354010	Nos.	6							
	2	Rigid through type Terminal Connector for 624kV Surge Arrestor suitable for Quad Bull AAAC/ Quad Moose ACSR conductor with Horizontal approach	85359090	Nos.	6							
	3	198 kV, Discharge current-20 kA, Class-IV, Creepage-31mm/kV Surge Arrestor complete with all accessories like corona ring, terminal pad, surge counter, insulating base, fixing hardware etc.	85354010	Nos.	3							
	4	Rigid through type Terminal Connector for 198kV Surge Arrestor suitable for Twin Bull AAAC/ Twin ACSR Moose conductor with Horizontal approach	85359090	Nos.	3							
	5	For 624 kV: Insulated connecting cable between Surge Arrestor & Surge Monitor along with Lugs (Single Length)	85446020	Mtr.	72							
	6	For 198 kV: Insulated connecting cable between Surge Arrestor & Surge Monitor along with Lugs (Single Length)	85446020	Mtr.	15							
		TOTAL										

1. It is certified that M/s _____ have quoted as per the specified price format of the tender, otherwise offer shall be liable for rejection.
2. PLEASE NOTE THAT UNPRICED COPY OF PRICE BID (i.e. WITH ALL PRICE BLANKED) SHALL BE FURNISHED ALONGWITH TECHNO-COMMERCIAL
3. Vendor to mention the word "QUOTED" against each item in UNPRICED SCHEDULE.

ENQUIRY NO. - 228G011 dated 26/04/2018

Project: TANGEDCO NORTH CHENNAI AND UPPUR[illegible]

3	198 kV, Discharge current-20 kA, Class-IV, Creepage-31mm/kV Surge Arrestor complete with all accessories like corona ring, terminal pad, surge counter, insulating base, fixing hardware etc.		Nos.	3												
4	Rigid through type Terminal Connector for 198kV Surge Arrestor suitable for Twin Bull AAAC/ Twin ACSR Moose conductor with Horizontal approach		Nos.	3												
5	For 624 kV : Insulated connecting cable between Surge Arrestor & Surge Monitor along with Lugs (Single Length)		Mtr.	72												
6	For 198 kV : Insulated connecting cable between Surge Arrestor & Surge Monitor along with Lugs (Single Length)		Mtr.	15												
Total																

NOTE-

Discharge Port:- Indian Sea Port - Any Indian Sea Port preferably Mumbai. Pl explicitly mention name of the port.

CIF (indian port) should be equal to "FOB (load port) + Sea Freight (upto indian Sea port-preferably Mumbai) +Insurance(upto Indian Sea port)"

Load port to be mentioned by bidder .

No of package with Dimensions and type of cargo/Break Bulk/LCL/FCL) and no. of container (with type of container) required-Is also to be mentioned by bidder.

Vendor has to mention tarrif no. against each item for custom duty purpose.

Vendor to mention QUOTED against each item in UNPRICED SCHEDULE.

We confirm that we have quoted as per this price format.

SEAL & SINGNATURE OF TENDERER

Enquiry No. 228G011 dated 26/04/2018**ACTIVITY SCHEDULE**

(To be filled ñ up by the supplier)

Sl. No.	ACTIVITY	Activity time in weeks	Cumulative time in Weeks (from LOI/PO date)	Remarks, If any
1	Submission of master document list			Max. with in 1 week by vendor
2	Submission of documents necessary for getting manufacturing clearance like Drawings, date sheet etc.			
3	Review and Approval of documents and issue of manufacturing clearance	3 weeks by BHEL		
4	Manufacturing Time			
5	Inspection	2 weeks by BHEL		
6	Issue of MICC/MDCC	1 week by BHEL		
7	Dispatch			
8	Transit time upto Site.			

Note: 1) Supplier must ensure the completeness and correctness of the requisite documents before submission for approval. Delay in approval on account of incomplete/inadequate information shall be the responsibility of supplier.

2) Inspection call should be given in the prescribed format only. Inspection calls not in the prescribed format shall not be entertained.

3) Qty. to be offered for Inspection should be in accordance within Delivery- schedule - lot. BHEL reserves the right not to entertain multiple inspection calls for a Delivery- lot and delay on this account shall be the responsibility of Supplier.

Name of Tenderer

SCHEDULE OF TECHNICAL DEVIATION

TENDER ENQUIRY NO. - 228G011 dated 26/04/2018

The following are the deviations/ variations exception from the Technical Specifications:

SL.NO.	CLAUSE NO. OF GENERAL TERMS AND CONDITIONS	STATEMENT OF DEVIATION

In case, this schedule is not submitted, it will be presumed that the equipment /material to be supplied under this contract is deemed to be in compliance with the Technical Specifications,

If there is NIL deviation,even then the format to be filled as NIL DEVIATION.

Note : Continuation Sheets of like size and format may be used as per the Bidder's Requirement and shall be annexed to this schedule.

All deviations must be mentioned in this format only. Deviation(s) to terms mentioned else where will not be considered.

Signature of the authorised representative of

Place: ë ë ë ë ë ë ë

Date : ě ě ě ě ě ě ě .

Bidder's name :ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë

Designation:ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ..

Company Seal:ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë

SCHEDULE OF COMMERCIAL DEVIATION

TENDER ENQUIRY NO. -228G011 dated 26/04/2018

The following are the deviations/ variations exception from the General Terms and Conditions:

SL.NO.	CLAUSE NO. OF GENERAL TERMS AND CONDITIONS	STATEMENT OF DEVIATION

In case, this schedule is not submitted, it will be presumed that the equipment /material to be supplied under this contract is deemed to be in compliance with the General Terms and Conditions.

If there is NIL deviation,even then the format to be filled as NIL DEVIATION.

Note : Continuation Sheets of like size and format may be used as per the Bidder's Requirement and shall be annexed to this schedule.

All deviations must be mentioned in this format only. Deviation(s) to terms mentioned elsewhere will not be considered.

Place: ë ë ë ë ë ë ë

Date : .

Signature of the authorised representative of

Bidder's name :ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë

Designation:ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ..

Company Seal:ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë ë

CHECKLIST

SCHEDULE OF INFORMATION TO BE FURNISHED WITH THE OFFER

NOTE: This format is to be submitted in original only, duly filled in. Reproduction of this format on bidder's letter head or on other paper is not acceptable.

Put a tick mark on "YES" if the information is enclosed with the offer or put a tick mark on "NO" if the information is not enclosed or write "NOT APPLICABLE" if the information is not applicable.

1.	Technical offer with detailed schedule of equipment / material and spares enclosed.	YES / NO
2.	Guaranteed Technical Particulars as per Section ñ 4 enclosed.	YES / NO
3.	Schedule of deviation, if any, clause wise with respect to Technical Specification enclosed.	YES / NO
4.	Standard Manufacturing Quality Plan enclosed.	YES / NO
5.	GA Drawings with dimensions and weights & foundation / fixing details enclosed.	YES / NO
6.	Drawing and Data submission schedule enclosed.	YES / NO
7.	Type Test Reports enclosed.	YES / NO
8.	Bar Chart showing the schedule indicating time required for design, manufacture, test and inspection, transport, erection, site testing and commissioning enclosed.	YES / NO
9.	Makes of all components as per technical Specification enclosed.	YES / NO

The above checklist is verified for:-

Offer Ref. :

Equipment :

Submitted by : M/s

Project Reference. :

Signed with Seal       ..

Date