

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

पावर सेक्टर – पच्छिम क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 – किंग्सवे
नागपुर – 440 001

फॅक्स / FAX: 0712 – 3048605



Bharat Heavy Electricals Limited

Power Sector – Western Region
Shreemohini Complex, 345 – Kingsway
Nagpur – 440 001

वेब साईट / WEB SITE: www.bhelpswr.co.in

Ref: BHE/PW/PUR/ RGIT-STR / 838/839/CLA-01 (Page-1/2)

DT: 30/03/2009

TO,

ALL BIDDERS

Dear Sir,

SUB: CLARIFICATIONS ON TENDER SPECIFICATION-01

NAME OF WORK: SUPPLY (EXCEPTING BHEL SUPPLIED MATERIALS), COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO FABRICATION YARD/ SITE; FABRICATION, ERECTION, ALIGNMENT, BOLTING/ WELDING/ FASTENING, GROUTING, TESTING AND HANDING OVER OF BUNKER STRUCTURES AND RAW COAL BUNKERS IN UNIT-1 & 2 OF 4X600 MW JPL TAMNAR, DIST – RAIGARH (CHATTISGARH)

TENDER SPECIFICATION No : BHE / PW / PUR / RGIT-STR / 838/839

Some of the bidders have asked the clarifications on tender specification which are as below :

1) Que-01 Sl.No. Ref. of NIT Description

1. ST No. 2300 of Rate Schedule, Page 1 of 8. Please delete the word "Supply" in 2nd line.

Ans by BHEL : -Item no 2301 is mother item which represents the total quantity for all sub items under this category .The word supply should be read as supply other than BHEL supply item i.e structural item and SS Liner only .All other material shall be supplied under the scope of contractor .

- 2.) Que-02- ST No. 2301 of Rate Schedule, Page 1 of 8. Please delete the word "Grating" in 7th line.

Ans by BHEL :-During the course of execution fabricated gratings may be required to suit site condition where factory made MS Gratings /Electroforged gratings of standard size can not be used .Therefore the word grating can not be deleted.

- 3.) Que -03- Missing of ST No.

We feel that St. No. 2302, 2303, 2304 & 2305 is missing in Rate Schedule. Please clarify this.

Ans by BHEL : It is not applicable for this package and hence not appearing.

4.) Que-04- **Distance of fabrication yard to erection site. Please inform the approx distance from fabrication yard to erection site.**

Ans by BHEL- *Distance of fabrication yard is within 2 kilometer (km) radius from Erection site within the plant boundry. Please further refer clause 11.21.4 of Tender document*

5.) Que-05 **Construction Power**

We shall be provided two locations for provision of Construction Power.

Ans : -As per contract with customer only at one location (single point) Construction power shall be provided and further distribution is to be done by BHEL Contractor.Please refer technical condition of contract (Facilities in the scope of Contractor/BHEL).

6.) Que-06- **ST No.2301 of Rate Schedule. GI Handrail word shall be deleted from item description and it shall be separate item head like supply of electroforged gratings of Item no. ST 2307 ,otherwise please specify the quantification of GI Handrail .Please also clarify that supply of GI Handrail is in bidder's scope or not.**

Ans :-Clarification is same as Sr no.2.

7.) Que-07 **ST No.2307 of Rate Schedule. Electroforged gratings supply of permanent grade MS Bolts and nuts shall be paid separately in item no.2309. Inadvertently it is typed as 2309(i). Please rectify the same.**

Ans : - It is 2309.

8.) Que-08-As per Cl no (F) ,Page 45, Chapter VII : Technical conditions of contract (TCC) of tender documents ,the terms of payment are mentioned as

F) No separate payment shall be made for providing grout materials and grouting of structures etc. specified elsewhere in these specifications. However as per St No 2322 Page 8 of 8 ,price bid ,Vol-II of tender document is mentioned in item rate for execution of this grouting work.Hence , Cl No ."f" ,Page 45, Chapter VII : Technical conditions of contract (TCC) of tender documents should be deleted.

Ans :-Grouting shall be paid separate under BOQ item no.2322 and hence Cl No ."f" ,Page 45, Chapter VII : Technical conditions of contract (TCC) of tender documents stands deleted.

The above clarification shall be a part of this tender specification. As such bidders are requested to submit the offer considering the above clarification.

Bidders may please download these documents from web and enclose print out of same with technical bid duly counter signed by your authorized signatory and stamped with official seal as a token of your unqualified acceptance of this clarification. All other terms & condition of the tender specification shall remain unchanged unless and otherwise expressly amended by BHEL.

Thanking you.

Yours faithfully

DY. GENERAL MANAGER (PURCHASE)