



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-14-Jun-21

CORRIGENDUM- 03

PROJECTs	:	2 X 660 MW THDC KHURJA-TG
PACKAGE	:	Elevators
ENQUIRY NO	:	PE/PG/THD/E-6646/2021 Dated 24.05.2021
SUBJECT	:	Reply of pre-bid queries and annexure-II of GCC Rev07

Type of Corrigendum			
Technical Corrigendum -	☒	Commercial Corrigendum -	☒

Bidders are requested to go through the following changes:

1. Reply of pre-bid queries is enclosed.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Upendra Chaudhary
Manager/BOP



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

2 X 660 MW KHURJA STPP					
PE-TS-475-502-A001 - TECHNICAL SPECIFICATION FOR ELEVATOR					
Sr. No.	Page No.	Clause No.	Statement of Referred Clause	Clarification Required	BHEL REPLY
1	8 of 276	1.12	Site Visit Before Bid Submission	Kindly note that due to this Covid Pandemic Situation, we are unable to visit the site at this stage. But we submit the offer as per your given technical details and submit the offer as per the same.	Technical specification requirement is clear. Bidder to also refer relevant clause in NIT regarding the same.
2	10 of 276	2.0.2 (11)	Intercom connection through EPABX or PA which shall be finalized during contract stage.	We will provide you Push 2 Talk System instead of EPABX. One Speaker in cabin and another speaker at Ground Floor. Further for PA System, we will provide you one extra cable from control panel to ground floor only. Further distribution or connection will be in your scope only.	Bidder to follow the technical specification. Further, bidder to refer cl. No. 19 of data sheet A, Section IC, page no. 262 of 276 of technical specification and also sl no 27 of "Description of Work" in Civil Input drgs, Annexure IX, page 185 & 186 of 276 of tender technical specification for EPABX connectivity details.
3	12 of 276	Notes (2)	Functional Guarantee test shall be carried out at site for over speed test and over load test, travel and hoist speed checks as per latest IS.	In this we will carried out over speed governor at site but in normal travel situation. Kindly note that free fall of elevator for Over speed Governor Testing at site or at workshop will not be done.	Bidder to follow the relevant functional test w.r.t over speed test in line with latest IS:14665 as specified in technical specification.
4	12 of 276	Notes (9)	Bidder shall supply erection and commissioning spares as required during E&C stage without any commercial implication.	Erection and Commissioning Spares are not applicable. Erection and Commissioning Tools and Tackles will provide you during erection stage free of cost on returnable bases.	Technical Specification requirement is clear. Complete scope of Erection and commissioning is in bidder scope and spares, tools and tackles required for erection and commissioning is in bidder's scope.
5	14 of 276	3.0 (2)	Painting of all equipments / items within the battery limit.	Please note that we will submit you our standard Painting Procedure with BID Documents and same will be follow. Further please note that this standard process already approved in NTPC.	Bidder to follow the technical specification requirement.
6	14 of 276	3.0 (3)	Unloading, storage, handling and transportation at site for all items of elevator.	We will provide you all material in sealed container and we used as a store. Further please note that the container will provide you rent free for 1 year. After that container charge will be applied 15,000/- per month.	Type of storage required is clear in the technical specification. Fix prices to be quoted for complete storage as per technical specifications
7	15 of 276	8.0	Cables and Wirings	All Cables are FRLS except trailing cables. We will provide you flat type trailing cable as per IEC 60227-6.	Technical specification requirement is clear.
8	22 of 276	1.02.00 (vi (a))	Cabin Accessories - Recessed LED Light fittings on car floor	LED Light fittings on car roof and 100 LUX level on car floor	Technical specification requirement is clear. Bidder to refer Clause no. 17 of



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

					Datasheet A, Section IC, page 262 of 276 of technical specification.
9	128 of 276		Quality Assurance Plan	We will submit you our standard quality plan during detail engineering and same will be followed.	Bidder to follow the technical specification requirement.
10	139 of 276	Annexure - A	List of Make	We will submit you our sub vendor list during BID Submission.	Bidder to follow the technical specification requirement. Further bidder to refer notes given in Annexure I of Section IA of tender technical specification.
11	257 of 276		Standard Manufacturing Quality Plan for Motors (Upto 55 KW)	Kindly note that motor is bought out items and make of motor is BBL. For bought out items, manufacturing quality plan is not applicable. We will submit you Test Certificate at the time of inspection stage or before dispatch.	Bidder to refer notes at page 259 of 276 of technical specification for requirement/applicability of tests/certificates.
12	260 of 276		Cable Schedule Format	Cable Schedule will submit you during detail engineering.	Bidder's understanding is correct.