



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-20-Aug-21

CORRIGENDUM- 02

PROJECTs	:	1 X 660 MW WBPDCS SAGARDIGHI EXTN V
PACKAGE	:	D/G EOT Cranes upto 100T
ENQUIRY NO	:	PE/PG/SGI/E-6718/2021 Dated 06.08.2021
SUBJECT	:	Reply of pre-bid queries and extension of due date

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

Bidders are requested to go through the following changes:

1. Reply of pre-bid queries is enclosed.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Upendra Chaudhary
Manager/BOP



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

PRE-BID CLARIFICATION SCHEDULE

Sr. No.	CLARIFICATION REQUIRED	BHEL REPLY
1	As per your technical data sheet clause no. 9.9 Brakes, you have mentioned foot brakes in LT motion. Hence, Foot brakes are applicable with cabin only. So, Foot Brakes are Not Suitable as per your requirement, As you have requirements for Pendant and RRC. Kindly clarify.	Bidder's understanding is correct.

Corrigendum