



A4-10

Purchase Specification for LT power and Control cables for
10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project

PS 439-1182

REV. No. 02

PAGE 1 OF 17

Technical specification of

LT power and Control cables for

10 MW (AC) Solar Photovoltaic Grid-connected Power plant

at Santaldih site (for WBSEDCL)

CORRIGENDUM

Cl No / Sheet No	Parameter	Before	Now
5.0(a), 5(c), sheet 3	Conductor class	Class-5	Class-2
5.0(b), sheet 5	Conductor class	Class-5	Class-2
5.0(a), Cl 11(a), sheet 4	Max DC resistance at 20° C (Main/core)	0.780 ohm / Km 0.1.21 ohm / Km	0.206 ohm per Km 0.386 ohm per Km
5.0(b)Cl (b), sheet 5	Cable detail	4-cx25 sq mm	3.5-cx25 sq mm
5.0(b),Cl 9(e), sheet 6	Overall dia	27.1mm	23 mm approx
5.0(c), sheet 7	Conductor class	Class-5	Class-2
5.0(c), cl 5(c), sheet 7	Conductor class	As per class-5 of IS:8130/84	As per class-2 of IS:8130/84
5.0(c), cl 9(e), sheet 8	Max DC resistance	7.98	7.41
5.0(d), cl 5(c), sheet 9	Conductor class	Class-5	Class-2
5.0(e), cl 2	Applicable standard	IS 1554	IS 694

Rev 02
Editing as per
corrigendum

Approved: V Radhakrishnan

V. Radhakrishnan 12/01/18

Prepared

Phalguni Sahoo

Issued

PVCE

Date

12/01/2018

COPY RIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in anyway detrimental to the interest of the company.

		बी एच ई एल BHEL A4-11	Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 3 OF 17
5.0 Technical specification					
(a) 3.5-cx95 sq mm Cu conductor as per IS: 8130, class 5, 1100 V grade, XLPE insulation as per IS:7098 (Part-1), Inner sheath of extruded PVC sheath ST-2 as per IS:5831, GI Flat strip armoured cable and Outer sheath of extruded FRLSH PVC ST-2 (UV-stabilised)					
1	Cable type	Flexible Annealed bare copper conductor, XLPE insulated, PVC inner sheathed, galvanised Steel flat strip armoured and overall FRLS PVC sheathed LT cable.	Vendor reply		
2	Applicable standards	IS:7098-1/88,IS:8130/84, IS:5831/84,IS:3975			
3	Voltage grade	1100 V			
4	No of cores	3.5 cores			
5	Conductor				
(a)	Material	Flexible Annealed bare copper conductor Conforming to IS:8130/84			
(b)	Area(Main & reduced)	95 / 50 sq mm			
(c)	No of strands	As per class-2 of IS:8130/84			
(d)	Shape	Flexible and circular			
6	Insulation				
(a)	Material	XLPE Compound Confirming to IS:7098-1/88			
(b)	Type	Extruded			
(c)	Thickness (Nominal)(Main/ Reduced core)	1.1/1.0 mm			
(d)	Core identification	Red, Yellow, Blue & Reduced core Black			
7	Inner sheath				
(a)	Material	PVC Compound Type ST-2 Conforming to IS:5831/84			
(b)	Type	Extruded			
(c)	Thickness (Min)	0.5 mm			
(d)	Colour	Black			
8	Armour				
(a)	Material	Galvanised Steel Flat Strip Conf. to IS:3975			

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 4 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(b)	Type	Single layer
			(c)	Size of armour (Nominal)	4x0.8mm
			9	Outer sheath	
			(a)	Material	PVC Compound Type ST-2 conforming to IS:5831/84 with FRLS properties
			(b)	Type	Extruded
			(c)	Thickness (Min)	1.88 mm
			(d)	Colour of outer sheath	Black
			(e)	Overall diameter	43.4 mm
			(f)	Tolerance on overall diameter	+/- 3 mm
			(g)	Marking on outer sheath	Manufacturer name, Year of manufacture, No of core x cross-sectional area, 1100V, FRLS, sequential length on outer cable sheath at every metre
			10	Drum length	Less or equal 500 m / 1000 m
			(a)		
			(b)	Tolerance on drum length	+/- 5%
			11	Electrical parameters	
			(a)	Max DC resistance at 20 deg C (Main/core)	0.206 ohm per Km /0.386 ohm per Km
			(b)	HV test	3 kV rms for 5 minutes
			(c)	Min volume resistivity	1 x 10 ¹⁴ ohm-cm at 27 ⁰ C and 1 x 10 ¹² ohm-cm at 90 ⁰ C
			12	FRLS properties (Outer sheath)	
			(a)	Min oxygen index as per ASTMD-2863	29%
			(b)	Min temp index as per ASTMD-2863	250 ⁰ C
			(c)	Max HCL emission as per IEC-754-1	20% by weight
			(d)	Max smoke density rating as per ASTMD-2843	60%

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 5 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2
			(b)	3.5-cx25 sq mm Cu conductor as per IS: 8130, class 2 , 1100 V grade, XLPE insulation as per IS:7098 (Part-1), Inner sheath of extruded PVC sheath ST-2 as per IS:5831, GI Flat strip armoured cable and Outer sheath of extruded FRLSH PVC ST-2 (UV-stabilized)	
			1	Cable type	Flexible Annealed bare copper conductor, XLPE insulated, PVC inner sheathed, galvanised Steel flat strip armoured and overall FRLS PVC sheathed LT cable.
			2	Applicable standards	IS:7098-1/88,IS:8130/84, IS:5831/84,IS:3975
			3	Voltage grade	1100 V
			4	No of cores	4 cores
			5	Conductor	
			(a)	Material	Stranded Annealed bare copper conductor Conforming to IS:8130/84
			(b)	Area (Main and reduced)	25 sq mm for main 16 sq mm for other
			(c)	No of strands	As per class-2 of IS:8130/84
			(d)	Shape	Flexible and circular
			6	Insulation	
			(a)	Material	XLPE Compound Confirming to IS:7098-1/88
			(b)	Type	Extruded
			(c)	Thickness (Nom) - Main/ Reduced core	0.9 mm for main core
			(d)	Core identification	Red, Yellow, Blue & Black
			7	Inner sheath	
			(a)	Material	PVC Compound Type ST-1 Conforming to IS:5831/84
			(b)	Type	Extruded
			(c)	Thickness (Min)	0.3 mm
			(d)	Colour	Black
			8	Armour	
			(a)	Material	Galvanised Steel Flat Strip conforming to IS:3975
			(b)	Type	Single layer
			(c)	Size of armour (Nom)	4 x 0.8 mm

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 6 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			9	Outer sheath	
			(a)	Material	PVC Compound Type ST-2 Conforming to IS:5831/84 with FRLS properties
			(b)	Type	Extruded
			(c)	Thickness (Min)	1.4 mm
			(d)	Colour of outer sheath	Black
			(e)	Overall diameter	23 mm approx
			(f)	Tolerance on overall diameter	+/- 2 mm
			(g)	Marking on outer sheath	Manufacturer name, Year of manufacture, No of cores, cross-sectional area, 1100V, FRLS, sequential length on outer cable sheath at every meter
			10 (a)	Drum length	Less 1000 m
			(b)	Tolerance on drum length	+/- 5%
			11	Electrical parameters	
			(a)	Max DC resistance at 20 deg C (Main/core)	0.78 ohm / Km for Main core 1.15 ohm / Km for other core
			(b)	HV test	3 kV rms for 5 minutes
			(c)	Min volume resistivity	1 x 10 ¹³ ohm-cm at 27 ⁰ C and 1 x 10 ¹⁰ ohm-cm at 70 ⁰ C
			12	FRLS properties (Outer sheath)	
			(a)	Min oxygen index as per ASTM D-2863	29%
			(b)	Min temp index as per ASTM D-2863	250 ⁰ C
			(c)	Max HCL emission as per IEC-754-1	20% by weight
			(d)	Max smoke density rating as per ASTM D-2843	60%
			(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2

		बीएसडीएल BHEL	Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project	PS 439-1182
				REV. No. 02
				PAGE 7 OF 17
		A4-11		
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(c) 4-cx2.5 sq mm Cu conductor as per IS: 8130, class 2, 1100 V grade, PVC insulated, PVC inner sheathed, galvanized round wire armoured and overall FRLS PVC sheathed cable	

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 8 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(c)	Size of armour (Nom)	1.4 mm
			9	Outer sheath	
			(a)	Material	PVC compound type ST1, conforming to IS:5831/84 with FRLS properties
			(b)	Type	Extruded
			(c)	Thickness (Min)	1.24 mm
			(d)	Colour	Black
			(e)	Overall dia approx	16.4 mm
			(f)	Tolerance on overall diameter	+/- 2 mm
			(g)	Making of outer sheath	Manufacturer, Year of manufacture, No of core x cross-sectional area, 1100V, FRLS, sequential length on outer cable sheath at every metre
			8	Drum length	Less 1000 m
			(b)	Tolerance on drum length	+/- 5%
			9	Electrical parameters	
			(a)	Max DC resistance at 20 deg C (Main/core)	7.41 ohms per Km
			(b)	HV test	3 kV rms for 5 minutes
			(c)	Min volume resistivity	1 x 10 ¹³ ohm-cm at 27°C and 1 x 10 ¹⁰ ohm-cm at 70°C
			10	FRLS properties (Outer sheath)	
			(a)	Min oxygen index as per ASTM-D-2863	29%
			(b)	Min temp index as per ASTM-D-2863	250°C
			(c)	Max HCL emission as per IEC-754-1	20% by weight
			(d)	Max smoke density rating as per ASTM-D-2843	60%
			(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project	PS 439-1182
				REV. No. 02
				PAGE 9 OF 17
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.		A4-11	(d) 1c x25 sq mm Cu conductor, PVC insulated and overall FRLS-PVC sheathed unarmoured cable	
			1	Cable type Flexible Annealed bare copper conductor, PVC insulated, overall FRLS PVC sheathed and unarmoured cable.
			2	Applicable standards IS:1554-1/88,IS:8130/84,IS:5831/84
			3	Voltage grade 1100 V
			4	No of cores 1 core
			5	Conductor
			(a)	Material Stranded Annealed bare copper conductor Conforming to IS:8130/84
			(b)	Size (Main and reduced) 25 sq mm
			(c)	No of strands As per class-2 of IS:8130/84
			(d)	Shape Flexible and circular
			6	Insulation
			(a)	Material PVC Type-A Compound Confirming to IS:5831/84
			(b)	Type Extruded
			(c)	Thickness (Nominal)(Main/ Reduced core) 1.2
			(d)	Core identification Black
			7	Outer sheath
			(a)	Material PVC compound ST-1, conforming to IS:5831/84 with FRLS properties
			(b)	Type Extruded
			(c)	Thickness (Min) 1.8 mm
			(d)	Colour Black
			(e)	Overall diameter 12.1 mm approximately
			(f)	Tolerance on overall diameter +/- 2 mm
			(g)	Marking on outer sheath Manufacturer name, Year of manufacture, No of core x cross-sectional area, 1100V, FRLS, sequential length on outer cable sheath at every metre
			10	Drum length Less or equal 500 m / 1000 m
			(a)	
			(b)	Tolerance on drum length +/- 5%

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project	PS 439-1182
				REV. No. 02
				PAGE 11 OF 17
		A4-11		
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			Reduced core)	
	(d)	Core identification	Black	
	(e)	Overall diameter	To be mentioned	
	(f)	Tolerance on overall diameter	To be mentioned	
	(g)	Marking on outer sheath	To be mentioned	
	10 (a)	Drum length	Less or equal 500 m / 1000 m	
	(b)	Tolerance on drum length	+/- 5%	
	11	Electrical parameters		
	(a)	Max DC resistance at 20 deg C (Main/core)	13.3 ohms per Km	
	(b)	HV test	3 kV rms for 5 minutes	
	(c)	Min volume resistivity	1 x 10 ¹³ ohm-cm at 27°C and 1 x 10 ¹⁰ ohm-cm at 90°C	
	(f)) 2c x 1.5 sq mm copper PC insulated, PVC inner sheathed and overall FRLS PVC sheathed unarmoured cable			
	1	Cable type	Flexible annealed bare copper conductor, PVC insulated, PVC inner sheathed and overall FRLS-PVC sheathed unarm cable	
	2	Applicable standards	IS:1554-1/88,IS:8130/84, IS:5831/84, others to be mentioned	
	3	Voltage grade	1100 V	
	4	No of cores	2 cores	
	5	Conductor		
	(a)	Material	Stranded Annealed bare copper conductor Conforming to IS:8130/84	
	(b)	Size	1.5 sq mm, each core	
	(c)	No of strands	As per class-5 of IS:8130/84	
	(d)	Shape	Flexible and circular	
	6	Insulation		
	(a)	Material	PVC type-A compound conforming to IS:5831/84	

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 12 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(b)	Type	Extruded
			(c)	Thickness (Nominal)(Main/ Reduced core)	0.8 mm
			(d)	Core identification	Red and Black
			7	Inner sheath	
			(a)	Material	PVC compound ST-1, conforming to IS:5831/84
			(b)	Type	Extruded
			(c)	Thickness (Nominal)(Main/ Reduced core)	0.3 mm
			(d)	Colour	Black
			10	Outer sheath	
			(a)	Material	PVC compound ST-1, conforming to IS:5831/84 with FRLS properties
			(b)	Type	Extruded
			(c)	Thickness (Nom)	1.8 mm
			(d)	Colour of outer sheath	Black
			(e)	Overall diameter	To be mentioned
			(f)	Tolerance on overall diameter	To be mentioned
			(g)	Marking on outer sheath	To be mentioned
			10	Drum length	Less or equal 500 m / 1000 m
			(a)		
			(b)	Tolerance on drum length	+/- 5%
			11	Electrical parameters	
			(a)	Max DC resistance at 20 deg C (Main/core)	13.3 ohms per Km
			(b)	HV test	3 kV rms for 5 minutes
			(c)	Min volume resistivity	1 x 10 ¹³ ohm-cm at 27 ⁰ C and 1 x 10 ¹⁰ ohm-cm at 90 ⁰ C
			12	FRLS properties (Outer sheath)	
			(a)	Min oxygen index as per ASTM D-2863	29%
			(b)	Min temp index as per ASTM D-2863	250 ⁰ C
			(c)	Max HCL emission as per IEC-754-1	20% by weight

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 13 OF 17
		A4-11			
			(d)	Max smoke density rating as per ASTMD-2843	60%
			(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(g) 12-core x 1.5 sq mm copper conductor, PVC insulated, overall screened and overall FRLS-PVC sheathed unarmoured cable		
			1	Cable type	Flexible Annealed bare copper conductor, PVC insulated, Overall screened and overall FRLS PVC outer sheathed unarmoured instrumentation cable
			2	Applicable standards	IS:5038-2/86,IS:8130/84,
			3	Voltage grade	300/500 volts
			4	No of cores	12 cores
			5	Conductor	
			(a)	Material	Stranded Annealed bare copper conductor Conforming to IS:8130/84
			(b)	Size	1.50 sq mm
			(c)	No of strands	As per class-5 of IS:8130/84
			(d)	Shape	Flexible and circular
			6	Insulation	
			(a)	Material	PVC Type-A, conforming to IS:5831/84
			(b)	Type	Extruded
			(c)	Thickness (Nominal)(Main/ Reduced core)	0.6
			(d)	Core identification	All crores shall be grey, also numbering shall be provided on each core for core identification.
			7	Overall shielding	
			(a)	Material	Aluminum-Mylar Tape
			(b)	Type	Helical
			(c)	Thickness (Min)	0.018 mm
			(d)	Overlap/coverage	25/100
			8	Drain Wire	
			(a)	Material	Stranded Annealed Tinned Copper
			(b)	size	0.5mm ²

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 14 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(c)	No. of strands	7
			9	Outer sheath	
			(a)	Material	PVC Compound Type ST-1 Conforming to IS:5831/84
			(b)	Type	Extruded
			(c)	Thickness (Min)	1.2 mm
			(d)	Colour of outer sheath	Black
			(e)	Overall diameter	14.9 mm or to be mentioned if otherwise
			(f)	Tolerance on overall diameter	+/- 2 mm
			(g)	Marking on outer sheath	Manufacturer name, Year of manufacture, No of core x cross-sectional area, 300/500 V, FRLS, sequential length on outer cable sheath at every meter
			10	Drum length	Less or equal 500 m / 1000 m
			(a)		
			(b)	Tolerance on drum length	+/- 5%
			11	Electrical parameters	
			(a)	Max DC resistance at 20°C (Main/core)	13.3
			(b)	Min insulation resistance of completed cable at 20°C	25 Mohms
			(c)	Max mutual capacitance between any core & screen at 1 KHz	250 pF/ metre
			(d)	Max capacitance between any core & screen at 1 KHz	450 pF/ metre
			(e)	High voltage test	1 kV rms for 1 minute
			12	FRLS properties (Outer sheath)	
			(a)	Min oxygen index as per ASTM D-2863	29%
			(b)	Min temp index as per ASTM D-2863	250°C
			(c)	Max HCL emission as per IEC-754-1	20% by weight

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 15 OF 17
		A4-11			
			(d)	Max smoke density rating as per ASTMD-2843	60%
			(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(h) 2-pair x 4 sq mm copper conductor, PVC insulated, overall screened and overall FRLS-PVC sheathed instrumentation cable		
			1	Cable type	2-pair copper conductor, PVC insulated, Overall screened and overall FRLS PVC sheathed unarmoured instrumentation cable.
			2	Applicable standards	IS:5308-2/86,IS:8130/84, IS:5831/84
			3	Voltage grade	300/500 V
			4	No of Pair	2P
			5	Conductor	
			(a)	Material	Stranded Annealed bare copper conductor conforming to IS:8130/84
			(b)	Size	4 sq mm
			(c)	No of strands	As per class-5 of IS:8130/84
			(d)	Shape	Flexible and circular
			6	Insulation	
			(a)	Material	PVC Type-A conforming to IS:5831/84
			(b)	Type	Extruded
			(c)	Thickness (Nominal)(Main/ Reduced core)	0.8 mm
			(d)	Pair identification	All pair shall be white, blue, also Cores of each pair shall be numbered for pair identification
			(f)	Approx. number of Twist(for cores in pair)	10 twists/meter
			7	Overall Shielding	
			(a)	Material	Aluminum-Mylar Tape
			(b)	Type	Helical
			(c)	Thickness (Min)	0.018 mm
			(d)	Overlap/coverage	25/100%
			8	Drain Wire (for overall screening)	
			(a)	Material	Annealed Tinned copper

			Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project		PS 439-1182
					REV. No. 02
					PAGE 16 OF 17
		A4-11			
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.			(b)	Size	0.5 sq mm
			(c)	No. of strands / approx dia of each strand	7 strands / 0.3 mm
			9	Outer sheath	
			(a)	Material	PVC Compound Type ST-1 Conforming to IS:5831/84 with FRLS properties
			(b)	Type	Extruded
			(c)	Thickness (Min)	1.3 mm
			(d)	Colour of outer sheath	Black
			(e)	Overall diameter	17.2 mm
			(f)	Tolerance on overall diameter	+/- 2 mm
			(g)	Marking on outer sheath	Manufacturer name, Year of manufacture, No of core x cross-sectional area, 1100V, FRLS, sequential length on outer cable sheath at every meter
			10	Drum length	Less or equal 500 m / 1000 m
				Tolerance on drum length	+/- 5%
			11	Electrical parameters	
			(a)	Max DC resistance at 20°C (Main/core)	4.95 ohms per Km
			(b)	Min. insulation resistance of complete cable at 20°C	25 Mohms per Km
			(c)	Max. Mutual capacitance between pairs or adjacent cores at 1 KHz	250 pF per meter
			(d)	Max. capacitance between core and screen at 1 KHz	450 pF per meter
			(e)	HV test	2 kV rms for 1 minute
			12	FRLS properties (Outer sheath)	
			(a)	Min oxygen index as per ASTM D-2863	29%
			(b)	Min temp index as per ASTM D-2863	250°C

		Purchase Specification for LT power and Control cables for 10MW(AC) Solar Power Plant at Santaldih, WBSEDCL project	PS 439-1182								
	A4-11		REV. No. 02								
			PAGE 17 OF 17								
COPY RIGHT AND CONFIDENTIAL The information on this document is the property of Bharat Heavy Electricals Limited. It must not be used directly or indirectly in anyway detrimental to the interest of the company.		<table> <tr> <td data-bbox="236 603 314 680">(c)</td><td data-bbox="314 603 614 680">Max HCL emission as per IEC-754-1</td><td data-bbox="614 603 1093 680">20% by weight</td><td data-bbox="1093 603 1463 680"></td></tr> <tr> <td data-bbox="236 680 314 752">(e)</td><td data-bbox="314 680 614 752">Flammability test on completed cable</td><td data-bbox="614 680 1093 752">Shall meet as per test requirement as per IEC 60332-1-2</td><td data-bbox="1093 680 1463 752"></td></tr> </table> 7.0 Documents to be submitted within 1 week after receipt of Purchase order 1. Technical datasheet of the cable with cable cross section sketch shall be submitted to BHEL/BHEL customer for approval. 2. Manufacturing Quality Plan (MQP) indicating all tests/checks regarding raw material, in-process and final product as per relevant IS/IEC standards, as called in this document and any other relevant standards shall be submitted to BHEL/BHEL customer for approval. 8.0 Inspection and testing of transformers at vendor works: (i) BHEL and BHEL customer shall witness the testing of the cables as per relevant standard. (ii) Routine and acceptance tests Vendor shall submit routine and acceptance test plan for approval by BHEL / BHEL customer.	(c)	Max HCL emission as per IEC-754-1	20% by weight		(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2		
	(c)	Max HCL emission as per IEC-754-1	20% by weight								
	(e)	Flammability test on completed cable	Shall meet as per test requirement as per IEC 60332-1-2								