

Ref No. : PE/PG/APP/E-5429/2016/CORRIGENDA/03

Date: 14.02.2017

CORRIGENDA / ADDENDUM-04

Projects: 1 X 800 MW Krishnapattanam TPS & 1 X 800 MW Vijayawada TPS
Package: Oxygen Dosing System
Tender Enquiry No: PE/PG/APP/E-5429/2016 dated 11.01.2017

DUE DATE
23.02.2017
BY 10:00AM

Please note that Mandatory spare list of Technical specifications has been revised.

Vendor who has submitted their bid as on date are requested to submit the **Revised bid** by incorporating the change in line with BHEL corrigenda no. 4 Dt. 14.02.2017.

The due date has been extended upto 23.02.2017 (10:00 AM).

All bidders are requested to visit the website **www.bhel.com** (Tender Notifications Section), **www.bhelpem.com**. All future corrigenda/ amendment and due date extension, if any, for this tender shall be hosted only on above websites.

Encl:-

- Revised mandatory spare list of Technical Specification (PE-TS-419-154-12000-A001, Rev. No. 1 and PE-TS-420-154-12000-A001, Rev. No. 1)
- Suggested price format.

Thanking You,

With Regards,

For & on behalf of BHEL

(Prateek Gautam)

SR ENGINEER/PG1-1

प्रतीक गौतम / PRATEEK GAUTAM
ज्येष्ठ अभियंता (पी.जी.-1)/Sr. Engineer (PG-1)
भारत भारी इलेक्ट्रिकल्स लिमिटेड/Bharat Heavy Electricals Ltd.
पावर सेक्टर-प्रियोजना इंजीनियरिंग प्रबंधन
Power Sector-Project Engineering Management
पी.पी.ई.सी. बिल्डिंग, एच.आर.डी. एवं ई.एस.आई. कॉम्प्लेक्स,
BHEL Building, HRD & ESI Complex,
प्लॉट नं.-25, सेक्टर-16ए, नोइडा-201 301
Plot No. 25, Sector-16A, Noida-201 301

Please reply to:

Sh Prateek Gautam,

Sr. Engineer / PG1-1

Power Project Engineering Institute Building

HRD & ESI Complex Plot No. 25, Sector -16 A,

BHEL-PEM,Noida-201301 (U.P.)

Tel No.0120-4368929 / 9911949464



TITLE:
**1X800 MW Dr. NTPS VIJAYWADA
STAGE-V**

**TECHNICAL SPECIFICATION FOR
OXYGEN DOSING SYSTEM**

SPECIFICATION NO. PE-TS-419-154-12000-
A001

SECTION I

SECTION – I A

REV.NO. 1 DATE : 10/02/2017

ANNEXURE V:

MANDATORY SPARES LIST



TITLE:
**1X800 MW Dr. NTPS VIJAYWADA
STAGE-V**

**TECHNICAL SPECIFICATION FOR
OXYGEN DOSING SYSTEM**

SPECIFICATION NO. PE-TS-419-154-12000-
A001

SECTION I

SECTION – I A

REV.NO. 1 DATE : 10/02/2017

S. No.	Equipment/Package Name	Quantity
1.0	Complete Set of Valves	10% of the total quantity used for each unit for each type and Size or Minimum 2 No. whichever is higher
2.0	Transmitters/ Gauges/Switches etc. along with relevant accessories	5 % of total or at least two (whichever is higher) for each type along with accessories.

R1



TITLE:
**1X800 MW APPDCL KRISHNAPATNAM
STAGE-II**

**TECHNICAL SPECIFICATION FOR
OXYGEN DOSING SYSTEM**

SPECIFICATION NO. PE-TS-420-154-12000-
A001

SECTION I

SECTION I A

REV.NO. 1 DATE : 10/02/2017

ANNEXURE V :
MANDATORY SPARES LIST



TITLE:
**1X800 MW APPDCL KRISHNAPATNAM
STAGE-II**

**TECHNICAL SPECIFICATION FOR
OXYGEN DOSING SYSTEM**

**SPECIFICATION NO. PE-TS-420-154-12000-
A001**

SECTION I

SECTION I A

REV.NO. 1 DATE : 10/02/2017

S. No.	Equipment/Package Name	Quantity
1.0	Complete Set of Valves	10% of the total quantity used for each unit for each type and Size or Minimum 2 No. whichever is higher
2.0	Transmitters/ Gauges/Switches etc. along with relevant accessories	5 % of total or at least two (whichever is higher) for each type along with accessories.

R1

PE-PF-419-154-12000-A001

PE-PF-419-154-12000-A001	
--------------------------	--

[illegible][illegible]

[illegible]

Note: Mandatory spares listed above is bare minimum requirement. In case any additional mandatory spares requirement is covered elsewhere in the tender technical specification, same shall be deemed to have been covered in bidders scope of supply.

Name	Designation	Signature & Company Seal	Date

[illegible]

