



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-26-Jul-21

CORRIGENDUM-2

PROJECT	:	1 x 660 MW BHUSAWAL PROJECT
PACKAGE	:	CONTROL VALVE
ENQUIRY NO.	:	PE/PG/BHU/E-6682/2021 Dtd. 06.07.2021
SUBJECT	:	DUE DATE EXTENSION, Reply of Pre-Bid Query

Type of Corrigendum			
Technical Corrigendum -	<input type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

In reference to the above mentioned tender enquiry for **CONTROL VALVE** package, please note the following.

1. Due date has extended from **26.07.2021, 02:00 P.M.** to **06.08.2021, 02:00 PM**. Bid opening shall be done at 05.00 PM on due date.

2-Please note that for Control valve (Tag No.FDV-14) body material shall be of forged Steel and customer specification shall prevail.

All the other terms and conditions of the tender enquiry remain unchanged.

Yours faithfully,

**RAJENDR  
A PRASAD  
YADAV**  
Digitally signed by  
RAJENDRA PRASAD YADAV  
DN: cn=RAJENDRA  
PRASAD YADAV, o=BHEL,  
ou=PS-PEM,  
email=rajendra.prasad.yad  
av@bhel.in, c=IN  
Date: 2021.07.26 15:55:33  
+05'30'

For and on behalf of BHEL