



Project Group I
Power Sector, Project Engineering Management
Bharat Heavy Electricals Limited
NOIDA

Project	2x500 MW TUTICORIN FGD
Package	Misc. Pumps Horizontal
Enquiry No	PE/PG/NTF/E-6890/2021 DTD 22.02.2022
Dated	11.03.2022
Subject	Corrigendum-2: Amendment-1 to Technical Specification

Please note the following:

1. Amendment-1 to technical specification is issued and same is attached with this Corrigenda. Same shall be part of tender documents. Please consider the same while submitting offer.

All other terms and conditions are unchanged.

Thanking You.

For and on behalf of BHEL PEM

Ajay Kumar
(Engineer/PG-I/BHEL-PEM)
ajaykaushik@bhel.in
Ph. No. +91-120-4368879
Mob: 9899891358

NLC TAMILNADU POWER LIMITED

**NTPL 2X500 MW COAL FIRED UNITS AT TUTICORIN
FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE**


AMENDMENT NO. 1

**TO
TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS
(HORIZONTAL)**

Specification No. : PE-TS-483-100-N001 (REV. 01)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**

	TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS	SPECIFICATION NO.:	PE-TS-483-100-N001 (REV. 01)		
		SPECIFICATION DATE:	03-Feb-22		
	AMENDMENT NO. 1	REV. NO.	0	DATE:	10-Mar-22
1.0	With reference to Datasheet A, Section ID of Technical Specification, please consider the Specification amended as below:				
S.No.	Clause as mentioned in Technical Specification	Ammended Clause			
1.1	ACW Pumps : Benchmark efficiency for Bid evaluation: Pump Efficiency at S.No. 6.2.1 of Datasheet-A is mentioned as 78% .	ACW Pumps : Benchmark efficiency for Bid evaluation: Pump Efficiency at S.No. 6.2.1 of Datasheet-A is amended as 70% .			