

BHARAT HEAVY ELECTRICALS LIMITED
Transmission Business group
Noida

Dated: 20.07.18

Name of the Customer : Tamilnadu Transmission Corporation Limited (TANTRANSCO)
Name of the Project : 765/400kV AIS S/S Ariyalur

Corrigendum for Technical specification for LT ACDB & DCDB

CORRIGENDUM

Technical specification doc. No. TB-394-316-124, Rev -00

Sl. NO.	Reference cl. of technical specification/SLD	Requirements as per technical specification rev - 00/SLD	Technical specification /SLD Amendment
1.	Note Sl. No. 9 of cl. No. 1.3 of section-1 of technical specification	Bidders must furnish unit price for each type and rating of relays, multifunction meter , MCCB, MCB , CTs, PTs, Air circuit breaker, meters & switches with offer for addition / deletion (if any) at contract stage.	This clause is not applicable
2.	SLD drawing no. TB-0-394-316-004, Rev -01	Accuracy class of CT is 1	Accuracy class of CT will be 0.2S in line with Clause 1.26.7 of section -2 of technical specification.

Note - All other technical parameters of technical specification doc. No. TB-394-316-124, Rev -00 shall remain unchanged.

Signature
20/07/18

Signature
20/07/18
Sec. DGM (P&EM)