



Ref: E-6319/2019/08

Date:23/12/2019

Corrigendum -08 to OPEN Tender Enquiry of Misc Pump Horizontal for 2X660 MW UDANGUDI SUPERCRITICAL STPP

Sir/Madam,

1. Amendment No. 2 to technical specification is issued and attached with this corrigendum. Please refer the same while submitting your offer.
2. Due date of bid submission of subject tender is extended up to **31.12.2019;14:00 hrs.** Please submit your best offer before due date and time.

All other terms and condition shall remain unchanged as per NIT and corrigendum if any.

With regards
For & on behalf of BHEL

(Akash Verma)
Sr Engineer/ PG-I
PEM, BHEL, Noida

TANGEDCO

2X660 MW UDANGUDI TPP STG I

AMENDMENT NO. 2

**TO TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS (HORIZONTAL)**

Specification No. : PE-TS-435-100-N001 (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**

	TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS (HORIZONTAL)		SPECN. NO.: PE-TS-435-100-N001		
	AMENDMENT NO. 2		REV. NO.	0	DATE:
					21.12.2019

1.0	With reference to Datasheet A, Section ID of Technical Specification, please consider the Specification amended as below:			
S.No.	Clause as mentioned in Technical Specification	Ammended Clause		
1.1	Maximum permissible speed of pump (RPM) at S.No. 2.5 of Datasheet-A is mentioned as following: a. Potable Water Pump: 1500	Maximum permissible speed of pump (RPM) mentioned at S.No. 2.5 of Datasheet-A is amended as following: a. Potable Water Pump: Preferably 1500 RPM, however 3000 RPM is also acceptable with a proven model of 3000 RPM Pump Supply.		