



परियोजना इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)

Ref: PE/PG/EN1/E-5573/CORRIGENDUM-01

Date: 04/05/2017

Project: 2x660MW ENNORE SEZ STPP
Package: ELECTRIC HOIST
Enquiry No.: E-5573/2017 dated: 10.04.2017

This is in reference to the above Tender Enquiry No: E-5573/2017 dated: 10.04.2017, please note the followings:

1. Following documents is enclosed with Corrigendum-01:

- **PREBID CLARIFICATION (TECHNICAL)**

Bidder to submit their offer accordingly

Thanking You

With regards

For & on behalf of BHEL

AK PANDEY

DY.MGR | PG II-2, BHEL PEM | Noida

E-MAIL: apandey@bhpepm.co.in

Ph. No. +91-120-4213528, 09406903445

कृपया प्रेषित करें :
बीएचईएल, पीएस-पीएम
पीपीआई भवन
प्लॉट नं. २५, सेक्टर १६ ए
नोएडा - २०१ ३०१ उ.प्र.
भारत

Please reply to :
BHEL, PS-PEM,
PPEI Building,
Plot No.25, Sector 16A,
Noida-201301 (U.P.)
INDIA

फ़ोन Phone No:
91-120 - 436 8624

पंजीकृत कार्यालय
बीएचईएल हाउस
सीरी फोर्ट
नयी दिल्ली - ११० ०४९
भारत

Registered Office :
BHEL House,
Siri Fort,
New Delhi-110049
INDIA



TECHNICAL SPECIFICATION FOR
2X660 MW SEZ ENNORE STPP
ELECTRIC WIRE ROPE HOISTS

SPECIFICATION No: PE-TS-412-563-A002	
SECTION-III	
SUB-SECTION-IIID	
REV	00
DATE 04.05.17	

SUB SECTION-IIID
PRE BID CLARIFICATIONS- 1

Handwritten signature

	TECHNICAL SPECIFICATION FOR 2X660 MW SEZ ENNORE STPP ELECTRIC WIRE ROPE HOISTS		SPECIFICATION No: PE-TS-412-563-A002	
			SECTION-III	
			SUB-SECTION-IIID	
			REV 00	DATE 04.05.17

PRE-BID CLARIFICATIONS-1

S. no	Section/Clause/Paragraph No.	Statement of the referred clause	Clarification Required	BHEL's clarification
1	SECTION I-SUB SECTION IC /TECHNICAL DATA SHEET, CLAUSE NO 14.1 Page no. 71 of 124	Brake Type: DC EM (disc/shoe type- fail to safety)	Price difference of DC Disc Brake v/s DC Shoe Brake is significant and tender not clearly specify the choice between DC Disc Brake and DC Shoe Brake.	Both types of brakes (Disc and shoe type) are acceptable as per tender specification. This clarification may also be noted for clause no 15.1 of technical data sheet.

Handwritten signature and date: 04/5/17