

## CORRIGENDUM

**Specification No.:** TB-407-316-003 Rev 0  
**Items:** 624 & 336 kV Surge Arrester  
**Project:** Extension of 765/400kV S/S, Bara TPS (U.P.)

| Sl. No. | Specification clause No.         | Corrigendum                                                                                                                                                                                                                            |
|---------|----------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1       | Various clauses of specification | Arrester housing material as porcelain is specified in the technical specification for 624kV & 336 kV Surge Arrester. As confirmed by customer (UPPCL), polymer surge arresters are also acceptable for 624kV & 336 kV Surge Arrester. |