



BHARAT HEAVY ELECTRICALS LIMITED/PEM-NOIDA

PROJECT: 2X660 MW ENNORE STPP
PACKAGE: COMPRESSED AIR SYSTEM
ENQUIRY NO: E-5428/2016 Dtd. 12.01.2017

Date: 01.02.2017

Corrigendum to Enquiry No: E-5428/2016

1. Bidder to quote Guaranteed Power Consumption for Compressed Air System as per Annexure-I.
2. Swachh Bharat Cess (i.e.0.5% of Service tax rate) applicable on E&C price is not cenvatable. Hence, this 0.5% component of cess on E&C Price shall be considered for Evaluation.
3. Air Compressor Capacity shall be 40NM3/Min in line with clause no.1.1.1 of Vol-IIB (Sh. 23 of 617).

Sharad Chandra
01/02/2017
SHARAD CHANDRA
SR. ENGINEER/PG-II-2