



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-18-Apr-22

CORRIGENDUM- 02

PROJECT	:	1 X 660 MW WBPDCS SAGARDIGHI EXTN V
PACKAGE	:	MISC. TANKS(SITE FABRICATED)
ENQUIRY NO	:	PE/PG/SGI/E-6942/2022 dtd 08/04/2022
SUBJECT	:	PRE-BID CLARIFICATION + DUE DATE EXTENSION

Type of Corrigendum			
Technical Corrigendum -	<input type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

In reference to the above mentioned tender enquiry for **MISC. TANKS(SITE FABRICATED)** package.

Please note the following:

- 1.Pre-bid clarification attached along with this corrigendum, bidders are requested to go through the same and quote accordingly.
2. Due date for offer submission has been extended till 25/04/2022 (till 11:0AM) and P1 to be opened on 04:00 PM on 25/04/2022.

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Guru Das
Manager

Sl. No	Section/Clause/Page No.	Statement of the referred clause	Clarification required	BHEL Reply
Technical Clarifications				
1	Section - I, Sub-Section - C1A (Specific Technical Requirement - TANKS), Clause No. 3.0 (1-c) (Exclusions), Pg No. 35 of 348 PRICE FORMAT ANNEXURE-I	As per Specific technical requirement, it is mentioned as "Further, the supply, erection and commissioning of the agitators along with the mounting arrangements within the sump/drain pits shall be in bidder's scope of work". As per the Price Bid Format it is mentioned as "structural steel for agitator supporting structure & agitator platforms, fasteners & gaskets, pipes & fittings, paints, commissioning spares, Vinyl Ester based flake glass lining for the total scope defined in technical specification (PE-TS-445-167-A002) for Absorber Area Drain Pits (4 nos)".	Both the clauses are contradictory to each other, hence, kindly clarify the scope of Agitators including structural steel for agitator supporting structure & agitator platforms. Kindly provide the Agitators datasheet with details such as Slurry Analysis, MOC of Agitator, Type of Agitator & Dimensions of Drain Pit pertaining to Absorber Area Drain Pits.	Please note that Agitators, mounting arrangements, structural steel for agitator supporting structure & agitator platforms, fasteners & gaskets, pipes & fittings, paints, commissioning spares, Vinyl Ester based flake glass lining etc. is in bidder scope of works. The same has already been specified in the technical specification and as such there is no contradiction.