



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-23-Dec-20

CORRIGENDUM- 04

PROJECT	:	3x40 MW RAMMAM STAGE-III HEP
PACKAGE	:	D/G EOT CRANES UP TO 100T
ENQUIRY NO	:	E-6565/2020
SUBJECT	:	PRE- BID CLARIFICATION

Type of Corrigendum			
Technical Corrigendum -	☐	Commercial Corrigendum -	☒

In reference to the above mentioned tender enquiry, please note the following:

- 1) There is no source of power (availability of HT line) near Butterfly Valve House.
- 2) There is no connection between Valve House Building and Column erection of EOT Crane. Building construction is done after Column erection; so Crane may be installed before Building is ready.
- 3) All work of installation of EOT Crane to be done by Supplier using his own power sources.
- 4) Supplier shall complete Load Testing of EOT Crane using his own resources.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.