



BHARAT HEAVY ELECTRICALS LIMITED  
PROJECT ENGINEERING MANAGEMENT, NOIDA

Date-20-Jan-23

CORRIGENDUM- 01

<b>PROJECT</b>	:	2 x 660 MW NTPC TALCHER TPP, STAGE - III
<b>PACKAGE</b>	:	D/G EOT CRANE ABOVE 100 T
<b>ENQUIRY NO</b>	:	BID NO: GEM/2023/B/2968242 dated 10.01.2023
<b>SUBJECT</b>	:	<b>PRE-BID CLARIFICATION + DUE DATE EXTENSION</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input type="checkbox"/>

In reference to the above mentioned tender enquiry for D/G EOT CRANE ABOVE 100 T package.

Please note the following:

1. Due date for offer submission has been extended till **30.01.2023 till 4:00 PM** and P1 by 04:30 PM.
2. All bidders are requested to go through the attached pre-bid clarification please.

All the other terms and conditions of the tender enquiry shall remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

Guru Das  
Manager



**2x660MW TALCHER TPP STAGE-III  
DOUBLE GIRDER EOT CRANES ABOVE 100T**

**SPECIFICATION No: PE-TS-497-501-A501**

**VOLUME: III**

**SECTION-III**

**SUB-SECTION-IIIC**

REV 00

DATE 18.01.2023

**SUB SECTION-IIIC  
PRE BID CLARIFICATIONS**



2x660MW TALCHER TPP STAGE-III  
DOUBLE GIRDER EOT CRANES ABOVE 100T

SPECIFICATION No: PE-TS-497-501-A501

VOLUME: III

SECTION-III

SUB-SECTION-IIIC

REV 00

DATE 18.01.2023

**PRE-BID CLARIFICATIONS**

S. No.	Section/Clause/Para No.	Statement of the referred clause	Clarification Required	BHEL's clarification
1	SUB-SECTION – IC DATA SHEET, Clause 3.7.0, Page 196 of 368.  SECTION – IA, CRANE CLEARANCE DIAGRAM, Page 99 of 368.	Wheels details, Long travel, Numbers provided, 8 nos. or 16 nos.	LT wheel :- 16 Nos wheel required as per crane clearance diagram and 8 Nos wheel mentioned in the data sheet, - which one shall we consider? please confirm.	Please note that 8nos. wheels as mentioned in the datasheet is the minimum requirement. CCD showing 16nos. wheels shall be followed.
2	SUB-SECTION – IC DATA SHEET, Clause 3.18.2, Page 201 of 368	LT Motors, Numbers furnished- 2nos.	LT Drive:- As per data sheet 2 Nos. wheel drives are required but If the number of LT wheels required are 16, our recommendation would be 04Nos LT wheel drive so kindly confirm.	Please note that 2 nos. LT wheel drives is the minimum requirement. It is acceptable in case the bidder offers more as per their recommendation, subject to discussion during detailed engineering.
3	-	-	Cradle and testing load in vendor scope or BHEL scope ?	For cradle and testing load "at site", please refer following clause:  Page 15 of 368 of Technical Specification <b>"1.2.4 Arranging test load at site</b> Collecting the test load at site within a radius of 1-2 KM from owner's storage to final testing bed of crane shall be under bidder's scope of work. Test load in the form of rolled steel, plates, girder, angle etc., as available at the site shall be made available by the purchaser. The test load shall be put back to the place from where it was lifted by the vendor, after the load testing. Load testing sling, cradles and any other item required by the vendor during the load testing shall be arranged by the vendor at no extra cost to the purchaser. Slings & cradles will be allowed to be taken back by the vendor, after completion of the test at site."