

MM-Thermal

Corrigendum to NiC tender ID: 2025_BHEL_52237_1 with **E1653075**

(I) Details of required material thickness are as below:

1) Insulation Thickness:

0.65mm (nominal) & 0.585mm (min. at any point)

2) Inner sheath thickness:

0.3mm (Min.)

3) Outer sheath Thickness:

1) 1.30 mm (nom) & 1.04 mm (min at any point)

(II) All terms and conditions remain unchanged.

Sr. Manager(MTX)