

SPEC.NO. TCE.5750A-H-500-001	TATA CONSULTING ENGINEERS LIMITED		VOLUME II SECTION – B
	RRVUNL, 2 x 660 MW, Super-Critical TPS, Stage-V, Unit # 7 & 8 at Suratgarh, Rajasthan GENERAL PROJECT INFORMATION		SHEET 1 OF 3

1.0	Owner	Rajasthan Rajya Vidyut Utpadan Nigam Ltd., Jaipur
2.0	Consulting Engineer	TATA Consulting Engineers Ltd. 73/1, St. Marks Road, Bangalore – 560 001 Tel : 080 – 6622 6000 Fax : 080 – 22274874
3.0	Location of the plant	Prabat Nagar, Suratgarh Sriganganagar district, Rajasthan.
4.0	Latitude and longitude	Latitude : 29 deg. 10 min. N Longitude : 74 deg.01 min. E
5.0	Elevation above mean sea level	186 m (approximate)
6.0	Climatic conditions	
6.1	Temperatures : Monthly basis	
	Mean of daily max.	32.8 deg.C (in the month of May)
	Mean of daily min.	17.6 deg.C (in the month of Jan)
6.2	Temperatures : Annual basis	
	Mean of daily max.	32.3 deg.C
	Mean of daily min.	19.6 deg.C
	Highest temperature recorded	50 deg.C
	Lowest temperature recorded	(-) 2.8 deg.C
	Design Ambient Temperature for Electrical Equipment design	50 deg C
6.3	Relative humidity	Varies between 21% and 81%
6.4	Annual average rain fall	312 mm
6.5	Annual mean wind speed :	4 km / hr.
7.0	Wind load	

ISSUE R1

SPEC.NO. TCE.5750A-H-500-001	TATA CONSULTING ENGINEERS LIMITED		VOLUME II SECTION – B
	RRVUNL, 2 x 660 MW, Super-Critical TPS, Stage-V, Unit # 7 & 8 at Suratgarh, Rajasthan GENERAL PROJECT INFORMATION		SHEET 2 OF 3

	Calculations for wind effect shall be in accordance with IS:875-1987(Part-3) taking into account the following:	
	a) Basic wind speed = 47 m/sec	
	b) Factor K1 = 1.07	
	c) Category of terrain = Category 2	
	d) K3 – as per IS 875	
8.0	Seismic data (As per IS: 1893 latest issue)	
	a) Zone	Zone II
	Designs & design coefficients shall be based on IS 1893:2002	
	Design condenser cooling water inlet temperature	33 Deg C
9.0	Auxiliary power supply:	
	Auxiliary electrical equipment to be supplied against this specification shall be suitable for operation on the following system:	
	a) For motors rated 160 kW and below.	415V AC, 3-phase, 3-wire effectively earthed.
	b) For motors rated above 160 kW and up to 1500 kW	6600V AC, 3-phase, 3-wire, 50 Hz, non-effectively earthed
	c) For motors rated above 1500kW	11000V AC, 3-phase, 3-wire, 50 Hz, non-effectively earthed
	d) For motor control centres	415V AC, 3-phase, 3/4-wire effectively earthed.
	e) DC motor starters, DC solenoids, DC alarm control and protection	220 V DC, 2-wire unearthed
	f) AC control & protective devices	110 V 1 phase, 50Hz, 2 wire AC supply. The single phase 110V AC supply shall be derived by VENDOR by providing 415V / 110 V Control transformers of adequate rating with MCCB / MCB on both the primary and secondary sides.
	g) Uninterrupted power supply	230 V, 1-phase, 50 Hz, 2-wire, AC

ISSUE R1

SPEC.NO. TCE.5750A-H-500-001	TATA CONSULTING ENGINEERS LIMITED		VOLUME II SECTION – B
	RRVUNL, 2 x 660 MW, Super-Critical TPS, Stage-V, Unit # 7 & 8 at Suratgarh, Rajasthan GENERAL PROJECT INFORMATION		SHEET 3 OF 3

		supply (For all instrumentation and control system equipment and solenoid valves)
--	--	---

g) Lighting fixtures and space heaters

240 V, 1 phase, 2 wire, 50Hz,solidly earthed system

h) Construction supply

415 V, 3 phase, 4 wire, 50Hz AC supply with neutral lead solidly earthed.

i) The above voltages may vary as follows :

All devices shall be suitable for continuous operation over the entire range of voltage and frequency indicated below without any change in their performance.

AC supply

Voltage variation $\pm 10\%$
Frequency variation $\pm 5\%$

DC supply

Combined voltage & frequency variation 10%
Voltage variation +10% ,-15%

j) For instrument and control system of steam generator and steam turbine generator.

230 V $\pm 5\%$ AC UPS, 1-phase, 50 Hz, 2-wire. The 24 V DC required for control system shall be generated from this UPS.

10.0

All the electrical equipment shall be designed for 50° C reference ambient temperature.

ISSUE
R1

FORM NO. 329 R5