





6160-0120



CAUTION THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LTD. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY




ITEM.03




ITEM No. 01



ITEM 04



ITEM05



ITEM No. 02

NOTE

1. THIS CLAMP (TYPE-A) SHALL BE USED FOR PIPE INSULATION OF OVERALL DIAMETER OF 200 mm AND BELOW.
2. WELD ITEM No.04 AFTER ASSEMBLY.
3. ITEM No.04 IS TO BE RIVETTED AFTER ASSEMBLING ITEM No.01 AND ITEM No.02 IN POSITION.
4. THE ENTIRE CLAMP SHALL BE GALVANIZED (15 μ -25 μ .) AFTER ASSY.
5. THE MATERIAL FOR ITEM No.03 & 04 SHALL BE SOFT AND ANNEALED.
6. THE CLAMP SHALL BE PACKED ALONG WITH NECESSARY FASTENING ITEMS (ITEM No.07 & 08) WHICH ARE INTENDED FOR FIXING THE CLAMP IN OUTER CASING, IN SEPARATE POLYTHENE POCKET.

ITEM NO	DESCRIPTION	QTY	UNIT	PRICE	TOTAL	TAX	NETT	GST	GRAND TOTAL
08	NUT HEX P8 M4								
07	SCRU SLT CHS A P-6 M4 X10								
06	RIVET SNAP 3X8								
05	SHEET 1 X 15 X 78								
04	WIRE Ø3.15 X 120								
03	WIRE Ø3.15 X 18								
02	SHEET 1 X 30 X 60								
01	SHEET 1 X 35 X 75								
01	SM CLAMP FOR DET INSIN TYPE 'A'	6160	0120	20					

١٠٠٠

TYPE OF PRODUCT
OR NAME OF
CUSTOMER/PROJECT

Bharat Heavy Electricals Ltd.,
BOILER PLANT UNIT
TIRUCHIRAPALLI-620 014

DOB	NAME	SIGN	DATE	NO. OF PAM
	G.D.N	<i>L. J. J. J. J.</i>	1-9-82	
CHB	T.K	<i>A. J. J. J. J.</i>		
	C.V			

REV	01	DATE	30/11/2018	BY	A.R.J. N.	W.	K.S. W.
ITEM NO. 08 MATL. SPECN. ALT D.							

TITLE	FORM CODE	DRAWING NO.	REV.
SHEET METAL CLAMP-A (FOR DETACHABLE INSULATION)	U 01	6160-0120	01