

ENQ: E1893198

Project: - Kameng HEP (4 x 150 MW)

Pre-Qualifying Criteria for Vendor/Authorized Dealers of Clamp-on Type Flow Meters

1. Vendor/Authorized Dealer should have supplied, installed and commissioned a 2-Path Clamp-on Type Ultrasonic Flow Meter for a minimum pipe size of 2250mm or more with an accuracy of $\pm 2\%$ or better in any hydro installation / industrial application in India or abroad in the last 5 years.
2. Vendor/Authorized Dealer has to submit a copy of unpriced PO/ Delivery Challan/ Invoice/ Commissioning report etc as a documentary evidence along with the offer as a proof of supplying and successfully installing the instrument with above parameters.
3. Authorized Dealer shall submit Authorization letter along with offer with validity date issued from OEM. It is not applicable for OEM.
4. The OEM of the instrument should have ISO certificate.
5. Vendor/Authorized Dealer to furnish audited balance sheet and profit & loss account for the last three financial years ending March 2019. Foreign Vendor/Authorized Dealers to furnish latest BIR (Business information report) issued by a reputed third party business-rating agency like Dun & Bradstreet, Creditreform etc. or empaneled third party business rating agency by BHEL, if any. Average turnover in last 3 years ending on 31.03.2019 should not be less than Rs 9 Lakhs.