


 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR TESTING INSTRUMENTS	SPECIFICATION NO. EM-PRAN-EWS-TS-16	
		Rev. No	00
	PRANHITA CHEVELLA LIS LINK-II(PKG #6,8,10 &11)	Date	03.08.2017

SPECIFIC TECHNICAL SPECIFICATIONS

 4/8/17 Dilip Wadhe	 Mandvi Gupta
PREPARED BY	APPROVED BY

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR TESTING INSTRUMENTS	SPECIFICATION NO. EM-PRAN-EWS-TS-16	
		Rev. No	00
	PRANHITA CHEVELLA LIS LINK-II(PKG #6,8,10 &11)	Date	03.08.2017

(1) Details of Equipment

Bidder must quote the make, model No, material description & quantity offered in their quotation /bid, as specified below. Bidder's alternate description can also be given in separate column.

Completeness of Equipment:

Each of the equipment listed shall be complete with applicable accessories like power supply main leads, screened guard leads, screened line test leads, earth leads, connectors and clips, leather carrying case and any other accessories required for completing the equipment. Bidder has to mention technical details & quantity of each item under this category along with offer.

1) Equipment for Pranhita # 6, WO No. 6863-11

Sl.No.	Item specification	Qty	Details of Equipment offered by the Bidder	
			Make & Model No	Catalogue No
1	DC High Voltage test set Input: 220/240V AC, 50Hz Output: 60kV, 10mA (min.) Accuracy: Applied test voltage: +2% Leakage current: +5% The equipment should be manufactured as per latest applicable standards & complete with all protection & interlocks, along with all essential accessories.	1 No.		

2) Equipment for Pranhita # 8, WO No. 6846-11

Sl.No.	Item specification	Qty	Details of Equipment offered by the Bidder	
			Make & Model No	Catalogue No
1	DC High Voltage test set Input: 220/240V AC, 50Hz Output: 60kV, 10mA (min.) Accuracy: Applied test voltage: +2% Leakage current: +5% The equipment should be manufactured as per latest applicable standards & complete with all protection & interlocks, along with all essential accessories.	1 No.		

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR TESTING INSTRUMENTS		SPECIFICATION NO. EM-PRAN-EWS-TS-16	
			Rev. No	00
	PRANHITA CHEVELLA LIS LINK-II(PKG #6,8,10 &11)		Date	03.08.2017

3) Equipment for Pranhita # 10, WO No. 6855-11

Sl.No.	Item specification	Qty	Details of Equipment offered by the Bidder	
			Make & Model No	Catalogue No
1	DC High Voltage test set Input: 220/240V AC, 50Hz Output: 60kV, 10mA (min.) Accuracy: Applied test voltage: +2% Leakage current: +5% The equipment should be manufactured as per latest applicable standards & complete with all protection & interlocks, along with all essential accessories.	1 No.		

4) Equipment for Pranhita # 11, WO No. 6867-11

Sl.No.	Item specification	Qty	Details of Equipment offered by the Bidder	
			Make & Model No	Catalogue No
1	DC High Voltage test set Input: 220/240V AC, 50Hz Output: 60kV, 10mA (min.) Accuracy: Applied test voltage: +2% Leakage current: +5% The equipment should be manufactured as per latest applicable standards & complete with all protection & interlocks, along with all essential accessories.	1 No.		

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR TESTING INSTRUMENTS		SPECIFICATION NO. EM-PRAN-EWS-TS-16	
			Rev. No	00
	PRANHITA CHEVELLA LIS LINK-II(PKG #6,8,10 &11)		Date	03.08.2017

(2) Technical Deviation Statement (if any)

Sr No.	Item	Deviation	Justification for Deviation

Note: Bidder has to indicate clearly the deviations if any w.r.t. specification. Bidder has to indicate all the deviations on this sheet only, deviations mentioned elsewhere in Bidder's offer will not be considered.