

GATE Electric/Pneumatic Actuator Indenting Parameters

INTERNAL

Ref: GATE :Act:Data:ora:R676 R677

Indenting Agency:
RPT_CI

Project Name:
BANGLADESH-1 660

Customer numbers
R676 R677

Revno: 1

SI No	PG	Ma	Pgma Desc	Tag	Qty	No Of Turns	Min RPM	6 minute Reqd Run Torque (kgm)	Starting Torque (kgm)	Stall Torque (kgm)	Bore Dia (mm)	Length (mm)	Width (mm)	Depth (mm)	Direction	Revision number	Revision Reason
1	57	010	GATE-FD FAN OUTLET		2	4.67	1.6	702	1755	1800	80.05	160	22	5.4	LH		
2	57	010	GATE-FD FAN OUTLET		2	4.67	1.6	702	1755	1800	80.05	160	22	5.4	RH		
3	57	470	GATE-ESP OUTLET		4	3.55	1.6	702	1755	5300	80.05	160	22	5.4	LH		
4	57	470	GATE-ESP OUTLET		4	3.55	1.6	702	1755	5300	80.05	160	22	5.4	RH		
5	57	460	GATE-ESP INLET		4	2.34	1.6	1248	3120	5300	95.05	230	25	5.4	LH		
6	57	460	GATE-ESP INLET		4	2.34	1.6	1248	3120	5300	95.05	230	25	5.4	RH		
7	57	370	GATE-GAS TRISECTOR APH INLET		4	4.58	1.6	1326	3315	5300	95.05	230	25	5.4	LH		
8	57	370	GATE-GAS TRISECTOR APH INLET		4	4.58	1.6	1326	3315	5300	95.05	230	25	5.4	RH		
9	57	110	GATE-PA FAN OUTLET		1	2.13	1.6	1716	4290	5300	95.05	230	25	5.4	LH		
10	57	110	GATE-PA FAN OUTLET		1	2.13	1.6	1716	4290	5300	95.05	230	25	5.4	RH		
11	57	490	GATE-ID FAN OUTLET		2	4.22	1.6	1716	4290	5300	95.05	230	25	5.4	LH		
12	57	490	GATE-ID FAN OUTLET		2	4.22	1.6	1716	4290	5300	95.05	230	25	5.4	RH		
13	57	480	GATE-ID FAN INLET		2	5.45	1.6	2030	5074	8500	125.05	230	32	7.4	LH	1	BORE/STAL L CHANGED
14	57	480	GATE-ID FAN INLET		2	5.45	1.6	2030	5074	8500	125.05	230	32	7.4	RH	1	BORE/STAL L CHANGED
15	57	430	FLUE GAS AH OUT GATE		2	5.58	1.6	2418	6045	8500	125.05	230	32	7.4	LH		
16	57	430	FLUE GAS AH OUT GATE		2	5.58	1.6	2418	6045	8500	125.05	230	32	7.4	RH		

* Rerol 57480 Bore, key way & stall torque altered.

M. Suresh
26/10/2017
M. SURESH
Engineer / G & D
BHEL/BAP/ RANIPET - 632 406.

Kesavan V
26/10/2017
KESAVAN.V
DEPUTY GENERAL MANAGER
EDC - GATES & DAMPERS
BHEL/BAP/ RANIPET - 632406.