

Selective Catalytic Reduction System

Project DN101



**High Pressure Boiler Plant
BHEL, Tiruchirapalli**

Attachment I

to

CFT REPORT ON Preparation of Technical Specification of DeNox
system for meeting new MOEF emission norms published on 8th December
2015

The Specification for High Dust SCR system was prepared by the listed CFT members as below:

Sl.no	Name S/Shri.	Designation	Sign
1	D.Jayanthee	DGM / Marketing(FB) - Convener	<i>D. Jayanthee</i>
2	T.Balamurugan Murali	SM / BPP	<i>T. Balamurugan Murali</i>
3	K.Priyakamesh	Sr. Engr./ BPP	<i>K. Priyakamesh</i>
4	G.Saravana Kumar	SM / FS / PE(B)	<i>G. Saravana Kumar</i>
5	Dheeraj Kumar	Sr. Engr. /FS / PE(B)	<i>Dheeraj Kumar</i>
6	D.Ramachandran	SM /C&I / PE(B)	<i>D. Ramachandran</i>
7	S.Sreenivasan	Sr. Engr./ LO /PE(B)	<i>S. Sreenivasan</i>
8	S.Santhosh Raaj	Sr. Engr./ CR	<i>S. Santhosh Raaj</i>
9	K.Saranya	Sr. Engr./ CR	<i>K. Saranya</i>

Dt.16.11.2016



High Pressure Boiler Plant
BHEL, Tiruchirapalli
Specification for High Dust SCR system

TDN:SCR:001
Rev 00
Page 1 of 32

Specification for High Dust SCR system

1. The specification Contains :

Part I – General Requirements

Part II – Detail specification Requirements

Part III – Contract specific Technical Requirements

2. If the requirement of Part-I and Part-II is differing with Part III, then the requirement of Part III will be mandatory.

3. Vendor should fill up all datasheets for evaluation of offer.

4. Vendor shall submit all the documents identified in the specification.

5. Incomplete offers will not be considered.

PREPARED BY:
CFT

REVIEWED BY:
CFT

DATE:
21.10.2016

REV No.	DETAILS	REVISED BY	APPROVED BY	DATE



High Pressure Boiler Plant
BHEL, Tiruchirapalli
Specification for High Dust SCR system

TDN:SCR:001

Rev 00

Page 2 of 32

Part-I

General Requirements



1.0. GENERAL

Selective Catalytic Reduction (SCR) System shall reduce overall NO_x (oxides of nitrogen) produced in the Steam Generator to the specified values. This system shall be based on catalysts which will enable reduction of NO_x by ammonia (NH₃). The complete SCR system shall be designed for outdoor location connected to the coal fired steam generator. The SCR system shall be designed to contain ammonia slip to specified values under all operating conditions. Ease of maintenance, repair and overhaul shall be a central consideration in the SCR equipment design/arrangement, assembly, access, provisions for spares/tooling etc. The design/specifications/sizing of various plants/systems/equipment offered for the SCR System & Auxiliaries shall comply with the requirements detailed hereinafter.

The SCR system supplier (the Vendor) shall design, fabricate, deliver and place the selective catalytic reduction (SCR) system into commercial operation for treating the flue gas NO_x emissions exiting the steam generators. The SCR system design conditions shall be as specified in Part II of this specification.

2.0. DESIGN CRITERIA FOR THE SCR SYSTEM

The design of the SCR system shall be based on proven concept of reduction of NO_x in the flue gas emanating from pulverized coal fired steam generator through mixing ammonia and passing it through catalyst bed placed in reactor. Ammonia shall be mixed to the flue gas upstream of the SCR reactor. The flue gas shall flow from top to the bottom of the reactor unless otherwise specified elsewhere in the specification. A reactor gas side by-pass shall be provided for operational flexibility. The total catalyst requirement shall be arranged in layers, on horizontally arranged support frames inside the reactor. Further provision for one spare future layer of catalyst shall be made within the reactor. Anhydrous ammonia shall be used as the reagent for the SCR system. Unloading from truck, Storage and forwarding facility for ammonia shall be provided including facility for its vaporization and dilute air-ammonia mixture preparation for feeding in to the flue gas through an injection system.

2.1 Materials and Equipment

2.1.1 Materials and equipment must be new and of proven design. Equipment deemed to be prototype in nature are unacceptable.

2.1.2 The use of asbestos, asbestos containing materials, or polychlorinated biphenyls (PCBs) is prohibited in any of the equipment furnished.

2.1.3 Parts subject to wear, corrosion, or deterioration, or requiring adjustment, inspection or repair shall be accessible and capable of convenient removal, replacement and repair.

3.0 REGULATIONS, CODES, STANDARDS AND SPECIFICATIONS

3.1 Referenced Standards

3.1.1 Reference to the standards of any technical society, organization, or association, or to the laws, ordinances, or codes of government authorities shall mean the latest standard, code, or specification adopted.

3.1.2 The referenced codes and standards shall govern in all cases except where they conflict with the requirements of these specifications. In case of conflict between this specification and codes or standards and, the stringent requirement shall be followed and the same shall be brought to the notice of the Purchaser.

3.1.3 Publications of the following agencies shall form a part of these specifications to the extent specified therein. References to the sponsoring agencies will be made in accordance with the abbreviations indicated:



ACI,	American Concrete Institute
AHI,	American Hydraulic Institute
AMCA,	Air Movement and Control Association, Inc.
ANSI	American National Standards Institute
ASME	American Society of Mechanical Engineers
ASTM,	American Society Testing and Materials
AWS,	American Welding Society
BIS,	Bureau of Indian Standards
ISA,	Instrument Society of America
IEEE,	Institute of Electrical and Electronics Engineers
NEMA,	National Electrical Manufacturers' Association
NEC,	National Electrical Code
NFPA,	National Fire Protection Association
OSHA	Occupational Safety Health Act
SMPV,	Static Mobile Pressure Vessel Code

3.1.4 Other Regulations and Codes:

- a. IS 4544, Ammonia - Code of Safety, Ammonia Code of Safety. This includes providing process safety information as well.
- b. IS 662/ 799 – Indian Standard for specification for Anhydrous Ammonia / Ammonia Liquor
- c. ANSI Pamphlet CGA G_2.1—2014 6th Edition (formerly ANSI K61.1), - Safety Requirements for the Storage and Handling of Anhydrous Ammonia
- d. ASME Boiler and Pressure Vessel Code, Section VIII- Pressure Vessels
- e. All local safety and handling ordinances concerning automatic sprinkler systems, canopies, impoundments, and venting requirements
- f. AISC specification for the Design, Fabrication and Erection of Structural Steel for Buildings (latest edition)

Omission of any codes or standards does not relieve the Vendor of his responsibility to follow all applicable codes, standards and regulations. Any conflict among standards shall be referred to the Purchaser who shall determine which standard governs. Should codes and standards be revised after the issue of these specifications, the Vendor should inform the Purchaser immediately upon receipt of such information. Before adoption of any subsequent issue, or case ruling, the Vendor shall discuss the effect of these requirements with the Purchaser and proceed with material and/or fabrication changes only after the Purchaser's written approval.

4.0 SCOPE OF SUPPLY

The SCR system scope of supply shall include the following:

4.1 SCR Reactor

- a. Reactor chamber including duct plate housing, insulation, lagging and all structural internal supports. The reactor chamber housing shall include provisions for access as required to maintain the system, test ports, equipment mounted instrumentation for monitoring the performance & tuning the system, access doors for catalyst loading, removal & inspection. In addition, a permanent sealing system along the bottom support beams and between catalyst modules, baffle and seal bars on top of each module, internal reactor guide vanes & an upstream flow straightening system (if required), and reactor external sliding supports shall be furnished.

Note: The Vendor shall size/match the Purchaser's arrangement drawings (Refer Part III) in order to confirm adequate access provisions for all furnished equipment. Vendor



shall furnish SCR arrangement drawing indicating all access requirements including external stairways, ladders, platforms, handrails and handling requirements and accessories supplied by the Purchaser.

- b. An internal and external monorail/hoist system shall be utilized to remove, install and handle catalytic modules. Internal reactor monorail steel shall be provided by vendor at each catalyst layer to accommodate the installation and removal of modules. External monorail support steel and an interconnecting transition piece (if required) shall be provided by the Purchaser. Vendor to recommend the locations of catalyst removal access doors and loading scheme in the SCR arrangement drawing to be submitted for Purchasers review.
- c. Scope of SCR duct work including external stiffeners, internal supports, duct expansion joints, dampers, insulation and lagging shall be as per Terminal Point indicated in P&ID. Required test ports for sampling, fixed monitoring probes, guide vanes design and location, if required in the duct of Purchaser's scope, shall be provided by the Vendor.

Note: The external steel for ductwork support design shall be by Purchaser. The Vendor shall supply all relevant ductwork loading and expansion information to the Purchaser.

4.2 Catalyst Modules

- a. SCR catalyst modules including all equipment to safely install the modules within the reactor chamber. Activity testing of sample catalyst elements during the guaranteed service of the catalyst shall be provided. Catalyst instruction manuals describing short and long term storage requirements, installation procedures, permissible inlet operating conditions and disposal procedure shall be furnished. Correction curves for off-design field operating conditions shall also be provided.

4.3 Flue Gas Mixing Device and Flow Model Study

- a. Flue gas mixing devices, as required, to ensure a uniform distribution of ammonia, temperature and gas velocity entering the first catalyst layer. A physical flow model will evaluate the necessity for such a device.
- b. A 1/10th scale, Plexiglas flow model study of the SCR system arrangement shall be provided. This shall be supported with CFD study of the full scale model. Physical modelling for SCR reactor, upstream duct work from economizer outlet (including economizer gas bypass) along with cyclone separator (if applicable) and downstream ductwork from SCR reactor outlet upto Air preheater inlet including Ammonia injection grid/nozzle shall be carried out to examine and finalize the design options for the duct system, flow modification devices, Ammonia Injection system, etc. This shall confirm the Vendor's SCR system performance with respect to ammonia distribution, ammonia injection grid design and location, internal duct guide vane arrangement, areas of possible dust accumulation, flue gas mixer design and location, and reactor design and inlet ductwork arrangement. Based on the model test studies, the Vendor shall finalize the geometry of the reactor, ductwork, flow modification devices, sampling points etc. The model study shall be carried out in the presence of the Purchaser. The physical model shall use fan(s) to draw air through the model at a flow rate that provides similar fluid dynamic behaviour to the full scale system.



4.4 De-dusting System

- a. Steam assisted soot blowers shall be provided above each catalyst layer. All blowers, piping, valves, fittings, drains, reactor soot blower steel supports and complete controls and wiring shall be furnished.

Note: Steam piping shall be furnished by the Purchaser up to a single terminal point at the SCR boundary.

Alternatively, sonic horn and air cannon for blowing/dislodging accumulated/sticking ash and fouling on catalyst surface. Type of de-dusting system shall be offered based on Vendor's standard practice/ past supply experience.

The contractor shall establish/ recommend de-dusting device frequency and their performance tuning based on the actual operation through controlled tests/measurements. Cleaning effectiveness shall target recovery, as measured through gas pressure drop and visual inspection, up to a near pressure drop value with reference to completely clean reactor as measured at the time of commissioning. In case if above de-dusting systems are not sufficient for effective cleaning of the catalyst than the bidder may provide Dry Cleaning System for in-situ cleaning of the catalyst in addition to above.

4.5 Ammonia Unloading, Storage, Handling and Preparation System

- a. An ammonia handling and storage facility including unloading system, compressor to unload for supply truck, storage tanks, , and valves required for the safe unloading and storage of anhydrous ammonia with all equipment's, fittings, hose connections, monitoring and safety devices. All equipment shall meet international and local regulations codes.
- b. Two (2) x 100 % Ammonia vaporizers with all associated connecting piping to vaporise the ammonia required for the SCR system. If steam assisted vaporization system is offered associated accumulators, piping, instrumentation and controls shall be offered. Condensate formed due to the condensation of steam shall be connected to the condensate tank by the Purchaser from Vendors terminal point. Vendor to provide steam requirements and terminal points.
- c. Two (2) x 100 % common ammonia forwarding pumps skid (if applicable) (1 working and 1 standby pump) with recirculation line shall be provided to ensure steady supply of ammonia to the vaporizer and flow control units (located at the steam generator).
- d. Ammonia accumulators and associated systems capable of handling the ammonia to meet the requirements of SCR system.
- e. A dyke shall be provided around storage tank area with storage capacity equivalent to one storage tank, for collection of liquid ammonia in case of emergency. This dyke shall be connected to waste water retaining basin. Civil works are under Purchaser's scope.
- f. One (01) no. Waste water retaining basin near ammonia unloading & storage system along with 2x100% waste water/ ammonia disposal pumps with motors for transferring drains to Water Treatment Plant (WTP). Chemical dosing system for controlling pH of waste water before sending to WTP.

	High Pressure Boiler Plant BHEL, Tiruchirapalli Specification for High Dust SCR system	TDN:SCR:001 Rev 00 <i>Page 7 of 32</i>
---	---	--

- g. A dilution air skid including an ammonia/air mixer, two (2) x 100 % dilution air blowers, two (2) x 100 % dilution air heaters (if required), instrumentation, valves and local controls. The ammonia flow instrumentation shall include all necessary control, shutoff, bypass and relief valves and monitoring devices to ensure a safe operational system. The required control logics and interlocks for implementation in purchaser's DCS shall be furnished by vendor.
- h. An ammonia dilution tank of adequate capacity shall be provided with all interconnecting piping to allow the safe disposal of any excess ammonia vented or drained from the system.
- i. All interconnecting piping from the ammonia storage tank / vaporizer skid to the dilution air skid, and from the dilution air skid to the ammonia injection inlet manifold shall be provided. Fittings, hangers and supports shall be provided for all piping in the Vendor's scope of supply.
- j. Personnel safety equipment in order to comply with all local requirements. As a minimum, the following shall be provided:
 - i. Shower/eyewash stations located in the vicinity of the ammonia storage tanks and the dilution air skid
 - ii. Face masks and canisters
 - iii. Goggles
 - iv. Gloves and boots
 - v. Ammonia sensor alarms (for local & remote) located in the vicinity of the ammonia storage tanks and the dilution air skid

4.6 Ammonia Injection System

- a. Ammonia injection system including an inlet manifold with local temperature and pressure gauges, ammonia injection nozzles, flow control valves, flow orifices and manometers, flex hoses, compressed air valve connections and all required piping with internal and external structural supports. The space and access requirement shall be indicated in the AIG arrangement drawing.

4.7 Electricals, Controls and Instrumentation

The following shall be under vendor's scope of supply

- a. All the controls and interlocks required for safe operation of the complete SCR system and other auxiliary systems.
- b. The O₂ Analyser, SO₂ Analyser, NO_x analyser at inlet and outlet of SCR reactor, NH₃ analyser at outlet of SCR reactor as indicated in the P&ID. In addition, pH measurement (if applicable) and any other analysers connected elsewhere in the SCR system shall also be under vendor's scope of supply.
- c. The ammonia leak detector system with all its associated instrumentation, controls and annunciation system shall be under vendor's scope of supply. Detailed specification shall be referred.
- d. All instruments in the lines/equipment supplied by the vendor shall be in vendor's scope. These instruments shall be terminated in local junction box / local control panel / skid as



per vendor's standard practice. Vendor to refer Annexure U for Specification of field Instruments.

- e. All pneumatic actuators (with smart positioners for regulating duty) & electric actuators for regulating and Open/close applications shall be in vendor's scope of supply. Vendor to refer Annexure R for Specification of Actuators.
- f. All equipment/instruments in vendor scope shall be wired up to the local junction box/ local control panels. The Instrumentation & Control cables from field equipment / instruments to Local JB/ Local Control panels shall be in vendor's scope of supply. Vendor to refer Annexure V for Specification of all the varieties of cables.
- g. All Local Controls Panels, Field Junction boxes, Local instrument enclosures shall be in vendor's scope of supply. Vendor to refer Annexure W for detailed specification.
- h. All Instrument installation/erection materials including piping's, fittings, root valves etc., required for the vendor supplied instruments shall be in vendor's scope of supply. Vendor to refer Annexure W for detailed specification.
- i. All erection materials including cable glands, cable trays required for vendor supplied equipment/instruments/panels/enclosures/junction boxes/cables shall be in vendor's scope of supply. Vendor to refer Annexure W for detailed specification.
- j. All LT & HT motors part of the SCR system shall be in vendor's scope of supply. Vendor to refer Annexure S for Specification of Motors.
- k. Vendor to refer Annexure Q for Electrical Power supply details.
- l. Vendor to refer Annexure P for Terminal Points for Electrical C&I Equipment.

4.8 Other Requirements

- a. Utility piping, fittings, hangers and supports from a tie-in point at the Vendor's battery limit to service the SCR system steam, water and air requirements.
- b. Primer, finish painting of all uninsulated steel and piping surfaces shall be provided. Purchaser shall confirm if the Vendor's paint is acceptable.
- c. One (1) year spare parts (excluding catalyst) for maintaining the availability of the Vendor's supplied equipment shall be supplied along with main equipment.
- d. Mandatory spares as per the list enclosed separately shall be offered.
- e. Erection material for vendor supplied equipment.
- f. Supervisory services for the erection, start-up, testing and commissioning of the Vendor's equipment. Breakup price for the above services shall be quoted separately.
- g. Instruction manuals, performance test procedures and testing plan for the equipment supplied by the Vendor for purchasers review and acceptance.
- h. Performance testing and commissioning is Vendor's responsibility.
- i. Trouble shooting of equipment engineered or supplied by vendor before handing over of SCR system to end customer shall be in Vendor scope.
- j. Onsite SCR training program with instruction manuals for preparing the Purchaser's personnel to operate and maintain the equipment supplied by the Vendor.
- k. Vendor quality plan shall be submitted for Purchaser's review and approval.
- l. The Vendor shall provide the Purchaser with reasonable advance notice of all factory tests associated with the equipment/items under Vendor scope of supply. The Purchaser shall be entitled to witness all factory tests. The Purchaser shall also be allowed to specify a third party representative to witness these tests.



In general, all components, features and design parameters specified herein are minimum requirements. If the Vendor's design dictates that these requirements be exceeded to meet specified performance guarantees and to provide a safe, reliable operating unit, he shall include all equipment above and beyond the equipment required to meet these minimum requirements. The Vendor shall provide all accessories and appurtenances which are required for a complete, reliable and safe SCR operating unit whether or not the specific equipment which is customarily a part of such a system has been specified herein.

Note: For project specific scope of supply refer Division of Work document.

5.0 EXCLUSION

The following items shall be provided by others and are not a part of this specification:

- a. Supply of anhydrous ammonia
- b. Site permitting
- c. Water for the ammonia system
- d. Site utilities for construction and SCR operation - including instrument air, electrical power, water, steam, outdoor lighting, etc.
- e. All earthwork, foundations, base plates, anchor bolts and site remediation for accommodating the SCR system
- f. DCS/Remote control panels
- g. Complete Electricals including MCC, Switchgears, Distribution boards, Power Cables, Cable trays, Earthing, Grounding, Lighting & Illumination, Lightning protection system.
- h. Instrumentation and control cables beyond Local JB/local control panel (for Vendor supplied instruments)
- i. Instruments other than those specifically included under scope of supply
- j. UPS & its distribution
- k. Steam, water, air, oil, nitrogen and drain piping, valves, traps outside the Vendor's battery limit
- l. Thermal insulation as required for associated piping not furnished by the Vendor
- m. External structural steel for supporting ductwork, platforms and SCR reactor chamber. Access platforms, handrails, stairs, ladders, grating, and elevators.
- n. SCR reactor bypass duct with insulation and lagging
- o. Stack continuous emission monitoring system (CEMS) for regulatory compliance
- p. Erection of all SCR equipment
- q. Receiving and onsite storage of catalyst modules
- r. Supply of duct works from Eco out to inlet of reactor chamber.
- s. Supply of duct works from outlet of reactor chamber to APH inlet.
- t. Lining and insulation of duct works from eco outlet to APH inlet including reactor chamber



PART II

Detailed specification Requirements



1.0 SCR SYSTEM DESIGN REQUIREMENTS

1.1 The design of the SCR System shall be carried out taking following into consideration:

- a) All operating conditions of steam generator (e.g. gas temperature, ash, start/stops, load cycling) from start-up to 40% TMCR without ammonia injection and from 40% TMCR to BMCR with ammonia injection for complete range of specified coal and specified ambient air condition.
- b) Duct design for reduced gas stratification and effective gas-ammonia mixing for minimization of ammonia consumption and slip
- c) Prevention of formation of ammonium bisulfate (ABS) and other ammonia components, which deactivate or plug up or mask the catalysts and other downstream components
- d) Minimization of SO₂ to SO₃ conversion
- f) Prevention of plugging of the catalyst by ash particles
- g) Design life of 25 years (excluding catalyst).
- h) Modular construction to enable catalyst management plan (CMP) and periodic maintenance / inspections.

1.2 The SCR system shall be of a hot-side, high dust design, located between the economizer and the gas inlet duct to the air preheater.

1.3 The SCR system shall be designed for continuous operation with any of the fuels specified in Part III. The SCR equipment performance shall meet outlet emission requirements as detailed in the Part III

1.4 Anhydrous ammonia with a minimum ammonia content of 99.5 % shall be used at this facility. Anhydrous ammonia is supplied and stored as a compressed liquid with moisture limited to 0.50% maximum.

1.5 Site Conditions

1.5.1 The basis for the SCR system design shall be according to the site conditions specified in Part III

1.6 The catalyst shall be selected to meet outlet emission requirements based on the design criteria and SCR performance shall be achieved for all combinations of fuels and operating boiler loads indicated in Part III.

2.0 SCR SYSTEM GUARANTEES

2.1 The SCR system shall be designed and guaranteed to limit the NO_x emissions across all load range as specified in the Part III.

2.2 Unreacted ammonia exiting the SCR reactor shall not exceed the value specified in Part III for all operating conditions and fuels listed in Part III

2.3 The exit NO_x and unreacted ammonia emission guarantees shall be maintained over a period of minimum operational hours as specified in Part III without replenishing the catalyst. In case of non-performance of the catalysts as per guarantee terms, then the vendor is liable to replace the catalysts/equipment to meet the performance requirements.

2.4 The SCR system including all ductwork, flow distribution devices, ammonia injection grid, and reactor flow straightening grid in the Vendor's design or supply scope shall be guaranteed not to exceed the draft loss as specified in Part III with all initial and future catalyst loaded.



2.5 The draft loss across the initial loaded catalyst shall be designed and guaranteed for the inlet operating conditions specified in Part III.

2.6 The oxidation rate of SO_2 to SO_3 shall be guaranteed as per Part III at all inlet operating conditions specified in Part III while firing any of the fuels specified in Part III. The guarantee should be based upon having all future catalyst layers loaded into the reactor.

2.7 The anhydrous ammonia consumption rate shall be guaranteed for each of the fuels/ operating conditions specified in Part III.

2.8 Protocol to be signed by Vendor with end customer after proving all guarantee parameters identified in this specification.

3.0 SCR REACTOR CHAMBER

3.1 The SCR reactor shall be a high dust, hot side arrangement located downstream of the economizer and upstream of the two air preheaters. Flue gas will flow vertically down through the catalyst layers.

3.2 There shall be one SCR reactor with two outlets located directly above the two air preheaters. Alternatively vendor to consider two SCR reactor with one outlet each as an option for purchasers review. The geometry of the reactor chamber shall be as specified by vendor. The Vendor must maintain support points, reactor chamber dimensions, etc. to enable steel arrangement and design at Purchasers end. In general refer the arrangement drawing furnished by the Purchaser in Part III.

The distance between module layers shall be a minimum as specified in Part III . This distance shall provide adequate clearance between catalyst layers to facilitate loading and unloading of modules as well as internal reactor inspections.

Multiple layers of catalyst shall be provided. No modules shall be stacked upon each other in the reactor. The maximum module height in any one layer shall not exceed 1500 mm (Vendor may specify any other dimension to optimise). This shall effectively allow soot blowing to dislodge any possible ash accumulation within catalyst surfaces.

3.3 The SCR reactor chamber and inlet ductwork shall be designed to maintain sufficient velocity to prevent fly-ash dropout over the entire boiler operating load range. Reactor inlet transition ductwork shall make gradual changes in cross-sectional area and contain an adequate number of vanes and/or baffles to minimize gas separation zones, prevent dust stratification, prevent fly-ash agglomeration and erosion, and minimize the propagation of wake regimes at the inlet of the reactor upstream of the flow straightening grid.

All ductwork designed by the Vendor shall contain adequate vanes, baffles, and mixing devices to ensure that gas velocity, temperature and ammonia distribution requirements are met. The vanes and mixing devices shall be designed to promote streamlined flow and prevent erosion and vibration.

3.4 The catalyst reactor shall be a self-supporting structure designed to allow for thermal expansion and contraction. Module support shall also be designed to allow thermal expansion and contraction without stressing the modules. Internal reactor steel shall be fabricated from A-36/ IS 2062 material with rolled members. The design of the internal structure shall conform to the seismic and wind requirements specified in Part III. The structural steel design shall also confirm to the latest edition of the AISC/BIS Specification for the Design, Fabrication and Erection of Structural Steel for Buildings.



3.5 Obstructions within the reactor chamber by beams, pipes, soot blowers, etc. shall be kept to a minimum. There shall be no areas where dust can accumulate. Ledges or flat areas shall be avoided. The reactor design shall also accommodate the installation of either a plate or honeycomb catalyst without requiring major structural modifications.

3.6 The SCR reactor shall contain a flow straightening grid upstream of the catalyst layers to provide uniform flow distribution and streamlines. The reactor shall be designed to avoid non-uniform gas flow and dust deposits on the catalyst bed. Reactor inlet flow distributions shall achieve a flue gas velocity uniformity of $\pm 10\%$ from the average velocity when measured upstream of the first catalyst layer. The inlet and outlet gas flow around the straightening grid shall be as near normal (vertically downward) as possible.

3.6.1 A metal flow straightening grid shall be provided. The grid shall be provided in modules for ease of installation into the vertical flow reactor. The metal grid shall be bottom supported in the reactor.

3.6.2 The Vendor shall provide dimensional drawings of the metal grid assembled units. The drawings shall show adequate dimensions and clearances required for the proper installation and maintenance of the grid. The Vendor shall indicate the weights of each metal grid module component.

3.6.3 The metal grid modules shall be completely shop assembled and ready for installation into the reactor chamber. An optimized array of metal grid modules with lifting lugs shall be provided.

3.6.4 Module construction shall avoid flat surfaces which can potentially result in excessive ash deposition.

3.6.5 Structural tubing may be used to construct the grid. Module framework shall be constructed of carbon steel material or better. Provisions for expansion shall be inherent to the module construction. Exposure of the grid material to flue gas temperatures ranging from 200 to 400 C can be expected. All modules shall be completely welded. Other structural configurations may be proposed and considered by the Purchaser.

3.7 Reactor casing provided by the Vendor shall be welded steel plate construction fabricated from A-36 /IS 2062 material or better.

3.8 The catalyst reactor chamber shall be insulated and lagged. Adequate insulation shall be provided in order to ensure that the temperature of the catalyst surfaces does not go below the acid dew point during a shutdown. All insulation shall be applied against plate work, impaled on 10 gauge pins and secured with pin clips. All insulation shall be applied to prevent direct heat transfer through steel.

3.9 Catalyst and personnel access doors shall be independently insulated to allow convenient access or removal. Test ports and other flanged connections shall be insulated to the greatest extent possible.

3.10 Lagging shall be installed, sealed and flashed to provide a neat weatherproof protective covering. Lagging shall be a minimum of 0.81 mm on the reactor walls. Lagging on the reactor roof shall be a minimum of 1.27 mm.

3.11 The reactor shall accommodate sufficient catalyst to achieve guaranteed NO_x reduction and ammonia slip requirements as specified. A spare layer accommodating the future addition of a minimum of one layer shall be provided. Design loads, including weight, pressure, seismic, draft losses across catalyst, etc., shall consider the addition of this future layer.

3.12 A permanent sealing system shall be provided between individual catalyst modules and support beams, reactor walls, and adjacent modules to prevent bypass of the flue gas around the



catalyst. The system shall be designed to permit subsequent catalyst replacements without damaging the sealing mechanism. Baffles or shrouds (ash accumulation plates) shall be provided to prevent fly-ash accumulation between modules and along the perimeter of the reactor walls.

3.13 The SCR system shall include a reactor bypass (bypass ductwork supplied by the Purchaser) to be used during start-up, shutdown and emergency conditions. The reactor bypass shall include a tight shutoff damper to prevent flue gas slippage while the SCR is in operation. The Vendor shall assume 2 % flue gas bypassing the SCR reactor when selecting the proper catalyst volume for the design criteria specified in Clause 2 of Part II.

3.14 All access doors for inspection and catalyst loading shall be bolted construction. Square access doors shall be furnished with air tight gaskets suitable for the temperature and environment.

3.15 The Vendor shall furnish test ports on the reactor chamber to properly evaluate the performance of the catalyst. All test ports, except those used for permanent Analyzers and instrumentation connections, shall be a minimum of 101.6 mm diameter furnished with NPT thread on one end with screw cap. Pressure differential connections shall be provided between each catalyst layer. All test ports shall protrude outside the thermal insulation lagging a minimum of 101.6 mm. All other test ports not located in the Vendor's supplied ductwork and reactor shall be provided by the Purchaser. At a minimum, test ports shall be located upstream of the ammonia injection grid, upstream of the first catalyst layer and at a plane directly below the last catalyst layer (future layer). At a minimum, test ports used for portable probe traversing shall be located on 1 meter centres across any one plane.

3.16 Reactor start-up and shutdown thermal gradients shall not be limited by the internal reactor steel structure. Support beams, casings, and insulation shall be designed to allow the reactor to warm-up through the moisture and acid dew points as quickly as possible. The Vendor shall supply a start-up and shutdown sequence including a time line.

3.17 A hoist/monorail system shall be furnished by the Vendor to assist in the installation and removal of catalyst modules from the SCR reactor chamber. Internal monorail steel at each level of catalyst (including the future layer) shall be provided. An electric, slow speed hoist will be attached to the overhead monorail in order to facilitate the movement of individual catalyst modules from the ground to the proper level within the reactor. All monorail steel external to the reactor chamber shall be provided by the Purchaser. A hydraulic trolley provided with the catalyst modules shall be used to position each of the modules into the proper location within each layer.

The hoist requirements are as follows:

Number of hoists per SCR system: One (1)

Type : Lug mounted electric wire rope hoist

Load Capacity : As required to lift heaviest catalyst module

Vertical hook travel: To handle top most catalyst module level to ground level

Pendant assembly*: 1-Push-button pendant control station with conductor and support cables

Electrical requirements: Refer Part III.

**Note: The operator shall be capable of moving the load vertically 12.7 mm or less at a time by tapping the down button.*



4.0 CATALYST AND CATALYST MODULES

4.1 The catalyst supplied by the Vendor shall be plate or honeycomb type with a vanadium/titanium composition. Vendor to consider the maximum ash / dust concentration specified in Part III.

4.2 Sufficient catalyst volume shall be provided in order to meet the specified guarantees. The catalyst shall be designed in accordance with the criteria specified in Part III. Consideration shall be taken for 2 % gas flow bypass around the SCR reactor chamber. This leakage accounts for the slide gate shutoff damper located in the reactor bypass duct. The catalyst shall be capable of maintaining the performance with normal operating variations in gas temperature (+/- 10 deg. C from the average) and velocity (+/- 10% from the average) across the face of the catalyst surface.

4.3 Catalyst pitch shall be selected by the Vendor to provide an optimized design of geometric surface area versus volume and differential pressure. The pitch shall be such that the catalyst will not be prone to fly-ash pluggage. Vendor to consider the maximum ash / dust concentration specified in Part III

4.4 The Vendor shall submit a laboratory procedure for activity testing of the catalyst. Activity tests using samples from modules installed in the reactor shall be provided. These tests shall occur at mutually acceptable intervals during the service life guarantee period of the catalyst. The frequency of activity tests shall be at a minimum of once per year. The number of activity tests shall be consistent with achieving an optimum and cost effective catalytic management program. A final report shall describe laboratory test results and recommendations for future catalyst replacement. As part of the report, a plot of catalyst activity (K/K_0) versus operating hours shall be included.

4.5 The SCR system performance guarantees shall be based upon field measurements. Correction curves for off-design conditions shall be provided by the Vendor. At a minimum, these curves shall include the impact of flue gas volumetric flow, temperature, inlet NO_x and O₂ upon the NO_x removal efficiency. Also, a curve of SO₂ to SO₃ oxidation rate vs temperature and area velocity shall be provided.

4.6 The catalyst's chemically active constituents which are bonded to metallic substrates (plate type catalyst) shall not delaminate due to stresses induced by thermal or pressure forces for the life of the catalyst.

4.7 An option for the disposal of the initial charge of catalyst shall be provided. The Vendor shall adhere to all local regulations pertaining to handling, and disposing of the catalyst material. It should be noted that the catalyst will be exposed to coal fly-ash which contains heavy metals. Consequently, consideration for a hazardous waste disposal shall be assumed by the Vendor. This shall be indicated as an optional price.

4.8 The catalyst element baskets shall be shop assembled into modules for ease of installation and removal from the reactor. The module framework shall be constructed of carbon steel material. Grating protection shall be furnished on the upstream face of each module for ease of internal maintenance and inspection. Screening shall also be provided on the upstream face of each catalyst module to prevent large ash particles from becoming lodged within the catalyst plate material. Similar construction shall be provided if a honeycomb catalyst module is supplied.

4.9 Lifting lugs shall be provided on the catalyst modules for ease of installation into the reactor chamber. All special tools required for the proper installation of the modules shall be provided.



This shall include a hydraulic trolley for individual module positioning within the SCR reactor chamber. A spreader beam specially designed for lifting the modules from grade to each appropriate catalyst elevation shall be furnished. Any additional special tools required for the unloading of catalyst modules from either truck or rail delivery of the modules to the site shall be supplied.

4.10 All catalyst modules shall be packed in appropriate containers to prevent damage and/or exposure to moisture during shipment. The Vendor shall supply long and short term storage and handling procedures and recommendations for onsite storage of the modules.

4.11 The Vendor shall provide dimensional drawings of the catalyst modules, hydraulic trolley and spreader beam used for installation. The drawings shall show adequate dimensions and clearances required for proper installation and maintenance. The drawings shall show the weights of all major components. All Vendor drawings shall be submitted to the Purchaser for approval.

4.12 The Vendor shall provide the Purchaser with reasonable advance notice of all factory tests associated with the catalyst material and module fabrication. The Purchaser shall be entitled to witness all factory tests. The Purchaser shall also be allowed to specify a third party representative to witness these tests.

4.13 The Vendor shall provide Material Safety Data sheets for the catalyst material, as well as any information pertaining to applicable safety regulations for compliance with OSHA requirements (29 CFR 1710.111) and safety regulation standards applicable in India. In addition, all information required to support the Purchaser's safety regulations and site permitting shall be provided.

4.14 The Vendor shall supply operating and instruction manuals describing the procedures (including recommended hot, warm and cold start, shutdown for short and long term periods), as well as maintenance and other special instructions required for the proper care and safe and reliable operation of the catalyst. These instructions shall be specific to the Purchaser's ductwork arrangement, equipment and overall system design.

4.15 The catalyst Vendor shall specify the continuous recommended minimum allowable gas temperatures to the SCR for the full range of fuels/operating condition specified. The final method of flue gas temperature control shall be determined and supplied by the boiler supplier.

4.16 The following information shall be provided for the catalyst and module supplied by the Vendor:

- a. Catalyst pitch, specific surface area (m^2/m^3), chemical composition, and selected volume (m^3)
- b. Space velocity, area velocity, actual face velocity, linear velocity, SO_2 to SO_3 oxidation rate, draft loss across the initial installed catalyst, NO_x removal efficiency and ammonia slip for a fresh catalyst as well as the NO_x removal efficiency and ammonia slip for a catalyst after 8000 and 16000 hours of operation for all conditions specified in Part III.
- c. Catalyst module width, module depth, module height, module weight, catalyst density, number of modules per layer, total number of modules per reactor. Arrangement and dimensions of modules shall accommodate the reactor dimensions.
- d. For the full range of fuels specified in Part III, specify the minimum continuous allowable inlet operating temperature in order to avoid ammonium bisulphate formation on catalytic surfaces. Short term inlet temperatures, below those indicated above, and allowable maximum operating hours at these temperatures shall also be provided. Subsequent recovery temperatures and duration of operation shall be furnished.



- e. A recommended, optimized schedule of catalyst module additions and replacements for a 10 year period. Provisions in the reactor chamber for a minimum one layer shall be provided for future.
- f. A description of the module sealing method and sealing material.
- g. The Vendor shall furnish the allowable conditions for the design of a superheated soot blowing system. Recommendations for steam temperature, pressure, and frequency of blowing shall be furnished. The vendor shall also recommend the distance between the top of the catalyst plate surface and soot blower nozzle. Utility requirements for sonic horns and air canons (if applicable) has to be furnished by the Vendor.
- h. Typical laboratory procedures for activity testing of the catalyst shall be furnished. This shall include a list of all items tested and a summary of the type of report that can be expected.
- i. The vendor shall provide recommended hot, warm, cold start-up and shutdown procedures. Permissible temperature ramp rates across the catalyst shall be furnished. An SCR reactor bypass has been furnished in order to provide operating flexibility during these conditions. A process control description functionally indicating the control logic, permissive, alarms, and control schemes as it affects catalytic reactive performance shall also be included.
- j. The Vendor shall provide recommended jobsite handling and storage procedures for the catalyst modules.
- k. The Vendor shall review the adequacy of the load/support requirements and access requirements for the SCR system and furnish the same for Purchasers engineering/BOM calculation at the time of document approval. Any additional access/supports not identified during document approval stage shall be in Vendors scope.
- l. The Vendor shall provide the allowable continuous minimum operating temperatures to the catalyst for all fuels and inlet load conditions specified by the Purchaser.

5.0 Flue Gas Mixing Device and Flow Model

5.1 The Vendor shall construct a three-dimensional 1/10th scale (Plexiglas or equal) model of the proposed SCR equipment and boiler back-pass with associated ductwork, reactor transition pieces, and reactor internals. The model shall verify the size, configuration, and location of all necessary SCR installed equipment and final ductwork arrangement, guide vanes, and mixing devices necessary to provide uniform velocity, temperature and ammonia distribution across the catalyst.

5.2 The distribution of ammonia shall be simulated and the injection grid design verified.

5.3 The boundary limits of the physical flow model shall be from economiser outlet to the air preheater gas inlet flange. The Purchaser's boiler arrangement drawings shall be supplied to assist the Vendor in the construction of the model.

5.4 The model shall be arranged such that it simulates the aerodynamic effects on gas flow and distribution due to physical features such as internal ductwork bracing, guide vanes, mixing devices, injection grid, flow straightening grid, etc. The objective of the model is to verify the SCR system design for the following:

- a. Gas velocity of +/- 10% from the average at the inlet to the ammonia injection grid and at the inlet to the first catalyst layer
- b. Gas temperature within +/- 10 deg C at the inlet to the first catalyst layer
- c. Ammonia distribution within +/- 5% of theoretical requirements at the entrance to the first catalyst layer. This distribution objective shall confirm the adequacy of the ammonia injection grid and flue gas mixing design and location.
- d. Analysis of ash accumulation throughout the proposed SCR ductwork and reactor chamber.



e. Evaluation of pressure losses throughout the system including across inlet and outlet ductwork, catalyst layers, ammonia injection grid dampers, straightening grid, mixing devices and other significant reactor/ductwork internals. A discussion of the device used to simulate gas draft loss across the catalyst shall be presented in the final report.

5.5 The Vendor shall submit the following to the Purchaser for review and approval before actual testing:

- a. Drawings and description of the flow model showing all dimensions and details
- b. Detailed description of the flow model test procedure
- c. Tests to be performed
- d. Data to be recorded
- e. Testing results format
- f. Limits, tolerances, and uncertainty in testing
- g. Criteria for determining that the testing is complete and successful
- h. Discussion of similitude between the flow model and the actual SCR system. The discussion shall include a comparison of the Reynolds, Prandtl, Schmidt, Grashof and Froude numbers for the model and the actual system.

5.6 The Purchaser and/or his representative shall have the right to inspect the flow model and to witness testing at any time. Adequate notice will be given by the Purchaser.

5.7 After completion of the successful model testing, the Vendor shall submit to the Purchaser the following:

- a. Test report and results
- b. Drawings showing design, dimensions and location of all required flue gas and ammonia mixing devices
- c. Drawings showing design, dimensions and location of all duct turning vanes
- d. Any changes that will be made to the ductwork, ammonia injection grid, reactor or other parts of the SCR system that are a result of the flow model test

5.8 Any changes in the SCR equipment design resulting from the flow model shall be retested to confirm the adequacy of the revisions. Close coordination of the flow model testing shall be achieved at all times with the Purchaser.

The Vendor shall submit to the Purchaser the proposed schedule for the complete model fabrication, testing and report submittals.

5.9 For the duct work in Purchaser's scope of supply, the arrangement of internals shall be based on mutual agreement

5.10 Final disposition of the model shall be the Purchaser's option.

5.11 Flue Gas Mixing Devices

5.11.1 Flue gas mixing devices shall be provided, as required to ensure the uniformity of gas velocity, temperature and ammonia dispersion into the flue gas stream. The effectiveness of the mixer design and location shall be confirmed by physical flow model testing.

5.11.2 The mixing device material shall be compatible with the ductwork casing in the area.

6.0 De-Dusting System

6.1 Soot blowers are effective in keeping particulate matter entrained in the flue gas stream so as to avoid the possible formation of deposits on catalytic surfaces. Blowers shall be furnished



upstream of each catalyst layer within the SCR reactor. Each soot blower shall use superheated steam supplied at sufficient velocity and dynamic pressure to keep the catalyst modules clean. The steam source shall be from the steam generator with the tap-off point specified by the Purchaser. The Vendor shall recommend maximum acceptable steam conditions (steam temperature and pressure) for the catalyst. The Purchaser shall furnish steam piping up to a single point connection to interface with Vendor's steam piping supply. Vendor shall take care of the Inlet Dust Burden for designing the Soot blower.

6.2 Soot blowers shall be of the transverse arm, rake type design having nozzles or orifices spaced at regular intervals suitable for cleaning the catalyst without erosion. Location of the blowers shall ensure full cleaning coverage of the face area of the catalyst layer. The Vendor shall ensure that the nozzles are properly located on the blower arms above the catalyst in order to avoid structural damage to the catalyst material and provide effective cleaning.

6.3 Structural support and space provisions in the reactor chamber shall be furnished to accommodate the future installation of soot blowers above the spare catalyst layer.

6.4 Soot blowers shall be located on both sides of the reactor. The central pipe of the blowers shall be positioned in a zone of low flow intensity below reactor support beams. If internal soot blower pipes are exposed to the direct impact from flue gas, then flow deflector baffles shall be installed on the pipes to improve overall flow patterns.

6.5 The soot blower design shall avoid abrupt temperature changes to the catalyst surfaces to minimize the adverse effects of thermal shock. Maximum temperature differential between the soot blowing medium and the catalyst surface temperature shall not exceed 50 C.

6.6 The soot blower design shall minimize erosion of the catalyst caused by excessive medium velocity and water droplets.

6.7 The steam supply system provided by the Purchaser shall be designed assuming all soot blowers are installed and operational including those for the spare layer.

6.8 The blower equipment shall include all valves, piping, fittings, drains, wall boxes, rail assemblies, structural supports, hangers, motors, and controls for a complete system.

6.9 The Vendor shall state recommended soot blowing frequency, soot blower operational time, and mass steam flow per blower. Operation of the soot blower system shall be from top to bottom.

6.10 Commissioning services shall be provided for the soot blower system.

6.11 Vendor shall furnish takeout price for Soot blowing system supply.

6.12 Sonic Horn (if applicable)

a) Sonic horn shall be provided for cleaning all catalyst layers, including the future layer. Number of sonic horn shall be provided so that it should cover complete catalyst surface area. Sonic horns may be arranged on the single wall or opposite walls of the SCR reactor based on its cleaning intensity.

b) Sonic horns shall be provided to generate low frequency and high energy sound waves to resonate and dislodge ash deposits/fouling which develops on the catalyst modules/cassettes. The horns shall be driven using service air available at site sequentially at regular frequency. The horns shall be constructed of stainless steel having diaphragm of titanium alloy. Diaphragm shall



have a minimum life of five (05) years. Each horn shall be provided with acoustic enclosures to reduce ambient noise. The arrangement and type of sonic horns shall be as per standard practice of the contractor.

c) Each Sonic horn shall be provided with separate solenoid operated isolation valve along with associated piping. Adequate number of moisture traps shall be provided at each catalyst layer for removal of moisture from service air supply line.

6.13 Air Cannons (if applicable)

a) Air cannons shall be provided for cleaning all catalyst layers, including the future layer. Number of air cannons shall be provided so that it should cover complete catalyst surface area. Air Cannon may be arranged on the single wall or opposite walls of the SCR reactor based on its cleaning range.

b) Two (02) multiport air cannon system with fan jet nozzles shall be provided for each catalyst layer including the future layer.

c) Air Cannon shall be operated in combination with sonic horn. Initially air cannon shall discharge to break any adhered material loose and then acoustic cleaner shall continue to sound to keep ash deposits in suspension. Air Cannon discharge nozzle shall preferably be placed directly below the sonic horn.

6.14 Dry Cleaning System (if applicable) for in-situ cleaning shall include removal of the particulates and plug(s) on the catalyst using a blasting stream of a pressurized carrier gas having a particulate blasting medium (dry ice) directed at the SCR catalyst. Complete pressurization system for the carrier gas along with feeding/mixing of the blasting medium shall be provided along with necessary injection lances for in-situ cleaning of catalyst at each layer elevation.

7. Ammonia Unloading, Storage, Handling and Preparation System

A complete anhydrous ammonia unloading, storage, handling and dilution system shall be furnished. The equipment shall include an unloading compressor, ammonia storage tanks, vaporizers, associated piping, fittings, supports, valves, instrumentation, neutralization tank, dilution air blower skid and ammonia injection grid.

7.1 An unloading compressor shall be furnished to transfer liquid anhydrous ammonia from the delivery vessel to the main storage tanks. A compressor, local control panel incorporating all controls and monitoring, equipment and skid mounted instruments and unloading bulkhead shall be furnished near the vicinity of the tanks. The capacity of the compressor shall be properly sized to unload an ammonia shipment within a reasonable time period and at a maximum head of 18 kg/cm² gauge. The motor shall meet the requirements mentioned in Part III.

7.1.1 Two (02) oil free reciprocating type ammonia unloading compressors complete with motor drives and receivers shall be provided with all necessary fittings, monitoring and safety devices for unloading of ammonia from the truck to ammonia storage tank. The compressors shall be skid mounted. The compressor design shall have double and triple packing to obviate harmful gas leaks. Further, any leakage gas shall be returned to the suction line and no nitrogen purge and leak gas monitoring device with gland seal of the piston rod shall be required. Same compressor shall be used for liquid ammonia transfer and ammonia vapour recovery. The compressor shall be designed with the consideration of ammonia vapour recovery which may result in excessive temperature rise.

7.1.2 Each compressor shall be provided with gas filter and liquid trap with level control on its suction side. Liquid trap shall be designed for pressurized and vacuum operating condition. 4-way

	High Pressure Boiler Plant BHEL, Tiruchirapalli Specification for High Dust SCR system	TDN:SCR:001 Rev 00 Page 21 of 32
---	---	---

valve ball valve shall be provided for each unloading compressor for switching the direction of gas conveyance.

7.1.3 One (1) pressure relief valve shall be installed in the discharge line of each compressor and its connecting pipe shall be routed back to the storage tanks.

7.1.4 The design of compressor shall ensure the compliance with the following operational requirements:

- i. Facilities for emergency shutdown of compressor at low suction pressure, high discharge pressure and high differential pressure across suction & discharge of the compressor.
- ii. Facilities for emergency shutdown of compressor at high discharge temperature. Parallel operation and auto changeover of compressors shall not be envisaged. After completion of unloading of ammonia from the tank truck, the compressor must be switched off by means of a flow monitor and the unloading process completed.

7.1.5 Material of construction of compressor shall be suitable for handling anhydrous ammonia.

7.1.6 A clear space shall be provided around the compressor for inspection purpose.

7.1.7 Local control panels with all necessary controls, Protection & interlocking system for operating the compressors shall be provided. These controls shall be achieved through microprocessor based redundant controllers with Graphic User Interface (GUI) with LCD screen based display unit, control switches and other operational keys panels and hooked up to purchaser's DCS

7.2 Ammonia Storage Tank

7.2.1 The anhydrous ammonia storage tank shall be non-refrigerated, cylindrical, all-welded steel construction, complete with level, pressure, and temperature instrumentation, safety valves and vent/fill connections. The tank will be located outdoors at a location to be determined later.

7.2.2 The liquid capacity of the ammonia storage tank shall be as specified in Part III based upon an anhydrous ammonia flow. A margin of 20% shall be considered on the stoichiometric ammonia flow.

A vapour space of approximately 15 % of the total tank capacity shall be provided at the top of the tank. An optimized, cost effective arrangement of the storage facility shall be achieved. If more than one tank is provided per SCR unit, they shall be interconnected so either tank can be utilized to furnish the required ammonia flow to the system. The ammonia storage facility shall have the flexibility of being an emergency backup for number of units specified in enquiry.

7.2.3 The ammonia storage tanks shall be designed as per ASME Boiler and Pressure Vessel Code Sec VIII. The tank shall be fully welded construction. All welds shall be 100 % radiographed and stressed relieved. All connections to the tank shall be welded. No threaded connections are acceptable. Tank plate material shall be ASTM A516-Gr 70 or better.

7.2.4 The storage tank shall have the flexibility of accepting ammonia delivery by truck. Each ammonia tank filling connection shall be provided with a combination of back pressure check and excess flow valve to prevent massive ammonia leakage in the event of a catastrophic line break.

7.2.5 The storage tank and handling facilities shall be designed to the following codes and standards:



- a. IS 4544 latest edition
- b. CGA G_2.1—2014 6th Edition (formerly ANSI K61.1), OSHA etc.
- c. ASME Section VIII - Pressure Vessels
- d SMPV, Static Mobile Pressure Vessel

In addition, the Vendor shall be responsible for meeting all the latest local codes and standards for the safe storage of anhydrous ammonia.

7.2.6 Each tank shall be equipped with the following equipment as a minimum:

- a. One manhole shall be provided
- b. Pressure measurements (gauge/transmitter) connections with isolation valves
- c. Two (2) safety relief valves sized so that either valve can protect the tank

Note: The safety relief valve design shall permit maintenance and removal without draining the tank.

- d. Level Indicator/transmitter
- e. An ammonia sensor and alarm located near the vicinity of the tanks.

Note: The permissible liquid anhydrous ammonia level shall not exceed 85% of the tank's total capacity. The level measurement shall be capable of actuating an alarm signal in the main control room when the storage level reaches a low or high level. The low level alarm shall allow the plant a reasonable amount of time to order an additional shipment of anhydrous ammonia while operating the plant at full load capacity.

7.2.7 All materials furnished for the ammonia storage and handling facility shall be compatible with anhydrous ammonia. Use of copper, brass, zinc, galvanized steel and copper containing alloys are not acceptable. Cast iron fittings shall not be used.

7.2.8 All piping, tubing and fittings shall be at least ASTM A-53, Grade B seamless or electric resistance welded (ERW) pipe. All piping joints shall be fully welded. No threaded connections anywhere in the ammonia equipment shall be acceptable. Hydrostatic relief valves shall be included where there is a possibility of liquid ammonia being trapped between two valves.

7.2.9 All necessary platforms, grating, handrails, ladders, etc. shall be provided to access all instrumentation, hose connections, safety relief valves, safety equipment and maintenance items.

7.2.10 Tank supports shall be designed to minimize settlement or lateral movement. In addition, the supports should be capable of withstanding exposure to fire, wind, earthquake, floods, etc.

7.2.11 A water spray system shall be provided for cooling the tank and hence, controlling the vapour pressure inside the storage tank. The actuation of the spray system shall be connected to the local control system to initiate spray when the vapour pressure rises above permissible level. Local control panel with required control logics and interlocks shall be supplied by vendor.

7.2.12 A covering or canopy shall be furnished to protect the tank from direct exposure to sunlight.

7.2.13 The ammonia storage tanks shall be protected by guard posts or other appropriate traffic barriers.

7.2.14 The Vendor shall supply an eyewash and safety shower station in close proximity to the storage tanks. Additional safety equipment such as a face masks and canisters, gloves, boots, etc. shall be provided. The safety equipment shall satisfy international and local code requirements.



7.2.15 All primers and finish paints furnished by the Vendor shall be compatible for outdoor ammonia applications.

7.3 Ammonia Vaporizers

7.3.1 The ammonia delivery system shall be designed for vapour withdrawal from the storage tank. Two (2) x 100% capacity, ammonia vaporizers (electric/ steam) capable of furnishing the maximum design anhydrous ammonia flow rate shall be supplied.

7.3.2 The steam vaporizer assembly shall be installed in a natural circulation loop, taking liquid ammonia from the bottom of the storage tank and returning the vaporized ammonia to the top of the tank. All piping welds in this loop shall be stressed relieved. All piping connections shall be fully welded. Threaded connections are not acceptable.

7.3.3 Vaporizer operation shall be controlled by an adjustable pressure switch or transmitter on the storage tank. The vaporizers shall operate whenever the vapour pressure in the storage tank drops below the set-point.

The Vendor is to recommend the set point pressure range for the pressure switch.

7.3.4 A thermostat controller shall be located within each vaporizer to prevent overheating. The vaporizers shall be designed so they cannot be activated unless liquid ammonia surrounds the heating elements.

7.3.5 The vaporizers shall be capable of being independently isolated for maintenance without draining the ammonia storage tank.

7.3.6 Electric heating elements (if applicable) shall not be in direct contact with the ammonia. The vaporizers shall be designed for an electric source as specified in Part III.

7.4 Dilution Blower Skid

7.4.1 A separate dilution air skid located near the ammonia injection grid shall be provided. The skid shall include the following equipment:

- a. Ammonia flow control and stop valves
- b. Two 2x100% dilution air blowers
- c. Local skid piping and instrumentation
- d. Inline ammonia - air mixer

7.4.2 The skid shall be furnished complete with piping, valves and fittings. Design shall be in accordance with the ASME Boiler Code and the Power Piping Code ANSI B31.1. ANSI Standards B1.1, B2.1, and B18.2 shall govern all material and workmanship. All piping connections shall be fully welded.

7.4.3 All materials furnished shall be compatible with anhydrous ammonia. All instrumentation required for the safe operation and maintenance of the skid shall be provided.

7.4.4 Two (2)x100% dilution air blowers shall be furnished. The blowers shall be installed on the same skid. The following specified conditions, shall be provided by the vendor for each blower.

- a. Minimum air volume per blower
- b. Minimum discharge pressure per blower
- c. Maximum ambient air temperature



Operation of the blower shall be continuous even after the ammonia to the system has been terminated. The system shall also accept operation of two blowers at the same time. Capability of starting the idle blower within ten (10) seconds shall be provided.

7.4.5 Each blower shall be furnished with the following accessories:

- a. Flanged inlet and outlet connection with vibration isolators
- b. Inlet air filter
- c. Silencer to meet 85 d.BA at one (1) meter
- d. Motor as specified as in Part III
- e. Direct drive
- f. Local cabinet for manual start/stop capability
- g. Remote automatic start/stop capability
- h. Discharge line check valve to ensure no air backup through the idle blower

7.4.6 Checks on operation of all fans and all rotating equipment to ascertain level of noise and vibration.

7.4.7 Characteristic curves of the performance of both single and dual blower operation shall be provided. The Vendor shall ensure that the ammonia requirements of the SCR system do not necessitate having the concentration of ammonia in air above 5% by volume over the entire operating range of the unit. The Vendor shall also include the predicted sound pressure levels at one meter from the source during blower operation.

7.4.8 Vendor may recommend any other alternate dilution air source for purchasers review and acceptance.

7.4.9 A mixing device (if applicable), located on the skid, shall be furnished in the dilution air piping to ensure a homogeneous ammonia-air mixture to the ammonia injection inlet manifold.

7.4.10 The Vendor shall be responsible for testing all piping, hose and tubing at a pressure not less than the normal operating pressure to ensure a completely leak free system.

7.5 An ammonia sensor and alarm (local and remote) shall be located in close proximity to the dilution air skid area.

7.6 The Vendor shall supply an eyewash and safety shower station in close proximity to the dilution air skid. Additional safety equipment such as face masks and canisters, gloves, boots, etc. shall also be provided in this area.

The equipment shall satisfy international and local safety codes.

7.7 Ammonia Connecting Piping

7.7.1 The Vendor shall supply all required interconnecting piping between the ammonia storage tank/vaporizer skid and the dilution air skid, and from the dilution air skid to the ammonia distribution inlet manifold. All piping shall be selected for the safe installation of an above ground system compatible with anhydrous ammonia. Final location of the ammonia tank and the dilution air skid shall be specified by the Purchaser. The Purchaser shall review and approve all field run ammonia piping supplied by the Vendor.

7.7.2 All piping and fittings shall be at least ASTM A-53, Grade B seamless or electric resistance welded (ERW) pipe. All pipe joints shall be fully welded. Piping larger than NB 50mm shall be a minimum of schedule 40. All pipe sizes equal to or less than NB 50mm shall be a minimum of



schedule 80. Hydrostatic relief valves shall be included where there is a possibility of liquefied ammonia being trapped between two valves.

7.7.3 Piping stress analysis, support details and locations shall be furnished by the Vendor.

7.7.4 All piping supplied by the Vendor shall be properly supported above ground.

7.8 Waste Ammonia Dilution Tank

7.8.1 The Vendor shall provide an ammonia dilution tank to thoroughly neutralize any ammonia gas and/or liquid discharge from the ammonia plant (various equipments). The dilution tank shall be sized to accommodate neutralizing the quantity of liquid ammonia resulting from the complete drainage of the ammonia storage tanks. An optimized arrangement using one (1) large tank to accommodate the number of SCR units specified in the enquiry.

7.8.2 The Vendor shall supply all required interconnecting piping from the ammonia equipment, relief valves, etc. to the dilution tank.

7.8.3 The dilution tank shall operate at atmospheric pressure via an atmospheric vent. Ammonia gas shall be prevented from escaping through the atmospheric vent. The vent line shall be extended beyond the canopy of the dilution tank along with rain cap.

7.8.4 Dilution tank shall be provided with a service water make-up line and a drain line along with control valve in each line. A motorized isolation valve shall be provided on the upstream of control valve and a manual isolation valve shall be provided on the downstream of control valve.

8. Ammonia Injection System

8.1 In general, the ammonia injection system shall consist of multiple flow control zones across the SCR inlet duct. Each zone shall be independently controlled by modulating flow control valves located on the piping exiting the ammonia distribution manifold. Individual injection pipes shall be configured with nozzles spaced uniformly across the inlet gas duct plane to enable thorough mixing of the ammonia/air mixture. Number of nozzles shall be suitably decided by the vendor and the supporting documents shall be furnished. Injection of ammonia shall be in the direction of the gas flow. Counter-current injection is not acceptable. All ammonia injection grid pipe openings shall be protected to avoid ash laden flue gas from plugging nozzles. The system shall be designed with external connections to allow a compressed air source to purge nozzles in any individual line.

8.2 The location of the ammonia injection grid in the ductwork shall ensure the uniform distribution of ammonia in the flue gas stream prior to entering the first catalyst layer. The ammonia injection grid shall maintain the ammonia to NO_x molar ratio at the entrance to the first catalyst layer to within +/-5% of theoretical requirements. The Vendor shall provide a test procedure for fine-tuning the grid and validating this criteria.

8.3 Ammonia injection grid piping NB 50mm and larger shall be minimum ASTM A53, schedule 40 carbon steel pipe. Each branch shall have a manual flow regulating or throttling valve, flow orifice, and test connection with valve for a manometer. The ammonia inlet supply manifold shall be provided with temperature and pressure gauges.



8.4 All ammonia injection piping extending into the ductwork shall have carbon steel angle sections welded on the leading edge to minimize flue gas flow separation across the injection grid.

8.5 The ammonia injection grid shall be properly supported to prevent thermal distortion and damage due to vibration induced by the gas flow. The grid shall be designed for maximum thermal expansion, assuming no cooling is available from ammonia or dilution air. Flex hoses shall be furnished as required to connect the internal grid piping to external piping from the inlet manifold.

8.6 Detailed drawings of the Vendor's ammonia injection grid design shall be furnished to the Purchaser for review and approval.

8.7 The ammonia injection grid design shall be tested in a 1/10th physical flow model as in Clause No 5.0. Layout and number of ammonia injection nozzles, flue gas mixer design, and the location of the grid and gas mixer upstream of the catalytic layers shall be confirmed by flow model testing. Ammonia concentration uniformity shall meet the requirements specified in 8.2.

8.8 Alternatively, any other proven and successfully operating technology for ammonia injection into SCR system can be offered by vendor with sufficient technical back up documents subject to Purchaser's approval.

9.0 INSTRUMENTATION AND CONTROLS

9.1 Controls

9.1.1 All the control logics and interlocks required for the SCR system shall be furnished by the vendor for implementation in purchaser's DCS. The control system logics and interlocks shall ensure safe and efficient operation of the system.

9.1.2 The controls shall be based upon monitoring of NO_x at the inlet and outlet of the SCR reactor integrated with boiler load and the ammonia to NO_x molar ratio setting.

9.1.3 The control shall also include logics for all auxiliary equipment/systems associated with the SCR system, i.e., ammonia unloading, storage, handling and preparation system, dilution air supply system, ammonia injection system, de-dusting system and any other associated systems/equipment etc.

9.1.4 For the de-dusting system offered by vendor, all relevant control logics, interlocks and sequence of operation shall be provided by the vendor for implementation in purchaser's DCS.

9.1.5 All automatic controls, interlock/protection and monitoring shall have high integrity. No single failure / fault shall cause failure of the controls or cause the protection system to operate spuriously or become inoperative. All critical logics in the control system shall be structured with triple redundancy so that no single failure within the control system can cause the failure of SCR system / plant.

9.1.6 The control panels associated with the system shall be located in purchaser's control equipment room. However, vendor shall provide local control panels wherever necessary, based on process control requirements. Irrespective of location, these panels shall communicate with the purchaser's DCS, as applicable.

	High Pressure Boiler Plant BHEL, Tiruchirapalli Specification for High Dust SCR system	TDN:SCR:001 Rev 00 <i>Page 27 of 32</i>
---	---	---

9.1.7 The Vendor shall provide a complete description of the SCR system's control and operation including cold, warm and hot start-up and shutdown procedures and normal operation. A Complete description of the process and the control logic write-up shall be supplied.

9.1.8 As a minimum, the following signals shall be included in the vendor's control logic and shall be used for alarm/indication/SOE in the Purchaser's DCS. The list of signals listed is indicative only and vendor to include additional signals as applicable. The complete list of signal shall be finalised during the detailed engineering stage.

- a. SCR gas temperature "Low"
- b. SCR gas temperature "High"
- c. SCR differential draft loss "High" - monitored across SCR system and across each catalyst layer
- d. Dilution air flow "Low"
- e. "Loss of power"
- f. Ammonia shutoff valve "Closed/Open"
- g. Ammonia storage level "Low" and "High"
- h. Ammonia storage pressure "High" and "Low"
- i. Indication of SCR inlet and outlet NO_x-O₂ values
- j. Indication of SCR system gas draft loss
- k. Ammonia flow
- l. Indication of SCR gas temperature (three locations)- upstream of ammonia injection grid, upstream of the first catalyst layer and on the last layer of catalyst
- m. Dilution air blower on/off - specified for each blower
- n. Ammonia liquid storage level in the tank
- o. Ammonia storage pressure
- p. Ammonia slip

Note: Alarm set points shall be specified by the Vendor. All Instruments required for the generation of the above signals shall be supplied by the vendor.

9.1.9 Requirement of any other controls/system not specified herein, but shall be a requirement for the intended process shall be judiciously decided by the vendor and supplied along with the system.

9.2 Instrumentation

9.2.1 Vendor shall provide complete instrumentation for the SCR system and other associated systems specified under section 4.

9.2.2 The minimum requirement/quantity of instruments/equipments shall be as indicated in the P&ID. However, Vendor shall include the additional instruments/equipments if required, to meet the process requirement. Vendor shall consider redundancy for instruments as specified in the detailed specification.

9.2.3 NO_x analyser shall be provided to continuously measure NO_x emissions in the ductwork upstream of the ammonia injection grid and in the outlet duct directly below the SCR reactor chamber. An air conditioned cabinet shall house the two rack-mounted inlet and outlet analysers. All analog inputs/outputs shall be 4- 20mA (2 wire) signals. All digital input/output signals shall be dry contacts.

9.2.4 In addition to the NO_x analysers, other analysers such as O₂ and SO₂ SCR reactor inlets and NO_x, O₂, SO₂, NH₃ Analysers at SCR reactor outlets shall be provided by the vendor. Other instruments such as differential pressure transmitter to measure draft loss across all/individual



catalyst layers, gas temperature measurements at upstream of the ammonia injection grid and before the first catalyst layer, catalyst surface thermocouples on the last active catalyst layer, local pressure and temperature indicators shall also be provided.

9.2.5 In addition to the NH₃ analyser at SCR reactor, acceptable wet chemistry methods shall be used for ammonia level measurements at the outlet of the reactor chamber are required.

9.2.6 For other auxiliary systems such as the Ammonia unloading, handling, storage and preparation system, Ammonia injection system, dilution air supply system and De-dusting system, complete instrumentation shall be provided by the vendor.

9.2.7 The material of construction of all instruments/equipment and the sensing element in all the instruments shall be decided by the vendor to suit the process medium. However, the same shall meet the minimum requirement of the detailed specifications (Refer annexures) as applicable.

9.2.8 All local instruments shall be suitably grouped and mounted on (LIR) local instrument racks located at appropriate places. All process transmitters shall be housed in (LIE) local instrument enclosures. All the field equipment, drives & instrument enclosures shall be suitable for the Hazardous area of classification.

9.2.9 Individual pair shielded and overall shielded instrumentation cables shall be used for interconnection of analog signals. Overall shielded cables shall be used for interconnection of digital signals. Instrumentation cables used for feedback signals from field and control cables used for command signals to field instrument/equipment shall be separated and shall be terminated in different junction boxes.

9.2.10 All the equipment in vendor's scope shall be suitable to operate in the power supply/voltage ratings indicated in Annexure -Q (electrical power supply details).

10.0 PAINTING AND FINISHING

10.1 Painting

The Vendor shall perform surface preparation, primary and finish painting in accordance with the manufacturer's standards for all exposed surfaces. Painting schedule shall be furnished for purchaser's review and approval.

10.2 Marking

- a) Stainless steel nameplates with following boldly engraved shall be firmly fixed to the body: Maker's name & production serial number and technical/process parameters.
- b) Each spare shall be individually tagged with part name, maker's name & spare code.

10.3 Packing

- a) All opening shall be firmly capped against ingress of water or dust.
- b) Shall be roadworthy/seaworthy packed in wooden boxes with water proof under cover.
- c) Liberal packing material & struts shall be used to arrest rolling & to protect from transit damages.



11.0 SPARES AND SPECIAL TOOLS

11.1 Mandatory spares as per the list enclosed separately shall be offered.

11.2 Vendor shall recommend one (1) year spare parts necessary for maintaining the SCR equipment.

11.3 The item wise price for the spares (recommended and mandatory) offered shall be mentioned.

11.4 Vendor shall supply the required commissioning spares at the time of commissioning at site.

11.5 Special tools or materials shall be furnished, as required, for the proper handling, storage, erection, start-up and maintenance of the Vendor's equipment.

12.0 INSPECTION AND TESTING

12.1 Access to the Vendor's or sub-contractor's manufacturing facilities shall be provided for the purpose of inspecting the work and witnessing testing of the SCR equipment. At least two (2) weeks advance notice shall be given by the Vendor to the Purchaser or his representative.

12.2 Acceptance of the Vendor's equipment shall be based upon the successful completion of performance tests carried out by the Purchaser. The Vendor shall submit correction curves for gas temperature, oxygen content, flue gas volumetric flow and inlet NOx for determining performance for off- design field operating conditions. The Vendor shall provide a field representative to assist in tuning of the ammonia grid and advise the Purchaser during all performance testing.

12.3 The Vendor shall submit a performance test procedure as well as plans for tuning all furnished equipment for the Purchaser's review and approval.

12.4 All performance tests confirming SCR guarantee requirements shall be in accordance with acceptable EPRI testing methods or equivalent.

13.0 TRAINING

13.1 The Vendor shall provide a one (1) week training program for the Purchaser's personnel to operate and maintain the equipment supplied by the Vendor.

13.2 The training program shall include a description of the equipment, the proper operation of the system, the limits of the design, and the recommended maintenance (including module storage and disposal) and inspection procedures. Training manuals shall be submitted to all participants. Both classroom and field instruction shall be provided by the Vendor.

13.3 The Vendor shall submit a copy of the proposed training manual three (3) months prior to training for the Purchaser's review and approval.



14.0 DOCUMENT SUBMITTAL REQUIREMENTS

14.1 The following documents, drawings and information shall be furnished by the Vendor along with the offer:

Point-wise confirmation to the technical specification. Any deviation shall be clearly brought-out separately along with proper technical justification for Purchasers review.

14.1.1 General arrangement of SCR reactor & systems including but not limited to the following:

- a) SCR housing and ductwork dimensions including terminal points
- b) Catalyst module dimensions and arrangement within the reactor chamber
- c) SCR housing and ductwork loadings
- d) SCR catalyst and reactor chamber and loading plan –elevation wise
- e) SCR catalyst handling load and location sketch
- f) SCR catalyst loading intensity for floor design
- g) Canopy requirements (if any) of reactor chamber and sketch
- h) Sample and Recommended structural arrangement and cautions to be taken in steel design
- i) No bracing and no beam zone marked in arrangement drawing (if applicable)
- j) Cable, rack and any other loading requirements to be taken care by the steel design
- k) Horizontal guide loads and location (Support and seismic/wind guide requirements)
- l) Expansions required to interface with the Purchaser's ductwork and support steel
- m) Structural steel support and access platform requirements. The Vendor must maintain support points, box dimensions, etc. to those shown on the SCR arrangement drawing.
- n) Proposed monorail and hoist arrangement, handling procedure
- o) Internal and external support steel requirements and loadings for the installation and removal of catalyst modules
- p) Access door locations and dimensions in the SCR reactor housing and associated ductwork
- q) Ammonia injection grid location, supports and access requirements. The support documents for number of nozzles and its arrangement
- r) Flue gas mixing devices including location, dimensions, support details and access requirements (if applicable)
- s) De-dusting equipment locations and internal/external support requirements and access requirements
- t) Dilution air skid size and location
- u) Piping layout and proposed support from dilution skid to ammonia injection distribution manifold

14.1.2 Other documents

- a) Ammonia consumption calculation and storage tank sizing calculation
- b) All essential Civil inputs for ammonia dyke area shall be furnished
- c) Confirmation of the Purchaser's information shown on plant arrangement drawings
- d) All P & I diagrams along with write up and applicable valve schedule for all related systems
- e) Control logic diagrams including a list of all analog and digital inputs and outputs associated with the SCR control system
- f) Proposed permanent sealing method with a detailed description of the sealer material and material safety data sheet for sealer
- g) Proposed catalyst disposal requirements and procedures
- h) Proposed module activity tests and recommended ten (10) year replacement schedule



- i) Summary of predicted performance at all operating load conditions specified in Part III.
- j) Utility consumption list (i.e., auxiliary steam, service air, instrument air, service water, etc.).
- k) Summary of operating and installed power for all supplied equipment
- l) Auxiliary Power Consumption
- m) Recommended list of one (1) year spare parts
- n) Instrument List clearly indicating the Scope of Instruments.
- o) Drive List indicating type of drive (pneumatic, electric, LT motor, valve/damper etc.), Voltage, Type of power supply, rating, FLC, Speed
- p) List of Analog and Digital I/Os
- q) Electrical Load list indicating Voltage, Type of power supply, rating, location of load
- r) List of Local control panels indicating the system which is controlled from the local panel
- s) List specifying the systems which are controlled from purchaser's DDCMIS.
- t) List of all bought-out items with vendor details. The vendors are subject to Purchaser's review and approval.
- u) Filled in data sheets (Refer Part –III).
- v) Terminal Point drawing/document with well-defined boundaries for scope.

14.2 The following documents, drawings and information shall be furnished by the Vendor on award of the contract:

- a. Detail drawings of the hydraulic trolley and spreader beam for the catalyst installation.
- b. Test port and instrument locations including number of proposed sampling probes and locations for permanent instrumentation
- c. Structural steel drawings of reactor housing and internals including catalyst support steel and installation rails, monorail support steel, soot blower support steel, casing details, internal baffles, sealing plates, etc.
- d. Ductwork drawings showing internal supports, sealing plates, vaning, baffles, access door locations, test port locations, instrumentation locations, etc.
- e. Soot blower arrangement drawings including details of internal lances and supports, proposed supply piping layout to a common terminal point, piping support requirements, etc.
- f. Detail drawing of ammonia storage tank including associated piping, instrumentation, support, etc.
- g. Detail drawing of ammonia vaporizers.
- h. Ammonia piping layout drawings including support details from the storage tanks to the vaporizer skid and from the vaporizer skid to the dilution air skid. Drawings shall also provide details of the ammonia accumulator.
- i. Detail drawings of the neutralization tank including location, all instrumentation and interconnecting piping.
- j. Module handling, storage, installation and removal procedures.



- k. Operating instruction manuals (minimum 3 manuals along with soft copy). The manuals shall contain complete operating and maintenance instructions for the care and operation of the Vendor's equipment.
- l. List of all bought out items along with technical specification, datasheets and support documents.
- m. Details of the Vendor's training program per the requirements listed in Clause 13.
- n. Submittal of physical flow model test report.
- o. Completely Filled in Data sheets
- p. The Vendor's control philosophy shall be incorporated into the Purchaser's overall distributed control system. As a minimum the following information shall be provided by the Vendor in order to assist the Purchaser in the detailed design of the control system:
 - i. P&IDs with write up
 - ii. SCR digital logic diagrams & Write-up for SCR and all associated systems
 - iii. SCR analog logic diagrams & Write-up for SCR and all associated systems
 - iv. SCR graphic display diagrams
 - v. Interconnection drawings, Location of JB's, Local panels, cable lists
 - vi. Instrument List, Drive List, I/O List, Electrical Load list as per the purchaser's format
 - vii. Signal exchange list between SCR control system and plant control system
 - viii. Alarm and SOE list
 - ix. Valve/dampers list
 - x. Equipment/Instrument grouping, LIE/LIR grouping list
 - xi. Instrument installation drawings/ Hook up drawings
 - xii. Instrument air requirement
 - xiii. Vendor datasheets and O&M manuals
 - xiv. Quality Plan, Inspection and Test Plan, Type test certificates
 - xv. Any other drawings/documents found applicable during contract stage
 - xvi. Vendor to clearly furnish the special requirements to be taken care by purchaser for equipment/instruments in Purchaser's scope.



Part-III

Contract specific Requirements

Project Name: DN101



List of Documents

S.No.	Description
1	Performance and Guarantee
2	SCR Selection sheet
3	Fuel Analysis
4	Site Condition
5	Electrical C&I Specifications
5.1	Terminal Points for Electrical C&I Equipment- Annexure P
5.2	Electrical Power supply Details – Annexure Q
5.3	Specification for Electric Actuators – Annexure R
5.4	Specification for Motors – Annexure S
5.5	Specification for Field Instruments and Analysers – Annexure U
5.6	Specification for Cables, Cable Trays and Cable Glands – Annexure V
5.7	Specification for Local Panels/Cabinets – Annexure W
5.8	C&I Input for Selection of Mechanical Equipment
6	Data Sheets
7	Process and Instrumentation Diagrams
7.1	Scheme of De-NOx system – Key Diagram (1-SR-DNX-00001)
7.2	Scheme of De-NOx system – Ammonia Unloading and Storage system (1-SR-DNX-00002)
7.3	Scheme of De-NOx system – Ammonia Vaporizer and Accumulator (1-SR-DNX-00003)
7.4	Scheme of De-NOx system – Boiler Island (1-SR-DNX-00004)
7.5	Scheme of De-NOx system – Waste ammonia handling, Safety system (1-SR-DNX-00005)
8	SCR Arrangement drawing (0-SK-SCR-00001)



PERFORMANCE AND GUARANTEE

The Supplier shall Guarantee that the equipment/materials furnished hereunder will be entirely suitable for the service specified, conform to all conditions of performance and design, be free from manufacturing and material defects.

The Supplier shall guarantee the following based on all operation conditions for any coal specified, during the guarantee of catalyst life, unless otherwise specified:

A) Overall NOx removal efficiency (%)	
B) NOx content of the flue gas as measured downstream of the SCR system (ppm vol dry. as O ₂ 6%)	
C) Ammonia slip as measured downstream of the SCR reactor (ppm vol dry as O ₂ 6%)	
D) Conversion rate of SO ₂ to SO ₃ (%)	
E) Catalyst life (after Commercial Operation Declaration) to meet the NOx removal efficiency and ammonia slip (From the point of boiler flue gas passing through SCR De-NOx system initially) - with the initial charge of catalyst (Operating Hours)	
F) SCR De-NOx system gas side draft loss (mmH ₂ O) - With all catalyst including future layer at BMCR (max. pressure drop) - With the initial fresh/dirty catalyst at TMCR	
G) Ammonia consumption at TMCR (kg/h unit)	
H) Molar ratio of NH ₃ to NOx	
I) Auxiliary Power consumption at TMCR-Design coal	

Project Name: DN101
SCR Selection Sheet Rev 00

PROJECT DN101

TDN-SCR-001 / Part III

Page 4 of 86

Slno	Description	Units	Load					
			BMCR- Design Coal	TMCR- Design Coal (Guarantee Condition)	HP Out- Design Coal	60TM- Design Coal	BMCR- Worst Coal	TMCR- Worst Coal
1	Flue gas flow at Economiser Outlet	kg/hr	3248962	2959465	3069706	1833372	3221170	2911296
2	Flue gas temperature entering SCR	deg C	362	352	294	312	358	348
3	Total Volumetric Gas Flow at Actual Temperature	m3/hr	5928763	5313223	4999521	3065839	5846044	5189476
4	Total Volumetric Gas Flow at 0 deg C	Nm3/hr	2548901	2320816	2407177	1430725	2529271	2281364
5	Pressure at SCR Inlet	mmWC	-141	-124	-130	-70	-140	-121
6	Flue gas constituents, Wet Basis - % By Weight							
i	CO ₂	%	20.576	20.576	20.576	20.576	21.321	21.321
ii	N ₂	%	67.950	67.950	67.950	67.950	69.574	69.574
iii	O ₂	%	3.420	3.420	3.420	3.420	3.493	3.493
iv	SO ₂	%	0.068	0.068	0.068	0.068	0.128	0.128
v	H ₂ O	%	7.987	7.987	7.987	7.987	5.485	5.485
7	SO ₃ in Flue gas at SCR Inlet at 6% O₂ dry volume basis	ppm	3.9	3.9	3.9	3.9	7.3	7.3
8	Inlet Particle Dust Concentration	gm/Nm3	17.1	17.1	17.1	17.2	48.9	49.0
9	Permissible SO ₂ to SO ₃ conversion in SCR at 6% O₂ dry volume basis	%	Less than 1 %					
10	NO _x concentration to SCR Inlet at 6% O₂ dry volume basis	mg/Nm3	300 to 325					
11	NO _x required at SCR Outlet at 6% O₂ dry volume basis	mg/Nm3	Less than 100					
12	Maximum Permissible slip	ppm	3					

Note:

- 1) A variation of +/- 5% may be considered on the flue gas volume for design
- 2) Maximum pressure drop allowed : 100mmWC (From Eco Outlet to SCR Outlet including duct losses)
- 3) Required Catalyst life: Minimum 16000 hrs after Commercial Operation Declaration (both mechanical and Chemical Life)
- 4) Reagent Used : Anhydrous Ammonia (99.5%)
- 5) Min distance between Catalyst modules = 1300mm
- 6) Liquid capacity of ammonia storage tank should be for 14 days
- 7) Ammonia tank to be located 1.2 km from boiler area

Project Name: DN101 SCR Selection Sheet Rev 00

Fuel Analysis

DESCRIPTION (Source / Type)	UNIT	Design Coal (Imported Coal)	Worst Coal (Indian Washed Coal)	
PROXIMATE ANALYSIS				
Fixed carbon	%	26.85	30.25	
Volatile matter	%	34.25	26.47	
Moisture	%	23.00	9.45	
Ash	%	13.90	33.83	
Total	%	100	100	
HHV	kcal / kg	4910	4200	
Ash	kg / 10 ⁶ kcal			
ULTIMATE ANALYSIS				
Carbon	%	48.57	45.80	
Hydrogen	%	3.49	2.87	
Sulphur	%	0.28	0.50	
Nitrogen	%	0.26	1.47	
Oxygen (difference)	%	10.50	6.48	
Moisture	%	23.00	9.45	
Ash	%	13.90	33.83	
Carbonates	%			
Phosphorous	%			
HARD GROVE INDEX		51	52	
YGP Index				
ASH CHARACTERISTICS				
IT - Initial deformation temp.	°C	1190	1450	
ST - Softening temp. H = W	°C	1340	>1500	
HT - Hemispherical temp. H = W / 2	°C	1360	>1500	
FT - Fusion temp.	°C	1470	>1500	
ASH CONSTITUENTS				
A - SiO ₂	%	50.67	59.77	
A - Al ₂ O ₃	%	22.88	29.58	
B - Fe ₂ O ₃	%	13.74	5.60	
B - CaO	%	4.87	1.90	
B - MgO	%	1.76	0.52	
B - Na ₂ O	%	0.21	0.11	
B - Balance of Alkalies (by difference)	%	1.15	1.02	
		(MnO -0.13, K ₂ O-1.02)	(MnO -0.04, K ₂ O-0.98)	
A - TiO ₂	%	1.67	0.60	
P ₂ O ₅	%	0.84	0.63	
SO ₃	%	2.21	0.27	
Base / Acid Ratio		0.289	0.101	
Fe ₂ O ₃ / (CaO + MgO) Ratio		2.07	2.31	
Chloride	%	-	-	

Project Name: DN101
SCR Selection Sheet Rev 00

Site Condition

1. Ambient temperature and Relative humidity for
 - i. Steam generator design : 27 Deg.C & 60% RH
 - ii. Steam generator efficiency and auxiliary power consumption guarantee : 27 Deg.C & 60% RH

2. Ambient Temperature (Range) : 13 to 47.6 Deg.C
 Relative Humidity (Range) : 45 % to 82 %

3. Plant Elevation (above mean sea level) : 21.5 m

4. Wind Load
 - i. Mean Wind Speed : 16.5 kmph
 - ii. Category of Terrain : As per IS:875

5. Seismic Load : Zone – III
 As per IS 1893 (Part IV)



Terminal Points for Electrical C&I Equipments

a)	Remote pressure, level, flow measurements	:	Up to field junction boxes for vendor supplied equipment mounted instruments. Up to root valves for purchaser supplied line mounted instruments
b)	Remote temperature measurements	:	Up to field junction boxes for vendor supplied equipment mounted instruments. Up to tapping point stub with M33x2 (F) Thread, for purchaser supplied line mounted instruments
c)	Test temperature tapings Pressure & Flow Test pockets	: :	Thermowell with caps Up to root valves
d)	Electric drives (LT Motors and servomotors)	:	Terminal box with cable glands.
e)	UPS, 220 V DC, 240VAC	:	At individual equipment's input terminal
f)	Signals from/to motorized actuators to/from DDCMIS	:	At actuator terminal box.
g)	Signals from/to local control panels	:	At the terminals of local control panels
h)	Pneumatic Control valves and regulating actuators.	:	Integral terminal box. All signals of valves shall be internally wired & terminated in the Integral Junction Box for external connection to DDCMIS
i)	Instrument air distribution	:	Equipment end
j)	Earthing	:	Equipment terminals



Electrical Power supply Details:

1. The voltage level for motors shall be as follows:
 - a) Up to 0.2 KW: Single phase 240V AC / 3 phase 415V AC, 50 Hz
 - b) Above 0.2 KW and up to 175 KW: 3 phase, 415V AC, 50 Hz
 - c) Above 175 KW and up to 1500 KW: 3 phase, 3.3 kV AC, 50 Hz
 - d) Above 1500 KW: 11 kV, 50 Hz
2. DC System Voltage: 220 V DC
3. UPS Power supply: 240 V AC, 50 Hz
4. Utility Power supply (Space Heating, Lighting): 240 V AC, 50 Hz



PROJECT: DN 101

ANNEXURE-R
Electrical actuator
(Open/Close duty& Inching duty applications)

Sl. No.	Details	Technical Requirements
1	Actuator Application	Open/Close or Inching or Regulating duty, suitable for Valve/damper applications. Suitable gearboxes shall be coupled (if required) to achieve the torque requirements of the load. Actuator mounting shall be suitable to the load requirement.
2	Actuator type	Electrical Actuator with integral starter for Open/Close and inching duty applications.
3	Actuator Duty	The actuator shall be of Open/Close or Inching or Regulating duty as per the application requirement.
4	Actuator Construction	Totally enclosed weatherproof construction meeting IP-65 protection class requirements. All the gears available in the actuator shall be of metal (Fiber gears are not acceptable). Actuator shall have self-locking facility.
5	Manual operation through Hand-wheel	Shall have a lever and hand wheel mechanism for manual operation. The hand wheel mechanism shall be designed such that it is declutched automatically when the power supply to the motor, is restored.
6	Torque requirement	Shall be designed to meet with the required torque at the output shaft as per the load requirement. The adjustable range of run torque and starting torque of actuator shall be indicated (in kgm) for the actuator offered.
7	Operating time	The operating time of the actuator required for the complete travel has to match with the load requirement.
8	Supply voltage	415 V, 3 phase AC supply, 50Hz.
9	Power supply variation	The actuator shall operate without any trouble under power supply voltage variation of $\pm 10\%$ of the rated value, power supply frequency variation of $\pm 5\%$ of the rated value, combined voltage and frequency variation of 10% of the rated value.

Sl. No.	Details	Technical Requirements
10	Motor type & construction	Motor type shall be of Squirrel Cage induction type (or) Permanent Magnet Synchronous motor (or) BLDC. Shall be of Totally Enclosed, Self-Ventilated construction with weather proof enclosure conforming to IP-65. Shall have double shielded, grease lubricated anti-friction bearings.
11	Motor Insulation	Shall have class F insulation with temperature rise of the motor winding limited to Class B. Motor winding shall be tropicalized, suitable for the site conditions. Temperature rise over ambient temperature of 50 °C shall be 70 °C.
12	Motor duty cycle	The duty cycle of the motor shall be short time S2 duty cycle rated for the period of operation of 15 minutes or rated for 3 successive open-close operations whichever is longer. For inching duty, motor shall be suitable for 150 starts/hour. For regulating duty, motor shall be S4 duty with Cyclic Duration Factor of 60% and suitable for 1200 starts/hour.
13	Motor Starting	Motor shall be suitable for direct on-line starting. Starting current shall be limited to 6 times the full load current exclusive of tolerance. Shall be capable of starting at 85% of rated voltage and Running at 80% of rate voltage for a period of 5 minutes.
14	Standards	Actuator shall be conforming to IS-9334 or any other equivalent international standard for all requirements. Motor shall be conforming to IEC-60034, IS-325 or any other equivalent international standard for all requirements.
15	Motor Thermostat	Motor winding shall be provided with inbuilt thermostat connected in series (one thermostat in each phase) and shall be wired to terminal box.
16	Space heater	Shall have a space-heater with suitable rating and the power supply shall be derived internally from the main power supply.
17	Earth terminals	2 Nos. of earth terminals shall be provided on the body of the motor.



Sl. No.	Details	Technical Requirements
18	Torque & position limit switches	2 numbers of adjustable torque limit switches (one for open and one for close), each with 2 NO and 2 NC potential free contacts. The torque limit switches shall have calibration in Kg-m (for whole actuator including gear box if supplied), so that the switches could be easily set to any desired value, within the range specified for each actuator. Torque switches shall be bypassed in both the end positions using the position Limit switches available at the other end of the travel. Actuators shall have provision for bypassing the torque switch during initial 5% opening of valves. 4 numbers of position limit switches, rotary drum type capable of being set at any position(2 nos. for open and 2 nos. for close) each with 2 NO & 2 NC potential free contacts. All Gear train mechanism shall be made of suitable metal only. Shall be enclosed in a dust & weather proof compartment and the compartment shall have enough space suitable for calibration. Contacts of limit and torque switches shall be Silver plated having high conductivity and non -corrosive type. Contact rating of all the above limit switches shall be 5 A at 240 V AC and 0.5 A at 220 V DC.
19	Local position indicator	Shall be provided to indicate 0 to 100% travel.
20	Positioner Controls (Applicable only for regulating duty applications)	Actuator shall be provided with an electronic positioner and related electronic controls required for positioning the actuator, accepting 4-20 mA command signal. Shall have following standard, adjustable control features in the actuator. SPAN :- To calibrate the position feedback signal with the travel of the actuator for 100% range of position demand signal. ZERO :- To calibrate the position feedback signal with the travel of the actuator for minimum value of demand signal.

Sl. No.	Details	Technical Requirements
		DEAD BAND :- The actuator should meet the process requirements. STAYPUT :- The positioner shall have STAYPUT characteristics on loss of the demand signal. Solid State reversing circuit shall be provided for forward and reverse operation of the actuator.
21	Position Feedback transmitter	For inching duty and regulating duty applications, position feedback transmitter has to be supplied. Shall be 2 wire, non-contact type (LVDT) electronic position transmitter with an output of 4-20 mA DC and shall be loop powered from external power supply. The output shall also be capable of driving minimum 500 ohms load in the control circuits.
22	Internal wiring	Shall be done with 1.5 sq.mm PVC insulated, stranded copper wire of 650V grade for control signals. For Power circuits, internal wiring shall be done using suitable size of stranded cables, taking care of the motor current rating. Ferrules should be used for easy identification. Internal wiring and the terminal block drawing shall be neatly pasted on the internal side of the terminal box.
23	Terminal box	All terminals of the position limit switches, torque limit switches, space heaters shall be terminated in the terminal box. The terminals shall be of cage clamp type suitable for the cables of size 2.5sq.mm. Minimum 6 numbers of spare terminals shall be made available in the terminal board. Terminal box of actuator shall be weatherproof conforming to IP-65 and shall have enough space for connecting cable glands/plug and sockets. Terminal box shall be fitted with a removal front cover-plate.



Sl. No.	Details	Technical Requirements
24	Cable Termination philosophy	Termination of Power Cable :- Double compression type, Brass with Nickel plated cable glands shall be provided for the termination of power cable. Motor terminals shall be of stud type. Cable gland along with blanking washers shall be selected suitable for the power cable sizes as indicated below. - Up to 3 KW – 3C x 2.5 sq.mm. Copper, OD – 17 mm $\pm$ 2 mm. > 3 KW & up to 7 KW - 3C x 6 sq.mm, Aluminium, OD – 19 mm $\pm$ 2 mm. Termination of Control Cable:- 3 Nos. of Double Compression type, Brass with Nickel plated cable glands have to be supplied for the termination of the control/instrumentation cables suitable for a cable OD of 18mm.
25	Fasteners	All fasteners used in the equipment shall be of a corrosion resistant material.
26	Paint & finish	All external Parts shall be finished and painted to produce a neat and durable surface which would prevent Corrosion & Rusting.
27	Lubricant	The gear box of the actuator shall be either oil filled or grease filled.
28	Inspection & Testing	For the purpose of inspection & testing of electrical actuator, Quality Plan Ref. QA:CI:STD:QP:13 has to be referred.

Technical Description of the Electronic Integral Starter

Sl. No.	Details	Technical Requirements
1	Integral starter	Control logic of the starter shall be designed using suitable electronic control circuit. The starter shall have the following minimum features : Power supply isolation switch & fuses of suitable rating. - Thermal Over load relay. - Lockable Local- Off -Remote selector switch. - Push buttons for Local Operation (OPEN, CLOSE, STOP) - Indication lamps (OPEN, CLOSE, TRIP) - Remote Signal interface - Output Contacts - Status/Fault annunciation

2	Open/Close Command	Interposing relays of coil burden $\leq 2.5\text{VA}$ shall be provided to initiate opening and closing using 24V DC signal from the external control system. Actuator shall also be suitable for remote operation by potential free contacts for Open/Close & Stop, the necessary 24V DC power supply shall be derived internally. Open/Close command termination logic with position and torque limit switches shall be suitably built inside the starter Electrically & mechanically interlocked contactors shall be provided for forward and reverse operation. Contactor rating shall be sufficient to withstand the extreme conditions like valve jamming and instantaneous reversal of motor.
3	Protection Features in Starter	Shall have various protection features such as Single Phasing prevention, Wrong phase sequence protection, Overheating protection through thermostat, Short Circuit protection, Overload, Supply Under Voltage, over and above other standard protection features as per manufacturer's design.
4	Control Supply	Control supply voltage of the starter shall be 24V DC. If other control voltage rating is used, then the same shall be derived internally by the manufacturer. Necessary primary and secondary fuses shall be provided. Opto isolation circuit shall be provided with suitable coupling relays for 24V DC commands from external control system.
5	Local Operation	Provision shall be available to operate the actuator locally. Lockable local/remote selection shall be provided on the front panel of the actuator.
6	Status indication	The following status indication signals shall be provided in the actuator over and above the standard signals available in the actuator as per the manufacturer's standard • Actuator Open • Actuator Close • Actuator in travel



PROJECT: DN 101

7	Output Contacts	A Common potential free contact for collective fault annunciation of following faults such as Thermal Overload trip, Motor Thermostat trip, Control supply failure, Power Supply Failure/Single Phasing, Local/Remote switch in LOCAL/OFF, Torque Switch acted along with Other protections acted shall be provided for customer use. Potential free contacts shall be provided for Local/Remote/Off positions of the selector switch.
8	Fault Annunciation	The following fault annunciation signals shall be provided in the actuator over and above the standard signals available in the actuator as per the manufacturer's standard Open Torque Switch/Close Torque Switch acted Motor thermostat trip Motor Overload relay acted Actuator shall have necessary provision for diagnosing the fault locally.
9	General features to be provided in the actuator	Open Torque Switch shall be bypassed initially for 3 seconds or 5% of the valve travel. It should be possible to reverse the direction of travel for inching duty application. Automatic phase correction facility and single phasing prevention shall be provided.
10	Details to be furnished	The ratings of the various components of the starter, various signal exchanges to/from the starter and the wiring interconnections shall be clearly indicated in the wiring drawing of the actuator.

Pneumatic Actuator-Regulating type

Sl. No.	Details	Technical Requirements	
1	General :	This technical specification covers the requirements of Regulating Duty, pneumatic actuators, SMART positioner and accessories, to be used for control damper applications.	
2	Actuator :		
a.	Actuator type	Double or Single acting type, to suit the application. Piston operated type. The actuator shall be sized to meet the requirements of the load.	
b.	Actuator Duty	Regulating duty	
c.	Actuator mounting type	The actuator mounting shall be of any one of the following types. Stand mount type with output shaft and output lever. The actuator shall be connected to the load through linkage rod mechanism. (Or) Direct Mount type: The actuator (piston rod) shall be directly connected to the load. The actuator shall have trunnion base.	
d.	Actuator assembly	The actuator base shall be suitable for mounting the cylinder and for fixing the foundation bolts. The entire arrangement should be able to withstand the load and torque requirements.	
3	Air Supply	Power Air	Minimum : 3 Kg/sq. cm (g) Maximum : 7 Kg/sq. cm(g)
4	Stroking time	To suit the process requirement.	
5	Action on Loss of Power Air Supply.	To suit the process requirement.	
6	Action on Loss of Command Signal.	To suit the process requirement.	
7	Position indicator	1 No. local mechanical position indicator is required.	
8	Provision for reversal of action	Actuator assembly to be configured in Direct acting. Provision to change to reverse action shall be provided	
9	Material :		
a.	Piston rod	Hard chrome plated high strength steel. Leather bellows / Gaiters shall be provided to prevent actuator inner parts from rusting.	
b.	Piston	High Strength Steel.	
c.	Actuator body/Cylinder	Honed & hard chrome plated seamless Carbon steel.	



PROJECT: DN 101

Sl. No.	Details	Technical Requirements
	barrel	
d.	Actuator seals	Viton.
e.	General	Necessary surface treatment shall be provided for all the components (as applicable) to prevent rust and corrosion.
10	Limit Switch :	
a.	Quantity	One for open and one for close.
b.	Number of contacts	In case of SMART positioner, 1 NO + 1 NC
c.	Type	Snap action
d.	Limit Switch Enclosure	Dust & Weather Proof, IP-65
e.	Contact Rating	5A at 240 V AC / 0.2A at 220 V DC.
f.	Make	Shall be as per the manufacturer's standard.
11	Air Lock Device :	
a.	Type	Set point has to be adjustable. Self-Reset.
12	Air filter cum regulator :	
a.	Supply air pressure	7 Kg / sq.cm
b.	Type	Diaphragm
c.	Pressure rating	15 Kg / sq.cm
d.	Filter Material	Phosphor Bronze
e.	Body	Die-cast aluminum
f.	Inner valve, seating and spring	Stainless steel
g.	Enclosure protection	IP-65
h.	Output pressure	0 – 7 Kg / sq.cm
i.	Filter Element	Phosphor Bronze
j.	Filter size	5 microns
k.	Drain	Auto Drain feature shall be provided
l.	Accessories	Blow down valve shall be provided
13	Pressure gauge :	
a.	Dial	50 mm Diameter
b.	Type	Bourdon
c.	Material of sensing element (Bourdon)	Phosphor bronze
d.	Range	0 – 10 Kg / sq. cm
e.	Accuracy	± 5%
f.	Make	Shall be as per manufacturer's standard

Sl. No.	Details	Technical Requirements
g.	Air connection inlet	Air connection inlet shall be suitable to accept 1/4" OD PVC sheathed copper tube
h.	Hand wheel / Lever	To be provided along with actuator for manual operation.
14	Integral Junction Box	
a.	Junction Box	All the electrical connections from the accessories, shall be wired suitably as per the wiring drawing to the junction box. Protection Class: IP-65. Terminal blocks shall be of Cage-Clamp type, suitable for 2.5 sq.mm. Cable.
b.	Termination of external cable to the Junction box.	3 nos. of double compression type brass with nickel plated weather proof cable glands suitable for cable OD of 18 mm.
c.	Linkage rods for Stand mount type pneumatic actuators.	The Linkage rods shall be supplied as per the drawings referred in the purchase enquiry. The application names & tag nos. have to be painted on the linkage rods for easy identification.
d.	Inspection & testing	As per quality plan CI:QAC:STD:QP:42 (latest revision) or project specific quality plan. The applicable quality plan will be indicated in the purchase enquiry.
15	Painting/Finish for both Power Cylinder & Linkage rods	
a.	Paint Shade	Shall be as per manufacturer's standard
b.	Finish	Corrosion resistant, Epoxy based resin.
16	Packing	Shall be as per manufacturer's standard practice. The packing shall be suitable for safe transport, safe delivery at site and shall be suitable to avoid damages due to water entry and shall withstand the environmental conditions during storage at site.



PROJECT: DN 101

SMART positioner (For Control Valve and Damper applications)

Sl. No.	Technical Requirement	
1	Make of the SMART positioner	Vendor to specify.
2	Type of Input	4-20 mA, 24 V DC, 2 wire system (Loop powered from DCS)
3	Operational signal range	3.6 mA - 21 mA (4-20 mA). Split range operation shall also be possible.
4	Voltage	12 to 36 V DC
5	Input impedance	Vendor to specify
6	Supply Air pressure	3 – 7 Kg/cm ²
7	Air Capacity	Vendor to match with the requirement of the actuator.
8	Sensitivity, Accuracy, Repeatability, Hysteresis	Vendor to match with the requirement of application requirement.
9	Type of Acting (Direct/Reverse)	Vendor to match with the requirement of the actuator.
10	Flow Characterization	SMART positioner shall be compatible to fit valve characteristic curves, Linear/Equal percentage etc.
11	Stroke time	Vendor to match with the requirement of the actuator.
12	No. of pneumatic outputs (Single/Double)	Vendor to match with the requirement of the actuator.
13	Pneumatic Process Connection	To suit the impulse line as per the process P & ID.
14	Communication by Hart Protocol	SMART positioner shall be compatible for Remote calibration & Diagnostics using Hart Management System.
15	Calibration	SMART positioner shall be compatible for Auto Start with self-calibration, Remote calibration from Hart Management System & manual calibration using push buttons available on the positioner.
16	Position sensing & feed back	Output: 4-20mA position feedback signal shall be provided.
17	Electrical Cable entry	Side or bottom entry to avoid water ingress.
18	Protection Class	IP-65
19	Action required during 4 to 20 mA control signal failure.	SMART positioner shall be compatible for achieving Fail Open, Fail Close & Stay put (Fail freeze) functions to be configured at site.
20	Accessories	For Supply & output pressure, pressure gauges shall be

Sl. No.	Technical Requirement	
		provided on the positioner.
21	EMC Compliance	SMART positioner shall conform to EMC Compliance as per international standards IEC/EN. 61000-4-2/3/6/12
22	Diagnostic Features	Soft Open / Close limit switch output. Alarm on loss of demand signal. Fault. Manual/Auto operation indication. Alarm on Power air failure. Travel/ Stroke counter. Diagnosis of leakage in actuator. On line partial closure test (as per requirement of valve) Valve signature analysis Valve friction/jamming detection Step Response Test
23	In built Operator panel	The positioner shall have a display with push buttons for configuration and for read out. The same shall be Password protected/Hardware lock
24	Mounting Assembly	Required mounting accessories & fasteners for mounting the positioner on valve actuators shall be provided.



ANNEXURE - S

LT AC Motor

Sl. No.	Description	Requirement
1	General Description	Squirrel cage type induction motor, suitable for direct on line starting.
2	Applicable Standards	IS-325, IS-1231, IS-6362, IS-2253, IS-5572, IS-12065, IS-12075, IS/IEC-60079, IS-12615, IS/IEC-60529 & IEC-60034. (Latest version of relevant standards shall be referred)
3	Type of enclosure	Totally Enclosed Fan Cooled (TEFC), IP-55 as per IS/IEC-60529. Motors located in hazardous area shall have flame proof enclosure as per IS/IEC -60079. Vendor to provide flame proof enclosure as per the area of classification, meeting the requirements of type of fuel being.
4	Duty Cycle	Continuous, S1
5	Energy Efficiency Class	IE-2 as per IS-12615/IEC 60034-30. The requirement of a particular project will be indicated in the project specific annexure.
6	Rated Voltage & Tolerance	415 V, AC, 3 Phase, $\pm 10 \%$.
7	Rated Frequency & Tolerance	50 Hz, $\pm 5 \%$
8	Combined voltage & frequency tolerance	10 % (absolute sum)
9	General Requirements	a. All motors shall be so designed that maximum inrush currents, locked rotor and pull out torque developed at extreme voltage and frequency variations do not endanger the motor and driven equipment. b. Motor shall be designed to keep torsional and rotational natural frequencies of vibration at least 25 percent above the motor rated speed ranges to avoid resonant vibration over the operating speed range of the motor and driven equipment. c. Maximum continuous rating (MCR) of the motor shall have at least 15 % margin over the maximum load demand of the driven equipment including voltage and frequency

Sl. No.	Description	Requirement
		variation. (Applicable only if vendor supplies motor along with the driven equipment or load). d. Requirements during running :- The motor shall be capable of operating satisfactorily at full load for 5 minutes without injurious heating with 75 % rated voltage at motor terminals. The motor shall be designed to withstand momentary over-load of 60% of full load torque for 15 seconds without any damage. The motor shall be designed to withstand 120 % of rated speed for 2 minutes without any mechanical damage. e. Requirements during starting :- Motor shall start with rated load and accelerate to full speed with 80 % rated voltage at motor terminals The motor shall be capable of withstanding the stresses imposed if started at 110 % rated voltage. f. Torque requirements :- Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% of motor full load torque. Pull Out torque at rated voltage shall not be less than 205 % of full load torque
10	Class of Insulation	Class-F insulation with temperature rise limited to Class-B. Temperature rise of the motor shall be limited to 70°C (by resistance method) over an ambient temperature of 50°C
11	Stress withstanding capability during Bus Transfer	The motor may be subjected to sudden application of 150% rated voltage during bus transfer, due to the phase difference between the incoming voltage and motor residual voltage.
12	Capacity to restart for rated voltage	a. Two successive starts from cold condition b. Three equally spread starts per hour c. Two hot starts in succession, with motor initially running at normal temperature.



Sl. No.	Description	Requirement
13	Locked Rotor Condition	The ratio of Locked Rotor KVA at rated voltage to rated KW shall not exceed as indicated below, including tolerance ✓ For Motor rating <110KW : 10 ✓ For Motor rating ≥110KW : 9
14	Locked Rotor with-stand time	For motor with starting time up to 20 seconds at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 2.5 seconds more than starting time. For motor with starting time more than 20 seconds but not exceeding 45 seconds at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 5 seconds more than the starting time. For motor with starting time more than 45 seconds at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be 10% more than the starting time Vendor to provide Speed switches mounted on the motor shaft in case the above requirement is not met with.
15	Type of balancing of rotor	Dynamic balancing
16	Method of cooling	IC-0411 as per IS-6362
17	Direction of cooling air flow	NDE side to DE Side
18	Winding wire	Enameled Copper Wire, Grade-2, as per IS-13730, Part-3. Windings shall be non-hygroscopic, oil resistant and flame resistant.
19	Treatment on Winding Insulation	Winding Insulation shall be given tropical and fungicidal treatment for operation of motor in hot, humid & tropical climate.
20	Starting Current	The starting current (% of FLC) shall be limited to 600%, subject to tolerances as per the standard.
21	Noise level	Noise level shall be limited to 85dB at 1.5 meter distance from the outer surface of the motor.
22	Vibration level	The peak amplitude of vibration shall be as per IS-12075 (Limits of Severity-Normal grade shall be followed).

Sl. No.	Description	Requirement
23	Shaft extension	Motor shall be provided with key slotted bare shaft extension, with key at the drive end.
24	Terminal box	Flame proof as per IS/IEC-60079, capable of being turned through 360° in steps of 180°. Terminal box shall have adequate space to terminate the Power cable applicable to the motor by using suitable lugs. Minimum Distance between center of the terminal stud & the gland plate and Minimum inter-phase/phase-earth air clearance shall be provided as per the details indicated in the annexure (project specific requirement). 1 No. Earth terminal shall be provided inside the terminal box. Connection diagram shall be marked inside the terminal box. The motor terminal box shall be suitable for withstanding the system fault current of 50 KA for a duration of at least 0.25 seconds, without any rupture.
25	Cable Entries, Cable Glands & Lugs	Cable entries, Cable glands and Lugs shall be provided suitable for the power cable size as indicated in the annexure (project specific requirement). Double Compression type, brass with nickel plated flame proof cable glands shall be supplied – Quantity to be matched with the number of entries. 3Nos. of Tinned Copper Lugs shall be provided.
26	Terminals	Separate Terminals for Space heaters and Windings with suitable connecting links shall be supplied.
27	Body Earth	Shall have 2 Nos. of earthpoints (Threaded hole with suitable GI Bolt) at appropriate location (in motor base frame).
28	Space heater for motors rated 30 KW and above	Separate space heater suitable for 240 V AC, Single Phase supply shall be provided.
29	Lifting provision	Eye bolt.
30	Project specific requirements	- Motor bearing shall be insulated wherever required. - All LT motors 15 KW and above shall be provided with external greasing arrangement



Sl. No.	Description	Requirement
		All motors for outdoor duty shall have detachable metal canopy.
31	Bearing	Bearings shall be of ball or roller type effectively sealed against ingress of dust. The bearing shall be so constructed that the loss of lubricating grease is kept to minimum. Bearing shall be rated for a minimum standard life of 40000 hours.
32	Tests	- Measurement of resistance of windings of stator and wound rotor. - Reduced voltage running up test at no load (for squirrel cage motors). - No load test. - Full load test to determine efficiency, power factor and slip. - Insulation resistance test. - High voltage test - Test for vibration severity of motor. - Test for noise levels of motor. - Test for degree of protection by enclosure. - Temperature rise test at limiting values of voltage and frequency variations. - Over speed test. - Locked rotor readings of voltage, current and power input at a suitable reduced voltage.
33	Name Plates	Motor shall have name plate as per relevant IS and in addition, Manufacture's name, frame size, Energy Efficiency class, Insulation class designation shall also be indicated.
34	Documents to be submitted by the vendor for approval by BHEL/Customer, after placement of purchase order.	3 Sets of the following :- - Final technical Data sheet as per the format submitted by BHEL. - Motor GA drawing indicating foundation, shaft details and terminal box arrangement with complete dimensions. - Motor Characteristic curves (Torque Vs. Speed, Current Vs. Speed, Speed Vs. time, Current Vs. time, Efficiency and PF Vs. load, Thermal withstand characteristic)
35	Packing	Shall be as per manufacturer's standard practice. The packing shall be suitable for safe transport, safe delivery at site and shall avoid damages due to environmental conditions during storage at site.

POWER CABLE SIZE:

Vendor to provide the cable entry, glands and lugs as per the specification requirement suitable for the power cable sizes as indicated below. However, the sizes indicated herein are tentative and shall be finalised during detailed engineering.

Sl. No.	From (KW)	To (KW)	Power Cable size in sq. mm.
1.	0.01	1	3C-2.5mm ² (CU)
2.	1.01	2	3C-2.5mm ² (CU)
3.	2.01	3.7	3C-10mm ² (AL)
4.	3.71	5.5	3C-10mm ² (AL)
5.	5.51	7.5	3C-25mm ² (AL)
6.	7.51	9.3	3C-25mm ² (AL)
7.	9.31	11	3C-25mm ² (AL)
8.	11.1	15	3C-50mm ² (AL)
9.	15.1	18.5	3C-50mm ² (AL)
10	18.51	22.0	3C-50mm ² (AL)
11	22.0	27.0	3C-50mm ² (AL)
12	27.1	30.0	3C-70mm ² (AL)
13	30.1	37.0	3C-70mm ² (AL)
14	37.1	45.0	3C-95mm ² (AL)
15	45.1	55.0	3C-150mm ² (AL)
16	55.1	75.0	3C-150mm ² (AL)



17	75.1	90.0	3C-185mm ² (AL)
18	90.1	110.0	3C-240mm ² (AL)
19	110.1	125.0	2-3C-240mm ² (AL)
20	125.1	132.0	2-3C-240mm ² (AL)
21	132.1	160.0	2-3C-240mm ² (AL)
22	160.1	174.0	2-3C-240mm ² (AL)

DIMENSIONS OF TERMINAL BOXES (For Flame proof motors)

Sl. No.	Motor MCR in KW	Minimum Distance between centre of stud and the gland plate (in mm)
1	Up to 3 KW	As per manufacturers' practice
2	Above 3 KW – Up to 7 KW	85
3	Above 7 KW – Up to 13 KW	115
4	Above 13 KW – Up to 24 KW	167
5	Above 24 KW – Up to 37 KW	196
6	Above 37 KW – Up to 55 KW	249
7	Above 55 KW – Up to 90 KW	277
8	Above 90 KW – Up to 125 KW	331
9	Above 125 KW – Up to 200 KW	403

ANNEXURE-U

FIELD INSTRUMENTS & ANALYSERS

FIELD INSTRUMENT REDUNDANCY

Redundant instruments shall be provided for all control applications. For all closed loop controls (CLCS) triple redundant sensors shall be provided. This will include sensors provided for compensation also. Similarly for critical protection logic requirements triple redundant sensors for 2 out of 3 logic shall also be provided to avoid spurious tripping. For all other control application dual redundant sensors shall be provided.

Two out of three measurements philosophy shall be adopted for all CLCS and Protection for reliability of operation. The control system shall select the median value for the normal control purpose. In case of deviation of one transmitter output from the other two, the same shall be automatically isolated and average output of the remaining transmitters shall be fed to the control and measurement system and the control loop in this case shall be maintained on auto, with an alarm. In case of failure of the two remaining transmitters in circuit, deviation of one transmitter output is more than the preset limit compared to the other transmitter, there shall be automatic bump less transfer to manual and changeovers shall have suitable alarms. For signal compensations, separate signals from separate transmitters other than used for measurement & control shall be used.

For open loop controls (OLCS), all sensors used for the protection shall be triple redundant. All sensors for permissive and interlock shall be dual redundant.

1.00.00 SPECIFICATION FOR ELECTRONIC TRANSMITTERS

1.01.00 PRESSURE TRANSMITTER

- | | |
|----------------------|--|
| 1. Working Principle | : Smart (HART 5/7 protocol Compatible) |
| 2. Type | : Microprocessor based, 2 – Wire |
| 3. Output Signal | : 4-20 mA DC along with superimposed Digital signal |
| 4. Measuring Element | : Capsule / Diaphragm |
| 5. Element material | : SS-316 (Stainless Steel) or better – Shall be decided by the vendor to suit the process medium |



6. Static Pressure : 150 % of maximum span continuously, without affecting the calibration
7. Turn-down ratio : 10:1 – For low pressure application
30:1 – For high pressure application
8. Span and Zero : Continuous, tamper proof, remote as well locally adjustable with zero elevation and suppression by 100% of span
9. Enclosure Class : IP-65 (Explosion proof for NEC Class-1, Division area)
10. Output Indicator : LCD (Integral indicator of 5 digit display)
11. Nameplate : Tag number, service engraved in SS tag plate
12. Body : SS
13. Operating Voltage : 24V DC
14. Load : 500Ohms (min.) at 24 Volts D.C.
15. Ambient Temperature : 0 - 50 °C
16. Performance:
 - i. Accuracy : $\pm 0.1\%$ of calibrated span (minimum)
 - ii. Repeatability : $\pm 0.05\%$ of Span or better
17. Sealing/Isolation : Extended diaphragm (Silicon oil/ Fluorolubfilled) with 5 meters SS armoured capillary for corrosive/viscous/solid bearing or slurry type fluid applications - Shall be decided by the vendor to suit the process medium
18. Accessories :
 - a. Universal mounting bracket suitable for 2" pipe mounting
 - b. High tensile carbon steel Ubolts
 - c. Siphon for steam and hot water services
 - d. $\frac{1}{2}$ " NPT 2-valve stainless steel manifold, constructed from SS316 bar stock
 - e. Companion flange with nuts, bolts and gaskets
 - f. $\frac{1}{2}$ " NPT cable gland

- g. Handheld calibrator
 - h. All accessories shall be suitable to handle the process medium
19. Adjustment/Calibration/: From handheld calibrator/ HART
Maintenance management system

Notes: For primary air/ secondary air/ flue gas applications, DP type transmitters shall be provided for pressure measurement. LVDT type is not acceptable.

1.02.00 DIFFERENTIAL PRESSURE TRANSMITTER / FLOW TRANSMITTER

- | | |
|-----------------------|---|
| 1. Working Principle | : Smart (HART 5/7 protocol Compatible) |
| 2. Type | : Microprocessor based, 2 – Wire |
| 3. Output Signal | : 4-20 mA DC along with superimposed digital signal |
| 4. Measuring Element | : Capsule / Diaphragm |
| 5. Element material | : SS-316 (Stainless Steel) or better - Shall be decided by the vendor to suit the process medium |
| 6. Static Pressure | : 150 % of maximum span continuously, without affecting the calibration |
| 7. Turn-down ratio | : 10:1 – For low pressure application
30:1 – For high pressure application |
| 8. Span and Zero | : Continuous, tamper proof, remote as well locally adjustable with zero elevation and suppression by 100% of span |
| 9. Enclosure Class | : IP-65 (Explosion proof for NEC Class-1, Division 1 area) |
| 10. Output Indicator | : LCD (Integral indicator of 5 digit display) |
| 11. Nameplate | : Tag number, service engraved in SS tag plate |
| 12. Body | : SS |
| 13. Operating Voltage | : 24V DC |



14. Load : 500Ohms (min.) at 24 Volts D.C.
15. Ambient Temperature : 0 - 50 °C
16. Performance:
- i. Accuracy : $\pm 0.1\%$ of Span or better
 - ii. Repeatability : $\pm 0.05\%$ of Span or better
17. Sealing/Isolation : Extended diaphragm (Silicon oil/Fluorolubfilled) with 5 meters SS armoured capillary for corrosive/viscous/solid bearing or slurry type fluid applications - Shall be decided by the vendor to suit the process medium
18. Accessories :
- a. Universal mounting bracket suitable for 2" pipe mounting
 - b. High tensile carbon steel U-bolts
 - c. Siphon for steam and hot water services
 - d. $\frac{1}{2}$ " NPT 5-valve stainless steel manifold, constructed from SS316 bar stock
 - e. Companion flange with nuts, bolts and gaskets
 - f. $\frac{1}{2}$ " NPT cable gland
 - g. Handheld calibrator
 - h. All accessories shall be suitable to handle the process medium
19. Adjustment/Calibration/: From handheld calibrator/ HART
Maintenance management system

1.03.00 ULTRASONIC LEVEL TRANSMITTER

1. Type : Microprocessor based, 2-wire, Smart (HART 5/7 protocol Compatible)
2. Operating Principle : Detection of reflected ultrasonic pulse
3. Output Signal : 4-20 mA DC along with superimposed digital signal
4. Operating frequency : 10 KHz to 50 KHz (typical)
5. Display : LCD
6. Temperature : Built in –Programmable

Compensation

7. Power supply : 24 V DC
8. Enclosure : SS, IP-65 (Explosion proof for NEC Class-1, Division 1 area)
9. Zero & Span : Continuous, tamper proof, remote as well locally adjustable. It shall be possible to calibrate the instrument without any level in the sump/ tank
10. Accuracy & Repeatability: 0.15 % of span or better
11. Resolution : 0.1 % of span
12. Operating temp. : Transmitter- 500 °C and Sensor - 800 °C
13. MOC Sensor : SS-316/Body- PVC and Face –Polyurethane - - Shall be decided by the vendor to suit the process medium
14. Mounting : 4" Flanged/ 2" NPT for sensor and Transmitter on panel
15. Accessories :
- a. Handheld calibrator
 - b. Weather canopy for protection from direct sunlight and direct rain
 - c. ½"NPT cable gland
 - d. All mounting hardware (SS- 316), Prefab cable
 - e. SS Nameplate
16. Diagnosis : On-line
17. Status Indication : Power On, High, V. High, Low, V. Low, Fault
18. Output Contacts : 2 SPDT, 230V, 5A
19. Adjustment/Calibration/: From handheld calibrator/
Maintenance HART management system
20. Applications : Coal Bunker, Water Service etc.

1.04.00 ULTRASONIC FLOW TRANSMITTER

1. Type : Ultrasonic – Clamp On



2. Accuracy : +/- 1 % of reading
3. Repeatability : +/- 0.3 % of reading
4. Rangeability : 400: 1
5. Output Signal : 4-20 mA DC with HART
6. Measured Parameter : Volumetric flow, Totalized flow and flow Velocity
7. Display : LCD with internal Key Pad (Flow rate & totalization)
8. Power Supply : 24 V DC (2 Wire)
9. Enclosure : SS (IP- 68 – Submersible)
10. Mounting : SS Chain or Strap
11. Accessories
 - a. Handheld calibrator
 - b. ½"NPT cable gland
 - c. Transducer cable
 - d. All mounting hardware (SS-316)
 - e. SS Nameplate
12. Adjustment/Calibration/: From handheld calibrator/
Maintenance HART managementsystem
13. Applications : Plant water service

Note: Multi-path insertion type (minimum 4 path) Ultrasonic Flow meter shall be provided for raw water/ Cooling Water flow measurements.

1.05.00 MASS FLOW METER

1.05.01 SENSOR

1. Measuring Principle : Coriolis Mass flow
2. Primary Element : Flow Tube of 316SS or better
3. Heating Arrangement : Integral
4. Process Connection : Flanged of rating as per process requirement
5. Drain : Self-draining facility
6. Enclosure : Stainless steel
7. Accessories : Counter flanges, Mounting nuts, bolts, gaskets etc.

1.05.02 TRANSMITTER

1. Measured quantities : Mass Flow rate, Total Mass Flow, Density
2. Input Signal Processing : Smart (HART compatible)
3. Display : LCD
4. Output : 2 nos. isolated output of 4-20mA DC selectable from four measured quantities
5. Load : < 750 ohms
6. Power supply : 240V AC, 50 Hz

2.00.00 HART HAND HELD CALIBRATOR

Universal type Hand held calibrators shall be provided for adjustment/calibration/maintenance of the HART compatible transmitters. The hand held calibrator shall be suitable for all types of transmitters supplied in the package. If one type of hand held type calibrator is not suitable for communicating with all types of transmitters then separate hand held calibrator shall be provided.

3.00.00 PROCESS ACTUATED SWITCHES

3.01.00 PRESSURE SWITCH

1. Type :
 - a. Piston for high pressure application
 - b. Bellow / Diaphragm for low pressure application
2. Sensing element material : SS-316 or better - shall be decided by the vendor to suit the process medium
3. Case Material : SS or better - shall be decided by the vendor to suit the process medium
4. Setter Scale : Black graduation on white linear scale. Graduation 0-100% with red pointer for set points
5. Over range : 150 % of maximum pressure
6. Adjustments :
 - a. Internal Set Point
 - b. Adjustable Dead band
7. End Connection : 1/2" NPT(F) bottom connected
8. Switch configuration : Two SPDT (240V, 5A AC/220V, 0.5A DC)
9. Switch Type : Snap acting, shock & vibration proof



- 10. Terminal Block : Suitable for full ring lugs
- 11. Enclosure Class : IP-65 (Explosion proof for NEC Class-1, Division 1 area)
- 12. Performance :
 - a. Repeat accuracy $\pm 1.0\%$
 - b. Accuracy of Setting Indication of $\pm 1.5\%$
- 13. Ambient temperature : 0 – 50 °C
- 14. Nameplate : Tag number, service engraved in SS tag plate
- 15. Accessories :
 - a. Silicon oil/ Fluorolub filled Remote diaphragm seal with SS-316 capillary for corrosive/ viscous/ solid bearing or slurry type fluid applications
 - b. Snubbers for pulsating fluid applications
 - c. Siphons for steam and hot water services
 - d. Retention ring and screws for surface mounting
 - e. 1/2" NPT 2 Valve SS-316 barstock manifold
 - f. 1/2" NPT cable gland
 - g. All accessories shall be suitable to handle the process medium
- 16. Applications : During Detail Engineering on Owner's approval

3.02.00 DIFFERENTIAL PRESSURE SWITCH

- 1. Type :
 - a. Piston for high pressure application
 - b. Bellow / Diaphragm for low pressure application
- 2. Sensing element material : SS-316 or better - Shall be decided by the vendor to suit the process medium
- 3. Case Material : SS
- 4. Setter Scale : Black graduation on white linear scale. Graduation 0-100% with red pointer for set points
- 5. Over range : 150 % of maximum pressure
- 6. Adjustments :
 - a. Internal Set Point

b. Adjustable Dead band

7. End Connection : 1/2" NPT (F) bottom/ back connected
8. Switch configuration : Two SPDT (240V, 5A AC/220V, 0.5A DC)
9. Switch Type : Snap acting, shock & vibration proof
10. Terminal Block : Suitable for full ring lugs
11. Enclosure Class : IP-65 (Explosion proof for NEC Class-1, Division 1 area)
12. Performance :
- a. Repeat accuracy $\pm 1.0\%$
 - b. Accuracy of Setting Indication of $\pm 1.5\%$
13. Ambient temperature : 0 – 50 °C
14. Nameplate : Tag number, service engraved in SS tag plate
15. Accessories :
- a. Silicon oil/ Fluorolub filled Remote diaphragm seal with SS-316 capillary Diaphragm seals for corrosive/ viscous/ solid bearing or slurry type fluid applications
 - b. Snubbers for pulsating fluid applications
 - c. Siphons for steam and hot water services
 - d. Retention ring and screws for surface mounting
 - e. 1/2" NPT 5 Valve SS-316 bar stock manifold
 - f. 1/2" NPT cable gland
 - g. All accessories shall be suitable to handle the process medium
16. Applications : During Detail Engineering on Owner's approval

3.03.00 LEVEL SWITCH**3.03.01 FLOAT OPERATED**

1. Float material : SS-316 or better - shall be decided by the vendor to suit the process medium
2. Wetted parts : SS-316 or better - shall be decided by the vendor to suit the process medium



3. Float chamber : Stainless steel/Carbon steel, construction welded - to suit the process medium
4. Float chamber mounting : Side mounted
5. Fluid connection : Side – Side
6. Fluid connection size : 1" ANSI RF Flange (rubber line, if required)
7. Drain : ½ inch NPT with Plug
8. Pressure rating of chamber: Minimum 1.5 times of design pressure
9. Repeatability : ±1.5 mm or better
10. Switch housing : Stainless Steel
11. Switch housing type : IP- 65
12. Type of switch : Snap acting magnetically operated hermetically sealed
13. Switch configuration : 2 SPDT (5A, 240 V AC, 0.5A, 220V DC)
14. Accessories :
 - a. Counter flange, nuts & bolts, suitable gasket etc.
 - b. Steel globe typedrain valve
 - c. ½"NPT cable gland
 - d. Stainless steel nameplate with alpha-numeric engraved for service and tag
 - e. All accessories shall be suitable to handle the process medium
15. Application : During Detail Engineering on Owner's approval

3.04.00 FLOW SWITCH

1. Type : Paddle /Piston/Disk
2. Wetted part material : Stainless steel or Hastelloy for acidic application - shall be decided by the vendor to suit the process medium
3. End connection :
 - a. Threaded up to 1" line size with integral Tee
 - b. Flanged for line size > 1 ½"



4. Enclosure material : Stainless Steel
5. Enclosure class : IP 65
6. Switch configuration : 2 SPDT (5A, 240 V AC, 0.5A, 220V DC)
7. Repeatability : 2%
8. Cable connection : ½"NPTF
9. Accessories :
 - a. Tee, Counter flange, nuts & bolts, suitable gasket etc.
 - b. ½"NPT cable gland
 - c. Stainless steel nameplate with alpha-numeric engraved for service and tag
 - d. All accessories shall be suitable to handle the process medium

3.05.00 RF LEVEL SWITCH

1. Type : RADIO FREQUENCY Sensing probe
2. Material : SS-316
3. Mounting application : Threaded
4. Temperature : 250°C (Max.)
Electronic Controller
5. Input Supply Voltage : 240V AC ±10%, 50 Hz.
6. Relay Output : 2 SPDT (240V AC, 5A)
7. Ambient Temperature : 50 °C
8. Enclosure Protection : IP-66
9. Enclosure Housing : SS
10. Local LED Indication :
 - a. Normal Level
 - b. Power On
 - c. Alarm Level
 - d. Probe Healthy



11. Switching Repeatability : $\pm 0.5\%$

12. Accessories : Co-axial cable for probe connection to controller SS
Tag plate $\frac{1}{2}$ " NPT Cable Glands

13. Application : Solid level

3.06.00 CONDUCTIVITY TYPE LEVEL SWITCH

1. Type : Conductivity discrimination

2. Probe MOC : SS-316

3. Mounting Application : Flanged on external cage

4. Temperature : 250°C (Max.)

5. Test Pressure : Two times rated pressure

6. Input Supply Voltage : 240V AC $\pm 10\%$, 50 Hz.

7. Input : Four independent channel with selectable switching threshold for water conductivity

8. Relay Output : 2 SPDT (240V AC, 5A)

9. Ambient Temperature : 50°C

10. Enclosure Protection : IP-65 (Explosion proof for NEC Class-1, Division-1 area)

11. Enclosure Housing : SS

12. Local LED Indication : High, Low, Very High, Very Low, Power Fault

13. Accessories :
- a. Interconnecting cable from probe to electronics
 - b. Mounting accessories
 - c. External cage
 - d. Washer & Gasket
 - e. $\frac{1}{2}$ " NPT Cable Glands
 - f. SS Tag Plate

14. Application : During Detail Engineering on Owner's approval

3.07.00 TEMPERATURE SWITCH

1. Type : Bimetallic or gas filled or liquid filled
2. Sensing Element Material : SS-316 – to suit the process medium
3. Bulb Material : SS-316
4. Capillary : Stainless Steel armoured
5. Movement Material : Stainless Steel
6. Case material : Stainless Steel with neoprene gasket and clear glass where applicable cover conforming to IP-65.
(Explosion proof for NEC Class-1, Division 1 area).
7. Scale : Black graduation on white linear scale. Graduation 0-100% with red pointer for set points
8. Over range Protection : 120 %
9. Instrument connection : Bottom
10. Switch configuration : Two SPDT (240V, 5A AC/220V, 0.5A DC)
11. Switch type : Snap acting, shock and vibration-proof
12. Adjustability : Internal Set point adjustable over span range
13. Compensation :
 - a. Capillary compensation with invar wire throughout the capillary length
 - b. Case compensation
14. Performance
 - a. Scale Accuracy: ± 1.0 % of full scale
 - b. Repeatability : < 0.5 % of full range
 - c. Response time : Less than 40 seconds with thermowell
15. Capillary length : 5 meters (minimum) for local mounting/15 meters for local panel mounting



- | | |
|------------------|---|
| 16. Nameplate | : Tag number, service engraved in stainless steel tag plate |
| 17. Accessories | : Mounting accessories, 1/2" NPT cable gland |
| 18. Applications | : During Detail Engineering on Owner's approval |

4.00.00 LOCAL INSTRUMENTS

4.01.00 PRESSURE GAUGE AND DIFFERENTIAL PRESSURE GAUGE

- | | |
|---------------------------|---|
| 1. Type | : Bourdon/Bellows/Diaphragm |
| 2. Applicable Standard | : EN-837/ANSI B 40.1 |
| 3. Sensing & Socket | : SS-316 or better – To suit the process medium |
| 4. Movement Material | : SS-316 or better – To suit the process medium |
| 5. Case Material | : Stainless steel. IP-65 (Explosion proof for NEC Class-1, Division 1 area) |
| 6. Dial Size | : Generally 150 mm |
| 7. Scale | : Black lettering on white back-ground. |
| 8. Window | : Shatterproof glass |
| 9. Range Selection | : Normal process pressure: 50~70 % of range – Shall be finalised during detailed engineering with owner's approval. |
| 10. Over-range Protection | : 125% of maximum range by internal stop. External stop at zero |
| 11. Adjustment | : For Zero adjustment (Micrometre screw external) |
| 12. Element Connection | : Argon welding |
| 13. Process Connection | : 1/2" NPT (M) Bottom for local, back for panel mounting |
| 14. Performance | : Accuracy of ± 1.0 % of span or better |

15. Operating ambient : 0 - 50 °C
16. Safety Feature : Blow out disc /diaphragm at the back
17. Accessories :
- a. Snubbers for pulsating fluid application.
 - b. Stainless steel Diaphragm seals for corrosive/ viscous/ solid bearing or slurry type fluid applications
 - c. 3-Way SS316 Gauge cock for pressure gauges
 - d. 5-valve SS316 manifold from barstock for differential pressure gauge
 - e. Siphons for steam and hot water services
 - f. All accessories shall be suitable to handle the process medium
18. Nameplate : Tag number, service engraved in stainless steel tag plate

4.02.00 LEVEL INDICATOR (FLOAT & BOARD TYPE)

1. Type : Float and Board
2. Float Material : SS-316 or better -Shall be decided by the vendor to suit the process medium
3. Float Cable : SS-316
4. Indicator Assembly : Epoxy painted Aluminium
5. Guide wire spring assembly : SS-316 (2 Nos.)
6. Guide Wire Anchor : SS-316
7. Scale Board : Anodized Aluminium with engraved marking (Minimum graduation 10mm), mounting brackets and suitable hardware required as per tank height
8. Elbow Assembly : Anodized Aluminium
9. Flanges : RF, ANSI 150, SS (3 Nos.)
10. Accuracy : + 10 mm or better



11. Accessories : All mounting accessories including counter flange, nuts & bolts, suitable gasket etc. as applicable, SS Tag plate

4.03.00 ROTAMETER WITH DP REGULATOR

1. Type : ON-LINE for line up to and including 50 mm NB.
Borosilicate BY-PASS for line size above 50 NB
2. Metering tube : Toughened Borosilicate - to suit the process medium
3. Float : SS-316
4. End fittings : SS-316
5. Packing material : Teflon / PTFE
6. Casing : Stainless Steel
7. Gland Rings/Followers/ : Stainless Steel
Other wetted parts
8. Orifice Plate : Stainless Steel (for bypass type)
9. Operating Temperature : 0-50 °C
10. Test Pressure : 200% of maximum operating pressure
11. Scale : 250 mm nominal length
12. Graduation : Direct reading
13. Process Connection : Flanged (RF) to line size as per ANSI standards
14. Tapping : D & D/2
15. Accuracy : $\pm 2\%$ of full scale reading
16. Reproducibility : Within 0.5% of instantaneous reading
17. Accessories : SS Tag Plate, orifice plate

5.00.00 TEMPERATURE ELEMENTS & ACCESSORIES**5.01.00 RESISTANCE TEMPERATURE DETECTOR**

1. Element Type : PT100, Ungrounded
2. Wiring : 3 Wire
3. Protecting Tube
 - a. O.D. : 8mm
 - b. Material : Seamless, SS-316 or better - Shall be decided by the vendor to suit the process medium
 - c. Filling : Magnesium oxide (Purity above 99.4%).
4. Response time :
 - a. Less than 15 sec. (bare).
 - b. Less than 50 sec. (with thermowell)
5. Calibration : DIN 43760
6. Accuracy : $\pm 0.5\%$
7. Head
 - a. Type : IP-65 universal screwed type
 - b. Material : Stainless Steel
 - c. Terminal blocks : Nickel plated Brass-screw type / silver plated
 - d. Cable connection : $\frac{1}{2}$ " NPT gland and grommet
 - e. Others : Terminal head cover with SS chain and suitable gasket. Head of TE to be provided with sufficient space and arrangement to mount head mounted temperature transmitter (as applicable).
10. Accessories :
 - a. Adjustable nipple-union-nipple [$\frac{1}{2}$ " Sch 80 X $\frac{1}{2}$ " NPT] with thermowell connection
 - b. Compression fittings/unions
 - c. Flanges etc. (for flanged connections only)
 - d. Thermowell (As specified below)
11. Thermowell connection : $\frac{1}{2}$ " NPT (M) or 150 RF Flanged - shall be finalised during detailed engineering based on stub connection
12. Nameplate : Tag number, service engraved in stainless steel tag plate

Note: The specifications for RTDs of winding/ bearing of motor/pump, can be as per their manufacturer standards. The manufacturer shall submit the adequate supporting documents for establishing their standard practice. However, the type of RTD shall be Pt-100.

5.02.00 THERMOCOUPLES

1. Type :
 - a. 16 SWG wire of Chromel-Alumel) (Type-K) or Platinum Rhodium (Type-R)
 - b. Duplex
 - c. Ungrounded
2. Protecting Tube
 - a. O.D. : 8mm
 - b. Material : Seamless, SS-316 or better Shall be decided by the vendor to suit the process medium
 - c. Filling : Magnesium oxide (Purity above 99.4%).
3. Response time
 - a. Less than 15 sec. (bare).
 - b. Less than 50 sec. (with thermowell)
4. Accuracy : As per standard ANSI MC 96.1
5. Head
 - a. Type : IP-65 universal screwed type
 - b. Material : Stainless Steel
 - c. Terminal blocks : Nickel plated Brass-screw type / silver plated
 - d. Cable connection : ½" NPT gland and grommet
 - e. Others : Terminal head cover with SS chain and suitable gasket. Head of TE to be provided with sufficient space and arrangement to mount head mounted temperature transmitter (as applicable).
6. Accessories :
 - a. Adjustable nipple-union-nipple [1/2" SCH 80 X ½" NPT] with thermowell connection
 - b. Compression fittings/unions
 - c. Flanges etc. (for flanged connections only)
 - d. Thermowell (As specified below)
7. Thermowell connection : ½" NPT (M) or 150 RF Flanged -shall be finalised during detailed engineering based on stub connection

8. Nameplate : Tag number, service engraved in stainless steel tag plate

5.03.00 TEMPERATURE GAUGE

1. Type : Expansion type (Liquid/Gas filled system/Bimetallic)
2. Applicable Standard : EN-13190
3. Sensing Element Material : Bourdon – SS-316 or better - shall be decided by the vendor to suit the process medium
4. Bulb & Capillary Material : SS-316
5. Capillary Tubing : SS316 capillary with SS304 armouring. Shall be decided by the vendor to suit the process medium
6. Movement Materials : Stainless Steel / Direct Bourdon tip connection to pointer spindle
7. Case Material :Stainless Steel stove enamelled, black finish, threaded bezel ring, clear glasscover conforming to IP 65.
8. Dial size : 150 mm
9. Scale : Black lettering on white back-ground
10. Over range protection : 125 percent of FSD
11. Instrument Connection : Bottom connection for local mounting, back connection for panel mounting
12. Process Connection : ½" NPT (M) or RF Flanged - Shall be finalised during detailed engineering based on stub connection
13. Extension Neck Length : 50 mm
14. Compensation :
 - a. Capillary compensation



b. Case compensation

15. Performance

- a. Accuracy : ± 1.0 percent of full scale Deflection
- b. Repeatability : Less than 0.5 percent of full range
- c. Response time : 15 seconds (max.).

16. Capillary length : 5 metres (local) / 15 metres (local panel)

17. Other features : Shatter proof glass

18. Nameplate : Tag number, service engraved in stainless steel tag plate

19. Accessories : SS316 thermowell or better - shall be decided by the vendor to suit the process medium

5.04.00 THERMOWELL

1. Material : SS-316 or better - shall be decided by the vendor to suit the process medium

2. Manufacture : Drilled from bar stock, Hex Head, Tapered design (As per ASME PTC 19.3-2016)

3. Process connection : M33x2

4. IBR Certification : Applicable for process pressure above 3.5 kg/sq.cm.

5. Bore concentricity : +5% of wall thickness

6. Identification mark : Tag number punched on head

7. Surface treatment : Polish after machining

8. Element connection : $\frac{1}{2}$ " NPT (M) or 150 RF Flanged

9. Head : Hexagonal

10. Length of the hex head : 31.75 mm (min.) - Shall be finalised during detailed engineering

11. Accessories : SS Plug and chain for test thermo wells SS
Nameplate, Flange with companion flange & all
required accessories for flanged connections.

Note: Bidder shall provide calculation for thermo well as per ASME – PTC-19.3 2016 for approval. IBR form III C or Equivalent certificate and detailed drawings shall be furnished for all thermowells.

6.00.00 ANALYSERS

6.01.00 OXYGEN ANALYZER

1. Operating Principle : Zirconium Oxide (ZrO₂)
2. Sampling/Non-sampling : In-Situ
3. Type : Microprocessor based
4. Range : 0.1-10% / 0.25-25%
5. Accuracy : $\pm 1\%$ of Full Scale
6. Response time (up to 90 : Less than 5 seconds
% of full scale)
7. Linearity : $\pm 1\%$ of Full Scale
8. Repeatability : $\leq 0.5\%$ of Span
9. Calibration : Automatic & Manual (Zero & Span)
10. Power Supply : 240 V AC
11. Output signal : 4-20 mA DC (with superimposed HART signal) into
500 ohms
12. Alarm annunciation : Four relay contacts, Dual Alarm setpoints
(240V AC, 5A)
13. Enclosure : Stainless Steel (IP-65)
14. Material for gas carrying: SS-316
- Components
15. Reference : Instrument Air
16. Probe Length : 1800 mm or as applicable
17. Indication : LCD display
18. Operating Temperature : Min.1600 °C
Range
19. Accessories :
 - a. Interconnection cable (asrequired) in flexible conduits
 - b. Tubes/Fittings, mounting brackets as required
 - c. Bolts, Nuts, Gaskets
 - d. Automatic calibration kit for oneyear continuousoperation(complete with
allaccessories and standard GasCylinders)
 - e. Surge Arrester



6.02.00 GAS (SOX/NOX) ANALYZER

1. Operating Principle : NDIR
2. Sampling/Non-sampling : Dilution
3. Type : Microprocessor based
4. Range :
 - a. SO₂ : 0-450 ppm
 - b. NO_x : 0-500 ppm
 - c. CO/CO₂ : 0-500 ppm
5. Accuracy : 1% F.S.
6. Response time (up to 90% offull scale) : Less than 5 (five) seconds
7. Linearity : ±1% of Full Scale
8. Repeatability : ≤1% of Span
9. Calibration : Automatic & Manual (Zero & Span)
10. Power Supply : 240 V AC
11. Output signal : 4-20 mA DC each channel (withsuperimposed HART signal) into 600ohms
12. Alarm annunciation : Four relay contacts, Dual Alarm setpoints(240V AC, 5A)
13. Enclosure : Stainless Steel
14. Indication : LCD display
15. Operating Temp.Range : 0-300 °C
16. Accessories :
 - a. Interconnection cable (as required) in flexible conduits
 - b. Tubes/Fittings, mountingbrackets/pads as required
 - c. Purge system for cleaning
 - d. Surge Arrester
 - e. Standard gas for calibration.

ANNEXURE - V

SPECIFICATION FOR CABLES, CABLE TRAYS AND CABLE GLANDS

1.0 GENERAL TECHNICAL REQUIREMENTS

- 1.0.01 All cable and materials shall be designed, manufactured and tested in accordance with the latest applicable Indian Standards (IS) and IEC except where modified and/or supplemented by this specification.
- 1.0.02 Cable and material conforming to any other standard which ensures equal or better quality, may be accepted. In such case, copies of the English version of the standard adopted shall be submitted along with the bid.
- 1.0.03 The electrical installation shall meet the requirements of Indian Electricity Rules as amended up to date and relevant IS Code of Practice. In addition, rules and regulations applicable to the work shall be followed.
- 1.0.04 Cables shall be flame retardant low smoke (FRLS) type. In hazardous areas cables of suitable R/L ratio shall be provided for intrinsic safety. Repaired cables are not acceptable.
- 1.0.05 FRLS marking shall be provided on the surface of the cable at intervals not exceeding 5 m. Durable marking at intervals not exceeding 625mm shall include Manufacturer's name, Year of manufacture, Voltage grade, Type of cables (Conductor size & number of pairs / type of compensating /extension cable), Insulation material, FRLS etc.
- 1.0.06 Progressive sequential length marking shall also be provided at every meter interval on outer sheath of cable.
- 1.0.07 Non-returnable standard seasoned wooden drum containing minimum 500/1000 m $\pm 5\%$ length. Drum shall be anti-rodent, anti-termite and smooth finish. Both end of cable shall be capped by means of non-hygroscopic sealing material.
- 1.0.08 For continuous operation at specified rating, maximum conductor temperature shall be limited to the permissible value as per relevant standard and/or this specification which one is more stringent.
- 1.0.09 The insulation and sheath materials shall be resistant to oil, acid and alkali and shall be tough enough to withstand mechanical stresses during handling.



- 1.0.10 Armouring shall be single round wire of galvanized steel for multicore cables and aluminum for single core cable for power and control cables. For fire survival control cable, the armouring over inner sheath shall consist of single layer of wire / round galvanized steel wire as per IS-3975 amended up to date.
- 1.0.11 The outer sheath shall have flame retardant low smoke halogen evolution (FRLSH) characteristics or fire survival characteristics as applicable and shall meet the requirements of additional tests specified for the purpose.
- 1.0.12 Core identification for multicore cable shall be provided by colour coding.
- 1.0.13 All control cables shall be 2.5 Sq. mm copper cable.
- 1.0.14 Multicore control cables will generally have spare conductor(s) in accordance with the following chart :

Conductors	Required Cables
i. 1 or 2	1-3/C
ii. 3 or 4	1-5/C
iii. 5 or 6	1-7/C
iv. 7 or 8	1-9/C
v. 9 or 10	1-12/C
vi. Above 10	Two or more of above cables

1.0.15 Cable Identification

Cable identification shall be provided by embossing on the outer sheath the following:

- Manufacturer's name or trade mark
- Manufacturer's name or trade mark
- Voltage grade
- Year of manufacture
- Type of insulation, e.g. XLPE, HRPVC & IE2 etc.
- No. of core & size of cables
- Type of outer sheath e.g. FRLSH, FS etc.

1.1 Thermocouple Extension & Compensating Cable

01. Conductor : Solid conductor



02. Conductor size	: 16 AWG (1.31 Sq. mm)
03. Type	: KX (Compensating) (Chromel Alumel) RX (Compensating) (Copper-Copper alloy) JX (Compensating) (Iron-Constantan)
04. Conductor Insulation	: HR PVC Type-C (IS-5831, 1984) 0.6mm thick
05. Operating Voltage	: 650V
06. Twisting	: Pair twisted with lay of 60 mm (max)
07. Twisting Direction	: All pairs in the same direction. Lapped to form bunch with Mylar tape.
08. Screen (Pair & Overall)	: Aluminium Mylar tape with a thickness of 28 μm (min.) for individual pair screen and 60 μm (min.) for overall screen with 100% coverage and 25% overlapped edges. Over the individual pair screening tape two laps of 0.05 mm thick (min.) polyester tape shall be applied with Minimum overlap of 25%. Metallic side of the screen shall be in contact with drain wire.
09. Drain wire	: Annealed tinned copper wire, stranded. Size 0.5 Sq. mm. (No. of strands / size: - 7 / 0.3mm) (For both individual and overall screen)
10. Inner Sheath	: Extruded FRLS PVC (anti-rodent, anti-termite & moisture resistant properties) HR PVC Type ST2 of IS-5831, 1984 Thickness as per IS-1554 Part-I 1976
11. Rip Cord	: Nonmetallic under sheath
12. Armouring	: GI wire / strip as per IS 3975
13. Outer Sheath	: Extruded FRLS PVC (anti-rodent, anti-termite & moisture resistant properties) HR PVC Type ST2 of IS-5831, 1984 Thickness 1.8 mm (Min)



14. Filler : Non hygroscopic with FRLS property

15. Temperature Range : Up to 85 °C

16. Insulation at 200 C : 100 MΩ/Km [Min]

17. Capacitance at 800 Hz : 200 nf/km

18. Cross talk : 60 dB

19. Attenuation : 1.2 dB/Km

20. Codes & Standards :

- a. IEC 332-1
- b. ANSI MC 96.1
- c. IS-8784-1987

21. Tests :

- a. Oxygen Index : Min.29 at roomtemp. (ASTM-D-2863)
- b. Acid Gas Gen. : Max.20% by weight as per IEC 754 Part-I
- c. Temp Index : Min 250 °C at 210 oxy. Ind. (ASTM-D-2863)
- d. Smoke Density Rating : Max.60%(ASTM-D-2843).
- e. Flammability Test : as per IEC 332 Part-I /IEEE-383
- f. Swedish Chimney Test - SS-424-1475 F3
- g. High voltage test
Core to core- 2.0 KV for 1 min.
Core to screen- 2.0 KV for 1 min.
- h. Insulation Resistance 100 MΩ /Km Min
- i. Rodent & Termite repulsion test(Presence of lead shall be confirmed)

22. Conductor material & sheath color for thermocouple cable as per ANSI MC96.1

Cable Type	Colour of Outer sheath	Wire	Colour of Insulation	Conductor material
KX	Yellow	Positive	Yellow	Nickel / Chromium
		Negative	Red	Nickel / Aluminum
JX	Black	Positive	White	Iron
		Negative	Red	Constantan
RX	Green	Positive	Black	Copper

		Negative	Red	Copper Nickel
--	--	----------	-----	---------------

23. Durable printed or embossed numbering at regular interval of 50mm shall be provided for identification of pairs. Each core printed with number or numbered binder tape shall be provided on each pair.

1.2 Instrumentation multi Paired Signal Cable

01. Conductor type	: Stranded (7) annealed tinned copper
02. Conductor size	: 0.5
03. Conductor resistance	: 39 Ω
04. Conductor Insulation	: HR PVC Type-C (IS-5831, 1984) 0.6 mmthick
05. Operating Voltage	: 650V
06. Twisting	: Twin twisted with lay of 60 mm
07. Twisting Direction	: All pairs in the same direction. Lapped to form bunch with Mylar tape.
08. Screen (Pair & Overall)	: Aluminium Mylar tape with a thickness of 28 μ m. (min.) for individual pair screen and 60 μ m. (min.) for overall screen with 100% coverage and 25% overlapped edges. Over the individual pair screening tape two laps of 0.05 mm thick (min.) polyester tape shall be applied with minimum overlap of 25%. Metallic side of the screen shall be in contact with drain wire. • Analog signals- Individual pair & overall shield to be considered. • Binary signals- overall shield to be considered.
09. Drain wire	: Annealed tinned copper wire, stranded. Size 0.5 Sq. mm. (No. of strands / size: - 7 / 0.3mm)
10. Inner Sheath	: Extruded FRLS PVC (anti-rodent, anti-termite & moisture resistant properties) HR PVC Type ST2 of IS-5831, 1984



Thickness as per IS-1554, Part-I 1976

- | | |
|----------------------------|--|
| 11. Rip Cord | : Nonmetallic under sheath |
| 12. Armouring | : GI wire / strip as per IS 3975 |
| 13. Outer Sheath | : Extruded FRLS PVC (anti-rodent, anti-termite & moisture resistant properties)
HR PVC Type ST2 of IS-5831, 1984
Thickness 1.8mm (Min) |
| 14. Filler | : Non hygroscopic with FRLS property. |
| 15. Temperature Range | : 85 °C |
| 16. Insulation at 20 Deg.C | : 100 MΩ/Km [Min] |
| 17. Capacitance at 800 Hz | : 120 nf/km |
| 18. Cross talk | : 60 dB |
| 19. Attenuation | : 1.2 dB/Km |
| 20. Codes & Standards | : |
| a. IPCEA-S-61-402 | |
| b. BS 5308 | |
| c. IEC 332-1 | |
| d. ASTM-B-33 | |
| e. IS-8130-1984 | |
| f. IS 1554 Part-1 | |
| g. IS 10810 | |
| 21. Sheath color | : Inner- Black and Outer- Gray |
| 22. Tests | : |
| a. Oxygen Index | : Min.29 at room temp.(ASTM-D-2863) |
| b. Acid Gas Gen. | : Max.20% by weight as per IEC 754 Part-I |
| c. Temp Index | : Min 250 °C at 21Oxy.Ind. (ASTM-D-2863) |
| d. Smoke Density Rating | : Max.60%(ASTM-D-2843). |
| e. Flammability Test | : as per IEC 332Part-I |

- f. Swedish Chimney Test-SS-424-1475F3
 - g. Insulation Resistance 100 MΩ / KmMin
 - h. High voltage test
 - Core to core- 2.0 KV for 1 min.
 - Core to screen- 2.0 KV for 1 min.
 - i. Rodent & Termite repulsion test(Presence of lead shall be confirmed)
23. Color of pair/core for Instrumentation Cable (As per IS-9938)

1 st Pair	Blue, Red
2 nd Pair	Gray, Yellow
3 rd Pair	Green, Brown
4 th Pair	White, Black

Above 4 Pairs, 4 Pairs making a unit shall have indelible printed color coded bands like Pink for 1st unit, Orange for 2nd unit and Violet for 3rd unit and soon. In addition band marking, for example single band for 1st. unit, doubleband for 2nd. Unit and so on, shall be provided on each conductor for identification of unit. Band marking on individual core shall be provided at regular intervals not exceeding 50 mm.

Cables near high temperature zone shall be capable of withstanding high temperature and terminated in junction box / panel in normal temperature zone. Teflon insulated and sheathed thermocouple extension cables and copper conductor cables shall be used in high temperature zone. Conductor and sheath shall be extruded FEP (Teflon) as per VDE 0207 Part 6 and ASTM D2116. These cables shall be pair, multipair, and twisted & shielded.

1.3 CONTROL CABLES

1100 V grade 85°C continuous rating under normal condition and 160°C under short circuit condition rating HRPVC Control cable (YWY) conforming to following requirement and in line with IS:1554, IS:8130, IS:5831 and IS:3975.

1. Conductor : Stranded, non-compacted & circular, high conductivity annealed plain copper, generally conforming to IS: 8130.
2. Insulation : Extruded HRPVC type-C compound conforming to IS: 5831. The minimum volume resistivity of insulation shall be 1×10^{14} ohm-cm at 27°C and 1×10^{11} Ω cm at 85°C.
3. Core Identification : By color coding and numbering at interval of 100mm or less



4. Inner sheath : Extruded HRPVC compound conforming to type ST2 FRLS of IS: 5831 for multicore cables. Single core cables shall have no inner sheath. Filler shall be of same material as of inner sheath i.e. ST2.
5. Armour : Galvanized single round steel wire for twin and multicore cables.
6. Overall sheath : Extruded FRLSH HRPVC compound conforming to type ST2 of IS: 5831.
7. Drum : Conforming to IS: 10418 (Wooden drum)

1.4 LV POWER CABLES [1.1KV (XLPE TYPE)]

1100 V grade, 90 °C continuous rating under normal condition and 250°C under short circuit condition rating, XLPE heavy duty, power cable conforming to following requirement and in line with IS 7098 Part-I, IS 8130 & IS 5831 and IS 3975.

1. Conductor : Stranded and compacted plain aluminium of grade H2 and class 2 stranded, high conductivity annealed plain copper for cable sizes up to 2.5 mm² conforming to IS: 8130.
2. Insulation : Extruded cross-linked polyethylene (XLPE) conforming to IS: 7098 (Part-1)
3. Core Identification : By color coding
4. Inner Sheath : Extruded HRPVC FRLS compound conforming to type ST2 of IS: 5831 for multicore cable. Single core cables shall have no inner sheath. Filler shall be of same material as of inner sheath i.e. ST2
5. Armour : Galvanized single round steel wire armour for twin and multicore cables. Non-magnetic hard drawn aluminum single round wire conforming to H4 of IS-8130 latest for single core cables
6. Overall Sheath : Extruded FRLSH HRPVC compound conforming to type ST2 of IS: 5831.
7. Drum : Conforming to IS-10418 (Wooden drum)

1.5 Cable Tray

Pre-fabricated perforated & covered cable trays of average 3 meters length and of minimum dimension 100X35X3 mm shall be used. The tray shall be of minimum 100 mm wide, fabricated

from not less than 2 mm thick sheet steel and of vertical edge of height not less than 35 mm on both sides. Cable trays shall be hotdip galvanized after fabrication. Minimum value of average mass of zinc coating shall be 460 gm/sq.mt. as per IS: 4759. Supporting galvanized brackets shall be provided at regular intervals for fixing the trays.

- | | | |
|----------------|---|----------------------|
| 1. Material | : | Mild steel, slotted |
| 2. Thickness | : | not less than 2.0 mm |
| 3. Finish | : | Hot dip galvanized |
| 4. Perforation | : | As per MFR standard |
| 5. Cover | : | Suitable for tray |

1.6 Cable Gland

- | | | |
|-----------------|---|--|
| 1. Type | : | Double compression |
| 2. Entry Thread | : | NPT / ET |
| 3. Material | : | Brass |
| 4. Finish | : | Cadmium / Nickel Plated. |
| 5. Protection | : | IP 54 or better |
| 6. Accessories | : | Neoprene gasket, locknuts, reducers etc. |



ANNEXURE-W

1.0 LOCAL CONTROL PANELS/CABINETS

1.0.01 LocalControl panels (PLC/Relay based) shall be as specifiedbelow.

1.0.02 The cabinet mounted equipment's shall be fully assembled, installed inmounting racks, wired and fully tested as per specification requirements andOwner approved drawings prior to shipment to the project site.

1.0.03 The vendor shall ensure that the cabinets are complete & ready for installationbefore dispatch from manufacturing works. The installation work at projectsite for these cabinets shall only involve connections through multi-pair cablesfrom marshalling cabinets (wherever provided) to system cabinets and intercabinet/cabinet to Control Desk/ Back up Panel.

1.0.04 All electronic cards, network components, power supply modules etc. locatedshall be suitably housed in cabinets and shall be neatly arranged in sub-racks.Network components shall be visible in door closed condition (e.g.Glass doors etc.) as approved by Purchaser.

1.0.05 Vendor shall design the cabinet internal arrangementand cablegland plate such that all the cables entering or leaving the cabinet can beproperly glanded in the gland plate.

1.0.06 The packaging density of panels shall be such that the temperature rise withinthe panels shall never exceed 10°C above ambient even under worstoperating conditions. Cooling Fans shall be provided wherever required andthis shall be of industrial grade.

1.0.07 TECHNICAL PARTICULARS

1. Material ofConstruction : Cold Rolled Coal Annealed (CRCA) steelsheet
2. Thickness of Sheet :
 - a. 2.0 mm for faces supportinginstruments / terminals
 - b. 1.6 mm for other sides and top
3. Construction : Welded throughout as per approvedNational Standards
4. Post welding operation :
 - a. Grounding of all welds tosmoothness
 - b. Rounding of corners
5. Panel height : 2300 mm (approx)
6. Corners : 7 mm inner radius



7. Dimensional Tolerances :
 - a. In height & length - 3 mm
 - b. In height between adjacent sections - 2 mm
 - c. Total for a group - 6 mm
8. Doors : Double, recessed, turned back edges, full height front & rear
 - a. Thickness of Sheet : 2 mm
 - b. Hinges : Stainless steel
 - c. Door latches : Three point type
 - d. Door gaskets : Neoprene rubber on fixed frame to result dust proof/weatherproof enclosure
 - e. Opening of the doors : Outward
 - f. Louvers : With removable wire mesh to ensure dust and vermin proof
9. Gland plates : Removable in sections - 4 mm thick (bottom)
10. Cable entry : Bottom
11. Hardware :
 - a. Anti-vibration pad - 15 mm
 - b. Predrilled base channel ISMC - 100 or equivalent for all sides
 - c. Stainless steel buff-finished 2 mm thick kick plate for all sides
 - d. Stainless steel scratch strips along desk edges fixed with pan-head recessed screws
 - e. Rubber strips to ensure air tightness between kick plate and finished floor
 - f. Lifting hook / Eye bolt
 - g. Drawing pocket
 - h. Door switch, lamps, thermostat, heaters and industrial grade cooling fans, illumination fixtures.
12. Name Plate : Both at front and back surface of the panel
13. Fixing of name plate : Stainless steel pan head screws
14. Name plate material : Laminated phenolic (3 layers)
15. Lettering : Black with white engraved
16. Mounting of terminal blocks : Vertical angle support bracket tack welded on sheet steel plate, screwed on internal wall of enclosure

2.0 LOCAL INSTRUMENT RACK (LIR) / LOCAL INSTRUMENT ENCLOSURE (LIE)

- 2.0.01** Devices (Transmitters/ Switches) located in the field shall be suitably grouped together to the extent possible and installed in the LIE (Closed Rack).



- 2.0.02** Enclosure shall be factory prefabricated & painted and shall complete with internal piping, tubing, manifold, isolation valves, blowdown valves, integral junction box, illumination etc. No more than six instruments shall be grouped in a single rack / enclosure.
- 2.0.03** Enclosures shall be installed above the tapping points for air, flue gas and coal air mixture application whereas for applications such as for water and steam, racks to be installed below the source point.
- 2.0.04** Attention shall be paid in the layout to avoid air traps in liquid piping and water accumulation in air / gas piping.
- 2.0.05** Enclosures used for furnace, flue gas and air application shall be provided with intermittent & continuous air purging.
- 2.0.06** Welding of impulse lines shall comply with the provisions of the latest applicable ANSI Code for Pressure Piping. Earth stud shall be furnished at rack for safety grounding.

2.1 LOCAL INSTRUMENT ENCLOSURE (LIE)

- 2.1.01** Enclosure shall be free standing type. Racks shall be adequately reinforced to ensure true surfaces and to provide support. Major load - bearing posts shall be suitably supported by gusset plates or moment members.
- 2.1.02** Enclosure outer shall be constructed from at least 3 mm thick steel plate and epoxy painted to shade gray. Base frame shall be made of ISMC- 100 and black colour finish.
- 2.1.03** 2" NB galvanized pipes shall be laid horizontally and supported at two end channels to mount transmitters at accessible height. Center posts or any member, which would reduce access, shall be avoided.
- 2.1.04** Double leaf interlocking front opening doors with three point locking shall be provided and shall be arranged for maximum possible access to the interior. Key shall be of identical for all enclosures.
- 2.1.05** Doors shall have concealed quick removal type pinned stainless steel hinges and locking handles. Gaskets shall be used between all mating sections to achieve dust and weather proof enclosure rated for IP-65 including the internal junction box. All enclosures shall have access doors on front side.
- 2.1.06** Removable type bulkhead plates of thickness not less than 6 mm shall be mounted at the racks with suitable high temperature gasket. Impulse lines within the enclosures shall be properly clamped.



- 2.1.07** All internal wirings between the instruments and junction box shall run through flexible conduits. No exposed wirings within transmitter racks both open and closed type, is admissible.
- 2.1.08** Racks shall have a common blowdown drain header, which will connect individual instrument blowdown line after suitable pressure breaking through regulating globe type blowdown valves. Covered funnels shall be used for saturated liquid and steam service, whereas, open funnels may be used for cold liquid services. Header (2" NB ASTM A 106, Sch-80 Gr. C) shall be suitably sloped and shall have one end flanged and extending beyond the rack for connection to plant drain header.
- 2.1.09** Each rack shall be provided with one receptacle, light fixtures with wire guard and one lighting switch each at instrument & Junction box compartments with wire guard. Lighting switches may be door actuated & mounted inside the panel. Outlet box, switch box and device covers shall be of galvanized stamped steel. Light switches and receptacles shall be installed inside the enclosure on the wall near the latch side of the enclosure door. Light fixtures shall be installed on the ceilings of the enclosures.
- 2.1.10** Power supplies for miscellaneous devices shall be provided with MCB located within the enclosures. MCB shall be mounted in fuse blocks. Nameplates shall be furnished above the MCB blocks, identifying the devices being served.
- 2.1.11** Vibration dampeners shall be installed for supporting each enclosure. The loading at each corner of the enclosure shall be determined by actual test weighting when construction is complete to determine the correct length of each dampener for proper loading of the dampener in accordance with manufacturer's recommendations.

3.0 JUNCTION BOX

- | | |
|----------------------|---|
| 1. Type of Enclosure | : Dust tight & weatherproof conforming to IP 65 |
| 2. Material | : 3 mm fiberglass reinforced polyester (UV stabilized) |
| 3. Type of Cover | : Solid unhinged with retention chain / Screwed at all four corners |
| 4. Paint | : |
| a. Exterior | : Opaline green shade 275 of IS: 5 |
| b. Interior | : Brilliant Glossy White. Surface / Two (2) inch Pipe stanchion |
| 5. Mounting | : (At a dry compartment at one side of the enclosure / rack with front opening type door) |
| 6. Cable Entry | : 3 mm (min) Bottom / side Gland plate |
| 7. Gasket | : Neoprene |



- 8. Grounding : Brass earth lug with green screw head External-2 nos, Internal-1no. (M6)
- 9. Number of DrainHoles : Two at bottom capped
- 10. Identification : Label for JB and Tags for cable
- 11. Accessories :
 - a. Rail mounted cage clamp typescrew less terminals (suitable for conductor size up to 2.5sq.mm of suitable voltage grade) with markers and 20% spare terminals.
 - b. Cable gland (Brass) & raceways.
 - c. Ferrules & lugs (Brass).
 - d. Aluminum back panel.
 - e. Canopy at top.
 - f. Mounting brackets.
 - g. Bolts and nuts made of brass etc.

4.0 ERECTION MATERIALS

4.0.01 General Technical Requirements

This section provides the general technical guidelines for the erection materials for instruments. All erection materials shall be of good quality and conform to the operating environment of the corresponding instrument. However, any item required for erection of vendor supplied system but not categorically indicated in this section, shall be supplied by the vendor and all these items shall conform to International / National standards / codes.

4.0.02 Process Hook Up Accessories & specification

Material and rating of the hook up items shall suit the piping and fluid condition. Hook up materials shall be IBR certified for applicable cases. Vendor shall furnish hook up drawings and the drawings for open racks & closed racks for purchaser's approval.

I. Seamless Stainless Steel Pipe

- a. Reference : ASTM A-312 TP 316
- b. Material Grade : TP 316
- c. Type : Seamless / Plain end
- d. Size : As applicable (e.g. 1/2" NB etc)
- e. Schedule : 40
- f. Standard Length : 5 meter

II. Stainless Steel Pipe Fittings

- a. Reference : ASTM A-182 F 316 / ANSI B16.11
- b. Type : Forged
- c. Rating : 3000 lbs / 6000 lbs / 9000 lbs
- d. Size : To suit related SS pipe.
- e. End connection : Generally socket weld



- f. Type of Fittings : Reducing coupling, male-female reducer, straight coupling, equal tee, three piece union, elbow, cap etc.

III. Seamless Stainless Steel Tube

- a. Reference : ASTM A-213 , ASTM A-249 or ASTM A-269
b. Material Grade : TP 316
c. Size : As applicable (e.g. ½" OD X 0.083" wall thickness / ¼" OD X 0.049" wall thickness etc.)
d. Type : Cold drawn annealed, pickled, passivated, descaled, hydraulically cleaned seamless tube.
e. Properties : The tube shall be free from scratches and suitable for bending and capable of being flared by hardened and tapered steel pin. The expanded tube shall show no crack or rupture. Hardness shall be RB 80.
f. Test Pressure : 400 Kg/Sq. cm (minimum)
g. Tolerance thickness : ± 0.13 mm for outside diameter ± 15 % for wall
h. Standard Length : 5 meter
i. Test : Flare, Hardness, Ball and Bubble Test

IV. Stainless Steel Tube Fittings

- a. Reference : ASTM-A-182
b. Type : Double ferrule double compression
c. Material : 316 Stainless steel forged
d. Ferrule : 316 Stainless Steel
e. Type of Fittings : Male / female connector, elbow, cross / equal tee, straight connector, bulkhead union, ferrule etc. as required to suit installation.
f. Size : To suit SS tubing and NPT end connection

V. CS Pipe

- a. Reference : ASTM-A 106 Gr. C
b. Material : Cold drawn seamless black C.S.
c. Type : Seamless / Plain ends
d. Size : As applicable (e.g. ½" NB etc)
e. Schedule : 80, 160, XXS as required
f. Standard Length : 5 meter

VI. CS Pipe Fittings

- a. Reference : ASTM-A 105 / ANSI B16.11
b. Type : Forged
c. Rating : 3000 lbs / 6000 lbs / 9000 lbs
d. Size : Suitable to related C.S. Pipe
e. End connection : Generally socket weld
f. Type of Fittings : Reducing coupling, male-female reducer, straight coupling, equal tee, three piece union, elbow, cap etc.

**VII. AS Pipe**

- a. Reference : ASTM-A 335 P22 AS PER ANSI B 36.10
- b. Material : Cold drawn seamless A.S.
- c. Type : Seamless / Plain ends
- d. Size : As applicable (e.g. ½" NB etc)
- e. Schedule : XXS
- f. Standard Length : 5 meter

VIII. AS Pipe Fittings

- a. Reference : ASTM-A 182 F22 AS PER ANSI B 16.11
- b. Type : Forged
- c. Rating : 9000 lbs
- d. Size : Suitable to related AS Pipe
- e. End connection : Generally socket weld
- f. Type of Fittings : Reducing coupling, male-female reducer, straight coupling, equal tee, three piece union, elbow, cap etc.

IX. GI Pipe

- a. Reference : IS-1239, Part-I
- b. Type : Medium grade, threaded at both ends protected with end caps
- c. Material : Continuous ERW galvanized MS pipe
- d. General : Pipe shall be galvanized both inside and outside
- e. Size : As applicable (e.g. 1/2"/3/4"/1" etc.)

X. GI Pipe Fittings

- a. Reference : IS-1239, Part-II for material, dimension, thread etc.
- b. Style : Threaded
- c. Type of Fittings : Equal tee, three piece union, unequal tee, straight socket, 90 Deg. elbow, reducing socket cap. Etc. to suit installation.
- d. Size : Suitable to related GI Pipe.

XI. Carbon Steel Globe Valve

- a. Reference : ASTM A-105
- b. Type : Globe
- c. Construction : Forged Body Cadmium Plated
- d. End Connection : As applicable (e.g. ½" Socket Weld etc.)
- e. Rating : CL. 800 / CL. 2500
- f. Material :
 - Body - Carbon steel
 - Stem - Hardened Steel
 - Plug - AISI 316 SS
 - Seat- Stainless steel stellited
- g. Packing : Teflon / Grafoil as required
- h. Yoke : ASTM A105

- i. Hand wheel : Carbon steel
- j. Design standard : As per ANSI B 16.34

XII. Stainless Steel Globe Valve

- a. Reference : ASTM A-182 F316
- b. Type : Globe
- c. Construction : Forged Body
- d. End Connection : As applicable (e.g. ½" Socket Weld etc.)
- e. Proof Pressure : 400 Kg/Cm²
- f. Material :
 - Body - Stainless steel
 - Stem - Hardened Steel
 - Plug - AISI 316 SS
 - Seat- Stainless steel stellited
- g. Packing : Teflon as required
- h. Yoke : ASTM A182 F316
- i. Hand wheel : Carbon steel
- j. Design standard : As per ANSI B 16.34

XIII. Alloy Steel Globe Valve

- a. Reference : ASTM A-182 F22
- b. Type : Globe
- c. Construction : Forged Body
- d. End Connection : As applicable (e.g. ½" Socket Weld etc.)
- e. Rating : CL. 2500
- f. Material :
 - Body - Alloy steel
 - Stem - Hardened Steel
 - Plug - AISI 316 SS
 - Seat- Stainless steel stellited
- g. Packing : Grafoil as required
- h. Yoke : ASTM A182 F22
- i. Hand wheel : Carbon steel
- j. Design standard : As per ANSI B 16.34

XIV. Instrument Valve Manifold

- a. Type :
 - Two valve manifold
 - Five valve manifold
- b. Mounting : Remote 2" Pipe Mounting / Transmitter Rack
- c. Construction : Single block (bar stock)
- d. Material : Forged body and bonnet AISI 316 stainlesssteel
- e. Ports : Manufacturer's standard(e.g. 1/2 " NPT (F) etc.)
- f. Rating : 420 Kg/Sq. cm at ambient
- g. Operating temperature : (-)30 to (+)170 Deg C



PROJECT: DN 101

h. Packing	: PTFE Wafer
i. Seat & Stem	: AISI 316 SS
j. Plug	: AISI 316 SS free to turn on stem / 17-4 PH
k. Handle Bar	: AISI 316 SS
l. Connection	: Straight
m. Accessories	: Plugs for all ports, Mounting Bracket , bolts ,nuts

C&I Inputs for Selection of Mechanical Equipments

1. Solenoid valves shall fulfil the following requirements:
 - a. Type 2/3/4 way SS 316/Forged Brass (depending on the application subject to Employer's approval during detailed Engg.)
 - b. Power supply: 24 V DC + 10%.
 - c. Plug and socket electrical connection.
 - d. Insulation: Class 'H'
2. All Control valves to be provided with SMART positioner as per the requirements indicated in the Annexure R



Data Sheets

PERFORMANCE DATA - SCR REACTOR			
S.No	Description	Unit	Data to be filled
1.1	General		
1	Unit load range for NOx guarantee		
2	De-NOx efficiency with newly installed catalyst	(%)	
3	De-NOx efficiency at the end of catalyst life	(%)	
4	Activity of newly installed catalyst		
5	Catalyst Activity at the end of catalyst life		
6	Catalyst Pluggage at the end of catalyst life	(%)	
7	Loss of catalyst material at the end of catalyst life	(%)	
1.2	Temperature (deg. C)		
1	Gas temperature at SCR reactor inlet	deg. C	
2	Gas temperature at SCR reactor outlet	deg. C	
3	Temperature of ash collected in SCR reactor ash hopper (if applicable)	deg. C	
4	Temperature of ash collected in duct ash hopper (if applicable)	deg. C	
5	Temperature of ammonia-air mixture at ammonia injection grid inlet	deg. C	
6	Maximum catalyst heating up rate (deg C/min)	deg. C	
7	Maximum catalyst cooling down rate (deg C/min)	deg. C	
8	Minimum flue gas temperature for continuous SCR operation with ammonia injection	deg. C	
1.3	Pressure (mmwc)		
1	Gas pressure at SCR reactor inlet	mmwc	
2	Gas pressure at SCR reactor outlet	mmwc	
1.4	Differential pressure (mmwc)		
1	Gas pressure drop across SCR reactor with new catalyst	mmwc	
2	Gas pressure drop across SCR reactor at end of catalyst life	mmwc	
3	Gas pressure drop from economizer outlet to APH inlet with new catalyst	mmwc	
4	Gas pressure drop from economizer outlet to APH inlet at end of catalyst life	mmwc	



1.5	Flow rate (Nm³/s)		
	Gas flow rate at SCR reactor inlet	Nm ³ /s	
	Gas flow rate at SCR outlet	Nm ³ /s	
1.6	Flue gas constituents		
1	NO _x concentration at SCR reactor outlet	mg/Nm ³ @ 6% O ₂ dry basis	
2	Ammonia Slip at reactor outlet with new catalyst	ppm	
3	Ammonia Slip (ppm) at reactor outlet at end of catalyst life	ppm	
4	SO ₂ to SO ₃ conversion rate in SCR with new catalyst (%)	%	
5	SO ₂ to SO ₃ conversion rate in SCR at end of catalyst life(%)	%	
6	Molar ratio NH ₃ /NO _x at reactor inlet		
7	NH ₃ /Air ratio at Ammonia Injection grid inlet		
8	Conversion of elemental mercury to oxidized mercury (%) (if measured)	%	
1.7	Velocity (m/s)		
1	Gas velocity in SCR reactor inlet duct	m/s	
2	Gas velocity through SCR reactor	m/s	
3	Gas velocity in SCR reactor outlet duct	m/s	
1.8	Supplementary Data for SCR System		
1	Water requirement i) DM water ii) Service Water iii) Potable water		
2	Service air		
3	Instrument air		
4	Super-heated steam		
5	Number and electrical rating of AC power supply feeders for each control instrumentation system in Bidder's scope		
6	Schedule of power consumption		



PERFORMANCE DATA - AMMONIA SYSTEM

S.No	Description	Unit	100% TMCR Design Coal	BMCR Design Coal	HP Out Design Coal	60 TMCR Design Coal	BMCR Worst Coal	TMCR Worst Coal
	Ammonia Handling System							
1.1	Temperature (deg. C)	deg. C						
	Ammonia forwarding pump suction temperature at minimum ambient temperature							
1		deg. C						
	Ammonia forwarding pump discharge temperature at minimum ambient temperature							
2		deg. C						
3	Temperature of ammonia at vapouriser inlet	deg. C						
4	Temperature of ammonia at vapouriser outlet	deg. C						
5	Temperature of steam to ammonia vapouriser	deg. C						
6	Temperature of ammonia at air-ammonia mixer inlet	deg. C						
7	Temperature of dilution air at air-ammonia mixer inlet	deg. C						
1.2	Pressure (mmwc)							
	Ammonia storage tank pressure at minimum ambient temperature	mmwc						
2	Ammonia forwarding pump suction pressure at minimum ambient temperature	mmwc						
3	Ammonia forwarding pump discharge pressure at minimum ambient temperature	mmwc						
4	Pressure of ammonia at vapouriser inlet	mmwc						
5	Pressure of ammonia at vapouriser outlet	mmwc						
6	Pressure of ammonia at air-ammonia mixer inlet	mmwc						
7	Pressure of dilution air at air-ammonia mixer inlet	mmwc						
8	Pressure of ammonia-air mixture at ammonia injection grid inlet	mmwc						
9	Ammonia pressure drop from vapouriser outlet to air-ammonia mixer inlet	mmwc						
1.3	Flow rate (Kg/hr)							
1	Ammonia flow rate at vapouriser outlet	Kg/hr						
2	Ammonia flow rate at air-ammonia mixer inlet with new catalyst	Kg/hr						
3	Ammonia flow rate at air-ammonia mixer inlet at end of catalyst life	Kg/hr						
4	Dilution air flow rate at air-ammonia mixer inlet	Kg/hr						
5	Ammonia-air flow rate through ammonia injection grid	Kg/hr						
1.4	Ammonia Piping							
1	Pipe size							
2	Material							
3	Length							
1.5	Foundation details of Ammonia tanks							



EQUIPMENT DETAILS FOR SELECTIVE CATALYTIC REDUCTION

S.No	Description	Unit	Data to be filled
1.1	General		
1	Manufacturer of SCR System		
2	Manufacturer's model number		
3	No. of SCR reactors per steam generator		
4	Capacity of each SCR reactor (% of BMCR FG flow)		
5	Reactor Width (m)	m	
6	Reactor depth (m)	m	
7	Reactor height (m)	m	
8	Total no. of catalyst layers / reactor		
9	No. of catalyst layers / reactor in service		
10	Height between two adjacent catalyst support levels (m)	m	
11	Height between top edge of catalyst module and bottom edge of the immediately upper catalyst support level (m)	m	
12	Number of catalyst modules and elements per module for each layer		
13	Catalyst pluggage considered for catalyst volume determination		
14	Total Catalyst volume per reactor (m3)	m3	
15	Catalyst volume per reactor per layer (m3)	m3	
16	Total Catalyst surface area per reactor (m2)	m2	
17	Catalyst weight per layer / per reactor (MT)	MT	
18	Percentage of Catalyst pluggage (filled with ash) considered for support structure design (MT)	MT	
19	Space Velocity (m3/s/m3)	m3/s/m3	
20	Area Velocity (m3/s/m2)	m3/s/m2	
21	Type of Static mixer for ammonia and flue gas mixing		
22	No. of nozzles in ammonia Injection Grid		
23	Type and material of nozzle		
24	No. of catalyst de-dusting levels/reactor		
25	Type and number of catalyst de-dusting devices/layer/reactor		
26	Medium and its consumption rate for catalyst de-dusting		
27	Guaranteed power consumption of SCR system for one steam Generator at the guarantee point (KW)	KW	
28	Capacity of Economiser bypass system (if in Vendor scope)		
29	Capacity of SCR bypass system (if in Vendor scope)		
30	Proposed standard for conducting the performance tests		
31	Type of catalyst handling device		
32	Capacity of catalyst handling device (MT)	MT	
1.2	SCR reactor casing		
1	Material		
2	Casing wall thickness (mm)	mm	
3	Design pressure (mmwc) (+ve & -ve)	mmwc	
4	Design temperature (deg C)	deg C	
5	Max. pressure withstand capacity		
6	Max. temperature withstand capacity and duration		
7	No. of catalyst support levels		
8	Maximum load bearing capacity of each catalyst support layer(MT)	MT	
9	Number of inspection doors/layer		
10	Dimensions of access openings of inspection doors (mm x mm)	mm xmm	
1.3	Catalyst		
1	Supplier name		
2	Type of catalyst		
3	Catalyst material chemical composition		
4	Dimension of each catalyst module and element (L x W x H) (mm)	mm	
5	No. of catalyst element per module		
6	No. of plates in each element box for plate type catalyst		
7	No. of catalyst sub-layer per module		
8	Catalyst pitch (mm)	mm	
9	Catalyst plate thickness (mm)	mm	
10	Catalyst Substrate material		
11	Substrate thickness (mm)	mm	
12	Catalyst plate dimension for plate type catalyst (HXW) (mm)	mm	
13	Catalyst Porosity (%)	%	
14	Specific surface area (m2/m3)	m2/m3	
15	Specific Weight (Kg/m3)	Kg/m3	
16	Whether module contains a removable sample element		
17	Maximum Continuous Operating Temperature (deg C)	deg C	
18	Minimum Continuous Operating Temperature (deg C)	deg C	

19	Heating up rate (max.)(oC/min)	oC/min	
20	Cooling down rate (max.)(oC/min)	oC/min	
21	Type of catalyst erosion protection (if applicable)		
22	Minimum chemical life (months)	months	
23	Minimum mechanical life (months)	months	
24	Total Number of sample catalyst for two Reactor		
25	Space velocity (m3/h/m3)	m3/h/m3	
26	Area velocity (m3/h/m2)	m3/h/m2	
27	Physical properties of Catalyst		
	Geometry		
	Pitch		
	Plate thickness		
	Compressive Strength		
	Bend Strength		
	Bond Strength		
	Abrasion Resistance		
	Surface Area (m2/m3)	m2/m3	
	Pore Volume (m2/g)	m2/g	
1.4	Ammonia Injection Grid		
1	Type of Ammonia Injection grid		
2	Control of ammonia Injection (Zonal / overall)		
3	No. of nozzles		
4	Material of the nozzle		
5	Material of the ammonia pipes/manifold		
6	Nozzle size (mm)	mm	
7	Nozzle pitch (mm)	mm	
8	Nozzle spray direction		
9	Velocity at nozzle outlet (m/s)	m/s	
10	Size and weight of pipe frames (diameter and schedule) Vertical frames and Cross frames		
11	Drawing reference No		
1.5	Catalyst De-dusting System		
1	Type Sonic Horn/ Air Cannon/Soot Blower		
2	Manufacturer		
3	Location (Outdoor)		
4	Cleaning medium		
5	Parameters of cleaning medium		
	Pressure	(Kg/cm2) (abs)	
	Temperature (deg.C)	deg C	
	Flow rate (m3/s)	m3/s	
6	Source of cleaning medium		
7	De-dusting Frequency per day		
8	Number of De-dusting device/layer		
9	Total time required for one complete cycle of De-dusting operation (min)	min	
10	Depth of penetration (mm)	mm	
11	Cleaning radius/angle		
12	Effective area cleaned by one De-dusting device (m2)	m2	
13	Reduction in flue gas pressure drop across SCR reactor after each de-dusting cycle (mmwc)	mmwc	



1.6	For Sonic Horn(if applicable)		
1	Horn Material		
2	Diaphragm Material		
3	Diaphragm Life (yrs)	years	
4	Output power level (dB) and frequency (Hz)	Hz	
5	Maximum operating temperature (oC)	deg C	
6	Weight of each sonic horn (Kg)	kg	
1.7	For Air Cannon(if applicable)		
1	Nozzle Material		
2	Compressed air storage tank Material		
3	No. of ports		
4	No. of compressed air storage tanks/layer		
5	Capacity of each compressed air storage tank (Nm3)	Nm3	
1.8	For Soot Blower		
1	Type of Electric Drive Dual/Single Electric Drive		
2	Material		
	Lance / Swivel tube		
	Nozzle		
3	Motor rating (kW)	KW	
4	Location drawing of De-dusting devices		
5	Description of panels & system equipment offered		
6	Reference drawing Nos.		
1.8	Dilution Air System		
1.8	Dilution Air Fan		
1	Manufacturer		
2	Type Dual/Single Electric Drive		
3	Number and configuration of dilution air fan per steam generator		
	Capacity Max Flow (m3/sec)Head (mmwc)		
	Associated temp. (deg C)		
	Density (Kg/m3)		
4			
5	Source of air supply		
6	Max speed of fan (rpm)	rpm	
7	Fan efficiency at 100% TMCR	%	
8	Auxiliary power consumption at 100% TMCR (kW)	KW	
9	Overall dimensions		
10	Motor rating (KW)	KW	
11	Total weight of fan and motor (tonnes)	tonnes	
12	Method of lubrication		
	For fans		
	For motors		
13	Mode of air flow control adjustment		
14	Impeller diameter (mm)	mm	
15	Shaft diameter (mm)	mm	
16	Material of construction		
	Casing		
	Impeller blades		
	Shaft		
1.9	Dilution Air Heater (if applicable)		
1	Manufacturer		
2	Type		
3	Number and configuration per steam generator		
4	Auxiliary power consumption at 100% TMCR (kW)	KW	
5	Heater rating (KW)	KW	
6	Voltage level (V)	V	
7	Estimated life of heating element (years)	years	
1.10	Ash Hoppers		
	For SCR Reactor (if applicable)		
1	No. per SCR reactor		
2	Material		
3	Plate thickness (mm)	mm	
4	Side angle	degrees	
5	Valley angle	degrees	
6	Storage capacity of each hopper (hours)	hours	
7	Volumetric storage capacity of each hopper (m3)	m3	
8	No. of access doors per hopper		
9	Access door dimensions (mm x mm)	mmxmm	
10	Hopper dust level detectors		
	a) Number per hopper		
	b) Type		
11	Ash collection rate (Kg/hr)	kg/hr	

1.11	Ammonia Unloading, Storage and Forwarding System		
1	Name of overall system designer		
2	Design codes and standard		
1.12	Truck Tank Unloading Station		
1	Manufacturer		
2	Type of connections		
3	Hose Material		
1.13	Ammonia storage Tank		
1	Type of Ammonia storage tanks Horizontal		
2	No. and configuration of ammonia storage tanks		
3	Design code		
4	Storage capacity (days)	days	
5	Operating pressure	(Kg/cm2) (abs)	
6	Design pressure (Kg/cm2) (abs) (+ve & -ve) vii) Operating Temperature (deg. C)	deg C	
7	Design Temperature (deg. C)	deg C	
8	Tank Volume (m3)	deg C	
9	Maximum storage volume (m3)	m3	
10	Vapour space in tank (%)	%	
11	Hydraulic test pressure (if required)	(Kg/cm2) (abs)	
12	Shell thickness (mm)	mm	
13	Corrosion allowance		
14	Tank diameter (mm)	mm	
15	Tank length (mm)	mm	
16	Weight when empty (Kg)	kg	
17	Material		
	Shell and head		
	Nozzle necks		
	Nozzle flanges		
	Manhole nozzle		
	Manhole flange		
	Supports and structural attachments		
18	Reference drawing Nos		



1.14	Ammonia Unloading Compressor		
1	Manufacturer		
2	Type		
3	No. and configuration		
4	No. of stages		
5	No. of cylinders		
6	Cylinder bore (mm)	mm	
7	Stroke (mm)	mm	
8	Rated Capacity (Nm ³ /s)	Nm ³ /s	
9	Design temperature (oC)	deg C	
10	Design pressure	(Kg/cm ²) (abs)	
11	Maximum Discharge pressure	(Kg/cm ²) (abs)	
12	Maximum Compression ratio		
13	Speed of the compressor (rpm)	rpm	
14	Efficiency (%)	%	
15	Motor rating and speed	(KW, rpm)	
16	Construction features		
	Built in relief valve Yes/No	Yes/No	
	Relief valve set pressure adjustable Yes/No	Yes/No	
	Common base plate for compressor & motor Yes/No	Yes/No	
17	Material of construction		
	Cylinder		
	Piston		
	Piston Rod		
	Crank Shaft		
	Connecting rod		
	Bearing		
18	Noise Level (dB)	dB	
19	Dimension (LxWxH)(mm)	mm	
20	Reference drawing Nos.		
21	Codes and Standards applicable		
1.15	Ammonia Forwarding Pump (if applicable)		
1	Manufacturer		
2	Type		
3	No. and configuration		
4	No. of stages		
5	Rated Capacity (M ³ /hr)	m ³ /hr	
6	Design temperature (oC)	deg C	
7	Design pressure	(Kg/cm ²) (abs)	
8	Minimum temperature ammonia pump can handle (oC)	deg C	
9	Specific gravity of ammonia at above temperature		
10	Maximum Discharge pressure	(Kg/cm ²) (abs)	
11	Maximum differential pressure between suction and discharge pump can handle	(Kg/cm ²) (abs)	
12	Speed of the pump (rpm)	rpm	
13	Efficiency (%)	%	
14	Maximum entrained vapour pump can handle (%)	%	
15	Motor rating and speed (kw, rpm)	kw, rpm	
16	Minimum allowable suction pressure (mmwc)	mmwc	
17	Construction features		
	Built in relief valve Yes/No	Yes/No	
	Relief valve set pressure adjustable Yes/No	Yes/No	
	Magnetic coupling drive Yes/No	Yes/No	
	Common base plate for pump & motor Yes/No	Yes/No	
18	Material of construction		
	Casing		
	Rotor		
	Shaft		
	Shaft sleeves		
	Base plate		
	Wearing rings (if required)		
	Bearing		
19	Dimension (LxWxH)(mm)	mm	
20	Reference drawing Nos.		
21	Codes and Standards applicable		

1.16 Ammonia Vaporization system		
1 Manufacturer		
2 Type		
3 No. and configuration		
4 Steam source		
1.17 Ammonia Accumulator		
1 Number		
2 Type of accumulator Cylindrical & Vertical		
3 Net capacity of each accumulator (m3)	m3	
4 Design temperature (oC)	deg C	
5 Design pressure (Kg/cm2) (abs)	abs	
6 Inner diameter of accumulator (mm)	mm	
7 Height of accumulator (mm)	mm	
8 Corrosion Allowance (mm)	mm	
9 Material/Thickness(mm)		
Shell		
Head		
Nozzle		
Codes and Standards applicable		
1.18 Waste Ammonia Dilution Tank		
1 No. and configuration		
2 Storage Capacity of each tank (m3)		
3 Diameter of each tank (m)	m3	
4 Height of each tank (m)	m	
5 Maximum storage volume (m3)	m	
6 Tank Material/Thickness(mm)	m3	
a) Side Wall	mm	
b) Bottom	mm	
c) Roof	mm	
7 Design Pressure (Pa) / Temperature (oC)	deg C	
8 Codes and Standards applicable		
1.19 Waste Water Collection System		
1 Dimension of dyked area		
2 Storage capacity of dyked area (m3)	m3	
3 No. of waste water retaining basin		
4 Storage capacity of retaining basin (m3)	m3	
5 Dyke and retaining basin material		
6 No. and configuration of waste water disposal pump		
7 Design capacity of waste water disposal pump (m3/s)	m3/s	
8 Design pressure of waste water disposal pump (bar)	bar	
9 Design pressure of waste water disposal pump (oC)	deg C	
10 Pump material		
1.20 Water Spray Devices		
1 Location		
2 Type of spray device		
3 Material of nozzle		
4 Spray Water flow rate (m3/s)	m3/s	
5 Spray Water pressure (bar)	bar	



1.21	Chemical dosing system for waste ammonia neutralization		
1	Type of chemical for dosing		
2	Pump capacity		
	POWER CONSUMPTION (kW) FOR SCR SYSTEM OF ONE BOILER Normal Maximum		
1.22			
1	Ammonia unloading compressor	KW	
2	Ammonia forwarding pump (if applicable)	KW	
3	Ammonia vaporizer	KW	
4	Dilution air fan	KW	
5	Dilution air heater (if applicable)	KW	
6	Any other load	KW	
7	Total	KW	
1.23	Thermal Insulation		
1	Type of insulating material (s)		
2	Manufacturer's name		
3	Maximum hot face temp. (deg. C) the insulating material can withstand	deg C	
4	Bulk Density of insulating material (Kg./m3)	Kg./m3	
5	Area to be insulated and insulation thickness		
	SCR reactor Casing		
	SCR inlet duct		
	SCR outlet duct		
	SCR bypass duct		
	Economiser bypass duct		
6	Ash hopper		
	SCR Reactor (if applicable)		
	Duct (if applicable)		
7	Ammonia pipelines		
8	Ammonia Vapouriser		
9	Any other		
10	Total		
11	Insulation material standard		
1.24	EQUIPMENT WEIGHT (TOTAL)		
1	Structural Steel	ton	
2	SCR reactor including catalyst	ton	
3	SCR inlet duct including Ammonia injection grid, static mixer, Guide vanes, flow splitters etc	ton	
4	SCR outlet duct	ton	
5	SCR bypass duct	ton	
6	Economiser bypass duct(if in Vendor scope)	ton	
7	Platforms, Walkways stairways	ton	
8	Insulation and cladding	ton	
9	Control and Instrumentation	ton	
10	Others	ton	
11	Total estimated weight (Per Steam Generator)	ton	
	Excluding dust	ton	
	Including dust	ton	



GENERAL TECHNICAL INFORMATION / DRAWINGS FOR SELECTIVE CATALYTIC REDUCTION SYSTEM
(After Award of the Contract)

1.1	Characteristic/Correction Curves for SCR System
1	Gas flow rate vs DeNOx efficiency
2	Gas temperature vs DeNOx efficiency
3	Inlet NOx concentration vs DeNOx efficiency
4	Catalyst deactivation (Relative activity & Ammonia slip V/s operating time
5	Gas flow rate vs pressure drop across SCR reactor
6	Pressure drop vs Aux Power Consumption (KW)
7	Combined effect of gas flow rate and NOx concentration vs Ammonia consumption
8	Gas velocity vs catalyst life
9	Gas inlet dust concentration vs catalyst life
10	Nox/ ammonia molar ratio V/s outlet Nox concentration
11	Ammonia slip & SO3 concentration Vs Ammonium bi-sulphate formation Temperature
12	Ammonia slip & SO3 concentration Vs Ammonium bi-sulphate formation rate



LIST OF MANDATORY SPARES FOR SCR SYSTEM

Sl. No.	ITEM DESCRIPTION	QUANTITY
1	Catalyst ##	
1.1	Catalyst Module (to be supplied in a suitable packing so that it is not affected by outside environmental conditions during storage)	Total no equivalent to 1 Layer for each unit and to be supplied matching 75% guaranteed life of running catalyst.
2	Catalyst Module Seals ##	100% for each unit
3	Soot Blower/ Sonic Horn Assy	
3.1	Complete Assembly	2 no. per Unit
4	Dilution Air Blower	
4.1	Complete Impeller Assembly	1 no. of each type
4.2	Bearing	1 set of each type
4.3	Motor	1 no. of each type
5	Ammonia injection Nozzles, if applicable ##	25% for each unit
6	Injection Grid assembly pipes	10 % quantity of each type and size for each unit
7	Valves	10% of each type and size (minimum 1 no of each type and size)
8	Ammonia unloading System	
8.1	Complete compressor assembly	1 no
8.2	Complete vaporizer assembly	1 no
8.3	Disposal pump assembly	1 no
9	Ammonia Forwarding Pump	
9.1	Complete Impeller Assembly	1 no. of each type
9.2	Casing Liners	1 set of each type
9.3	Bearing	1 set of each type
9.4	Motor	1 no. of each type
9.5	Pump discharge valve assembly	1 no. of each type
10	Flow guide vanes/straightener/splitters	10% quantity of each shape and size for each unit
11	Static Flow Mixer(Guide vane/splitter/liner)	10% quantity of each shape and size for each unit

Note: (1) Item wise price break up to be furnished

(2) ## - The items under Sl.No. 1, 2 and 5 will be considered for price evaluation.

Selective Catalytic Reduction System

Project DN104



**High Pressure Boiler Plant
BHEL, Tiruchirapalli**

Attachment I

to

CFT REPORT ON Preparation of Technical Specification of DeNox system for meeting new MOEF emission norms published on 8th December 2015

The Specification for High Dust SCR system was prepared by the listed CFT members as below:

Sl.no	Name S/Shri.	Designation	Sign
1	D.Jayanthee	DGM / Marketing(FB) - Convener	<i>D. Jayanthee</i>
2	T.Balamurugan Murali	SM / BPP	<i>T. Balamurugan</i>
3	K.Priyakamesh	Sr. Engr./ BPP	<i>K. Priyakamesh</i>
4	G.Saravana Kumar	SM / FS / PE(B)	<i>G. Saravana Kumar</i>
5	Dheeraj Kumar	Sr. Engr. /FS / PE(B)	<i>Dheeraj Kumar</i>
6	D.Ramachandran	SM / C&I / PE(B)	<i>D. Ramachandran</i>
7	S.Sreenivasan	Sr. Engr./ LO /PE(B)	<i>S. Sreenivasan</i>
8	S.Santhosh Raaj	Sr. Engr./ CR	<i>S. Santhosh Raaj</i>
9	K.Saranya	Sr. Engr./ CR	<i>K. Saranya</i>

Dt.16.11.2016



Specification for High Dust SCR system

1. The specification Contains :

- Part I – General Requirements
- Part II – Detail specification Requirements
- Part III – Contract specific Technical Requirements

2. If the requirement of Part-I and Part-II is differing with Part III, then the requirement of Part III will be mandatory.

3. Vendor should fill up all datasheets for evaluation of offer.

4. Vendor shall submit all the documents identified in the specification.

5. Incomplete offers will not be considered.

PREPARED BY:
CFT

REVIEWED BY:
CFT

DATE:
21.10.2016

REV No.	DETAILS	REVISED BY	APPROVED BY	DATE



Part-I

General Requirements



1.0. GENERAL

Selective Catalytic Reduction (SCR) System shall reduce overall NO_x (oxides of nitrogen) produced in the Steam Generator to the specified values. This system shall be based on catalysts which will enable reduction of NO_x by ammonia (NH₃). The complete SCR system shall be designed for outdoor location connected to the coal fired steam generator. The SCR system shall be designed to contain ammonia slip to specified values under all operating conditions. Ease of maintenance, repair and overhaul shall be a central consideration in the SCR equipment design/arrangement, assembly, access, provisions for spares/tooling etc. The design/specifications/sizing of various plants/systems/equipment offered for the SCR System & Auxiliaries shall comply with the requirements detailed hereinafter.

The SCR system supplier (the Vendor) shall design, fabricate, deliver and place the selective catalytic reduction (SCR) system into commercial operation for treating the flue gas NO_x emissions exiting the steam generators. The SCR system design conditions shall be as specified in Part II of this specification.

2.0. DESIGN CRITERIA FOR THE SCR SYSTEM

The design of the SCR system shall be based on proven concept of reduction of NO_x in the flue gas emanating from pulverized coal fired steam generator through mixing ammonia and passing it through catalyst bed placed in reactor. Ammonia shall be mixed to the flue gas upstream of the SCR reactor. The flue gas shall flow from top to the bottom of the reactor unless otherwise specified elsewhere in the specification. A reactor gas side by-pass shall be provided for operational flexibility. The total catalyst requirement shall be arranged in layers, on horizontally arranged support frames inside the reactor. Further provision for one spare future layer of catalyst shall be made within the reactor. Anhydrous ammonia shall be used as the reagent for the SCR system. Unloading from truck, Storage and forwarding facility for ammonia shall be provided including facility for its vaporization and dilute air-ammonia mixture preparation for feeding in to the flue gas through an injection system.

2.1 Materials and Equipment

2.1.1 Materials and equipment must be new and of proven design. Equipment deemed to be prototype in nature are unacceptable.

2.1.2 The use of asbestos, asbestos containing materials, or polychlorinated biphenyls (PCBs) is prohibited in any of the equipment furnished.

2.1.3 Parts subject to wear, corrosion, or deterioration, or requiring adjustment, inspection or repair shall be accessible and capable of convenient removal, replacement and repair.

3.0 REGULATIONS, CODES, STANDARDS AND SPECIFICATIONS

3.1 Referenced Standards

3.1.1 Reference to the standards of any technical society, organization, or association, or to the laws, ordinances, or codes of government authorities shall mean the latest standard, code, or specification adopted.

3.1.2 The referenced codes and standards shall govern in all cases except where they conflict with the requirements of these specifications. In case of conflict between this specification and codes or standards and, the stringent requirement shall be followed and the same shall be brought to the notice of the Purchaser.

3.1.3 Publications of the following agencies shall form a part of these specifications to the extent specified therein. References to the sponsoring agencies will be made in accordance with the abbreviations indicated:



ACI,	American Concrete Institute
AHI,	American Hydraulic Institute
AMCA,	Air Movement and Control Association, Inc.
ANSI	American National Standards Institute
ASME	American Society of Mechanical Engineers
ASTM,	American Society Testing and Materials
AWS,	American Welding Society
BIS,	Bureau of Indian Standards
ISA,	Instrument Society of America
IEEE,	Institute of Electrical and Electronics Engineers
NEMA,	National Electrical Manufacturers' Association
NEC,	National Electrical Code
NFPA,	National Fire Protection Association
OSHA	Occupational Safety Health Act
SMPV,	Static Mobile Pressure Vessel Code

3.1.4 Other Regulations and Codes:

- a. IS 4544, Ammonia - Code of Safety, Ammonia Code of Safety. This includes providing process safety information as well.
- b. IS 662/ 799 – Indian Standard for specification for Anhydrous Ammonia / Ammonia Liquor
- c. ANSI Pamphlet CGA G_2.1—2014 6th Edition (formerly ANSI K61.1), - Safety Requirements for the Storage and Handling of Anhydrous Ammonia
- d. ASME Boiler and Pressure Vessel Code, Section VIII- Pressure Vessels
- e. All local safety and handling ordinances concerning automatic sprinkler systems, canopies, impoundments, and venting requirements
- f. AISC specification for the Design, Fabrication and Erection of Structural Steel for Buildings (latest edition)

Omission of any codes or standards does not relieve the Vendor of his responsibility to follow all applicable codes, standards and regulations. Any conflict among standards shall be referred to the Purchaser who shall determine which standard governs. Should codes and standards be revised after the issue of these specifications, the Vendor should inform the Purchaser immediately upon receipt of such information. Before adoption of any subsequent issue, or case ruling, the Vendor shall discuss the effect of these requirements with the Purchaser and proceed with material and/or fabrication changes only after the Purchaser's written approval.

4.0 SCOPE OF SUPPLY

The SCR system scope of supply shall include the following:

4.1 SCR Reactor

- a. Reactor chamber including duct plate housing, insulation, lagging and all structural internal supports. The reactor chamber housing shall include provisions for access as required to maintain the system, test ports, equipment mounted instrumentation for monitoring the performance & tuning the system, access doors for catalyst loading, removal & inspection. In addition, a permanent sealing system along the bottom support beams and between catalyst modules, baffle and seal bars on top of each module, internal reactor guide vanes & an upstream flow straightening system (if required), and reactor external sliding supports shall be furnished.

Note: The Vendor shall size/match the Purchaser's arrangement drawings (Refer Part III) in order to confirm adequate access provisions for all furnished equipment. Vendor

	High Pressure Boiler Plant BHEL, Tiruchirapalli Specification for High Dust SCR system	TDN:SCR:001 Rev 00 <i>Page 5 of 32</i>
---	---	--

shall furnish SCR arrangement drawing indicating all access requirements including external stairways, ladders, platforms, handrails and handling requirements and accessories supplied by the Purchaser.

- b. An internal and external monorail/hoist system shall be utilized to remove, install and handle catalytic modules. Internal reactor monorail steel shall be provided by vendor at each catalyst layer to accommodate the installation and removal of modules. External monorail support steel and an interconnecting transition piece (if required) shall be provided by the Purchaser. Vendor to recommend the locations of catalyst removal access doors and loading scheme in the SCR arrangement drawing to be submitted for Purchasers review.
- c. Scope of SCR duct work including external stiffeners, internal supports, duct expansion joints, dampers, insulation and lagging shall be as per Terminal Point indicated in P&ID. Required test ports for sampling, fixed monitoring probes, guide vanes design and location, if required in the duct of Purchaser's scope, shall be provided by the Vendor.

Note: The external steel for ductwork support design shall be by Purchaser. The Vendor shall supply all relevant ductwork loading and expansion information to the Purchaser.

4.2 Catalyst Modules

- a. SCR catalyst modules including all equipment to safely install the modules within the reactor chamber. Activity testing of sample catalyst elements during the guaranteed service of the catalyst shall be provided. Catalyst instruction manuals describing short and long term storage requirements, installation procedures, permissible inlet operating conditions and disposal procedure shall be furnished. Correction curves for off-design field operating conditions shall also be provided.

4.3 Flue Gas Mixing Device and Flow Model Study

- a. Flue gas mixing devices, as required, to ensure a uniform distribution of ammonia, temperature and gas velocity entering the first catalyst layer. A physical flow model will evaluate the necessity for such a device.
- b. A 1/10th scale, Plexiglas flow model study of the SCR system arrangement shall be provided. This shall be supported with CFD study of the full scale model. Physical modelling for SCR reactor, upstream duct work from economizer outlet (including economizer gas bypass) along with cyclone separator (if applicable) and downstream ductwork from SCR reactor outlet upto Air preheater inlet including Ammonia injection grid/nozzle shall be carried out to examine and finalize the design options for the duct system, flow modification devices, Ammonia Injection system, etc. This shall confirm the Vendor's SCR system performance with respect to ammonia distribution, ammonia injection grid design and location, internal duct guide vane arrangement, areas of possible dust accumulation, flue gas mixer design and location, and reactor design and inlet ductwork arrangement. Based on the model test studies, the Vendor shall finalize the geometry of the reactor, ductwork, flow modification devices, sampling points etc. The model study shall be carried out in the presence of the Purchaser. The physical model shall use fan(s) to draw air through the model at a flow rate that provides similar fluid dynamic behaviour to the full scale system.



4.4 De-dusting System

- a. Steam assisted soot blowers shall be provided above each catalyst layer. All blowers, piping, valves, fittings, drains, reactor soot blower steel supports and complete controls and wiring shall be furnished.

Note: Steam piping shall be furnished by the Purchaser up to a single terminal point at the SCR boundary.

Alternatively, sonic horn and air cannon for blowing/dislodging accumulated/sticking ash and fouling on catalyst surface. Type of de-dusting system shall be offered based on Vendor's standard practice/ past supply experience.

The contractor shall establish/ recommend de-dusting device frequency and their performance tuning based on the actual operation through controlled tests/measurements. Cleaning effectiveness shall target recovery, as measured through gas pressure drop and visual inspection, up to a near pressure drop value with reference to completely clean reactor as measured at the time of commissioning. In case if above de-dusting systems are not sufficient for effective cleaning of the catalyst than the bidder may provide Dry Cleaning System for in-situ cleaning of the catalyst in addition to above.

4.5 Ammonia Unloading, Storage, Handling and Preparation System

- a. An ammonia handling and storage facility including unloading system, compressor to unload for supply truck, storage tanks, , and valves required for the safe unloading and storage of anhydrous ammonia with all equipment's, fittings, hose connections, monitoring and safety devices. All equipment shall meet international and local regulations codes.
- b. Two (2) x 100 % Ammonia vaporizers with all associated connecting piping to vaporise the ammonia required for the SCR system. If steam assisted vaporization system is offered associated accumulators, piping, instrumentation and controls shall be offered. Condensate formed due to the condensation of steam shall be connected to the condensate tank by the Purchaser from Vendors terminal point. Vendor to provide steam requirements and terminal points.
- c. Two (2) x 100 % common ammonia forwarding pumps skid (if applicable) (1 working and 1 standby pump) with recirculation line shall be provided to ensure steady supply of ammonia to the vaporizer and flow control units (located at the steam generator).
- d. Ammonia accumulators and associated systems capable of handling the ammonia to meet the requirements of SCR system.
- e. A dyke shall be provided around storage tank area with storage capacity equivalent to one storage tank, for collection of liquid ammonia in case of emergency. This dyke shall be connected to waste water retaining basin. Civil works are under Purchaser's scope.
- f. One (01) no. Waste water retaining basin near ammonia unloading & storage system along with 2x100% waste water/ ammonia disposal pumps with motors for transferring drains to Water Treatment Plant (WTP). Chemical dosing system for controlling pH of waste water before sending to WTP.



- g. A dilution air skid including an ammonia/air mixer, two (2) x 100 % dilution air blowers, two (2) x 100 % dilution air heaters (if required), instrumentation, valves and local controls. The ammonia flow instrumentation shall include all necessary control, shutoff, bypass and relief valves and monitoring devices to ensure a safe operational system. The required control logics and interlocks for implementation in purchaser's DCS shall be furnished by vendor.
- h. An ammonia dilution tank of adequate capacity shall be provided with all interconnecting piping to allow the safe disposal of any excess ammonia vented or drained from the system.
- i. All interconnecting piping from the ammonia storage tank / vaporizer skid to the dilution air skid, and from the dilution air skid to the ammonia injection inlet manifold shall be provided. Fittings, hangers and supports shall be provided for all piping in the Vendor's scope of supply.
- j. Personnel safety equipment in order to comply with all local requirements. As a minimum, the following shall be provided:
 - i. Shower/eyewash stations located in the vicinity of the ammonia storage tanks and the dilution air skid
 - ii. Face masks and canisters
 - iii. Goggles
 - iv. Gloves and boots
 - v. Ammonia sensor alarms (for local & remote) located in the vicinity of the ammonia storage tanks and the dilution air skid

4.6 Ammonia Injection System

- a. Ammonia injection system including an inlet manifold with local temperature and pressure gauges, ammonia injection nozzles, flow control valves, flow orifices and manometers, flex hoses, compressed air valve connections and all required piping with internal and external structural supports. The space and access requirement shall be indicated in the AIG arrangement drawing.

4.7 Electricals, Controls and Instrumentation

The following shall be under vendor's scope of supply

- a. All the controls and interlocks required for safe operation of the complete SCR system and other auxiliary systems.
- b. The O₂ Analyser, SO₂ Analyser, NO_x analyser at inlet and outlet of SCR reactor, NH₃ analyser at outlet of SCR reactor as indicated in the P&ID. In addition, pH measurement (if applicable) and any other analysers connected elsewhere in the SCR system shall also be under vendor's scope of supply.
- c. The ammonia leak detector system with all its associated instrumentation, controls and annunciation system shall be under vendor's scope of supply. Detailed specification shall be referred.
- d. All instruments in the lines/equipment supplied by the vendor shall be in vendor's scope. These instruments shall be terminated in local junction box / local control panel / skid as



per vendor's standard practice. Vendor to refer Annexure U for Specification of field Instruments.

- e. All pneumatic actuators (with smart positioners for regulating duty) & electric actuators for regulating and Open/close applications shall be in vendor's scope of supply. Vendor to refer Annexure R for Specification of Actuators.
- f. All equipment/instruments in vendor scope shall be wired up to the local junction box/ local control panels. The Instrumentation & Control cables from field equipment / instruments to Local JB/ Local Control panels shall be in vendor's scope of supply. Vendor to refer Annexure V for Specification of all the varieties of cables.
- g. All Local Controls Panels, Field Junction boxes, Local instrument enclosures shall be in vendor's scope of supply. Vendor to refer Annexure W for detailed specification.
- h. All Instrument installation/erection materials including piping's, fittings, root valves etc., required for the vendor supplied instruments shall be in vendor's scope of supply. Vendor to refer Annexure W for detailed specification.
- i. All erection materials including cable glands, cable trays required for vendor supplied equipment/instruments/panels/enclosures/junction boxes/cables shall be in vendor's scope of supply. Vendor to refer Annexure W for detailed specification.
- j. All LT & HT motors part of the SCR system shall be in vendor's scope of supply. Vendor to refer Annexure S for Specification of Motors.
- k. Vendor to refer Annexure Q for Electrical Power supply details.
- l. Vendor to refer Annexure P for Terminal Points for Electrical C&I Equipment.

4.8 Other Requirements

- a. Utility piping, fittings, hangers and supports from a tie-in point at the Vendor's battery limit to service the SCR system steam, water and air requirements.
- b. Primer, finish painting of all uninsulated steel and piping surfaces shall be provided. Purchaser shall confirm if the Vendor's paint is acceptable.
- c. One (1) year spare parts (excluding catalyst) for maintaining the availability of the Vendor's supplied equipment shall be supplied along with main equipment.
- d. Mandatory spares as per the list enclosed separately shall be offered.
- e. Erection material for vendor supplied equipment.
- f. Supervisory services for the erection, start-up, testing and commissioning of the Vendor's equipment. Breakup price for the above services shall be quoted separately.
- g. Instruction manuals, performance test procedures and testing plan for the equipment supplied by the Vendor for purchasers review and acceptance.
- h. Performance testing and commissioning is Vendor's responsibility.
- i. Trouble shooting of equipment engineered or supplied by vendor before handing over of SCR system to end customer shall be in Vendor scope.
- j. Onsite SCR training program with instruction manuals for preparing the Purchaser's personnel to operate and maintain the equipment supplied by the Vendor.
- k. Vendor quality plan shall be submitted for Purchaser's review and approval.
- l. The Vendor shall provide the Purchaser with reasonable advance notice of all factory tests associated with the equipment/items under Vendor scope of supply. The Purchaser shall be entitled to witness all factory tests. The Purchaser shall also be allowed to specify a third party representative to witness these tests.



In general, all components, features and design parameters specified herein are minimum requirements. If the Vendor's design dictates that these requirements be exceeded to meet specified performance guarantees and to provide a safe, reliable operating unit, he shall include all equipment above and beyond the equipment required to meet these minimum requirements. The Vendor shall provide all accessories and appurtenances which are required for a complete, reliable and safe SCR operating unit whether or not the specific equipment which is customarily a part of such a system has been specified herein.

Note: For project specific scope of supply refer Division of Work document.

5.0 EXCLUSION

The following items shall be provided by others and are not a part of this specification:

- a. Supply of anhydrous ammonia
- b. Site permitting
- c. Water for the ammonia system
- d. Site utilities for construction and SCR operation - including instrument air, electrical power, water, steam, outdoor lighting, etc.
- e. All earthwork, foundations, base plates, anchor bolts and site remediation for accommodating the SCR system
- f. DCS/Remote control panels
- g. Complete Electricals including MCC, Switchgears, Distribution boards, Power Cables, Cable trays, Earthing, Grounding, Lighting & Illumination, Lightning protection system.
- h. Instrumentation and control cables beyond Local JB/local control panel (for Vendor supplied instruments)
- i. Instruments other than those specifically included under scope of supply
- j. UPS & its distribution
- k. Steam, water, air, oil, nitrogen and drain piping, valves, traps outside the Vendor's battery limit
- l. Thermal insulation as required for associated piping not furnished by the Vendor
- m. External structural steel for supporting ductwork, platforms and SCR reactor chamber. Access platforms, handrails, stairs, ladders, grating, and elevators.
- n. SCR reactor bypass duct with insulation and lagging
- o. Stack continuous emission monitoring system (CEMS) for regulatory compliance
- p. Erection of all SCR equipment
- q. Receiving and onsite storage of catalyst modules
- r. Supply of duct works from Eco out to inlet of reactor chamber.
- s. Supply of duct works from outlet of reactor chamber to APH inlet.
- t. Lining and insulation of duct works from eco outlet to APH inlet including reactor chamber



PART II

Detailed specification Requirements



1.0 SCR SYSTEM DESIGN REQUIREMENTS

1.1 The design of the SCR System shall be carried out taking following into consideration:

- a) All operating conditions of steam generator (e.g. gas temperature, ash, start/stops, load cycling) from start-up to 40% TMCR without ammonia injection and from 40% TMCR to BMCR with ammonia injection for complete range of specified coal and specified ambient air condition.
- b) Duct design for reduced gas stratification and effective gas-ammonia mixing for minimization of ammonia consumption and slip
- c) Prevention of formation of ammonium bisulfate (ABS) and other ammonia components, which deactivate or plug up or mask the catalysts and other downstream components
- d) Minimization of SO₂ to SO₃ conversion
- f) Prevention of plugging of the catalyst by ash particles
- g) Design life of 25 years (excluding catalyst).
- h) Modular construction to enable catalyst management plan (CMP) and periodic maintenance / inspections.

1.2 The SCR system shall be of a hot-side, high dust design, located between the economizer and the gas inlet duct to the air preheater.

1.3 The SCR system shall be designed for continuous operation with any of the fuels specified in Part III. The SCR equipment performance shall meet outlet emission requirements as detailed in the Part III

1.4 Anhydrous ammonia with a minimum ammonia content of 99.5 % shall be used at this facility. Anhydrous ammonia is supplied and stored as a compressed liquid with moisture limited to 0.50% maximum.

1.5 Site Conditions

1.5.1 The basis for the SCR system design shall be according to the site conditions specified in Part III

1.6 The catalyst shall be selected to meet outlet emission requirements based on the design criteria and SCR performance shall be achieved for all combinations of fuels and operating boiler loads indicated in Part III.

2.0 SCR SYSTEM GUARANTEES

2.1 The SCR system shall be designed and guaranteed to limit the NO_x emissions across all load range as specified in the Part III.

2.2 Unreacted ammonia exiting the SCR reactor shall not exceed the value specified in Part III for all operating conditions and fuels listed in Part III

2.3 The exit NO_x and unreacted ammonia emission guarantees shall be maintained over a period of minimum operational hours as specified in Part III without replenishing the catalyst. In case of non-performance of the catalysts as per guarantee terms, then the vendor is liable to replace the catalysts/equipment to meet the performance requirements.

2.4 The SCR system including all ductwork, flow distribution devices, ammonia injection grid, and reactor flow straightening grid in the Vendor's design or supply scope shall be guaranteed not to exceed the draft loss as specified in Part III with all initial and future catalyst loaded.



2.5 The draft loss across the initial loaded catalyst shall be designed and guaranteed for the inlet operating conditions specified in Part III.

2.6 The oxidation rate of SO_2 to SO_3 shall be guaranteed as per Part III at all inlet operating conditions specified in Part III while firing any of the fuels specified in Part III. The guarantee should be based upon having all future catalyst layers loaded into the reactor.

2.7 The anhydrous ammonia consumption rate shall be guaranteed for each of the fuels/ operating conditions specified in Part III.

2.8 Protocol to be signed by Vendor with end customer after proving all guarantee parameters identified in this specification.

3.0 SCR REACTOR CHAMBER

3.1 The SCR reactor shall be a high dust, hot side arrangement located downstream of the economizer and upstream of the two air preheaters. Flue gas will flow vertically down through the catalyst layers.

3.2 There shall be one SCR reactor with two outlets located directly above the two air preheaters. Alternatively vendor to consider two SCR reactor with one outlet each as an option for purchasers review. The geometry of the reactor chamber shall be as specified by vendor. The Vendor must maintain support points, reactor chamber dimensions, etc. to enable steel arrangement and design at Purchasers end. In general refer the arrangement drawing furnished by the Purchaser in Part III.

The distance between module layers shall be a minimum as specified in Part III . This distance shall provide adequate clearance between catalyst layers to facilitate loading and unloading of modules as well as internal reactor inspections.

Multiple layers of catalyst shall be provided. No modules shall be stacked upon each other in the reactor. The maximum module height in any one layer shall not exceed 1500 mm (Vendor may specify any other dimension to optimise). This shall effectively allow soot blowing to dislodge any possible ash accumulation within catalyst surfaces.

3.3 The SCR reactor chamber and inlet ductwork shall be designed to maintain sufficient velocity to prevent fly-ash dropout over the entire boiler operating load range. Reactor inlet transition ductwork shall make gradual changes in cross-sectional area and contain an adequate number of vanes and/or baffles to minimize gas separation zones, prevent dust stratification, prevent fly-ash agglomeration and erosion, and minimize the propagation of wake regimes at the inlet of the reactor upstream of the flow straightening grid.

All ductwork designed by the Vendor shall contain adequate vanes, baffles, and mixing devices to ensure that gas velocity, temperature and ammonia distribution requirements are met. The vanes and mixing devices shall be designed to promote streamlined flow and prevent erosion and vibration.

3.4 The catalyst reactor shall be a self-supporting structure designed to allow for thermal expansion and contraction. Module support shall also be designed to allow thermal expansion and contraction without stressing the modules. Internal reactor steel shall be fabricated from A-36/ IS 2062 material with rolled members. The design of the internal structure shall conform to the seismic and wind requirements specified in Part III. The structural steel design shall also confirm to the latest edition of the AISC/BIS Specification for the Design, Fabrication and Erection of Structural Steel for Buildings.



3.5 Obstructions within the reactor chamber by beams, pipes, soot blowers, etc. shall be kept to a minimum. There shall be no areas where dust can accumulate. Ledges or flat areas shall be avoided. The reactor design shall also accommodate the installation of either a plate or honeycomb catalyst without requiring major structural modifications.

3.6 The SCR reactor shall contain a flow straightening grid upstream of the catalyst layers to provide uniform flow distribution and streamlines. The reactor shall be designed to avoid non-uniform gas flow and dust deposits on the catalyst bed. Reactor inlet flow distributions shall achieve a flue gas velocity uniformity of $\pm 10\%$ from the average velocity when measured upstream of the first catalyst layer. The inlet and outlet gas flow around the straightening grid shall be as near normal (vertically downward) as possible.

3.6.1 A metal flow straightening grid shall be provided. The grid shall be provided in modules for ease of installation into the vertical flow reactor. The metal grid shall be bottom supported in the reactor.

3.6.2 The Vendor shall provide dimensional drawings of the metal grid assembled units. The drawings shall show adequate dimensions and clearances required for the proper installation and maintenance of the grid. The Vendor shall indicate the weights of each metal grid module component.

3.6.3 The metal grid modules shall be completely shop assembled and ready for installation into the reactor chamber. An optimized array of metal grid modules with lifting lugs shall be provided.

3.6.4 Module construction shall avoid flat surfaces which can potentially result in excessive ash deposition.

3.6.5 Structural tubing may be used to construct the grid. Module framework shall be constructed of carbon steel material or better. Provisions for expansion shall be inherent to the module construction. Exposure of the grid material to flue gas temperatures ranging from 200 to 400 C can be expected. All modules shall be completely welded. Other structural configurations may be proposed and considered by the Purchaser.

3.7 Reactor casing provided by the Vendor shall be welded steel plate construction fabricated from A-36 / IS 2062 material or better.

3.8 The catalyst reactor chamber shall be insulated and lagged. Adequate insulation shall be provided in order to ensure that the temperature of the catalyst surfaces does not go below the acid dew point during a shutdown. All insulation shall be applied against plate work, impaled on 10 gauge pins and secured with pin clips. All insulation shall be applied to prevent direct heat transfer through steel.

3.9 Catalyst and personnel access doors shall be independently insulated to allow convenient access or removal. Test ports and other flanged connections shall be insulated to the greatest extent possible.

3.10 Lagging shall be installed, sealed and flashed to provide a neat weatherproof protective covering. Lagging shall be a minimum of 0.81 mm on the reactor walls. Lagging on the reactor roof shall be a minimum of 1.27 mm.

3.11 The reactor shall accommodate sufficient catalyst to achieve guaranteed NO_x reduction and ammonia slip requirements as specified. A spare layer accommodating the future addition of a minimum of one layer shall be provided. Design loads, including weight, pressure, seismic, draft losses across catalyst, etc., shall consider the addition of this future layer.

3.12 A permanent sealing system shall be provided between individual catalyst modules and support beams, reactor walls, and adjacent modules to prevent bypass of the flue gas around the



catalyst. The system shall be designed to permit subsequent catalyst replacements without damaging the sealing mechanism. Baffles or shrouds (ash accumulation plates) shall be provided to prevent fly-ash accumulation between modules and along the perimeter of the reactor walls.

3.13 The SCR system shall include a reactor bypass (bypass ductwork supplied by the Purchaser) to be used during start-up, shutdown and emergency conditions. The reactor bypass shall include a tight shutoff damper to prevent flue gas slippage while the SCR is in operation. The Vendor shall assume 2 % flue gas bypassing the SCR reactor when selecting the proper catalyst volume for the design criteria specified in Clause 2 of Part II.

3.14 All access doors for inspection and catalyst loading shall be bolted construction. Square access doors shall be furnished with air tight gaskets suitable for the temperature and environment.

3.15 The Vendor shall furnish test ports on the reactor chamber to properly evaluate the performance of the catalyst. All test ports, except those used for permanent Analyzers and instrumentation connections, shall be a minimum of 101.6 mm diameter furnished with NPT thread on one end with screw cap. Pressure differential connections shall be provided between each catalyst layer. All test ports shall protrude outside the thermal insulation lagging a minimum of 101.6 mm. All other test ports not located in the Vendor's supplied ductwork and reactor shall be provided by the Purchaser. At a minimum, test ports shall be located upstream of the ammonia injection grid, upstream of the first catalyst layer and at a plane directly below the last catalyst layer (future layer). At a minimum, test ports used for portable probe traversing shall be located on 1 meter centres across any one plane.

3.16 Reactor start-up and shutdown thermal gradients shall not be limited by the internal reactor steel structure. Support beams, casings, and insulation shall be designed to allow the reactor to warm-up through the moisture and acid dew points as quickly as possible. The Vendor shall supply a start-up and shutdown sequence including a time line.

3.17 A hoist/monorail system shall be furnished by the Vendor to assist in the installation and removal of catalyst modules from the SCR reactor chamber. Internal monorail steel at each level of catalyst (including the future layer) shall be provided. An electric, slow speed hoist will be attached to the overhead monorail in order to facilitate the movement of individual catalyst modules from the ground to the proper level within the reactor. All monorail steel external to the reactor chamber shall be provided by the Purchaser. A hydraulic trolley provided with the catalyst modules shall be used to position each of the modules into the proper location within each layer.

The hoist requirements are as follows:

Number of hoists per SCR system: One (1)

Type : Lug mounted electric wire rope hoist

Load Capacity : As required to lift heaviest catalyst module

Vertical hook travel: To handle top most catalyst module level to ground level

Pendant assembly*: 1-Push-button pendant control station with conductor and support cables

Electrical requirements: Refer Part III.

**Note: The operator shall be capable of moving the load vertically 12.7 mm or less at a time by tapping the down button.*



4.0 CATALYST AND CATALYST MODULES

4.1 The catalyst supplied by the Vendor shall be plate or honeycomb type with a vanadium/titanium composition. Vendor to consider the maximum ash / dust concentration specified in Part III.

4.2 Sufficient catalyst volume shall be provided in order to meet the specified guarantees. The catalyst shall be designed in accordance with the criteria specified in Part III. Consideration shall be taken for 2 % gas flow bypass around the SCR reactor chamber. This leakage accounts for the slide gate shutoff damper located in the reactor bypass duct. The catalyst shall be capable of maintaining the performance with normal operating variations in gas temperature (+/- 10 deg. C from the average) and velocity (+/- 10% from the average) across the face of the catalyst surface.

4.3 Catalyst pitch shall be selected by the Vendor to provide an optimized design of geometric surface area versus volume and differential pressure. The pitch shall be such that the catalyst will not be prone to fly-ash pluggage. Vendor to consider the maximum ash / dust concentration specified in Part III

4.4 The Vendor shall submit a laboratory procedure for activity testing of the catalyst. Activity tests using samples from modules installed in the reactor shall be provided. These tests shall occur at mutually acceptable intervals during the service life guarantee period of the catalyst. The frequency of activity tests shall be at a minimum of once per year. The number of activity tests shall be consistent with achieving an optimum and cost effective catalytic management program. A final report shall describe laboratory test results and recommendations for future catalyst replacement. As part of the report, a plot of catalyst activity (K/K_0) versus operating hours shall be included.

4.5 The SCR system performance guarantees shall be based upon field measurements. Correction curves for off-design conditions shall be provided by the Vendor. At a minimum, these curves shall include the impact of flue gas volumetric flow, temperature, inlet NO_x and O₂ upon the NO_x removal efficiency. Also, a curve of SO₂ to SO₃ oxidation rate vs temperature and area velocity shall be provided.

4.6 The catalyst's chemically active constituents which are bonded to metallic substrates (plate type catalyst) shall not delaminate due to stresses induced by thermal or pressure forces for the life of the catalyst.

4.7 An option for the disposal of the initial charge of catalyst shall be provided. The Vendor shall adhere to all local regulations pertaining to handling, and disposing of the catalyst material. It should be noted that the catalyst will be exposed to coal fly-ash which contains heavy metals. Consequently, consideration for a hazardous waste disposal shall be assumed by the Vendor. This shall be indicated as an optional price.

4.8 The catalyst element baskets shall be shop assembled into modules for ease of installation and removal from the reactor. The module framework shall be constructed of carbon steel material. Grating protection shall be furnished on the upstream face of each module for ease of internal maintenance and inspection. Screening shall also be provided on the upstream face of each catalyst module to prevent large ash particles from becoming lodged within the catalyst plate material. Similar construction shall be provided if a honeycomb catalyst module is supplied.

4.9 Lifting lugs shall be provided on the catalyst modules for ease of installation into the reactor chamber. All special tools required for the proper installation of the modules shall be provided.



This shall include a hydraulic trolley for individual module positioning within the SCR reactor chamber. A spreader beam specially designed for lifting the modules from grade to each appropriate catalyst elevation shall be furnished. Any additional special tools required for the unloading of catalyst modules from either truck or rail delivery of the modules to the site shall be supplied.

4.10 All catalyst modules shall be packed in appropriate containers to prevent damage and/or exposure to moisture during shipment. The Vendor shall supply long and short term storage and handling procedures and recommendations for onsite storage of the modules.

4.11 The Vendor shall provide dimensional drawings of the catalyst modules, hydraulic trolley and spreader beam used for installation. The drawings shall show adequate dimensions and clearances required for proper installation and maintenance. The drawings shall show the weights of all major components. All Vendor drawings shall be submitted to the Purchaser for approval.

4.12 The Vendor shall provide the Purchaser with reasonable advance notice of all factory tests associated with the catalyst material and module fabrication. The Purchaser shall be entitled to witness all factory tests. The Purchaser shall also be allowed to specify a third party representative to witness these tests.

4.13 The Vendor shall provide Material Safety Data sheets for the catalyst material, as well as any information pertaining to applicable safety regulations for compliance with OSHA requirements (29 CFR 1710.111) and safety regulation standards applicable in India. In addition, all information required to support the Purchaser's safety regulations and site permitting shall be provided.

4.14 The Vendor shall supply operating and instruction manuals describing the procedures (including recommended hot, warm and cold start, shutdown for short and long term periods), as well as maintenance and other special instructions required for the proper care and safe and reliable operation of the catalyst. These instructions shall be specific to the Purchaser's ductwork arrangement, equipment and overall system design.

4.15 The catalyst Vendor shall specify the continuous recommended minimum allowable gas temperatures to the SCR for the full range of fuels/operating condition specified. The final method of flue gas temperature control shall be determined and supplied by the boiler supplier.

4.16 The following information shall be provided for the catalyst and module supplied by the Vendor:

- a. Catalyst pitch, specific surface area (m^2/m^3), chemical composition, and selected volume (m^3)
- b. Space velocity, area velocity, actual face velocity, linear velocity, SO_2 to SO_3 oxidation rate, draft loss across the initial installed catalyst, NO_x removal efficiency and ammonia slip for a fresh catalyst as well as the NO_x removal efficiency and ammonia slip for a catalyst after 8000 and 16000 hours of operation for all conditions specified in Part III.
- c. Catalyst module width, module depth, module height, module weight, catalyst density, number of modules per layer, total number of modules per reactor. Arrangement and dimensions of modules shall accommodate the reactor dimensions.
- d. For the full range of fuels specified in Part III, specify the minimum continuous allowable inlet operating temperature in order to avoid ammonium bisulphate formation on catalytic surfaces. Short term inlet temperatures, below those indicated above, and allowable maximum operating hours at these temperatures shall also be provided. Subsequent recovery temperatures and duration of operation shall be furnished.



- e. A recommended, optimized schedule of catalyst module additions and replacements for a 10 year period. Provisions in the reactor chamber for a minimum one layer shall be provided for future.
- f. A description of the module sealing method and sealing material.
- g. The Vendor shall furnish the allowable conditions for the design of a superheated soot blowing system. Recommendations for steam temperature, pressure, and frequency of blowing shall be furnished. The vendor shall also recommend the distance between the top of the catalyst plate surface and soot blower nozzle. Utility requirements for sonic horns and air canons (if applicable) has to be furnished by the Vendor.
- h. Typical laboratory procedures for activity testing of the catalyst shall be furnished. This shall include a list of all items tested and a summary of the type of report that can be expected.
- i. The vendor shall provide recommended hot, warm, cold start-up and shutdown procedures. Permissible temperature ramp rates across the catalyst shall be furnished. An SCR reactor bypass has been furnished in order to provide operating flexibility during these conditions. A process control description functionally indicating the control logic, permissive, alarms, and control schemes as it affects catalytic reactive performance shall also be included.
- j. The Vendor shall provide recommended jobsite handling and storage procedures for the catalyst modules.
- k. The Vendor shall review the adequacy of the load/support requirements and access requirements for the SCR system and furnish the same for Purchasers engineering/BOM calculation at the time of document approval. Any additional access/supports not identified during document approval stage shall be in Vendors scope.
- l. The Vendor shall provide the allowable continuous minimum operating temperatures to the catalyst for all fuels and inlet load conditions specified by the Purchaser.

5.0 Flue Gas Mixing Device and Flow Model

5.1 The Vendor shall construct a three-dimensional 1/10th scale (Plexiglas or equal) model of the proposed SCR equipment and boiler back-pass with associated ductwork, reactor transition pieces, and reactor internals. The model shall verify the size, configuration, and location of all necessary SCR installed equipment and final ductwork arrangement, guide vanes, and mixing devices necessary to provide uniform velocity, temperature and ammonia distribution across the catalyst.

5.2 The distribution of ammonia shall be simulated and the injection grid design verified.

5.3 The boundary limits of the physical flow model shall be from economiser outlet to the air preheater gas inlet flange. The Purchaser's boiler arrangement drawings shall be supplied to assist the Vendor in the construction of the model.

5.4 The model shall be arranged such that it simulates the aerodynamic effects on gas flow and distribution due to physical features such as internal ductwork bracing, guide vanes, mixing devices, injection grid, flow straightening grid, etc. The objective of the model is to verify the SCR system design for the following:

- a. Gas velocity of +/- 10% from the average at the inlet to the ammonia injection grid and at the inlet to the first catalyst layer
- b. Gas temperature within +/- 10 deg C at the inlet to the first catalyst layer
- c. Ammonia distribution within +/- 5% of theoretical requirements at the entrance to the first catalyst layer. This distribution objective shall confirm the adequacy of the ammonia injection grid and flue gas mixing design and location.
- d. Analysis of ash accumulation throughout the proposed SCR ductwork and reactor chamber.



e. Evaluation of pressure losses throughout the system including across inlet and outlet ductwork, catalyst layers, ammonia injection grid dampers, straightening grid, mixing devices and other significant reactor/ductwork internals. A discussion of the device used to simulate gas draft loss across the catalyst shall be presented in the final report.

5.5 The Vendor shall submit the following to the Purchaser for review and approval before actual testing:

- a. Drawings and description of the flow model showing all dimensions and details
- b. Detailed description of the flow model test procedure
- c. Tests to be performed
- d. Data to be recorded
- e. Testing results format
- f. Limits, tolerances, and uncertainty in testing
- g. Criteria for determining that the testing is complete and successful
- h. Discussion of similitude between the flow model and the actual SCR system. The discussion shall include a comparison of the Reynolds, Prandtl, Schmidt, Grashof and Froude numbers for the model and the actual system.

5.6 The Purchaser and/or his representative shall have the right to inspect the flow model and to witness testing at any time. Adequate notice will be given by the Purchaser.

5.7 After completion of the successful model testing, the Vendor shall submit to the Purchaser the following:

- a. Test report and results
- b. Drawings showing design, dimensions and location of all required flue gas and ammonia mixing devices
- c. Drawings showing design, dimensions and location of all duct turning vanes
- d. Any changes that will be made to the ductwork, ammonia injection grid, reactor or other parts of the SCR system that are a result of the flow model test

5.8 Any changes in the SCR equipment design resulting from the flow model shall be retested to confirm the adequacy of the revisions. Close coordination of the flow model testing shall be achieved at all times with the Purchaser.

The Vendor shall submit to the Purchaser the proposed schedule for the complete model fabrication, testing and report submittals.

5.9 For the duct work in Purchaser's scope of supply, the arrangement of internals shall be based on mutual agreement

5.10 Final disposition of the model shall be the Purchaser's option.

5.11 Flue Gas Mixing Devices

5.11.1 Flue gas mixing devices shall be provided, as required to ensure the uniformity of gas velocity, temperature and ammonia dispersion into the flue gas stream. The effectiveness of the mixer design and location shall be confirmed by physical flow model testing.

5.11.2 The mixing device material shall be compatible with the ductwork casing in the area.

6.0 De-Dusting System

6.1 Soot blowers are effective in keeping particulate matter entrained in the flue gas stream so as to avoid the possible formation of deposits on catalytic surfaces. Blowers shall be furnished



upstream of each catalyst layer within the SCR reactor. Each soot blower shall use superheated steam supplied at sufficient velocity and dynamic pressure to keep the catalyst modules clean. The steam source shall be from the steam generator with the tap-off point specified by the Purchaser. The Vendor shall recommend maximum acceptable steam conditions (steam temperature and pressure) for the catalyst. The Purchaser shall furnish steam piping up to a single point connection to interface with Vendor's steam piping supply. Vendor shall take care of the Inlet Dust Burden for designing the Soot blower.

6.2 Soot blowers shall be of the transverse arm, rake type design having nozzles or orifices spaced at regular intervals suitable for cleaning the catalyst without erosion. Location of the blowers shall ensure full cleaning coverage of the face area of the catalyst layer. The Vendor shall ensure that the nozzles are properly located on the blower arms above the catalyst in order to avoid structural damage to the catalyst material and provide effective cleaning.

6.3 Structural support and space provisions in the reactor chamber shall be furnished to accommodate the future installation of soot blowers above the spare catalyst layer.

6.4 Soot blowers shall be located on both sides of the reactor. The central pipe of the blowers shall be positioned in a zone of low flow intensity below reactor support beams. If internal soot blower pipes are exposed to the direct impact from flue gas, then flow deflector baffles shall be installed on the pipes to improve overall flow patterns.

6.5 The soot blower design shall avoid abrupt temperature changes to the catalyst surfaces to minimize the adverse effects of thermal shock. Maximum temperature differential between the soot blowing medium and the catalyst surface temperature shall not exceed 50 C.

6.6 The soot blower design shall minimize erosion of the catalyst caused by excessive medium velocity and water droplets.

6.7 The steam supply system provided by the Purchaser shall be designed assuming all soot blowers are installed and operational including those for the spare layer.

6.8 The blower equipment shall include all valves, piping, fittings, drains, wall boxes, rail assemblies, structural supports, hangers, motors, and controls for a complete system.

6.9 The Vendor shall state recommended soot blowing frequency, soot blower operational time, and mass steam flow per blower. Operation of the soot blower system shall be from top to bottom.

6.10 Commissioning services shall be provided for the soot blower system.

6.11 Vendor shall furnish takeout price for Soot blowing system supply.

6.12 Sonic Horn (if applicable)

a) Sonic horn shall be provided for cleaning all catalyst layers, including the future layer. Number of sonic horn shall be provided so that it should cover complete catalyst surface area. Sonic horns may be arranged on the single wall or opposite walls of the SCR reactor based on its cleaning intensity.

b) Sonic horns shall be provided to generate low frequency and high energy sound waves to resonate and dislodge ash deposits/fouling which develops on the catalyst modules/cassettes. The horns shall be driven using service air available at site sequentially at regular frequency. The horns shall be constructed of stainless steel having diaphragm of titanium alloy. Diaphragm shall



have a minimum life of five (05) years. Each horn shall be provided with acoustic enclosures to reduce ambient noise. The arrangement and type of sonic horns shall be as per standard practice of the contractor.

c) Each Sonic horn shall be provided with separate solenoid operated isolation valve along with associated piping. Adequate number of moisture traps shall be provided at each catalyst layer for removal of moisture from service air supply line.

6.13 Air Cannons (if applicable)

a) Air cannons shall be provided for cleaning all catalyst layers, including the future layer. Number of air cannons shall be provided so that it should cover complete catalyst surface area. Air Cannon may be arranged on the single wall or opposite walls of the SCR reactor based on its cleaning range.

b) Two (02) multiport air cannon system with fan jet nozzles shall be provided for each catalyst layer including the future layer.

c) Air Cannon shall be operated in combination with sonic horn. Initially air cannon shall discharge to break any adhered material loose and then acoustic cleaner shall continue to sound to keep ash deposits in suspension. Air Cannon discharge nozzle shall preferably be placed directly below the sonic horn.

6.14 Dry Cleaning System (if applicable) for in-situ cleaning shall include removal of the particulates and plug(s) on the catalyst using a blasting stream of a pressurized carrier gas having a particulate blasting medium (dry ice) directed at the SCR catalyst. Complete pressurization system for the carrier gas along with feeding/mixing of the blasting medium shall be provided along with necessary injection lances for in-situ cleaning of catalyst at each layer elevation.

7. Ammonia Unloading, Storage, Handling and Preparation System

A complete anhydrous ammonia unloading, storage, handling and dilution system shall be furnished. The equipment shall include an unloading compressor, ammonia storage tanks, vaporizers, associated piping, fittings, supports, valves, instrumentation, neutralization tank, dilution air blower skid and ammonia injection grid.

7.1 An unloading compressor shall be furnished to transfer liquid anhydrous ammonia from the delivery vessel to the main storage tanks. A compressor, local control panel incorporating all controls and monitoring, equipment and skid mounted instruments and unloading bulkhead shall be furnished near the vicinity of the tanks. The capacity of the compressor shall be properly sized to unload an ammonia shipment within a reasonable time period and at a maximum head of 18 kg/cm² gauge. The motor shall meet the requirements mentioned in Part III.

7.1.1 Two (02) oil free reciprocating type ammonia unloading compressors complete with motor drives and receivers shall be provided with all necessary fittings, monitoring and safety devices for unloading of ammonia from the truck to ammonia storage tank. The compressors shall be skid mounted. The compressor design shall have double and triple packing to obviate harmful gas leaks. Further, any leakage gas shall be returned to the suction line and no nitrogen purge and leak gas monitoring device with gland seal of the piston rod shall be required. Same compressor shall be used for liquid ammonia transfer and ammonia vapour recovery. The compressor shall be designed with the consideration of ammonia vapour recovery which may result in excessive temperature rise.

7.1.2 Each compressor shall be provided with gas filter and liquid trap with level control on its suction side. Liquid trap shall be designed for pressurized and vacuum operating condition. 4-way



valve ball valve shall be provided for each unloading compressor for switching the direction of gas conveyance.

7.1.3 One (1) pressure relief valve shall be installed in the discharge line of each compressor and its connecting pipe shall be routed back to the storage tanks.

7.1.4 The design of compressor shall ensure the compliance with the following operational requirements:

- i. Facilities for emergency shutdown of compressor at low suction pressure, high discharge pressure and high differential pressure across suction & discharge of the compressor.
- ii. Facilities for emergency shutdown of compressor at high discharge temperature. Parallel operation and auto changeover of compressors shall not be envisaged. After completion of unloading of ammonia from the tank truck, the compressor must be switched off by means of a flow monitor and the unloading process completed.

7.1.5 Material of construction of compressor shall be suitable for handling anhydrous ammonia.

7.1.6 A clear space shall be provided around the compressor for inspection purpose.

7.1.7 Local control panels with all necessary controls, Protection & interlocking system for operating the compressors shall be provided. These controls shall be achieved through microprocessor based redundant controllers with Graphic User Interface (GUI) with LCD screen based display unit, control switches and other operational keys panels and hooked up to purchaser's DCS

7.2 Ammonia Storage Tank

7.2.1 The anhydrous ammonia storage tank shall be non-refrigerated, cylindrical, all-welded steel construction, complete with level, pressure, and temperature instrumentation, safety valves and vent/fill connections. The tank will be located outdoors at a location to be determined later.

7.2.2 The liquid capacity of the ammonia storage tank shall be as specified in Part III based upon an anhydrous ammonia flow. A margin of 20% shall be considered on the stoichiometric ammonia flow.

A vapour space of approximately 15 % of the total tank capacity shall be provided at the top of the tank. An optimized, cost effective arrangement of the storage facility shall be achieved. If more than one tank is provided per SCR unit, they shall be interconnected so either tank can be utilized to furnish the required ammonia flow to the system. The ammonia storage facility shall have the flexibility of being an emergency backup for number of units specified in enquiry.

7.2.3 The ammonia storage tanks shall be designed as per ASME Boiler and Pressure Vessel Code Sec VIII. The tank shall be fully welded construction. All welds shall be 100 % radiographed and stressed relieved. All connections to the tank shall be welded. No threaded connections are acceptable. Tank plate material shall be ASTM A516-Gr 70 or better.

7.2.4 The storage tank shall have the flexibility of accepting ammonia delivery by truck. Each ammonia tank filling connection shall be provided with a combination of back pressure check and excess flow valve to prevent massive ammonia leakage in the event of a catastrophic line break.

7.2.5 The storage tank and handling facilities shall be designed to the following codes and standards:



- a. IS 4544 latest edition
- b. CGA G_2.1—2014 6th Edition (formerly ANSI K61.1), OSHA etc.
- c. ASME Section VIII - Pressure Vessels
- d SMPV, Static Mobile Pressure Vessel

In addition, the Vendor shall be responsible for meeting all the latest local codes and standards for the safe storage of anhydrous ammonia.

7.2.6 Each tank shall be equipped with the following equipment as a minimum:

- a. One manhole shall be provided
- b. Pressure measurements (gauge/transmitter) connections with isolation valves
- c. Two (2) safety relief valves sized so that either valve can protect the tank

Note: The safety relief valve design shall permit maintenance and removal without draining the tank.

- d. Level Indicator/transmitter
- e. An ammonia sensor and alarm located near the vicinity of the tanks.

Note: The permissible liquid anhydrous ammonia level shall not exceed 85% of the tank's total capacity. The level measurement shall be capable of actuating an alarm signal in the main control room when the storage level reaches a low or high level. The low level alarm shall allow the plant a reasonable amount of time to order an additional shipment of anhydrous ammonia while operating the plant at full load capacity.

7.2.7 All materials furnished for the ammonia storage and handling facility shall be compatible with anhydrous ammonia. Use of copper, brass, zinc, galvanized steel and copper containing alloys are not acceptable. Cast iron fittings shall not be used.

7.2.8 All piping, tubing and fittings shall be at least ASTM A-53, Grade B seamless or electric resistance welded (ERW) pipe. All piping joints shall be fully welded. No threaded connections anywhere in the ammonia equipment shall be acceptable. Hydrostatic relief valves shall be included where there is a possibility of liquid ammonia being trapped between two valves.

7.2.9 All necessary platforms, grating, handrails, ladders, etc. shall be provided to access all instrumentation, hose connections, safety relief valves, safety equipment and maintenance items.

7.2.10 Tank supports shall be designed to minimize settlement or lateral movement. In addition, the supports should be capable of withstanding exposure to fire, wind, earthquake, floods, etc.

7.2.11 A water spray system shall be provided for cooling the tank and hence, controlling the vapour pressure inside the storage tank. The actuation of the spray system shall be connected to the local control system to initiate spray when the vapour pressure rises above permissible level. Local control panel with required control logics and interlocks shall be supplied by vendor.

7.2.12 A covering or canopy shall be furnished to protect the tank from direct exposure to sunlight.

7.2.13 The ammonia storage tanks shall be protected by guard posts or other appropriate traffic barriers.

7.2.14 The Vendor shall supply an eyewash and safety shower station in close proximity to the storage tanks. Additional safety equipment such as a face masks and canisters, gloves, boots, etc. shall be provided. The safety equipment shall satisfy international and local code requirements.



7.2.15 All primers and finish paints furnished by the Vendor shall be compatible for outdoor ammonia applications.

7.3 Ammonia Vaporizers

7.3.1 The ammonia delivery system shall be designed for vapour withdrawal from the storage tank. Two (2) x 100% capacity, ammonia vaporizers (electric/ steam) capable of furnishing the maximum design anhydrous ammonia flow rate shall be supplied.

7.3.2 The steam vaporizer assembly shall be installed in a natural circulation loop, taking liquid ammonia from the bottom of the storage tank and returning the vaporized ammonia to the top of the tank. All piping welds in this loop shall be stressed relieved. All piping connections shall be fully welded. Threaded connections are not acceptable.

7.3.3 Vaporizer operation shall be controlled by an adjustable pressure switch or transmitter on the storage tank. The vaporizers shall operate whenever the vapour pressure in the storage tank drops below the set-point.

The Vendor is to recommend the set point pressure range for the pressure switch.

7.3.4 A thermostat controller shall be located within each vaporizer to prevent overheating. The vaporizers shall be designed so they cannot be activated unless liquid ammonia surrounds the heating elements.

7.3.5 The vaporizers shall be capable of being independently isolated for maintenance without draining the ammonia storage tank.

7.3.6 Electric heating elements (if applicable) shall not be in direct contact with the ammonia. The vaporizers shall be designed for an electric source as specified in Part III.

7.4 Dilution Blower Skid

7.4.1 A separate dilution air skid located near the ammonia injection grid shall be provided. The skid shall include the following equipment:

- a. Ammonia flow control and stop valves
- b. Two 2x100% dilution air blowers
- c. Local skid piping and instrumentation
- d. Inline ammonia - air mixer

7.4.2 The skid shall be furnished complete with piping, valves and fittings. Design shall be in accordance with the ASME Boiler Code and the Power Piping Code ANSI B31.1. ANSI Standards B1.1, B2.1, and B18.2 shall govern all material and workmanship. All piping connections shall be fully welded.

7.4.3 All materials furnished shall be compatible with anhydrous ammonia. All instrumentation required for the safe operation and maintenance of the skid shall be provided.

7.4.4 Two (2)x100% dilution air blowers shall be furnished. The blowers shall be installed on the same skid. The following specified conditions, shall be provided by the vendor for each blower.

- a. Minimum air volume per blower
- b. Minimum discharge pressure per blower
- c. Maximum ambient air temperature



Operation of the blower shall be continuous even after the ammonia to the system has been terminated. The system shall also accept operation of two blowers at the same time. Capability of starting the idle blower within ten (10) seconds shall be provided.

7.4.5 Each blower shall be furnished with the following accessories:

- a. Flanged inlet and outlet connection with vibration isolators
- b. Inlet air filter
- c. Silencer to meet 85 d.BA at one (1) meter
- d. Motor as specified as in Part III
- e. Direct drive
- f. Local cabinet for manual start/stop capability
- g. Remote automatic start/stop capability
- h. Discharge line check valve to ensure no air backup through the idle blower

7.4.6 Checks on operation of all fans and all rotating equipment to ascertain level of noise and vibration.

7.4.7 Characteristic curves of the performance of both single and dual blower operation shall be provided. The Vendor shall ensure that the ammonia requirements of the SCR system do not necessitate having the concentration of ammonia in air above 5% by volume over the entire operating range of the unit. The Vendor shall also include the predicted sound pressure levels at one meter from the source during blower operation.

7.4.8 Vendor may recommend any other alternate dilution air source for purchasers review and acceptance.

7.4.9 A mixing device (if applicable), located on the skid, shall be furnished in the dilution air piping to ensure a homogeneous ammonia-air mixture to the ammonia injection inlet manifold.

7.4.10 The Vendor shall be responsible for testing all piping, hose and tubing at a pressure not less than the normal operating pressure to ensure a completely leak free system.

7.5 An ammonia sensor and alarm (local and remote) shall be located in close proximity to the dilution air skid area.

7.6 The Vendor shall supply an eyewash and safety shower station in close proximity to the dilution air skid. Additional safety equipment such as face masks and canisters, gloves, boots, etc. shall also be provided in this area.

The equipment shall satisfy international and local safety codes.

7.7 Ammonia Connecting Piping

7.7.1 The Vendor shall supply all required interconnecting piping between the ammonia storage tank/vaporizer skid and the dilution air skid, and from the dilution air skid to the ammonia distribution inlet manifold. All piping shall be selected for the safe installation of an above ground system compatible with anhydrous ammonia. Final location of the ammonia tank and the dilution air skid shall be specified by the Purchaser. The Purchaser shall review and approve all field run ammonia piping supplied by the Vendor.

7.7.2 All piping and fittings shall be at least ASTM A-53, Grade B seamless or electric resistance welded (ERW) pipe. All pipe joints shall be fully welded. Piping larger than NB 50mm shall be a minimum of schedule 40. All pipe sizes equal to or less than NB 50mm shall be a minimum of

	High Pressure Boiler Plant BHEL, Tiruchirapalli Specification for High Dust SCR system	TDN:SCR:001 Rev 00 Page 25 of 32
---	---	---

schedule 80. Hydrostatic relief valves shall be included where there is a possibility of liquefied ammonia being trapped between two valves.

7.7.3 Piping stress analysis, support details and locations shall be furnished by the Vendor.

7.7.4 All piping supplied by the Vendor shall be properly supported above ground.

7.8 Waste Ammonia Dilution Tank

7.8.1 The Vendor shall provide an ammonia dilution tank to thoroughly neutralize any ammonia gas and/or liquid discharge from the ammonia plant (various equipments). The dilution tank shall be sized to accommodate neutralizing the quantity of liquid ammonia resulting from the complete drainage of the ammonia storage tanks. An optimized arrangement using one (1) large tank to accommodate the number of SCR units specified in the enquiry.

7.8.2 The Vendor shall supply all required interconnecting piping from the ammonia equipment, relief valves, etc. to the dilution tank.

7.8.3 The dilution tank shall operate at atmospheric pressure via an atmospheric vent. Ammonia gas shall be prevented from escaping through the atmospheric vent. The vent line shall be extended beyond the canopy of the dilution tank along with rain cap.

7.8.4 Dilution tank shall be provided with a service water make-up line and a drain line along with control valve in each line. A motorized isolation valve shall be provided on the upstream of control valve and a manual isolation valve shall be provided on the downstream of control valve.

8. Ammonia Injection System

8.1 In general, the ammonia injection system shall consist of multiple flow control zones across the SCR inlet duct. Each zone shall be independently controlled by modulating flow control valves located on the piping exiting the ammonia distribution manifold. Individual injection pipes shall be configured with nozzles spaced uniformly across the inlet gas duct plane to enable thorough mixing of the ammonia/air mixture. Number of nozzles shall be suitably decided by the vendor and the supporting documents shall be furnished. Injection of ammonia shall be in the direction of the gas flow. Counter-current injection is not acceptable. All ammonia injection grid pipe openings shall be protected to avoid ash laden flue gas from plugging nozzles. The system shall be designed with external connections to allow a compressed air source to purge nozzles in any individual line.

8.2 The location of the ammonia injection grid in the ductwork shall ensure the uniform distribution of ammonia in the flue gas stream prior to entering the first catalyst layer. The ammonia injection grid shall maintain the ammonia to NO_x molar ratio at the entrance to the first catalyst layer to within +/-5% of theoretical requirements. The Vendor shall provide a test procedure for fine-tuning the grid and validating this criteria.

8.3 Ammonia injection grid piping NB 50 mm and larger shall be minimum ASTM A53, schedule 40 carbon steel pipe. Each branch shall have a manual flow regulating or throttling valve, flow orifice, and test connection with valve for a manometer. The ammonia inlet supply manifold shall be provided with temperature and pressure gauges.



8.4 All ammonia injection piping extending into the ductwork shall have carbon steel angle sections welded on the leading edge to minimize flue gas flow separation across the injection grid.

8.5 The ammonia injection grid shall be properly supported to prevent thermal distortion and damage due to vibration induced by the gas flow. The grid shall be designed for maximum thermal expansion, assuming no cooling is available from ammonia or dilution air. Flex hoses shall be furnished as required to connect the internal grid piping to external piping from the inlet manifold.

8.6 Detailed drawings of the Vendor's ammonia injection grid design shall be furnished to the Purchaser for review and approval.

8.7 The ammonia injection grid design shall be tested in a 1/10th physical flow model as in Clause No 5.0. Layout and number of ammonia injection nozzles, flue gas mixer design, and the location of the grid and gas mixer upstream of the catalytic layers shall be confirmed by flow model testing. Ammonia concentration uniformity shall meet the requirements specified in 8.2.

8.8 Alternatively, any other proven and successfully operating technology for ammonia injection into SCR system can be offered by vendor with sufficient technical back up documents subject to Purchaser's approval.

9.0 INSTRUMENTATION AND CONTROLS

9.1 Controls

9.1.1 All the control logics and interlocks required for the SCR system shall be furnished by the vendor for implementation in purchaser's DCS. The control system logics and interlocks shall ensure safe and efficient operation of the system.

9.1.2 The controls shall be based upon monitoring of NO_x at the inlet and outlet of the SCR reactor integrated with boiler load and the ammonia to NO_x molar ratio setting.

9.1.3 The control shall also include logics for all auxiliary equipment/systems associated with the SCR system, i.e., ammonia unloading, storage, handling and preparation system, dilution air supply system, ammonia injection system, de-dusting system and any other associated systems/equipment etc.

9.1.4 For the de-dusting system offered by vendor, all relevant control logics, interlocks and sequence of operation shall be provided by the vendor for implementation in purchaser's DCS.

9.1.5 All automatic controls, interlock/protection and monitoring shall have high integrity. No single failure / fault shall cause failure of the controls or cause the protection system to operate spuriously or become inoperative. All critical logics in the control system shall be structured with triple redundancy so that no single failure within the control system can cause the failure of SCR system / plant.

9.1.6 The control panels associated with the system shall be located in purchaser's control equipment room. However, vendor shall provide local control panels wherever necessary, based on process control requirements. Irrespective of location, these panels shall communicate with the purchaser's DCS, as applicable.



9.1.7 The Vendor shall provide a complete description of the SCR system's control and operation including cold, warm and hot start-up and shutdown procedures and normal operation. A Complete description of the process and the control logic write-up shall be supplied.

9.1.8 As a minimum, the following signals shall be included in the vendor's control logic and shall be used for alarm/indication/SOE in the Purchaser's DCS. The list of signals listed is indicative only and vendor to include additional signals as applicable. The complete list of signal shall be finalised during the detailed engineering stage.

- a. SCR gas temperature "Low"
- b. SCR gas temperature "High"
- c. SCR differential draft loss "High" - monitored across SCR system and across each catalyst layer
- d. Dilution air flow "Low"
- e. "Loss of power"
- f. Ammonia shutoff valve "Closed/Open"
- g. Ammonia storage level "Low" and "High"
- h. Ammonia storage pressure "High" and "Low"
- i. Indication of SCR inlet and outlet NO_x-O₂ values
- j. Indication of SCR system gas draft loss
- k. Ammonia flow
- l. Indication of SCR gas temperature (three locations)- upstream of ammonia injection grid, upstream of the first catalyst layer and on the last layer of catalyst
- m. Dilution air blower on/off - specified for each blower
- n. Ammonia liquid storage level in the tank
- o. Ammonia storage pressure
- p. Ammonia slip

Note: Alarm set points shall be specified by the Vendor. All Instruments required for the generation of the above signals shall be supplied by the vendor.

9.1.9 Requirement of any other controls/system not specified herein, but shall be a requirement for the intended process shall be judiciously decided by the vendor and supplied along with the system.

9.2 Instrumentation

9.2.1 Vendor shall provide complete instrumentation for the SCR system and other associated systems specified under section 4.

9.2.2 The minimum requirement/quantity of instruments/equipments shall be as indicated in the P&ID. However, Vendor shall include the additional instruments/equipments if required, to meet the process requirement. Vendor shall consider redundancy for instruments as specified in the detailed specification.

9.2.3 NO_x analyser shall be provided to continuously measure NO_x emissions in the ductwork upstream of the ammonia injection grid and in the outlet duct directly below the SCR reactor chamber. An air conditioned cabinet shall house the two rack-mounted inlet and outlet analysers. All analog inputs/outputs shall be 4- 20mA (2 wire) signals. All digital input/output signals shall be dry contacts.

9.2.4 In addition to the NO_x analysers, other analysers such as O₂ and SO₂ SCR reactor inlets and NO_x, O₂, SO₂, NH₃ Analysers at SCR reactor outlets shall be provided by the vendor. Other instruments such as differential pressure transmitter to measure draft loss across all/individual



catalyst layers, gas temperature measurements at upstream of the ammonia injection grid and before the first catalyst layer, catalyst surface thermocouples on the last active catalyst layer, local pressure and temperature indicators shall also be provided.

9.2.5 In addition to the NH₃ analyser at SCR reactor, acceptable wet chemistry methods shall be used for ammonia level measurements at the outlet of the reactor chamber are required.

9.2.6 For other auxiliary systems such as the Ammonia unloading, handling, storage and preparation system, Ammonia injection system, dilution air supply system and De-dusting system, complete instrumentation shall be provided by the vendor.

9.2.7 The material of construction of all instruments/equipment and the sensing element in all the instruments shall be decided by the vendor to suit the process medium. However, the same shall meet the minimum requirement of the detailed specifications (Refer annexures) as applicable.

9.2.8 All local instruments shall be suitably grouped and mounted on (LIR) local instrument racks located at appropriate places. All process transmitters shall be housed in (LIE) local instrument enclosures. All the field equipment, drives & instrument enclosures shall be suitable for the Hazardous area of classification.

9.2.9 Individual pair shielded and overall shielded instrumentation cables shall be used for interconnection of analog signals. Overall shielded cables shall be used for interconnection of digital signals. Instrumentation cables used for feedback signals from field and control cables used for command signals to field instrument/equipment shall be separated and shall be terminated in different junction boxes.

9.2.10 All the equipment in vendor's scope shall be suitable to operate in the power supply/voltage ratings indicated in Annexure-Q (electrical power supply details).

10.0 PAINTING AND FINISHING

10.1 Painting

The Vendor shall perform surface preparation, primary and finish painting in accordance with the manufacturer's standards for all exposed surfaces. Painting schedule shall be furnished for purchaser's review and approval.

10.2 Marking

- a) Stainless steel nameplates with following boldly engraved shall be firmly fixed to the body: Maker's name & production serial number and technical/process parameters.
- b) Each spare shall be individually tagged with part name, maker's name & spare code.

10.3 Packing

- a) All opening shall be firmly capped against ingress of water or dust.
- b) Shall be roadworthy/seaworthy packed in wooden boxes with water proof under cover.
- c) Liberal packing material & struts shall be used to arrest rolling & to protect from transit damages.



11.0 SPARES AND SPECIAL TOOLS

11.1 Mandatory spares as per the list enclosed separately shall be offered.

11.2 Vendor shall recommend one (1) year spare parts necessary for maintaining the SCR equipment.

11.3 The item wise price for the spares (recommended and mandatory) offered shall be mentioned.

11.4 Vendor shall supply the required commissioning spares at the time of commissioning at site.

11.5 Special tools or materials shall be furnished, as required, for the proper handling, storage, erection, start-up and maintenance of the Vendor's equipment.

12.0 INSPECTION AND TESTING

12.1 Access to the Vendor's or sub-contractor's manufacturing facilities shall be provided for the purpose of inspecting the work and witnessing testing of the SCR equipment. At least two (2) weeks advance notice shall be given by the Vendor to the Purchaser or his representative.

12.2 Acceptance of the Vendor's equipment shall be based upon the successful completion of performance tests carried out by the Purchaser. The Vendor shall submit correction curves for gas temperature, oxygen content, flue gas volumetric flow and inlet NO_x for determining performance for off- design field operating conditions. The Vendor shall provide a field representative to assist in tuning of the ammonia grid and advise the Purchaser during all performance testing.

12.3 The Vendor shall submit a performance test procedure as well as plans for tuning all furnished equipment for the Purchaser's review and approval.

12.4 All performance tests confirming SCR guarantee requirements shall be in accordance with acceptable EPRI testing methods or equivalent.

13.0 TRAINING

13.1 The Vendor shall provide a one (1) week training program for the Purchaser's personnel to operate and maintain the equipment supplied by the Vendor.

13.2 The training program shall include a description of the equipment, the proper operation of the system, the limits of the design, and the recommended maintenance (including module storage and disposal) and inspection procedures. Training manuals shall be submitted to all participants. Both classroom and field instruction shall be provided by the Vendor.

13.3 The Vendor shall submit a copy of the proposed training manual three (3) months prior to training for the Purchaser's review and approval.



14.0 DOCUMENT SUBMITTAL REQUIREMENTS

14.1 The following documents, drawings and information shall be furnished by the Vendor along with the offer:

Point-wise confirmation to the technical specification. Any deviation shall be clearly brought-out separately along with proper technical justification for Purchasers review.

14.1.1 General arrangement of SCR reactor & systems including but not limited to the following:

- a) SCR housing and ductwork dimensions including terminal points
- b) Catalyst module dimensions and arrangement within the reactor chamber
- c) SCR housing and ductwork loadings
- d) SCR catalyst and reactor chamber and loading plan – elevation wise
- e) SCR catalyst handling load and location sketch
- f) SCR catalyst loading intensity for floor design
- g) Canopy requirements (if any) of reactor chamber and sketch
- h) Sample and Recommended structural arrangement and cautions to be taken in steel design
- i) No bracing and no beam zone marked in arrangement drawing (if applicable)
- j) Cable, rack and any other loading requirements to be taken care by the steel design
- k) Horizontal guide loads and location (Support and seismic/wind guide requirements)
- l) Expansions required to interface with the Purchaser's ductwork and support steel
- m) Structural steel support and access platform requirements. The Vendor must maintain support points, box dimensions, etc. to those shown on the SCR arrangement drawing.
- n) Proposed monorail and hoist arrangement, handling procedure
- o) Internal and external support steel requirements and loadings for the installation and removal of catalyst modules
- p) Access door locations and dimensions in the SCR reactor housing and associated ductwork
- q) Ammonia injection grid location, supports and access requirements. The support documents for number of nozzles and its arrangement
- r) Flue gas mixing devices including location, dimensions, support details and access requirements (if applicable)
- s) De-dusting equipment locations and internal/external support requirements and access requirements
- t) Dilution air skid size and location
- u) Piping layout and proposed support from dilution skid to ammonia injection distribution manifold

14.1.2 Other documents

- a) Ammonia consumption calculation and storage tank sizing calculation
- b) All essential Civil inputs for ammonia dyke area shall be furnished
- c) Confirmation of the Purchaser's information shown on plant arrangement drawings
- d) All P & I diagrams along with write up and applicable valve schedule for all related systems
- e) Control logic diagrams including a list of all analog and digital inputs and outputs associated with the SCR control system
- f) Proposed permanent sealing method with a detailed description of the sealer material and material safety data sheet for sealer
- g) Proposed catalyst disposal requirements and procedures
- h) Proposed module activity tests and recommended ten (10) year replacement schedule



- i) Summary of predicted performance at all operating load conditions specified in Part III.
- j) Utility consumption list (i.e., auxiliary steam, service air, instrument air, service water, etc.).
- k) Summary of operating and installed power for all supplied equipment
- l) Auxiliary Power Consumption
- m) Recommended list of one (1) year spare parts
- n) Instrument List clearly indicating the Scope of Instruments.
- o) Drive List indicating type of drive (pneumatic, electric, LT motor, valve/damper etc.), Voltage, Type of power supply, rating, FLC, Speed
- p) List of Analog and Digital I/Os
- q) Electrical Load list indicating Voltage, Type of power supply, rating, location of load
- r) List of Local control panels indicating the system which is controlled from the local panel
- s) List specifying the systems which are controlled from purchaser's DDCMIS.
- t) List of all bought-out items with vendor details. The vendors are subject to Purchaser's review and approval.
- u) Filled in data sheets (Refer Part –III).
- v) Terminal Point drawing/document with well-defined boundaries for scope.

14.2 The following documents, drawings and information shall be furnished by the Vendor on award of the contract:

- a. Detail drawings of the hydraulic trolley and spreader beam for the catalyst installation.
- b. Test port and instrument locations including number of proposed sampling probes and locations for permanent instrumentation
- c. Structural steel drawings of reactor housing and internals including catalyst support steel and installation rails, monorail support steel, soot blower support steel, casing details, internal baffles, sealing plates, etc.
- d. Ductwork drawings showing internal supports, sealing plates, vaning, baffles, access door locations, test port locations, instrumentation locations, etc.
- e. Soot blower arrangement drawings including details of internal lances and supports, proposed supply piping layout to a common terminal point, piping support requirements, etc.
- f. Detail drawing of ammonia storage tank including associated piping, instrumentation, support, etc.
- g. Detail drawing of ammonia vaporizers.
- h. Ammonia piping layout drawings including support details from the storage tanks to the vaporizer skid and from the vaporizer skid to the dilution air skid. Drawings shall also provide details of the ammonia accumulator.
- i. Detail drawings of the neutralization tank including location, all instrumentation and interconnecting piping.
- j. Module handling, storage, installation and removal procedures.



- k. Operating instruction manuals (minimum 3 manuals along with soft copy). The manuals shall contain complete operating and maintenance instructions for the care and operation of the Vendor's equipment.
- l. List of all bought out items along with technical specification, datasheets and support documents.
- m. Details of the Vendor's training program per the requirements listed in Clause 13.
- n. Submittal of physical flow model test report.
- o. Completely Filled in Data sheets
- p. The Vendor's control philosophy shall be incorporated into the Purchaser's overall distributed control system. As a minimum the following information shall be provided by the Vendor in order to assist the Purchaser in the detailed design of the control system:
 - i. P&IDs with write up
 - ii. SCR digital logic diagrams & Write-up for SCR and all associated systems
 - iii. SCR analog logic diagrams & Write-up for SCR and all associated systems
 - iv. SCR graphic display diagrams
 - v. Interconnection drawings, Location of JB's, Local panels, cable lists
 - vi. Instrument List, Drive List, I/O List, Electrical Load list as per the purchaser's format
 - vii. Signal exchange list between SCR control system and plant control system
 - viii. Alarm and SOE list
 - ix. Valve/dampers list
 - x. Equipment/Instrument grouping, LIE/LIR grouping list
 - xi. Instrument installation drawings/ Hook up drawings
 - xii. Instrument air requirement
 - xiii. Vendor datasheets and O&M manuals
 - xiv. Quality Plan, Inspection and Test Plan, Type test certificates
 - xv. Any other drawings/documents found applicable during contract stage
 - xvi. Vendor to clearly furnish the special requirements to be taken care by purchaser for equipment/instruments in Purchaser's scope.

	High Pressure Boiler Plant BHEL, Tiruchirapalli Specification for High Dust SCR system	TDN:SCR:001 Rev 00 Part III
--	---	--

Part-III

Contract specific Requirements

Project Name: DN104



List of Documents

S.No.	Description	
1	Performance and Guarantee	
2	SCR Selection sheet	
3	Fuel Analysis	
4	Site Condition	
5	Electrical C&I Specifications	
5.1	Terminal Points for Electrical C&I Equipment- Annexure P	
5.2	Electrical Power supply Details – Annexure Q	
5.3	Specification for Electric Actuators – Annexure R	
5.4	Specification for Motors – Annexure S	
5.5	Specification for Field Instruments and Analysers – Annexure U	
5.6	Specification for Cables, Cable Trays and Cable Glands – Annexure V	
5.7	Specification for Local Panels/Cabinets, LIE/LIR, JB, Erection materials – Annexure W	
5.8	C&I Input for Selection of Mechanical Equipment	
6	Data Sheets	
7	Process and Instrumentation Diagrams	
7.1	Scheme of De-NOx system – Key Diagram	(1-SR-DNX-00006)
7.2	Scheme of De-NOx system – Ammonia Unloading and Storage system	(1-SR-DNX-00002)
7.3	Scheme of De-NOx system – Ammonia Vaporizer and Accumulator	(1-SR-DNX-00003)
7.4	Scheme of De-NOx system – Boiler Island	(1-SR-DNX-00004)
7.5	Scheme of De-NOx system – Waste ammonia handling, Safety system	(1-SR-DNX-00005)
8	SCR Arrangement drawing	(0-SK-SCR-00004)



PERFORMANCE AND GUARANTEE

The Supplier shall Guarantee that the equipment/materials furnished hereunder will be entirely suitable for the service specified, conform to all conditions of performance and design, be free from manufacturing and material defects.

The Supplier shall guarantee the following based on all operation conditions for any coal specified, during the guarantee of catalyst life, unless otherwise specified:

A) Overall NOx removal efficiency (%)	
B) NOx content of the flue gas as measured downstream of the SCR system (ppm vol dry. as O ₂ 6%)	
C) Ammonia slip as measured downstream of the SCR reactor (ppm vol dry as O ₂ 6%)	
D) Conversion rate of SO ₂ to SO ₃ (%)	
E) Catalyst life (after Commercial Operation Declaration) to meet the NOx removal efficiency and ammonia slip (From the point of boiler flue gas passing through SCR De-NOx system initially) - with the initial charge of catalyst (Operating Hours)	
F) SCR De-NOx system gas side draft loss (mmH ₂ O) - With all catalyst including future layer at BMCR (max. pressure drop) - With the initial fresh/dirty catalyst at TMCR	
G) Ammonia consumption at TMCR (kg/h unit)	
H) Molar ratio of NH ₃ to NOx	
I) Auxiliary Power consumption at TMCR-Design coal	

Project Name: DN104
SCR Selection Sheet Rev 00

PROJECT DN104

TDN:SCR-001 / Part III

Page 4 of 108

Sno	Description	Units	Load					
			BMCR- Design Coal	TMCR- Design Coal (Guarantee Condition)	HP Out- Design Coal	60TM- Design Coal	BMCR- Worst Coal	TMCR- Worst Coal
1	Flue gas flow at Economiser Outlet	kg/hr	3155188	2900772	3064522	1843000	3191530	2927988
2	Flue gas temperature entering SCR	deg C	363	355	288	317	361	353
3	Total Volumetric Gas Flow at Actual Temperature	m3/hr	5799978	5255022	4966810	3113176	5856018	5266165
4	Total Volumetric Gas Flow at 0 deg C	Nm3/hr	2488048	2284428	2415712	1440503	2521598	2296587
5	Pressure at SCR Inlet	mmWC	-87	-75	-80	-72	-89	-77
6	Flue gas constituents, Wet Basis - % By Weight							
i	CO ₂	%	20.573	20.573	20.573	20.573	20.426	20.426
ii	N ₂	%	68.426	68.426	68.426	68.426	68.204	68.204
iii	O ₂	%	3.438	3.438	3.438	3.438	3.427	3.427
iv	SO ₂	%	0.116	0.116	0.116	0.116	0.132	0.132
v	H ₂ O	%	7.448	7.448	7.448	7.448	7.810	7.810
7	SO ₃ in Flue gas at SCR Inlet at 6% O₂ dry volume basis	ppm	6.60	6.60	6.60	6.65	7.49	7.54
8	Inlet Particle Dust Concentration	gm/Nm3	22.8	22.8	22.7	22.3	36.6	36.9
9	Permissible SO ₂ to SO ₃ conversion in SCR at 6% O₂ dry volume basis	%	Less than 1 %					
10	NO _x concentration to SCR Inlet at 6% O₂ dry volume basis	mg/Nm3	300 to 325					
11	NO _x required at SCR Outlet at 6% O₂ dry volume basis	mg/Nm3	Less than 100					
12	Maximum Permissible slip	ppm	3					

Note:

- 1) A variation of +/- 5% may be considered on the flue gas volume for design
- 2) Maximum pressure drop allowed : 100mmWC (From Eco Outlet to SCR Outlet including duct losses)
- 3) Required Catalyst life: Minimum 16000 hrs after Commercial Operation Declaration (both mechanical and Chemical Life)
- 4) Reagent Used : Anhydrous Ammonia (99.5%)
- 5) Min distance between Catalyst modules = 1300mm
- 6) Liquid capacity of ammonia storage tank should be for 14 days
- 7) Ammonia tank to be located 1.2 km from boiler area

Project Name: DN104 SCR Selection Sheet Rev 00

Fuel Analysis

DESCRIPTION (Source / Type)	UNIT	DESIGN COAL (70% IMP + 30% DOMESTIC COAL)	WORST COAL (50% IMP + 50% DOMESTIC COAL)	BEST COAL (100% IMPORTED COAL)	DOMESTIC COAL (FOR INFORMATION)	Range of Coal (Imported)
PROXIMATE ANALYSIS						
Fixed carbon	%	34.3	30.22	40.43	20	30 - 50
Volatile matter	%	31.22	27.73	36.45	19	25 - 45
Moisture	%	16.35	16.25	16.5	16	Upto 23 Max
Ash	%	18.13	25.8	6.62	45	6.62
Total	%	100	100	100	100	
HHV	kcal / kg	4789.4	4221	5642	2800	5800 - 6500
LHV	kcal / kg					
ULTIMATE ANALYSIS						
Carbon	%	50.4	43.91	60.12	27.7	
Hydrogen	%	3.85	3.49	4.38	2.6	
Sulphur	%	0.52	0.52	0.53	0.5	Upto 1 Max
Nitrogen	%	1.19	1	1.48	0.52	
Oxygen (difference)	%	9.44	8.82	10.37	7.26	
Moisture	%	16.35	16.25	16.5	16	
Ash	%	18.13	25.8	6.62	45	
Carbonates	%	0.11	0.19	0	0.38	
Phosphorous	%	0.01	0.02	0	0.04	
HARD GROVE INDEX						
		52	52	51	45 - 55 (Avg. 52)	45 - 60
ASH CHARACTERISTICS						
IT - Initial deformation temp.	°C	1191	1165	1230	1100	1100 - 1250
ST - Softening temp. H = W	°C	1249	1235	1270	1200	
HT - Hemispherical temp. H = W / 2	°C	1314	1310	1320	1300	
FT - Fusion temp.	°C					
ASH CONSTITUENTS						
A - SiO ₂	%	43.06	47.77	36	59.54	
A - Al ₂ O ₃	%	18.43	21.45	13.9	29	
B - Fe ₂ O ₃	%	12.29	10.81	14.8	6.42	
B - CaO	%	9.34	7.1	12.7	1.5	
B - MgO	%	6.17	4.55	8.6	0.5	
B - Na ₂ O	%	0.51	0.39	0.7	0.08	
B - K ₂ O	%	1.19	0.85	1.7	0	
A - TiO ₂	%	1.04	1.2	0.8	1.6	
P ₂ O ₅	%	0.29	0.36	0.2	0.51	
SO ₃	%	7.5	5.43	10.6	0.25	
Others	%	0.18	0.3	-	0.6	
Base / Acid Ratio		0.42	0.31	0.63	0.1	
Fe ₂ O ₃ / CaO Ratio		1.32	1.49	1.17	4.28	
Chloride						



Project Name: DN104
SCR Selection Sheet Rev 00

Site Condition

1. Ambient temperature (Design & Guarantee of SG) : 30 Deg.C
Ambient temperature (Max.) : 37.8 Deg.C
Ambient temperature (Min.) : 22.3 Deg.C
2. Relative Humidity (Design & Guarantee of SG) : 75 %
3. Height above M.S.L : 4.8 m
4. Seismic Load Data*
Zone : Zone II
5. Wind Data*
Basic wind speed : 47 m/s

Terminal Points for Electrical C&I Equipments

a)	Remote pressure, level, flow measurements	:	Up to field junction boxes for vendor supplied equipment mounted instruments. Up to root valves for purchaser supplied line mounted instruments
b)	Remote temperature measurements	:	Up to field junction boxes for vendor supplied equipment mounted instruments. Up to tapping point stub with M33x2 (F) Thread, for purchaser supplied line mounted instruments
c)	Test temperature tappings Pressure & Flow Test pockets	: :	Thermowell with caps Up to root valves
d)	Electric drives (LT Motors and servomotors)	:	Terminal box with cable glands.
e)	UPS, 220 V DC, 240VAC	:	At individual equipment's input terminal
f)	Signals from/to motorized actuators to/from DDCMIS	:	At actuator terminal box.
g)	Signals from/to local control panels	:	At the terminals of local control panels
h)	Pneumatic Control valves and regulating actuators.	:	Integral terminal box. All signals of valves shall be internally wired & terminated in the Integral Junction Box for external connection to DDCMIS
i)	Instrument air distribution	:	Equipment end
j)	Earthing	:	Equipment terminals

Electrical Power supply Details:

1. The voltage level for motors shall be as follows:
 - a) Up to 0.2 KW: Single phase 240V AC / 3 phase 415V AC, 50 Hz
 - b) Above 0.2 KW and up to 200 KW: 3 phase, 415V AC, 50 Hz
 - c) Above 200 KW and up to 2000 KW: 3 phase, 6.6 kV AC, 50 Hz
 - d) Above 2000 KW: 11 kV, 50 Hz
2. DC System Voltage: 220 V DC
3. UPS Power supply: 240 V AC, 50 Hz
4. Utility Power supply (Space Heating, Lighting): 240 V AC, 50 Hz



ANNEXURE - R

Electrical actuator - (Open/Close duty&Inching duty applications)

Sl. No.	Details	Requirements
1	Actuator Application	Open/Close or Inching or Regulating duty, suitable for Valve/damper applications. Suitable gearboxes shall be coupled (if required) to achieve the torque requirements of the load. Actuator mounting shall be suitable to the load requirement.
2	Actuator type	Electrical Actuator with integral starter for Open/Close and inching duty applications.
3	Actuator Duty	The actuator shall be of Open/Close or Inching or Regulating duty as per the application requirement.
4	Actuator Construction	Totally enclosed weatherproof construction meeting IP 68 protection class requirements. All the gears available in the actuator shall be of metal (Fiber gears are not acceptable). Actuator shall have self-locking facility.
5	Manual operation through Hand-wheel	Shall have a lever and hand wheel mechanism for manual operation. The hand wheel mechanism shall be designed such that it is declutched automatically when the power supply to the motor, is restored.
6	Torque requirement	Shall be designed to meet with the required torque at the output shaft as per the load requirement. The adjustable range of run torque and starting torque of actuator shall be indicated (in kgm) for the actuator offered.
7	Operating time	The operating time of the actuator required for the complete travel has to match with the load requirement.
8	Supply voltage	415 V, 3 phase AC supply, 50Hz.
9	Power supply variation	The actuator shall operate without any trouble under power supply voltage variation of $\pm 10\%$ of the rated value, power supply frequency variation of $\pm 5\%$ of the rated value, combined voltage and frequency variation of 10% of the rated value.
10	Motor type & construction	Motor type shall be of Squirrel Cage induction type (or) Permanent Magnet Synchronous motor (or) BLDC.

Sl. No.	Details	Requirements
		Shall be of Totally Enclosed, Self-Ventilated construction with weather proof enclosure conforming to IP-65. Shall have double shielded, grease lubricated anti-friction bearings.
11	Motor Insulation	Shall have class F insulation with temperature rise of the motor winding limited to Class B. Motor winding shall be tropicalized, suitable for the site conditions. Temperature rise over ambient temperature of 50°C shall be 70°C.
12	Motor duty cycle	The duty cycle of the motor shall be short time S2 duty cycle rated for the period of operation of 15 minutes or rated for 3 successive open-close operations whichever is longer. For inching duty, motor shall be suitable for 150 starts/hour. For regulating duty, motor shall be S4 duty with Cyclic Duration Factor of 60% and suitable for 1200 starts/hour.
13	Motor Starting	Motor shall be suitable for direct on-line starting. Starting current shall be limited to 6 times the full load current exclusive of tolerance. Shall be capable of starting at 85% of rated voltage and Running at 80% of rate voltage for a period of 5 minutes.
14	Standards	Actuator shall be conforming to IS-9334 or any other equivalent international standard for all requirements. Motor shall be conforming to IEC-60034, IS-325 or any other equivalent international standard for all requirements.
15	Motor Thermostat	Motor winding shall be provided with inbuilt thermostat connected in series (one thermostat in each phase) and shall be wired to terminal box.
16	Space heater	Shall have a space-heater with suitable rating and the power supply shall be derived internally from the main power supply.
17	Earth terminals	2 Nos. of earth terminals shall be provided on the body of the motor.



Sl. No.	Details	Requirements
18	Torque & position limit switches	2 numbers of adjustable torque limit switches (one for open and one for close), each with 2 NO and 2 NC potential free contacts. The torque limit switches shall have calibration in Kg-m (for whole actuator including gear box if supplied), so that the switches could be easily set to any desired value, within the range specified for each actuator. Torque switches shall be bypassed in both the end positions using the position Limit switches available at the other end of the travel. Actuators shall have provision for bypassing the torque switch during initial 5% opening of valves. 4 numbers of position limit switches, rotary drum type capable of being set at any position(2 nos. for open and 2 nos. for close) each with 2 NO & 2 NC potential free contacts. All Gear train mechanism shall be made of suitable metal only. Shall be enclosed in a dust & weather proof compartment and the compartment shall have enough space suitable for calibration. Contacts of limit and torque switches shall be Silver plated having high conductivity and non -corrosive type. Contact rating of all the above limit switches shall be 5 A at 240 V AC and 0.5 A at 220 V DC.
19	Local position indicator	Shall be provided to indicate 0 to 100% travel.
20	Positioner Controls (Applicable only for regulating duty applications)	Actuator shall be provided with an electronic positioner and related electronic controls required for positioning the actuator, accepting 4-20 mA command signal. Shall have following standard, adjustable control features in the actuator. <u>SPAN :-</u> To calibrate the position feedback signal with the travel of the actuator for 100% range of position demand signal. <u>ZERO :-</u> To calibrate the position feedback signal with the travel of the actuator for minimum value of demand signal. <u>DEAD BAND :-</u> The actuator should meet the process requirements.

Sl. No.	Details	Requirements
		<u>STAYPUT :-</u> The positioner shall have STAYPUT characteristics on loss of the demand signal. Solid State reversing circuit shall be provided for forward and reverse operation of the actuator.
21	Position Feedback transmitter	For inching duty and regulating duty applications, position feedback transmitter has to be supplied. Shall be 2 wire, non-contact type (LVDT) electronic position transmitter with an output of 4-20 mA DC and shall be loop powered from external power supply. The output shall also be capable of driving minimum 500 Ω load in the control circuits.
22	Internal wiring	Shall be done with 1.5 sq.mm PVC insulated, stranded copper wire of 650V grade for control signals. For Power circuits, internal wiring shall be done using suitable size of stranded cables, taking care of the motor current rating. Ferrules should be used for easy identification. Internal wiring and the terminal block drawing shall be neatly pasted on the internal side of the terminal box. 9 Pin Plug in connections shall be provided between external customer connections and actuator.
23	Terminal box	All terminals of the position limit switches, torque limit switches, space heaters shall be terminated in the terminal box. The terminals shall be of cage clamp type suitable for the cables of size 2.5sq.mm. Minimum 6 numbers of spare terminals shall be made available in the terminal board. Terminal box of actuator shall be weatherproof conforming to IP 65 and shall have enough space for connecting cable glands. Terminal box shall be fitted with a removal front cover-plate.



PROJECT: DN 104

Sl. No.	Details	Requirements
24	Cable Termination philosophy	Termination of Power Cable :- Double compression type, Brass with Nickel plated cable glands shall be provided for the termination of power cable. Motor terminals shall be of stud type. Cable gland along with blanking washers shall be selected suitable for the power cable sizes as indicated below. a. Up to 3 kW – 3C x 2.5 sq.mm. Copper, OD – 17 mm $\pm$ 2 mm. b. > 3 kW & up to 7 kW - 3C x 6 sq.mm, Aluminium, OD – 19 mm $\pm$ 2 mm. Termination of Control Cable:- 3 Nos. of Double Compression type, Brass with Nickel plated cable glands have to be supplied for the termination of the control/instrumentation cables suitable for a cable OD of 18mm.
25	Fasteners	All fasteners used in the equipment shall be of a corrosion resistant material.
26	Paint & finish	All external Parts shall be finished and painted to produce a neat and durable surface which would prevent Corrosion & Rusting.
27	Lubricant	The gear box of the actuator shall be either oil filled or grease filled.

Technical Description of the Electronic Integral Starter			
1	Integral starter	Control logic of the starter shall be designed using suitable electronic control circuit. The starter shall have the following minimum features : • Power supply isolation switch & fuses of suitable rating. • Thermal Over load relay. • Lockable Local- Off -Remote selector switch. • Push buttons for Local Operation (OPEN, CLOSE, STOP) • Indication lamps (OPEN, CLOSE, TRIP) • Remote Signal interface • Output Contacts • Status/Fault annunciation	

2	Open/Close Command	Interposing relays of coil burden $\leq 2.5\text{VA}$ shall be provided to initiate opening and closing using 24V DC signal from the external control system. Actuator shall also be suitable for remote operation by potential free contacts for Open/Close & Stop, the necessary 24V DC power supply shall be derived internally. Open/Close command termination logic with position and torque limit switches shall be suitably built inside the starter Electrically & mechanically interlocked contactors shall be provided for forward and reverse operation. Contactor rating shall be sufficient to withstand the extreme conditions like valve jamming and instantaneous reversal of motor.	
3	Protection Features in Starter	Shall have various protection features such as Single Phasing prevention, Wrong phase sequence protection, Overheating protection through thermostat, Short Circuit protection, Overload, Supply Under Voltage, over and above other standard protection features as per manufacturer's design.	
4	Control Supply	Control supply voltage of the starter shall be 24V DC. If other control voltage rating is used, then the same shall be derived internally by the manufacturer. Necessary primary and secondary fuses shall be provided. Opto isolation circuit shall be provided with suitable coupling relays for 24V DC commands from external control system.	
5	Local Operation	Provision shall be available to operate the actuator locally. Lockable local/remote selection shall be provided on the front panel of the actuator.	
6	Status indication	The following status indication signals shall be provided in the actuator over and above the standard signals available in the actuator as per the manufacturer's standard • Actuator Open • Actuator Close • Actuator in travel	



7	Output Contacts	A Common potential free contact for collective fault annunciation of following faults such as Thermal Overload trip, Motor Thermostat trip, Control supply failure, Power Supply Failure/Single Phasing, Local/Remote switch in LOCAL/OFF, Torque Switch acted along with Other protections acted shall be provided for customer use. Potential free contacts shall be provided for Local/Remote/Off positions of the selector switch.	
8	Fault Annunciation	The following fault annunciation signals shall be provided in the actuator over and above the standard signals available in the actuator as per the manufacturer's standard • Open Torque Switch/Close Torque Switch acted • Motor thermostat trip • Motor Overload relay acted Actuator shall have necessary provision for diagnosing the fault locally.	
9	General features to be provided in the actuator	Open Torque Switch shall be bypassed initially for 3 seconds or 5% of the valve travel. It should be possible to reverse the direction of travel for inching duty application. Automatic phase correction facility and single phasing prevention shall be provided.	
10	Details to be furnished	The ratings of the various components of the starter, various signal exchanges to/from the starter and the wiring interconnections shall be clearly indicated in the wiring drawing of the actuator.	

Pneumatic Actuator-Regulating type

SL. NO.	DETAILS	TECHNICAL REQUIREMENTS	
1)	General :		
	This technical specification covers the requirements of Regulating Duty, pneumatic actuators, SMART positioner and accessories, to be used for control damper applications.		
2)	Actuator :		
a)	Actuator type	• Double or Single acting type, to suit the application. • Piston operated type. • The actuator shall be sized to meet the requirements of the load.	
b)	Actuator Duty	Regulating duty	
c)	Actuator mounting type	The actuator mounting shall be of any one of the following types. • Stand mount type with output shaft and output lever. The actuator shall be connected to the load through linkage rod mechanism. (Or) • Direct Mount type : The actuator (piston rod) shall be directly connected to the load. The actuator shall have trunnion base.	
d)	Actuator assembly	The actuator base shall be suitable for mounting the cylinder and for fixing the foundation bolts. The entire arrangement should be able to withstand the load and torque requirements.	
e)	Air Supply	Power Air	Minimum: 3 Kg/sq. cm (g) Maximum: 7 Kg/sq.cm (g)
f)	Stroking time	To suit the process requirement.	
g)	Action on Loss of Power Air Supply.	To suit the process requirement.	
h)	Action on Loss of Command Signal.	To suit the process requirement.	
i)	Position indicator	1 No. local mechanical position indicator is required.	



PROJECT: DN 104

j)	Provision for reversal of action	Actuator assembly to be configured in Direct acting. Provision to change to reverse action shall be provided
3)	Material :	
a)	Piston rod	Hard chrome plated high strength steel. Leather bellows / Gaiters shall be provided to prevent actuator inner parts from rusting.
b)	Piston	High Strength Steel.
c)	Actuator body/Cylinder barrel	Honed & hard chrome plated seamless Carbon steel.
d)	Actuator seals	Viton.
e)	General	Necessary surface treatment shall be provided for all the components (as applicable) to prevent rust and corrosion.
4)	Limit Switch :	
a)	Quantity	One for open and one for close.
b)	Number of contacts	In case of SMART positioner, 1 NO + 1 NC
c)	Type	Snap action
d)	Limit Switch Enclosure	Dust & Weather Proof, IP-65
e)	Contact Rating	5A at 240 V AC / 0.2A at 220 V DC.
f)	Make	Shall be as per the manufacturer's standard.
5)	Air Lock Device :	
a)	Type	Set point has to be adjustable. Self-Reset.
6)	Air filter cum regulator:	
a)	Supply air pressure	7 Kg / sq.cm
b)	Type	Diaphragm
c)	Pressure rating	15 Kg / sq.cm
d)	Filter Material	Phosphor Bronze
e)	Body	Die-cast aluminium
f)	Inner valve, seating and spring	Stainless steel
g)	Enclosure protection	IP-65
h)	Output pressure	0 – 7 Kg / sq.cm
i)	Filter Element	Phosphor Bronze
j)	Filter size	5 microns
k)	Drain	Auto Drain feature shall be provided
l)	Accessories	Blow down valve shall be provided

7)	Pressure gauge :	
a)	Dial	50 mm Diameter
b)	Type	Bourdon
c)	Material of sensing element (Bourdon)	Phosphor bronze
d)	Range	0 – 10 Kg / sq. cm
e)	Accuracy	± 5%
f)	Make	Shall be as per manufacturer's standard
g)	Air connection inlet	Air connection inlet shall be suitable to accept ¼" OD PVC sheathed copper tube
8)	Hand wheel / Lever	To be provided along with actuator for manual operation.
9)	Integral Junction Box	
a)	Junction Box	All the electrical connections from the accessories, shall be wired suitably as per the wiring drawing to the junction box. Protection Class: IP-65. Terminal blocks shall be of Cage-Clamp type, suitable for 2.5 sq.mm. Cable.
b)	Termination of external cable to the Junction box.	3 nos. of double compression type brass with nickel plated weather proof cable glands suitable for cable OD of 18 mm.
10)	Linkage rods for Stand mount type pneumatic actuators.	The Linkage rods shall be supplied as per the drawings referred in the purchase enquiry. The application names & tag nos. have to be painted on the linkage rods for easy identification.
11)	Painting/Finish for both Power Cylinder & Linkage rods	
a)	Paint Shade	Shall be as per manufacturer's standard
b)	Finish	Corrosion resistant, Epoxy based resin.
12)	Packing	Shall be as per manufacturer's standard practice. The packing shall be suitable for safe transport, safe delivery at site and shall be suitable to avoid damages due to water entry and shall withstand the environmental conditions during storage at site.

SMART positioner (For Control Valve and Damper applications)

Sl. No	Technical Description/Requirement	
1	Make of the SMART positioner	Vendor to specify.
2	Type of Input	4-20 mA, 24 V DC, 2 wire system (Loop powered from DCS)
3	Operational signal range	3.6 mA - 21 mA (4-20 mA). Split range operation shall also be possible.
4	Voltage	12 to 36 V DC
5	Input impedance	Vendor to specify



PROJECT: DN 104

Sl. No	Technical Description/Requirement	
6	Supply Air pressure	3 – 7 Kg/cm ²
7	Air Capacity	Vendor to match with the requirement of the actuator.
8	Sensitivity, Accuracy, Repeatability, Hysteresis	Vendor to match with the requirement of application requirement.
9	Type of Acting (Direct/Reverse)	Vendor to match with the requirement of the actuator.
10	Flow Characterization	SMART positioner shall be compatible to fit valve characteristic curves, Linear/Equal percentage etc.
11	Stroke time	Vendor to match with the requirement of the actuator.
12	No. of pneumatic outputs (Single/Double)	Vendor to match with the requirement of the actuator.
13	Pneumatic Process Connection	To suit the impulse line as per the process P & ID.
14	Communication by Hart Protocol	SMART positioner shall be compatible for Remote calibration & Diagnostics using Hart Management System.
15	Calibration	SMART positioner shall be compatible for Auto Start with self-calibration, Remote calibration from Hart Management System & manual calibration using push buttons available on the positioner.
16	Position sensing & feed back	Output:4-20mA position feedback signal shall be provided.
17	Electrical Cable entry	Side or bottom entry to avoid water ingress.
18	Protection Class	IP-65
19	Action required during 4 to 20 mA control signal failure.	SMART positioner shall be compatible for achieving Fail Open, Fail Close & Stay put (Fail freeze) functions to be configured at site.
20	Accessories	For Supply & output pressure, pressure gauges shall be provided on the positioner.
21	EMC Compliance	SMART positioner shall conform to EMC Compliance as per international standards IEC/EN. 61000-4-2/3/6/12
22	Diagnostic Features	1. Soft Open / Close limit switch output. 2. Alarm on loss of demand signal. 3. Fault. 4. Manual/Auto operation indication. 5. Alarm on Power air failure. 6. Travel/ Stroke counter. 7. Diagnosis of leakage in actuator.

Sl. No	Technical Description/Requirement	
		8. On line partial closure test (as per requirement of valve) 9. Valve signature analysis 10. Valve friction/jamming detection 11. Step Response Test
23	In built Operator panel	The positioner shall have a display with push buttons for configuration and for read out. The same shall be Password protected/Hardware lock
24	Mounting Assembly	Required mounting accessories & fasteners for mounting the positioner on valve actuators shall be provided.



ANNEXURE-S

LT AC Motor

Sl. No.	Description	Requirement
1	General Description	Squirrel cage type induction motor, suitable for direct on line starting.
2	Applicable Standards	IS-325, IS-1231, IS-6362, IS-2253, IS-5572, IS-12065, IS-12075, IS/IEC-60079, IS-12615, IS/IEC-60529 & IEC-60034. (Latest version of relevant standards shall be referred)
3	Type of enclosure	Totally Enclosed Fan Cooled (TEFC), IP-55 as per IS/IEC-60529. Motors located in hazardous area shall have flame proof enclosure as per IS/IEC -60079. Vendor to provide flame proof enclosure as per the area of classification, meeting the requirements of type of fuel being.
4	Duty Cycle	Continuous, S1
5	Energy Efficiency Class	IE-3 as per IS-12615/IEC 60034-30.
6	Rated Voltage & Tolerance	415 V, AC, 3 Phase, $\pm 10\%$.
7	Rated Frequency & Tolerance	50 Hz, $\pm 5\%$
8	Combined voltage & frequency tolerance	10 % (absolute sum)
9	General Requirements	a. All motors shall be so designed that maximum inrush currents, locked rotor and pull out torque developed at extreme voltage and frequency variations do not endanger the motor and driven equipment. b. Motor shall be designed to keep torsional and rotational natural frequencies of vibration at least 25 percent above the motor rated speed ranges to avoid resonant vibration over the operating speed range of the motor and driven equipment. c. Maximum continuous rating (MCR) of the motor shall have at least 15 % margin over the maximum load demand of the driven equipment including voltage and frequency variation. (Applicable only if vendor supplies motor along with the driven equipment or load). d. Requirements during running :- The motor shall be capable of operating satisfactorily at

Sl. No.	Description	Requirement
		full load for 5 minutes without injurious heating with 75 % rated voltage at motor terminals. The motor shall be designed to withstand momentary over-load of 60% of full load torque for 15 seconds without any damage. The motor shall be designed to withstand 120 % of rated speed for 2 minutes without any mechanical damage. e. Requirements during starting :- Motor shall start with rated load and accelerate to full speed with 80 % rated voltage at motor terminals The motor shall be capable of withstanding the stresses imposed if started at 110 % rated voltage. f. Torque requirements :- Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% of motor full load torque. Pull Out torque at rated voltage shall not be less than 205 % of full load torque
10	Class of Insulation	Class-F insulation with temperature rise limited to Class-B. Temperature rise of the motor shall be limited to 70°C (by resistance method) over an ambient temperature of 50°C
11	Stress withstanding capability during Bus Transfer	The motor shall be suitable for sudden application of 150 % of rated voltage during bus transfers, due to the phase difference between the incoming voltage and motor residual voltage.
12	Capacity to restart for rated voltage	a. Two successive starts from cold condition b. Three equally spread starts per hour c. Two hot starts in succession, with motor initially running at normal temperature.
13	Locked Rotor Condition	The ratio of Locked Rotor KVA at rated voltage to rated KW shall not exceed as indicated below, including tolerance - For Motor rating < 110KW : 10 - For Motor rating ≥ 110KW : 9
14	Locked Rotor with-stand time	For motor with starting time up to 20 seconds at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 2.5 seconds more than starting time. For motor with starting time more than 20 seconds but not



Sl. No.	Description	Requirement
		exceeding 45 seconds at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 5 seconds more than the starting time. For motor with starting time more than 45 seconds at minimum permissible voltage during starting, the locked rotor withstand time under hot condition at highest voltage limit shall be 10% more than the starting time Vendor to provide Speed switches mounted on the motor shaft in case the above requirement is not met with.
15	Type of balancing of rotor	Dynamic balancing
16	Method of cooling	IC-0411 as per IS-6362
17	Direction of cooling air flow	NDE side to DE Side
18	Direction of rotation	As required by the drive equipment, the motor shall be suitable for operation in both directions of rotation. A plate showing direction of rotation, as determined by the phase sequence on the terminals marking shall be screwed at non-driving end of the body of the motor.
19	Winding wire	Enameled Copper Wire, Grade-2, as per IS-13730, Part-3. Windings shall be non-hygroscopic, oil resistant and flame resistant.
20	Treatment on Winding Insulation	Winding Insulation shall be given tropical and fungicidal treatment for operation of motor in hot, humid & tropical climate.
21	Starting Current	The starting current shall be limited to 600 % of FLC, inclusive of tolerance as per the IS standard.
22	Noise level	Noise level shall be limited to 85 dB at 1.5 meter distance from the outer surface of the motor.
23	Vibration level	The peak amplitude of vibration shall be as per IS-12075 (Limits of Severity-Normal grade shall be followed).
24	Shaft extension	Motor shall be provided with key slotted bare shaft extension, with key at the drive end.
25	Terminal box	Flame proof as per IS/IEC-60079, capable of being turned through 360° in steps of 180°. Terminal box shall have adequate space to terminate the Power cable applicable to the motor by using suitable lugs. Minimum Distance between center of the terminal stud & the gland plate and Minimum inter-phase/phase-earth air clearance shall be provided as per the details indicated in the annexure (project specific requirement). 1 No. Earth terminal shall be provided inside the terminal

Sl. No.	Description	Requirement
		box. Connection diagram shall be marked inside the terminal box. The motor terminal box shall be suitable for withstanding the system fault current of 50 KA for a duration of at least 0.25 seconds, without any rupture.
26	Cable Entries, Cable Glands & Lugs	Cable entries, Cable glands and Lugs shall be provided suitable for the power cable size as indicated in the annexure (project specific requirement). Double Compression type, brass with nickel plated flame proof cable glands shall be supplied – Quantity to be matched with the number of entries. 3 Nos. of Tinned Copper Lugs shall be provided.
27	Terminals	Separate Terminals for Space heaters and Windings with suitable connecting links shall be supplied.
28	Body Earth	Shall have 2 Nos. of earth points (Threaded hole with suitable GI Bolt) at appropriate location (in motor base frame).
29	Space heater for motors rated 30 KW and above	Separate space heater suitable for 240 V AC, Single Phase supply shall be provided.
30	Lifting provision	Eye bolt.
31	Bearing	Bearings shall be of ball or roller type effectively sealed against ingress of dust. The bearing shall be so constructed that the loss of lubricating grease is kept to minimum. Bearing shall be rated for a minimum standard life of 40000 hours.
32	Tests (Certificates shall be furnished)	• Measurement of resistance of windings of stator and wound rotor. • Reduced voltage running up test at no load (for squirrel cage motors). • No load test. • Full load test to determine efficiency, power factor and slip. • Insulation resistance test. • High voltage test • Test for vibration severity of motor. • Test for noise levels of motor. • Test for degree of protection by enclosure. • Temperature rise test at limiting values of voltage and frequency variations. • Over speed test. • Locked rotor readings of voltage, current and power input at a suitable reduced voltage.



Sl. No.	Description	Requirement
33	Project specific requirements	- All LT motors 15 KW and above shall be provided with external greasing arrangement. - All motors for outdoor duty shall have detachable metal canopy.
34	Name Plates	Motor shall have name plate as per relevant IS and in addition, Manufacture's name, frame size, Energy Efficiency class, Insulation class designation shall also be indicated.
35	Documents to be submitted by the vendor for approval by BHEL/Customer, after placement of purchase order.	3 Sets of the following :- - Final technical Data sheet as per the format submitted by BHEL. - Motor GA drawing indicating foundation, shaft details and terminal box arrangement with complete dimensions. - Motor Characteristic curves (Torque Vs. Speed, Current Vs. Speed, Speed Vs. time, Current Vs. time, Efficiency and PF Vs. load, Thermal withstand characteristic)
36	Packing	Shall be as per manufacturer's standard practice. The packing shall be suitable for safe transport, safe delivery at site and shall avoid damages due to environmental conditions during storage at site.

Cable Entry Details

Vendor to provide the cable entry in the motor suitable for the power cable sizes indicated below. However, the sizes indicated herein are only tentative and shall be finalised during detailed engineering.

Sl. No.	From (KW)	To (KW)	Power Cable size in sq. mm.
1.	0.01	1	3C-10mm ² (AL)
2.	1.01	2	3C-10mm ² (AL)
3.	2.01	3.7	3C-10mm ² (AL)

4.	3.71	5.5	3C-10mm ² (AL)
5.	5.51	7.5	3C-25mm ² (AL)
6.	7.51	9.3	3C-25mm ² (AL)
7.	9.31	11	3C-25mm ² (AL)
8.	11.1	15	3C-50mm ² (AL)
9.	15.1	18.5	3C-50mm ² (AL)
10	18.51	22.0	3C-50mm ² (AL)
11	22.1	27.0	3C-95mm ² (AL)
12	27.1	30.0	3C-95mm ² (AL)
13	30.1	37.0	3C-95mm ² (AL)
14	37.1	45.0	3C-95mm ² (AL)
15	45.1	55.0	3C-150mm ² (AL)
16	55.1	64.8	3C-150mm ² (AL)
17	64.9	75	3C-240mm ² (AL)
18	75.1	90	3C-240mm ² (AL)
19	90.1	110	2-3C-150mm ² (AL)
20	110.1	125	2-3C-150mm ² (AL)
21	125.1	160	2-3C-240mm ² (AL)

Dimensions of Terminal Boxes (Flame proof motors)

Sl. No.	Motor MCR in KW	Minimum Distance between centre of stud and the gland plate (in mm)
1	Up to 3 KW	As per manufacturers' practice



2	Above 3 KW – Up to 7 KW	85
3	Above 7 KW – Up to 13 KW	115
4	Above 13 KW – Up to 24 KW	167
5	Above 24 KW – Up to 37 KW	196
6	Above 37 KW – Up to 55 KW	249
7	Above 55 KW – Up to 90 KW	277
8	Above 90 KW – Up to 125 KW	331
9	Above 125 KW – Up to 200 KW	403

Phase to Phase/Phase to earth air clearance

Minimum inter-phase and phase-earth air clearance for LT motors with lugs installed shall be as follow

Sl. No.	Motor MCR in KW	Clearance (in mm)
1	Up to 110 KW	10
2	Above 110 KW – Up to 150 KW	12.5
3	Above 150 KW	19

ANNEXURE - U**FIELD AND MEASURING INSTRUMENTS****Field & Measuring Instruments (Primary & Secondary Instruments)****1.01 General requirements**

The instrumentation and control equipment shall conform to all applicable codes and standards. The instrumentation/control equipment and accessories shall be from the latest proven design for which the performance and high availability have been demonstrated by a considerable record of successful operation in power station service for similar applications.

For plug in type instruments, the plug & sockets shall be polarized to prevent wrong connections and have facility for secure coupling in plug-in position to prevent loose connections.

Signal/Electrical connection shall be screwed connection with double compression type Nickel- plated brass cable glands for Explosion proof area, Flame proof area and high vibration prone area.

Every instrument requiring power supply shall be provided with a pair of easily replaceable glass cartridge fuse of suitable rating. Every instrument shall be provided with a grounding terminal and shall be suitably connected to the panel grounding bus.

All field instruments shall be weatherproof, drip tight, dust tight and splash proof suitable for use under outdoor ambient conditions prevalent in the subject plant. All field-mounted instruments shall be mounted in suitable locations where maximum accessibility for maintenance is achieved. The enclosures of all electronic instruments shall conform to IP-65 unless otherwise specified (Explosion proof for NEC article 500, class 1, Division 1 area & flame proof) and an anticorrosive paint shall be applied to the field mounted enclosures / instruments. All the field instruments shall also be provided with SS tag nameplate and double compression type Nickel-plated brass cable gland. Gaskets, Fasteners, Counter and mating flange shall also be included wherever required with the field instruments.

Following minimum requirement of field instruments shall be fulfilled by Bidder :-

- a. Level Transmitters (Type as per Owner approval) for open sump / tank /bunker / vessel / heaters.
- b. Stand pipes on both side of tank for all level instruments (LT, LS & LG).
- c. Flow elements (Type as per Owner approval) with flow transmitter & Flow meter for flow measurement of process medium like Steam, Water, Air, Flue Gas as decided by owner.



- d. Pressure gauges and temp. Gauges at inlet and outlet of each heat exchanger and cooler.
- e. DPG, DPT & DPS across the filters/strainers.
- f. Tapping points/test points shall be provided.
- g. All Thermocouples & RTDs (Type as per Owner approval) shall be Duplex. Thermocouples shall be provided for Services with Temperature > 200 °C.
- h. All Field Instruments used in acid or alkaline atmosphere shall be with standard Anti corrosion coating i.e. the combination of Polyurethane and epoxy resin baked coating (ANSI/ISA-71.04).
- i. All primary instruments installed at "Minus level or Floor" shall be with protection class of IP-68.
- j. Transmitters (all type) for monitoring & control purpose.
- k. All field mounted push button, selector switch etc. shall be as per IEC or NEMA 4X protection.
- l. All limit switch shall be conform to IEC-60947-5-1 and shall have minimum 2SPDT/DPDT contacts.
- m. Temp. Transmitters are envisaged with RTD & Thermocouples for monitoring services / application only. However any RTD & Thermocouples are used for control, interlock & protection application, same shall be directly wired to DDCMIS/DCS using instrumentation & Extension cables respectively.
- n. As for the water flow/ steam flow measurements, necessary flow elements/transmitters are chosen in the process line and supplied such that their algebraic summation shall be mass balanced for calculating the system efficiency.
- o. Non-contact type electronic 2-wire position transmitters shall be provided for all inching type motorised valves and dampers.
- p. Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application. For hazardous area, explosions proof enclosure as described in NEC article 500 shall be provided.
- q. Gauges (all type) for local monitoring in field.
- r. Each switching element including the limit and torque switches of valve actuators shall be provided with minimum two contacts i.e. 2SPDT or DPDT.
- s. All instruments should be supplied with valid calibration and test

certificates provided by OEM.

- t. Canopy/Enclosures shall be provided for field instruments like transmitters, switches & flow meters, etc. and any other equipment to protect from direct sun light, lightning & rain.

- u. **Redundancy:-**

Triple measurement scheme: Triple measurement scheme for analog inputs employing three independent transmitters connected to separate tapping points shall be employed for the most critical measurements. The same shall be used in analog control functions and all other trip & protection logics etc.

Dual measurement scheme: For binary and analog inputs required for other modulating control, protection and interlock purpose of other equipment and other critical monitoring application etc., minimum dual sensors shall be provided. Dual measurement scheme for analog inputs employing two independent transmitters/temperature element, connected to separate tapping points shall be employed for the remaining measurements used for analog control functions.

For binary and analog inputs used for alarm and monitoring only, single sensor criteria shall be applicable.

All the instruments/sensors/transmitters/switches meant for redundant applications shall have completely separate and independent impulse pipes/ root valves etc. No redundant instrument shall share a single process tapping. There will be separate and independent tapping for every individual instrument.

1.01 Transmitters, Switches, Gauges and Panel Mounted Instruments

I. Pressure, Differential Pressure, DP type Level and Flow Transmitters (PT, DPT, LT & FT)

Smart Transmitters of the electronic type shall be furnished. All Transmitter shall be installed in closed LIE in the boiler area. Transmitters shall be equipped with mounting brackets suitable for a mounting in transmitter enclosures.

In general, Transmitters are envisaged to be grouped at several places as to be decided during detailed Engg. Stage. For this purpose, suitable enclosures complete with all tubing, fittings, purge meters, loop cable trays etc. shall be provided.

S.No	Features	Essential / Minimum Requirements
1	Type/Construction	Sealed capacitance/ Inductance/ Silicon resonance type
2	Material	
	Body	Die cast Aluminium with epoxy coating for air & SS 316 With Teflon seal for process requirement/process media for other services
	Diaphragm	



S.No	Features	Essential / Minimum Requirements
	Measurement element	SS 316 (Suitable material/coating for Hydrogen pressure transmitters/Differential pressure transmitters)the suitable material/coating shall be chosen as per the suggestion of transmitter manufacturer.
	Valves	Carbon steel for non-corrosive applications &SS 316 for corrosive applications
3	Output Signal	4 to 20 mA. DC (Two wires) HART Compatible
4	Local Indicator	LCD indicator (5 digit) with scale of Engg. unit
5	Overall Accuracy	± 0.04% or better of Span for BTG package ± 0.065% or better of Span for BOP packages ± 0.2% or better of span for remote seal type transmitter.
6	Turn down ratio	100:1 in general 10:1 for vacuum/very low pressure applications. 10:1 for very high pressure application. 30:1 for other applications
7	Stability	+ 0.15% of URL for 5 years.
8	Response time	150 msec.
9	Power supply	24V DC nominal
10	Load Impedance	500 Ohms (min.)
11	Drive capability	600 Ohms nominal
12	Enclosure Class	IP-65 (Explosion proof for NEC Class-1, Division
13	Span and Zero	Locally adjustable, non-interacting
14	Zero suppression / elevation	At least 100% of Span
15	Connection	
	Process	Half (1/2) inch NPT (F) Quarter (1/4) inch NPT with / without ovalflanges
	Electrical	Suitable for Plug in type connection (Both side of transmitter), unused entry with blind plug.
16	Accessories	
	For Absolute Pressure Transmitters	Two (2) valve SS 316 manifold
	For Gauge & transmitter Vacuum pressure	Three (3) valve SS 316 manifold
	For DP, level & flow transmitter	Five (5) valve SS 316 manifold
	For oil and corrosive liquids	Separator diaphragm seals
	For all transmitters	Mounting bracket
	Steam Service	Syphon
	Pumps Discharge service	Snubbers
17	Adjustment / calibration From hand held calibrator / centralized OWS based system / maintenance (as applicable).	From system hand held calibrator / centralized OWS based

S.No	Features	Essential / Minimum Requirements
18	IBR Requirement	For high pressure service, Process tapping and root valves are as per IBR rules and regulations

Manifold should not be mounted on the transmitter, Manifold shall be non-integral and standalone type. Snubbers/Pulsation dampeners shall be used where the process media is unstable for measurement such as the discharge of a pump. Over range protection shall be used where necessary. The coil syphons& condensate pots shall be used for steam services. Transmitters shall be provided with suitable drain & vent points.

Transmitters, smart positioner & other HART based instruments shall be supplied along with 4 Nos. of universal type hand held/portable calibrators. Temperature transmitters shall be supplied along with 4 Nos. of hand held/portable mV source generators/signal reader.

If one type of hand held type calibrator is not suitable for communicating with all types of transmitters then separate hand held calibrator will be provided.

I. Pressure Switches (PS) & Differential Pressure Switches(DPS)

S.No	Features	Essential / Minimum Requirements
1	Applicable Standards	IS3624 – 1966/ISA-RP-8.1
2	Materials	
	Bellows	SS 316
	Bourdon tube	SS 316
	Movement	SS 316
	Enclosure	Die-cast aluminium with stoved enamel black finish. Epoxy coating shall be provided for corrosive atmosphere.
3	Type/Construction	Bourdon/Sealed Diaphragm Piston Actuated preferable. Indicators with contacts are not acceptable.
4	Protective Diaphragm	Teflon
5	Accuracy	± 1 % or better of full range
6	Repeatability	± 0.5 (half) percent or better of full range
7	Setting & Differential	Adjustable
8	Contact	
	Number	DPDT /2 SPDT
	Type	Auto reset with internal Adjustable snap action micro switch
9	Rating	5 A, 240 V AC / 0.2 A, 220 V DC
10	End connection	½" NPT (F) / Manufactures Standards



S.No	Features	Essential / Minimum Requirements
11	Connection - instrument	Half (1/2) inch NPT Male Process
12	Electrical	Suitable for Plug in type connection. All the switches are internally connected and brought to the surface with Amphenol male/female connection. Cabling need not terminated inside the switch. Cable ends are to be soldered in connector and to be inserted for easy maintenance.
13	Over range protection	One Fifty (150) percent of full scale
14	Enclosure Class	IP-65 or better (Explosion/Flame proof for NEC Class-1, Division 1 area)
15	Dead band adjustment	Adjustment up to 10% at set points.
16	Accessories	
	3 / 5 valve manifold	As applicable for all switches
	Self-cleaning type pulsation dampners / Snubbers (Material SS 316)	Pump and compressor
	Syphon	For all steam lines
	Protective separating diaphragm	For fuel oil & corrosive liquid lines.
	Mounting	Local (in LIE / LIR for BTG package)
17	IBR Requirement	For high pressure service, Process tapping and root valves are as per IBR rules and regulations

II. Pressure & Differential Pressure Gauges (PG &DPG)

S.No	Features	Essential / Minimum Requirements
1	Applicable Standards	IS:3602-1966, IS/3624, ASME B 40.1
2	Type / construction	
	760 mm to 1.0Kg/cm ²	Bellows/Diaphragm
	Above 1.0Kg/cm ²	Bourdon Tube
	Suction side of pumps	Compound gauge
3	Materials	
	Bellows	SS 316
	Bourdon tube	SS 316
	Movement	SS 316
	Case Enclosure	SS 316 / Die-cast aluminium with stoved enamel black finish. Epoxy coating shall be provided for corrosive atmosphere.
4	End connection	½" NPT (M)
5	Protective Diaphragm	Teflon
6	Dial Size	150mm with shatter proof glass

7	Scale Details	Graduations in black lines on white dial, on white dial, 270 degree pointer deflection scale provided with glass cover. Smallest scale division shall be one (1) percent of full scale value or smaller. Pointer stop for all gauges.
8	Range Selection	Cover 125% of max. of scale
9	Accuracy	± One (1) percent or better
10	Instrument process connection	½" NPT Male (Back Entry)
11	Mounting Type	Local / 1/2 inch NPT Male (Back entry) mounted on local gauge board.
12	Protection Class	IP-65 or better (Explosion/Flame proof for NEC Class-1, Division 1 area)
13	Accessories	
	3 way needle valve / manifolds	For all gauges
	Self-cleaning type	Pump and compressor discharge (Pulsation dampener / Snubbers (SS 316) lines
	Syphon	For all steam lines
	Protective separating	For fuel oil and corrosive liquid lines
14	Other Particulars	
	External Zero adjustment /	For all gauges
	Ranges 5 to 20 Kg/cm ²	Rubber blow out disc with open front
	Ranges above 20 Kg/cm ²	Neoprene safety diaphragm at the back with solid front construction.
15	Over range protection	150 %of full scale
16	Over Range Test	Test pr. For the assembly shall be 1.5 to the max. Design pr. At 38°C
17	Other Requirements	Movement mechanism shall be glycerin filled for oil services & vibration prone area.
		For Fuel oil & corrosive liquid lines diaphragm type sensors required. Armoured capillary of 10 M for Fuel oil & Corrosive liquid service.
		Contact type pressure gauges are not acceptable for interlock & protection.
		For condensate storage tank the pressure gauge in terms of 0-10000 mmwcl or suitable range having dial size of 300mm or bigger size shall be provided.
18	IBR Requirement	For high pressure service, Process tapping and root valves are as per IBR rules and regulations



1.02 Temperature Related Instruments

a) Temperature Transmitters(TT)

S.No	Features	Essential / Minimum Requirements
1	Type	SMART type configurable from control room through HART protocol (HMS System).
2	Display type	Indicating type (5 digit LCD Display)
3	Accuracy	$\pm 0.10 \%$,
4	Ambient temperature error	0.1 % per 10°C change
5	Input	Same transmitter shall be capable to handle Pt-100 RTD, Thermocouples –K & R types (input type to be selectable at site through HART terminal)
6	Output	4-20 mA DC (2 wire system) HART compatible signals for analogue monitoring inputs to the distributed control system (DDCMIS), DCS & PLC.
7	Isolation	Min. 500 V AC
8	EMC compatibility	as per EN 61326
9	Operating ambient temperature	0 to 85 ° C (without indicator) 0 to 70° C (with indicator)
10	Protection class	NEMA 4 / IP66 or equivalent degree of protection for enclosure)/ (Explosion / Flameproof for NEC Class-1, Division 1 area) / flame proof (IEC-79.1, Part I). As applicable).
11	Material of accessories	SS 316
12	Stability	$\pm 0.1 \%$ or $\pm 0.1 ^\circ \text{C}$ of reading (whichever is great) for 2 years in case of RTD inputs and for 1 year in case of Thermocouples inputs.
13	Operating Voltage	16 – 48 V DC
14	Calibration	As per NIST monograph 125 for T/C & European Curve Alpha = 0.00385 for RTD.
15	Ref. Junction compensation	Provided
16	Span/zero adjustment	Locally adjustable, Non interacting
17	Auto calibration	Provided
18	Burn out protection upscale	Provided
19	Input - output isolation	Provided
20	Circuit ungrounded	Provided
21	Accessories	Mounting arrangements including Clamps etc.

S.No	Features	Essential / Minimum Requirements
22	Composite Accuracy	For head mounted and DIN-rail mounted type RTD $\leq 0.4\%$ of 0 - 250 °C span For dual-input type: RTD $\leq 0.25\%$ of 0 - 250 °C span
23	For head mounted and DIN-rail mounted type RTD $\leq 0.4\%$ of 0 - 250 °C span For dual-input type: RTD $\leq 0.25\%$ of 0 - 250 °C span	Temperature transmitters of this category shall be field mounting type & shall be capable of withstanding operating ambient temperature up to 70 °C. These modules shall be connected to DDCMIS through field bus such as Profibus, Foundation Field bus etc. directly from the transmitter. Maximum Number of inputs per such temperature transmitter shall be eight. These shall be mounted in cabinets in non-AC areas. As an alternate, these signals from temperature transmitters can be connected to DDCMIS through standard remote I/O modules of the DCS, in which case, the temperature transmitter signals will be acquired through 4 - 20 mA input modules in the remote I/O cabinet for connecting to DDCMIS through remote I/O bus.

Any RTD or Thermocouples shall be directly wired to DDCMIS/DCS/PLC for metal temperature application, bearing & winding temp application only.

The Temperature transmitter shall accept Universal dual inputs of all types of thermocouples & RTD, 0-5V input signals etc.

Temp. Transmitter shall be extremely stable against ambient temp variation, the accuracy figure shall be inclusive of effect due to ambient temperature variation.

Temperature Transmitters shall not be used for CLCS, OLCS, interlock & protection services anywhere in the plant with RTD & Thermocouples. However RTD & Thermocouples are used for control, interlock & protection application, same shall be directly wired to DDCMIS/DCS/PLC using instrumentation & Extension cables respectively.

These transmitters shall be connected with duplex sensors and shall have bump less change over facility to second sensor in case first sensor fails .This change-over is to be alarmed.

b) Resistance Temperature Sensors (RTD) with Thermowells

S.No	Features	Essential / Minimum Requirements
1	Applicable Standard	ASME PTC 19.3 - Latest Revision DIN EN 60751:1996, BS EN/IEC60751: 2008



S.No	Features	Essential / Minimum Requirements
2	Element	Platinum, R0=100 ohm 4-wire, Duplex for Process Temp. Measurement Platinum, R0=100 ohm 3-wire Duplex for Bearing & Winding Temp. Measurement
3	Sheath Material/ Insulation	SS 316/Compacted Magnesium Oxide (Purity above 99.4%)
4	Sheath O D	8 MM
5	Gauge	18 AWG
6	Terminals	Spring loaded high temperature ceramic base with silver plated brass for high vibrating locations.
7	Calibration	As per DIN Standard – 43760/IEC 60751, Class A
8	Head	Hex Head, DieCast Aluminium (Screwed) with galvanized SS
9	Response Time	6-10 Seconds bare & 30 Seconds. With protective sheath / thermo well
10	Accuracy	$\pm 0.35^{\circ}\text{C}$ or Class-A whichever is better.
11	Electrical connection	Gold plated Plug in type. Double entry – one unused entry with blind plug
12	Enclosure Class	IP-65 or better (Explosion/Flame proof for NEC Class-1, Division 1 area)
13	Response Time	Repeat and contradictory.
14	Accessories	i. Adjustable nipple-union-nipple with thermowell ii. Compression fittings/unions Flanges etc. (for flanged connections only) iii. SS 316 forged thermo well as per ASME PTC (Latest version)
THERMOWELL		
15	Applicable Standard	ASME PTC 19.3 TW - 2016
16	Construction	Tapered drilled from Bar stock (Straight for Air & Gas systems)
17	Material	SS 316/F11/F22/F91 - water and steam Services depending upon process parameters. Inconel for air & flue gas services
18	Process Connection	(i) M 33 x 2 (ii) SS 316 Flanged, for Air & Gas systems, with mating flanges, fasteners, gasket etc.

S.No	Features	Essential / Minimum Requirements
19	Extension	Threaded union (SS 316) 1/2" NPT (F) with two nipples of SS 316 having 1/2"NPT(M) threads at both ends
20	Immersion length	Within ± 10 mm of centre line of pipe and as per ASME – PTC-19.3 - 2016
21	Extension neck length	Minimum 100 mm above insulation of pipe and Minimum 160 mm when there is no insulation on pipe.
22	IBR Certification	For high pressure service, Steam Temp. measurement as per IBR rules and regulations
	Note : In case, Duplex RTDs are not provided by bidder due to system/equipment limitation, two no. simplex RTD shall be provided instead of Duplex RTD. Both Simplex RTD shall be terminated at local JB/Termination Box.	

c) Thermocouples (T/C with T/W) With Thermowells

S.No	Features	Essential / Minimum Requirements
1	Applicable standard	ASME PTC 19.3- Latest Revision ANSI-MC 96.1 – 1982,
2	Element	Duplex
3	Sheath	8 MM OD
4	Sheath Material	SS 316
5	Spring Loaded	Yes
6	Nipple/Union	Yes
7	Packed connector	Compacted magnesium Oxide ungrounded
8	Type	i. Type K (Chromel -Alumel) ii. Type S/R (PlatinumRhodium-Platinum) iii. Type T (Cu-CuNi) with special limits to the standards
9	Gauge	16 AWG
10	Head	Die Cast Aluminium
11	Electrical connection	one unused entry with blind plug
12	Enclosure Class	IP-65 or better (Explosion/Flame proof for NEC Class-1, Division 1 area)
	Thermo well	
13	Construction	Tapered Drilled from Bar stock (Straight for Air & Gas systems)



S.No	Features	Essential / Minimum Requirements
14	Material	SS 316/F11/F22/F91 - water and steam Services depending upon process parameters. - Inconel for air & flue gas services Bidder shall provide calculation for thermo well as per ASME – PTC-19.3 2016.
15	Process Connection	SS 316 Flanged, for Air & Gas systems, with mating flanges, gaskets, fasteners etc.
16	Extension	Threaded union (SS 316) 1/2" NPT (F) with two nipples of SS 316 having 1/2"NPT(M) threads at both ends
Accuracy (Special Class as per IEC-751/ANSI-C-96.1)		
17	(For Type K T/C)	$\pm 1.1^{\circ}\text{C}$ (for 0 to 277°C) $\pm 0.4\%$ (for 277 to 1280°C) Class-A
18	For Type S & R T/C	$\pm 0.6^{\circ}\text{C}$ or $\pm 0.1\%$
19	For Type T T/C	$\pm 0.5^{\circ}\text{C}$ or $\pm 0.4\%$
20	Accessories	Bolts, nuts and gaskets for flanged connections.
Response Time (Bare Thermocouple)		
22	All applications	10 Sec.
23	Immersion length	As per ASME – PTC-19.3 - 2016
24	Extension neck length	Minimum 100 mm above insulation of Pipe and minimum 160 mm when there is no insulation on pipe.
25	IBR Certification	For high pressure service, Steam Temp., as per IBR rules and regulations.
CJC Boxes are not required, Thermocouple cables shall be directly terminated at Thermocouple I/P cards only.		
Bidder may also provide Triplex Thermocouples as per process requirements.		

d) Metal Temperature Thermocouples(MTE)

S.No	Features	Essential / Minimum Requirements
1	Measuring Medium	Metal Temperature
2	Material of Thermocouple	ChromelAlumel Type K

S.No	Features	Essential / Minimum Requirements
3	Type of Thermocouple	Duplex with separate hot junctions, ungrounded
4	Insulation	Mineral Insulation Magnesium Oxide.
5	Thermocouple wire gauge	16 AWG
6	Protective sheath	SS 321
7	Protective sheath dia	8 mm O.D
8	Characteristics of Thermocouple	Special limits of error as in ANSI thermocouple MC 96.01.1975
9	Mounting accessories	½" BSP SS Sliding end connector, weld pad, clamps of heat resistant steel SS310
10	Cold end sealing	SS pot seal with color coded PTFE headed sleeve insulated flexible tails. Sealing compound Epoxy resin
11	Minimum bending radius	30 mm
12	Length of T/C	30 Meter. (minimum)
13	Enclosure Class	IP-65 or better (Explosion/Flame proof for NEC Class-1, Division 1 area)

e) Temperature Switches(TS)

S.No	Features	Essential / Minimum Requirements
Type / Construction		
1	Switch	Industrial type inert gas filled with capillary and separable thermo well and contacts directly connected to Bourdon element/vapour pressure sensing, gas filled bellows type preferred.
2	Thermo well	Bar stock
a	Enclosure Class	IP 65 or better/ (Explosion/Flame proof for NEC Class 1/2, Division 1 area)/ flame proof (IEC-79.1, Part I). As applicable.
Material		
3	Bulb	SS 316
4	Capillary	Armoured Stainless Steel
5	Bourdon	SS 316
6	Bourdon Movement	SS 316
7	Casing	Die-cast aluminium with stoved enamel black finish Epoxy coating shall be provided for corrosive atmosphere.
8	Setting and Differential	Adjustable



S.No	Features	Essential / Minimum Requirements
9	Accuracy	± 1 % of setting and differential
10	Repeatability	One half (1/2) percent of setting.
Contacts		
11	Number	DPDT/2 SPDT
12	Type	Auto reset with internal Adjustable snap action micro switch
13	Rating	5 Amp, 240V AC / 0.2 Amp, 220V DC
14	Pipe Connection	M33 x 2
15	Extension	Threaded union (SS 316) 1/2" NPT (F) with two nipples of SS 316 having 1/2"NPT(M) threads at both ends
16	Thermo well	To suit Temp. switch with same design criteria as specified for RTDs.
17	Electrical	Suitable for Plug in type. All the switches are internally connected and brought to the surface with Amphenol male/female connection. Cabling need not terminated inside the switch. Cable ends are to be soldered in connector and to be inserted for easy maintenance.
Other Particulars		
18	Capillary length	As per requirement (min 10 meters)
19	Immersion Length	Within + 10 mm of centre line of pipe with adjustable nuts.
20	Extension neck length	Minimum 50 mm above insulation of pipe /As per approved hook up drawings
21	Packing glands	Yes
22	IBR Certification	For high pressure service, Steam Temp. as per IBR rules and regulations
23	N.B	Switches designed for cross ambient operation shall be used in applications where the ambient temperature will approximate or exceed the switch set point.

f) Temperature Gauges(TG)

S.No	Features	Essential / Minimum Requirements
1	Applicable Standard	IS : 3602, BS:5235 ISA:RP:8.1
Type/Construction		

S.No	Features	Essential / Minimum Requirements
2	Thermometer	Industrial type, Gas in Filled type with separable thermo well
3	Thermo well	Bar stock
	Material	
4	Bulb	SS 316
5	Capillary	Armoured SS (Applicable for capillary Type)
6	Casing	SS 316/ Die-cast aluminium with stoved enamel black finish. Epoxy coating shall be provided for corrosive atmosphere
7	Dial Size	150mm with shatter proof glass
8	Scale Details	270 degree dial rotation/deflection. Graduations in black lines on white dial provided with glass cover. Smallest scale division shall be one (1) percent of full scale value or smaller .Pointer stop for all gauges
9	Accuracy	$\pm 1\%$ or better
10	Response time	Maximum 15 seconds without thermo well and 30 seconds with thermo well
	Connection	
11	Pipe	M33 x 2
12	Thermo well	To suit instrument with same design criteria specified for RTDs.
13	Process Connection	M 33 x 2 (ii) SS 316 Flanged, for Air & Gas systems, with mating flanges, fasteners, gaskets etc.
14	Extension	Threaded union (SS 316) 1/2" NPT (F) with two nipples of SS 316 having 1/2"NPT(M) threads at both ends
15	Other Particulars	
16	Capillary length	5Meters/10 Meters as required
17	Immersion Length	Within + 10 mm of centre line of pipe with adjustable nuts.
18	Extension neck length	Minimum 50 mm above insulation of pipe /As per approved hook up drawings.
19	Stop at Maximum value	For all gauges of scale
20	Pointer	i) Externally adjustable ii) In general, Contact type Temp. Gauges are not acceptable for interlock & protection. iii) Contact type Temp. Gauges are acceptable for interlock & protection in case of bearing temp. Only.
21	Over range protection	150 % of full scale



S.No	Features	Essential / Minimum Requirements
22	IBR Certification	For high pressure service, Steam Temp. as per IBR rules and regulations
23	Enclosure Class	IP-65 or better (Explosion/Flame proof for NEC Class-1, Division 1 area)

g) Test Thermo wells(TW)

S.No	Features	Essential / Minimum Requirements
1	Applicable Standard	ASME PTC 19.3 TW-2016
2	Type/Construction	Machined from Bar stock
3	Material	SS 316/F11/F22/F91
	Connection	
4	Pipe	M33 x 2
5	Test Instrument	To suit test instruments
6	Accessories	Plug with chain
7	IBR Certification	For high pressure service, Steam temperature measurement as per IBR rules and regulations. Bidder shall provide calculation for thermo well as per ASME – PTC- 19.3 TW – 2016.

1.03 Level Instruments

a) Direct mounted level transmitter(LT)

Displacer type level transmitter shall not be used in the process anywhere in the plant.

b) Ultrasonic Level Transmitter (for Water sump/Tank level measurements)

S.No	Features	Essential / Minimum Requirements
1	Principle of Operation	Detection of reflected ultrasonic pulse
2	Measuring Ranges	Up to 30 meters (typical)
3	Signal Processing	Microprocessor Controlled Signal Processing
4	Operating Freq.	10 KHz to 50 KHz (typical)
5	Display	Head mounted alpha-numeric back lit LCD/LED

S.No	Features	Essential / Minimum Requirements
6	Calibration & Configuration	Accessible from front of panel & HART calibrator.
7	Diagnosis	On-line
8	Status	For power, Hi / Lo / V. Hi / V. Lo- level indication, fault etc.
9	Construction	Plug-on board
10	Power supply	240 V AC 50 Hz / 24 V DC
11	Signal Output	4-20 mA DC with HART (isolated) - 600 Ohm load.
12	Hysteresis	Fully adjustable preferred
13	Output contacts	2SPDT Potential free changeover contacts @ 8A 230V AC.
14	Accuracy & Repeatability	± 0.25 % of span or better
15	Resolution	± 0.1 % of span
16	Temperature Compensation	To be provided with Transducer.
17	Operating temp.	Transmitter-50 ° C and Sensor – 80 °C
18	MOC Sensor	Body- PVDF and Face – Polyurethane
19	Humidity	1 % to 95 % non-condensing.
20	Enclosure	IP-67 Epoxy painted die cast Aluminium or SS 316L housing.
21	Cable Connection	3/4" ET
22	Mounting	2" – 4" NPT or flanged
23	Accessories	Cable gland, prefab cable, mounting accessories like EPDM seal, SS 316 flanged etc. Additional separate local display unit with large Alphanumeric back light LCD / LED & to be provided for the applications which will be decided during detailed engineering. All weather canopy for protection from direct Sunlight, lightening and direct rain.

c) Capacitance type Level Transmitter

The total system shall consist of capacitance probe, pre-amplifier and transmitter.

S.No	Features	Essential / Minimum Requirements
1	Type	Capacitance type

S.No	Features	Essential / Minimum Requirements
2	Probe	a) Rod or suspended electrode. b) Rope type probes may be used only where required probe length is greater than 3 meters
3	Probe Mounting	Stainless steel 1-1/2 ANSI RF Flange / 3/4" NPT (M)
4	Material of construction	SS 316
5	Insulation	PTFE Part/Full as per service
6	Transmitter	The transmitter shall receive output of the preamplifier and convert it into 4-20 mA DC output signal.
7	Accuracy	± 1% of Full scale
8	Repeatability	± 0.5 % of Full scale
9	Load	Min 600 Ohms
10	Enclosure	Powder/Epoxy coated Die cast aluminium with neoprene gasket conforming to IP-65. (Explosion proof for NEC Class-1, Division 1 area).
11	Ambient temperature	0-60 °C.
12	Mounting	Wall / Surface
13	Supply voltage	240 V AC, 50 Hz / 24V DC
14	Response time	100 milli seconds or better
15	Cable connection	3/4" ET
16	Accessories	Counter flange, Cable gland, prefab cable if any
17	Preferable features	Alarm output contacts with adjustable set point facility

d) Dual Path Transit Time Clamp-on Ultrasonic FlowMeter

The flow meters shall be of proven reliability, accuracy and repeatability requiring a minimum of maintenance. They shall comply with relevant international standards and shall be subject to owner's approval.

All accessories required for mounting/erection of this instruments shall be furnished, erected and installed as necessary for completeness of the system though not specifically asked for. Also the equipment shall include necessary cables, flexible conduits, junction boxes required for the purpose.

Flow meters shall be provided with suitable environment protection devices/structures such that they shall be suitable for continuous operation in the operating environment of a coal fired utility station without any loss of function or departure from the specification requirements.

Technical Requirements

S.No	Features	Essential / Minimum Requirements
1	Type	Transit time Clamp On Ultrasonic meter
2	Mounting Style	Dual path with two sets of transducers on the same pipe
3	Flow measurement	Instantaneous Flow rate as well as totalized flow.
4	Power supply	230 V AC from UPS.
5	Outputs: Analog Current Binary Communication ports	Isolated 4-20mA linear outputs for each path Contact relay outputs, 2 NO + 2 NC for alarm RS 232 C digital, Hand held terminal port
6	Display/Indication	Flow meter with LCD screen backlight based local display and keypad, If required, transmitter shall be suitably located away from the sensor for better access and visibility.
7	Recording / Totalizing / Logging Facilities	Yes. Should be able to compute cumulative flow over intervals selectable by owner i.e., daily, weekly, monthly etc. The data shall be stored in the memory of flow computer for access in future
8	Software features	Compensation for any cross path errors. Programming, configuration, shall be possible from front panel.
9	Diagnostics	False signal tolerance , power supply failure etc.
10	Protection class	IP-65 'or better, Weather protection against direct sunlight, rain etc. for Flow . ' meter and suitable for Cooling water for Transducer
11	Accuracy	+/- 1 %
12	Electrical connection	Plug and socket
13	Pipe location	Underground
14	Accessories	All mounting hardware required like clamping fixtures, mechanism to remove the transducers online, interconnecting cables etc. All weather canopy for protection from direct sunlight and direct rain. Material of all fittings shall be SS 316.



e) LevelSwitches

S.No	Features	Essential / Minimum Requirements
1	Type / Construction	External float cage type with magnetic switch actuator for tanks and vessels.
Materials		
2	Body	i. Cast Carbon Steel/Die cast Aluminium suitable for specified pressure and temperature ratings ii. For corrosive liquids suitable anti-corrosive coat/lining shall be provided.
3	Float/Displacer	SS 316
4	Wire rope	SS 316
5	Differential	± 12 mm minimum (Adjustable)
Contacts		
6	Number	DPDT/2 SPDT
7	Type	Snap action Adjustable microswitch Autoreset with internal
8	Rating	5 A, 240V AC / 0.2 A, 220V DC
9	Connection - Process	1 inch SCRD NPT Female or 1 inch ANSI Flanged 4 inch ANSI Flange for sump services.
10	Electrical	Suitable for Plug in type connection
11	Temperature/pressure rating	As per service conditions
12	Accessories	Counter flanges, still pipe of requisite length with anticorrosive coating for sump services.
Note: Nuclear, capacitance, or ultrasonic type level switch for bulk material applications shall be provided.		

f) Capacitance type level switch

S.No	Features	Essential / Minimum Requirements
1	Type	Capacitance type

S.No	Features	Essential / Minimum Requirements
2	Probe	a) Rod or suspended electrode b) Rope type probes may be used only where required probe length is greater than 3 meters.
3	Probe Mounting	Stainless steel 1-1/2 ANSI RF Flange / 3/4" NPT (M)
4	Material of constructions	SS 316
5	Insulation	PTFE Part/Full as per service.
6	Enclosure	Powder/Epoxy coated Die cast Aluminium with neoprene gasket conforming to IP-65. (Explosion proof for NEC Class-1, Division 1 area).
7	Ambient temperature	0-60 °C.
8	Mounting	On Top
9	Supply voltage	240 V AC, 50Hz from UPS / 24 V DC
10	Relay output	2 SPDT
11	Contact rating	5 A min. at 240 V AC on resistive load
12	Response time	100 milli second or better
13	Cable connection	3/4" ET
14	Accessories	Counter flange, Cable gland, prefab cable and stainless steel name plate engraved with alpha-numeric.

g) RF type level switch

S.No	Features	Essential / Minimum Requirements
A	Electronic Controller	
1	Input supply	240 V AC from UPS
2	Construction	Cast Aluminium Housing
3	Relay Output	2 Nos. Relay Changeover Potential Free Contacts (2SPDT)
4	Contact Rating:	5A at 240 V AC & 0.25 at 220 V DC
5	Class of Protection	IP-66
6	Ambient Temperature	55 °C(Max)
7	Local Indication	Local LED Indications

S.No	Features	Essential / Minimum Requirements
	Green	Normal Level
	Red	Alarm Level
	Yellow	Probe Healthy
8	Cable Connection	3/4" ET (2 Nos.) for Supply and Output & 5/8" ET (1 No.) for Probe Connection
9	Repeatability	100%
B	Sensing Probe	
1	Type of Probe	Rigid
2	Material	Stainless steel SS 316
3	Probe Head Housing	Cast Aluminium
4	Insulation (B/W Active & Shield And Shield & Ground)	PTFE
5	Probe Head Protection	IP-66
6	Mounting	Side Mounted
7	Cable Connection	5/8" ET (1No.)
8	Process Connection	40 NB BSP THREADED
9	Signal Cable	Coaxial cable for Connection Between Sensing probe and electronic Controller (@ 10 Meters. Per Level Probe)
10	Application	Ash Silos

h) Float & Board type levelgauge

S.No	Features	Essential / Minimum Requirements
1	Type of Instrument	Mechanical Type (Float Operated)
2	Service/ Application	As per service requirement
3	Measuring Range	as per requirement
4	Material Specification	
a	Float Material	SS 316 having 2 nos. Guide wires

S.No	Features	Essential / Minimum Requirements
b	Float Wire Pulley	Shall comprise of 2 nos. Cast Aluminium Pulley hosing Assembly with SS 304 pulley and pulley shaft. Steel ball bearings shall be provided in pulley housing for easier float movement. Float wire material shall be SS 316L. Between 2 pulleys, 1" NB G.I. short pipe with tentative length as per P&ID
c	Guide wire Assembly	CS chamber with spring and adjuster having 1" Class 150 ANSI RF MS flange. Guide wire rope shall be SS 316L.
d	Counter Weight	MS counter – weight with Aluminium Pointer and Brass assembly Pull Chain.
e	Scale	SS 316/Aluminium material in mm with 1 % accuracy.
5	Nozzle Details	For float wire pulley assembly, one tapping and for guidewire assembly two tapping at the top of the tank; Size 1" NB (Top Mounting Type)
6	Process Connection	Flanged as per ANSI B 16.5 to suit 1" NB nozzle (Nozzle length - 150 mm for float wire, 100 mm for guide wire)
7	Accessories (to be supplied with the instrument)	
a	Counter flange	All mating Flanges, Nozzle
b	Mounting Accessories	All mounting accessories
c	Tag Plate	To be provided (material SS 316)

1.0.00 Flow Instruments

a) Mass flowmeter

S.No	Feat	Essential / Minimum Requirements
	Sensor	
1	Measuring Principle	Coriolis Mass flow.
2	Primary Element	Flow Tube of SS 316 or better
3	Heating Arrangement	Integral with Flow meter
4	Temperature Control	To be provided.
5	For Heating Process Connection	ANSI RF Flanged and rating as per process requirement.
6	Drain	Self-draining facility
7	Accessories	Counter flanges, Mounting nuts, bolts, gaskets etc.



	Transmitter	
8	Measured quantities	Mass Flow rate, Total Mass Flow, Density, Temperature as minimum.
9	Input Signal Processing	Digital Processing.
10	Display	Digital Display (LCD)
11	Output	2 Nos. isolated output of HART, 4-20mA DC selectable from four measured quantities
12	Load	< 600 ohms
13	Power supply	240V AC, 50 Hz. From UPS
14	Accuracy	0.15% of measured value for Liquid & 0.5% of measured value for Gas
15	Repeatability	0.05%
16	Housing	IP 65 (Explosion proof for NEC Class-1, Division 1 area)
17	Hazardous duty Version	FM Standards.
18	Nameplate	Tag number, service engraved in stainless steel tag plate
19	Accessories	a) As required for field mounting, Handheld configurator & complete Software, External zero adjustment facility b) Mounting U-bolts, nuts, bolts, prefab cable etc.
21	Fault Signal	Instrument fault signal through DPDT/2 SPDT for Diagnostics shall be provided and connected to DDCMIS.

b) Flow Transmitter(Ultrasonic)

S.No	Features	Essential / Minimum Requirements
	Sensor	
1	Type	Ultrasonic, 2 Wired
2	Sensing Elements	Non-contact
3	Output Signal	4-20mA with HART Protocol
4	Accuracy	± 0.1% FS
5	Supply	24 V DC
6	Enclosure class	IP-65
	Transmitter	
1	Mounting	On Nozzle
2	Mounting Position	Top Mounted
3	Housing	Plastic
4	Display	Head mounted LCD Display and remote LCD display
5	Process connection	NPT/Flanged
6	Electrical connection	NPT
7	Turn Down ratio	1:100
8	Measuring range	Adjustable (as per process requirement)
9	Totalizer	Required

10	Application	Open channel cooling water flow measurement
11	Accessories	As per process requirement Additional separate local display unit with large Alphanumeric back light LCD/LED & to be provided for the applications which will be decided during detailed engineering.

c) Positive Displacement Flow Transmitter

Positive displacement flow transmitters shall be offered. An electronic totalizer shall be provided for each flow meter and the location of the totalizers shall be acceptable to the Owner. Air eliminators shall also be provided to ensure maximum accuracy.

S.No	Features	Essential / Minimum Requirements
1	Type	Hall effect sensor
2	Body material	AISI 316L/Die Cast Aluminium.
3	Wetted part Material (Like Piston, Bearing, gear etc.)	AISI 316 L / Die Cast Aluminium.
4	O ring material	PTFE / higher based on temperature
5	Flow range	As required
6	Accuracy	± 0.5 % or better of reading
7	Repeatability	± 0.03 % or better.
8	Ambient temperature	50 ° C
9	Mounting	On-Line mounting with flanges of stainless steel.
10	Electronics	Solid State
11	Power Supply	240 V AC, 50 Hz. UPS
12	Display	4 ½ digit LCD for Flow rate & totalized value.
13	Output	Isolated 4-20 mA DC
14	Turn Down ratio	1 : 30
15	Totalized Value	Required
16	Housing	IP-65/ (Explosion proof for NEC Class-1, Division 1 area)/ flame proof (IEC-79.1, Part I). As applicable).
17	Nameplate	Tag number, service engraved in stainless steel tag plate
18	Accessories	a) Clamping strip, bracket, prefab cable, battery etc. & Nuts, bolts, gaskets, mesh etc. b) Special tool kit for calibration/configuration.

d) Electromagnetic Flowmeter



Electromagnetic flow meters shall have separate transmitter having accuracy $\pm 0.2\%$ with zero stability feature, suitable for process medium with >20 micro Siemens /cm for Demineralised water for water / chemicals. Conductivity, flanges material SS316, electrode & measuring tube material SS316, liner material Teflon and enclosure IP-66, local digital display configurable as totalizer, 4-20 mA output signal HART compatible with zero and span field adjustable. Application – DM Water and for other application as decided by owner.

e) **Flow Gauges (FG) and Flow Gauge cum Transmitter**

S.No	Features	Essential / Minimum Requirements
1	Type / Construction	a) On-line type Rotameter for 50 Nb and below lines b) Bypass type Rotameter for above 50 Nb lines.
Material – For On line type		
2	Metering Tube	Borosilicate glass
3	Float	SS 316
4	Packing	Teflon
5	End fittings	SS 304
Material – For Bypass type		
6	Metering Tube	Borosilicate glass
7	Float	SS 316
8	Packing	Teflon
9	End fittings	SS 304
10	Orifice Plate	SS 316
11	Carrier ring	SS 304
12	Flanges & Mating flanges	Same as pipe material, 200 lbs ANSI - RF
13	Impulse pipe	Same as pipe material
14	Fittings	2000 ANSI, SW ends to match with pipe material.
15	Dial Size/Scale length	250 mm
16	Scale Details	Direct reading type engraved on detachable Aluminium scale
17	Output	4-20 mA DC output shall be provided so as to have remote monitoring at OWS of respective control rooms.
18	Accuracy	$\pm 2\%$
19	Reproducibility	0.5 %
20	Rangeability	1:10
21	Connection	SCRD NPT
22	Accessories	a) Isolating valves (for Bypass type only) b) Bolts, Nuts and Gaskets as required
23	Tests	Shall be tested at 200 % of the maximum process pressure

1.04 Instrument airtsystem

The instrument Air Supply System for various pneumatic Control & Instrumentation devices like pneumatic actuators, power cylinders, I/P converters, pneumatically operated valves etc. shall be complete in all respect with necessary Air Filter Regulators, valves, piping/tubing etc.. Each pneumatic instrument shall have an individual air shut off valve. The pressure-regulating valve shall be equipped with an internal filter, a 50 mm pressure gauge and a built in filter-housing blow down valve.

Clean, dry, oil free instrument Quality air of the following quality shall be provided by bidder for various pneumatic instruments/control drives & accessories:-

1. Nominal pressure : 7Kg/cm² gauge
2. Range of pressure : 3.5 to 8.5Kg/cm²(g)
3. Dewpoint - 40 °C at NTP : + 2°C at the above pressure.
4. Maximum particle size : 5 microns

Pneumatically operated equipment offered by the Bidder shall be designed to operate with the above air supply and adequately cater to their respective duty within the full range of pressure variation. Wherever required, moisture separator with auto drain valve for vital instruments / actuator / analyzer may be provided in the airline by bidder.

The Bidder shall indicate system wise requirement of instrument air along with his proposal and same shall be included in the compressor capacity as supplied. Filter shall be of minimum 5-micron size & sintered bronze material.

On collection of water in the drains of instrument air lines, mechanical automatic drains and periodically solenoid operated drains (with electronic timer - 15m, 30m, 60m and 2 Hours & Timing adjustable) are to be provided.

For mechanical type & Electrical type, the locations to be provided in the instrument air lines of boiler area, Chimney area, turbine area etc., shall be decided during detailed Engineering.

Bulk header nearby the crowded applications shall be provided and from this bulk header individual air lines with necessary isolation valves are laid to the application.

These bulk header are to be provided with mechanical / electronic based automatic Drains. Individual moisture separator for O₂ analyser or vital application shall be provided nearby the instrument so as to enhance the cell life or the performance of vital final control elements.

1.05 Air Filter Regulator (AFR)

Air filter regulator along with gauges shall be provided in each of the

- a. Air supply line to valve positioners / power cylinders
- b. Air supply line to electric to pneumatic converters.
- c. Air supply line to pneumatic interlocked block valves.
- d. Constant bleed type AFR with an accuracy of + 1.0 % inlet pressure range of 5-10



kg/ cm² and suitable spring ranges (AFR) for use with positioners in control valves, control damper, E/P convertors and shut off valves with sintered phosphor bronze filter element; Filtering particles above five microns. IP 65 Weather and water proof enclosure. Material of accessories will be SS 316. Body material of filter regulator shall be Die Cast Aluminum or SS 316.

1.06 Technical Specification of Flue Gas Analysers

- i. Flue Gas Oxygen/SOX/NOX analyser / ammonia analyser shall be included.
- ii. Each analyser shall be independent and shall not share power supply modules, processor etc. with other analyser.
- iii. All mounting accessories including mating and blanking flanges shall be in vendor's scope.

1.07 Technical Specification of Flue Gas Oxygen Analyser

- a) Type Direct mounted Zirconia probe
(Non-heated In situ dry type for high Temperature service and Heated In situ type for Low Temperature service) Zirconia probe analyzer should have facility of "in situ" calibration as well as easy replacement of Zirconia cell. Zirconia cell protection shall be by providing ceramic filter of minimum 5 micron size at the end of probe.
- b) Probe SS - 316 (1800 mm long)
- c) Output
 - i) 4-20 mA DC HART for spare output
 - ii) 4-20 m Amp, DC HART, Separate outputs for DDCMIS.
 Digital output HART/RS 485 port Modbus Protocol/Ethernet TCP/IP protocol for communication with Plant DDCMIS system.
Indication - Digital Alphanumeric Display.
Display of reading in engineering units shall be provided.
- d) Power Supply 240V AC, 50 Hz from Plant UPS with redundant feeders
- e) Accuracy ± 1 per cent of span (or) better inclusive of linearity, repeatability.
- f) Repeatability $\pm 0.5\%$ of full scale
- g) Ranges Programmable.
- h) System response 90% of full scale Less than 3 seconds with test gases, with actual process 20 seconds.
- i) Connection Probe ANSI flanged
- j) Calibration Analyser shall be calibrated using standard test gases whilst the probe is installed in the flue gas. Analyser shall have built in auto calibration facility and comprehensive alarm facility.
- k) Diagnostic Diagnosis facility shall be available and Alarm for failure of heater, sensor voltage, failure of sensor, failure of thermo couple etc., to be initiated and given with necessary alarm contacts.
- l) Drift $\pm 1\%$ full scale per month
- m) Operating temperature range
600-1600 deg. C (High Temp)

0- 800 deg. C(Low Temp).

n) Accessories

- i. Electronic unit housed in a rugged sheet steel enclosure (IP54) houses transmitting system, probe heater control circuit etc. Electronic unit shall be separate from the probe and not be head mounted.
- ii. Calibration gas cylinder & accessories, reference air set, rota meters
- iii. Shield (316 SS), special cables, electronic control panel and Provision of SS 316 stainless steel diffuser assembly of required thickness for the protection of Zirconia cell.
- iv. Ownership certificate, pressure test certificate, explosion proof certificate for standard gas cylinders shall be given and these will be used for next filling up of standard gases.
- v. To validate the measurement, for mid-range value i.e. 6% of O₂ with 94% N₂, standard gas cylinder to be supplied for each analyser. (% O₂ shall be decided depending on the supplier & method of calibration during detailed engineering.
- vi. Moisture separator unit for reference air shall be installed for long life of Zirconia cell.
- vii. Auto calibration system with necessary solenoid valves, SS316 tubing, connector, zero & span gas, air purge lines etc.
- viii. Independent air lines with Isolation valves for left side & right side shall be drawn from main air header available in the Boiler area.
- ix. The construction of the sensor shall be such that joint between dissimilar materials are avoided to prevent formation of cracks.
- x. Any other accessories as required.

o) Air Purging System: To be provided as per requirements.

1.08 Technical Specification of Flue Gas (SOX/NOX) ANALYZER

1. Operating Principle : NDIR
2. Sampling/Non-sampling : Dilution
3. Type : Microprocessor based
4. Range :
 - a. SO₂ : 0-450 ppm
 - b. NO_x : 0-500 ppm
 - c. CO/CO₂ : 0-500 ppm
5. Accuracy : 1% F.S.
6. Response time (up to) : Less than 5 (five) seconds



- 90% of full scale)
- 7. Linearity : $\pm 1\%$ of Full Scale
 - 8. Repeatability : $\leq 1\%$ of Span
 - 9. Calibration : Automatic & Manual (Zero & Span)
 - 10. Power Supply : 240 V AC
 - 11. Output signal : 4-20 mA DC each channel (with superimposed HART signal) into 600 ohms
 - 12. Alarm annunciation : Four relay contacts, Dual Alarm set points (240V AC, 5A)
 - 13. Enclosure : Stainless Steel
 - 14. Indication : LCD display
 - 15. Operating Temp.Range : 0-300 °C
 - 16. Accessories :
 - a. Interconnection cable (as required) in flexible conduits
 - b. Tubes/Fittings, mounting brackets/pads as required
 - c. Purge system for cleaning
 - d. Surge Arrester
 - e. Standard gas for calibration



ANNEXURE - V

SPECIFICATION FOR CABLES, CABLE TRAYS AND CABLE GLANDS

1.0 CABLES – DESIGN CRITERIA

- i. Cables shall be so designed and manufactured that damage does not occur in handling, during transit, storage, installation and operation under any or all the climatic and operating conditions which they may be subjected to. Outer sheath of cables shall have rodent and termite repulsion property.
- ii. Cables shall be suitable for laying in conduits, ducts, trenches, trays or for direct burial in ground in both and wet locations.
- iii. Cables shall be capable of operating satisfactorily under the power supply voltage and frequency variations as specified in the specification. Current ratings and ratings factors of cables shall not be worse than the ones specified in IS-3961.
- iv. Performance characteristics of cables shall be based on the following conditions of laying:
 1. All cables shall be laid in multilayer and touching each other.
 2. Cables shall be suitable for laying in duct or burying in ground up to a depth of 1.5 meters with uncontrolled back fill and chances of flooding by water.
- v. Fillers in multiple conductor cables shall be flame retardant and moisture resistant.
- vi. All cables shall be provided with marking including manufacturer's name, insulation material, conductor sizes, no of pairs, voltage ratings, type of cable, etc., progressive markings to read marking of the length of the cable at each meter interval and "FRLS".
- vii. All cables shall be suitable for continuous operation at 85 °C except for high temperature resistant Teflon insulated cables, which shall be suitable for continuous operation at 205 °C.
- viii. All spare contacts/terminals on relays, control switches, limit switches or similar devices, process switches, duplex RTDs & Duplex T/Cs shall be wired to accessible terminal blocks/JBs for Owner's future connections.
- ix. All wiring leaving a junction box or enclosure shall leave from terminal blocks and not from other devices in the enclosure.
- x. Two (2) pair (individual & overall shielded) cables shall be provided for terminating the thermocouples, transmitters & switches i.e. Analog & Binary signals to local JB's. Similarly four (4) pair (individual & overall shielded) cables shall be provided for terminating the



Duplex (3/4 wire) RTD to local JBs. 10% spare pairs or min 1 pair cable (whichever is more) shall be provided with all type of cables.

- xi. Cable size & type shall be as below for different type of signals and control system.
1. Cables for analog signals shall be instrumentation cable of 0.5 sq. mm copper conductor size, with individual pair shielding & over all shielding.
 2. Cables for binary signals shall be instrumentation cable of 0.5 sq. mm copper conductor size, with individual pair shielding.
 3. Cables for binary signals in Fire protection & detection system shall be instrumentation cable of 1.5 Sq.mm conductor size, overall shielded.
 4. Cable for power supply to each solenoid valves shall be control cable of 3C x 2.5 Sq.mm copper conductor size.
 5. For cables single length more than 500 meters, the size of conductor shall be 1.5 sq. mm only irrespective of type of signals.

1.1 INSTRUMENTATION CABLES

Sl. No.	Parameter		Value/Requirement
1.	Applicable Standards		IS-1554, IS-5831, IS-8130, IS-10418, IS-10810, VDE-0815, IEC-332, IEC-754, IS-3975, ASTM-D-2843, ASTM-D-2863, SS-4241475 & BS-5308
2.	Voltage grade	V	660V/1100V
3.	Temperature Rating & Shortcircuit withstand Rating	°C	85 160
4.	Conductor:-		
a.	No. Of Pairs and Area of Conductor		0.5 / 1.5 Sq.mm
b.	No. of Strands / Strand Dia.(for finished cable) of Strand	No./ mm	7/0.307 for 0.5 sq.mm & 23/0.3 for 1.5 Sq.mm (Stranded & Non-compacted)
c.	Material		Annealed, Tinned, Copper Conductor
d.	Grade / Standard		High Conductivity, Electrolytic grade Copper to IS-8130

Sl. No.	Parameter	Value/Requirement
5.	Insulation :-	
a.	Material	HR PVC
b.	Type and Standard	Type-C, as per IS-5831
c.	Thickness (Nominal)	mm 0.6 mm for 0.5 sq.mm. cable & 0.8 mm for 1.5 Sq.mm. Cable
d.	Method of application	Extruded
e.	Pair Identification	As per Data sheet Clause No. 32
f.	Volume Resistivity as per IS-5831	Ω cm 3.5×10^{14} @ 27 °C & 3.5×10^{11} @ 85 °C
6.	Lay for Pairing	Twist/metre 20
7.	Direction of Lay	Right hand
8.	No. of Pairs for making a bundle	4 pair (Not applicable for 2 pair cable)
9.	Lay for laid-up Pairs	Twist/metre 4-6
10.	Lay for Laid-up Bundle	Twist/metre 2 - 3 (Not applicable for 2 & 4 pair cable)
11.	Binding material	
a.	Type of Material	Mylar Tape
b.	Thickness (min)	mm 0.028
c.	Coverage (min)	% 100
d.	Overlap (min)	% 25
12.	Fillers (wherever applicable)	Non-Hygroscopic with FRLS property suitable for the operating temperature of the cable. Fillers shall not be sticky
13.	Shielding :-	
a.	Type of Material	Aluminum Backed Mylar Tape
b.	Thickness (min)	micron For Pair Shielding 28 Micron, For Overall Shielding 60 Microns
c.	Coverage (min)	% 100



Sl. No.	Parameter		Value/Requirement
d.	Overlap (min)	%	25
14.	Drain wire for shielding		
a.	Material		Annealed, Tinned Electrolytic Copper
b.	No. of strands / Dia. of strand	No./ mm	7/0.3
c.	Area of cross section	sq.mm	0.5
15.	Inner Sheath :-		
a.	Material		HR PVC with FRLS Properties
b.	Type and Standard		Type-ST2 as per IS-5831
c.	Thickness (minimum)	mm	As per IS-1554
d.	Method of application		Extruded
e.	Colour		BLACK
f.	Rip Cord		Non-metallic Rip cord shall be provided under inner sheath
16.	Armouring :-		
a.	Material		Galvanized Steel
b.	Standard		As per IS-3975 & IS-1554
c.	Direction of lay		Left Hand
d.	Shape and dimension		Wire Armour – 1.4 mm dia Strip Armour – 4 mm x 0.8 mm
e.	Type of Armour		Cables having the calculated diameter over inner sheath, up to & including 13 mm will have Wire Armour, as per IS-1554. Cables having the calculated diameter over inner sheath, greater than 13 mm will have Strip Armour, as per IS-1554.
17.	Outer Sheath :-		

Sl. No.	Parameter		Value/Requirement	
a.	Material		HR PVC With FRLS Properties	
b.	Type and Standard		Type-ST2 as per IS-5831	
c.	Method of application		Extruded	
d.	Thickness (minimum)		As per IS-1554	
e.	Colour		BLACK	
18.	Cable Marking on Outer sheath		"Manufacturer's name, Year of manufacture, Type of Insulation, No. of pairs & Conductor size, Voltage rating, Type of Cable, FRLS" embossed @ 1 metre interval.	
19.	Sequential marking on Outer sheath		Every 1 Metre for Progressive Length by printing.	
20.	Tolerance on Outer diameter	mm	± 2	
21.	Tolerance on Outer diameterfor the entire length	mm	1	
22.	Ovality	mm	1	
23.	Bending Radius	minimum	12 times the Outer diameter	
24.	Standard Packing Length	metre	1000	
25.	Tolerance on standard packing length	%	± 5	
26.	Non-standard Length		Last length shall be supplied in single length	
27.	Electrical Parameters			
	Parameter	Unit	0.5 sq.mm. Cable	1.5 sq.mm. Cable
a.	Conductor DC Resistance (max.) @ 20° C	Ω/km	78.4	24.6
b.	Short circuit rating of conductor for 1 second	KA	0.052	0.156
c.	Characteristic impedance @ 0.8Khz	Ω/km	370	230



Sl. No.	Parameter		Value/Requirement
d.	Insulation Resistance (min.) @20° C	MΩ/km	100
e.	Mutual Capacitance (max.) @ 0.8 KHz	nF/km	120
f.	Attenuation (max.) @ 0.8 KHz	dB/100m	0.11
g.	Attenuation (max.) @ 10 KHz	dB/100m	0.29
h.	Cross talk (min.) @ 0.8 KHz	dB/km	70
i.	Coupling capacitance @ 0.8 KHz (max)	pF/100m	200
j.	Test Voltage - BetweenConductor-Conductor	KV/minute	2.0
k.	Test Voltage - Between: Conductor - Shield (min.)KV/minute 500 V for 1 Minute	KV/minute	2.0
28.	FRLS Properties of Inner & Outer Sheath :-		
a.	Oxygen Index @ ambient temp. As per ASTM-D-2863	%	Not Less than 29
b.	Temperature Index @ oxygen index 21 As perASTM-D-2863	° C	Not Less than 250
c.	Smoke density rating As perASTM-D-2843	%	Shall not be more than 60
d.	Acid gas generation As per IEC 60754-Part 1	%	Shall not be more than 20% by weight
e.	Flammability Tests As per IEC-60332, Part-3, Category-B, SS-4241475, Clause-F3		Shall pass
29.	Special Requirements:-		
a.	Outer sheath material shall have		Anti-rodent, Anti-termite & Moisture resistant properties. Presence of Lead shall be confirmed
30.	<u>Colour coding and Numerical order of cores → As per VDE-0815</u> The twisted pair of conductors are identified by 8 colours		
	Pair	Colour	

Sl. No.	Parameter	Value/Requirement																																																																				
	<table><tr><td>1</td><td>Blue & Red</td></tr><tr><td>2</td><td>Grey & Yellow</td></tr><tr><td>3</td><td>Green & Brown</td></tr><tr><td>4</td><td>White & Black</td></tr></table> The 4 pairs of conductors with the above colours are called 1 bundle. The cable will have number of such bundles according to the total number of pairs. The same colour appears in different Bundles. The Numerical order of the cores are identified by coloured Rings (ranging from 1 to 4) on the insulation @ 50 mm interval. This clause is not applicable for 2 pair and 4 pair cables. <table><tr><td>Cable</td><td colspan="4">8 Pair, 12 Pair, 16 Pair, 20 Pair, 24 Pair, 28 Pair, 32 Pair, 36 Pair, 40 Pair, 44 Pair & 48 Pair</td></tr><tr><td>Bundle Number</td><td>1st Bundle</td><td>2nd Bundle</td><td>3rd Bundle</td><td>4th Bundle</td></tr><tr><td>Number of Rings</td><td>1</td><td>2</td><td>3</td><td>4</td></tr><tr><td>Colour of Ring</td><td colspan="4">Pink</td></tr></table> <table><tr><td>Cable</td><td colspan="4">20 Pair, 24 Pair, 28 Pair, 32Pair, 36 Pair, 40 Pair, 44 Pair & 48 Pair</td></tr><tr><td>Bundle Number</td><td>5TH Bundle</td><td>6th Bundle</td><td>7th Bundle</td><td>8th Bundle</td></tr><tr><td>Number of Rings</td><td>1</td><td>2</td><td>3</td><td>4</td></tr><tr><td>Colour of Ring</td><td colspan="4">Orange</td></tr></table> <table><tr><td>Cable</td><td colspan="4">36 Pair, 40 Pair, 44 Pair & 48 Pair</td></tr><tr><td>Bundle Number</td><td>9th Bundle</td><td>10th Bundle</td><td>11th Bundle</td><td>12th Bundle</td></tr><tr><td>Number of Rings</td><td>1</td><td>2</td><td>3</td><td>4</td></tr><tr><td>Colour of Ring</td><td colspan="4">Violet</td></tr></table>	1	Blue & Red	2	Grey & Yellow	3	Green & Brown	4	White & Black	Cable	8 Pair, 12 Pair, 16 Pair, 20 Pair, 24 Pair, 28 Pair, 32 Pair, 36 Pair, 40 Pair, 44 Pair & 48 Pair				Bundle Number	1 st Bundle	2 nd Bundle	3 rd Bundle	4 th Bundle	Number of Rings	1	2	3	4	Colour of Ring	Pink				Cable	20 Pair, 24 Pair, 28 Pair, 32Pair, 36 Pair, 40 Pair, 44 Pair & 48 Pair				Bundle Number	5 TH Bundle	6 th Bundle	7 th Bundle	8 th Bundle	Number of Rings	1	2	3	4	Colour of Ring	Orange				Cable	36 Pair, 40 Pair, 44 Pair & 48 Pair				Bundle Number	9 th Bundle	10 th Bundle	11 th Bundle	12 th Bundle	Number of Rings	1	2	3	4	Colour of Ring	Violet				
1	Blue & Red																																																																					
2	Grey & Yellow																																																																					
3	Green & Brown																																																																					
4	White & Black																																																																					
Cable	8 Pair, 12 Pair, 16 Pair, 20 Pair, 24 Pair, 28 Pair, 32 Pair, 36 Pair, 40 Pair, 44 Pair & 48 Pair																																																																					
Bundle Number	1 st Bundle	2 nd Bundle	3 rd Bundle	4 th Bundle																																																																		
Number of Rings	1	2	3	4																																																																		
Colour of Ring	Pink																																																																					
Cable	20 Pair, 24 Pair, 28 Pair, 32Pair, 36 Pair, 40 Pair, 44 Pair & 48 Pair																																																																					
Bundle Number	5 TH Bundle	6 th Bundle	7 th Bundle	8 th Bundle																																																																		
Number of Rings	1	2	3	4																																																																		
Colour of Ring	Orange																																																																					
Cable	36 Pair, 40 Pair, 44 Pair & 48 Pair																																																																					
Bundle Number	9 th Bundle	10 th Bundle	11 th Bundle	12 th Bundle																																																																		
Number of Rings	1	2	3	4																																																																		
Colour of Ring	Violet																																																																					

1.2

EXTENSION & COMPENSATING CABLES

Applicable Standards :

ANSI MC96.1; IS:1554(Part-I) IS:5831-1984

Type :

Single / Multipair twisted and shielded type as per ANSI MC96.1

Conductor Size :

1.31sqmm, solid alloy (16 AWG)

Conductor Diameter :

1.29 mm



PROJECT: DN 104

Insulation :	PVC insulated, heavy duty, Self extinguishing type. Black Colour coded extruded PVC inner sheathed with overall PVC sheathed Type ST2 FRLS IS: 5831. Insulation of each wire with high grade 0.6 mm 85 deg.C Extruded HR PVC Type C as per IS: 5831, voltage grading shall be 1.1 kV.
Lay :	Twisted pairs within 50 mm max. lay.
Shield :	Single pair cable assembly only. Multiple pair - each pair and cable assembly. Each conductor shall be individually and overall shielded Through aluminium mylar tape min 0.06 mm (0.075 mm) with min 25% overlap & 100% coverage and 7 strand 20 SWG minimum size tin coated copper drain wire.
Outer sheath	FRLS HR PVC type ST-2 to IS: 5831. Colour as per ANSI standard.
Conductor Identification :	as below
Armour :	Galvanised steel wire/strip to IS: 3975
Multiple pair identification :	Each pair numbered every 250 mm.

Electrical Parameters:

Thermo electric specification, limit of error shall be as per IEC, ANSI

Description	KX type	SX/RX Type	TX Type
E.M.F at 100 Deg.C	4.095mV	0.646/0.647 mV	4.279 mV
E.M.F at 200 Deg.C	8.137mV	1.441/1.469 mV	9.228 mV
Tolerance	+ 2.2 °C from 0°C to 200°C	+ 1.5 °C from 0°C to 200°C	+ 1.0 °C from 0°C to 100°C
Conductor loop resistance for 1.31 sq. mm (16 AWG) size as per ANSI MC96.1 at 20 Deg.C Ohms/K.Mtr	760 (Typ)	95 (Typ)	390 (Typ)

Insulation Resistance (min) : 100 M ohm x KM

Mutual Capacitance at 0.8 resp. 1 KHz (max)

- Single pair and pair screened : 120nf/KM

- upto 4 pair overall screened : 96 nf/KM

- above 4 pairs overall screened : 80 nf/KM

CABLE DETAILS

ANSI Type	Conductor Material		ANSI Colour Code		
	Positive	Negative	Positive	Negative	Overall
KX type Extension cable for K type Thermocouple	(NICH/NIAI) Cromel	(NICHr/NiAl) Alumel	Yellow	Red	Yellow
SX/RX type	Cu (Copper) Cu	(Copper-	Black	Red	Green

Compensating cable for type S & R thermocouple	Ni	Nickel alloy)			
TX type Extension cable for type T thermocouple	Cu (Copper)	Constantan	Blue	Red	Blue

1.3 CONTROL & POWER CABLES

1.3.1 Technical Requirements

- i. The cables shall be suitable for laying on racks, in ducts, trenches, conduits and underground buried installation with chances of flooding by water.
- ii. Cable Identification
 - i. Outer sheath shall be of PVC (of suitable grade) & black in colour. In addition to meeting all the requirements of Indian standards referred to, outer sheath of all the cables shall have the following FRLS properties.
 - a. Oxygen index of min. 21 (As per NES-715-1).
 - b. Acid gas emission of max. 20% (As per IEC-60754-1).
 - c. Smoke density rating shall not be more than 60% during Smoke Density Test as per ASTM D-2843.
 - ii. All cables shall meet the fire resistance requirement of IEEE-383 with cable installations made in accordance with clause "Flammability test" and as per Category-B of IEC-60332 Part -3.
 - iii. Allowable tolerances on the overall diameter of the cables shall be ± 2 mm maximum over the declared value in the technical data sheets.
 - iv. In plant repairs to the cables shall not be accepted. Pimples, fish eye, blow holes etc., are not acceptable.

1.3.2 Cable selection & sizing

- i. Cables shall be sized based on the following considerations:
 - a. Rated current of equipment.
 - b. Maximum voltage drop limits under steady state and during starting for motor being fed from 415V switchgear restricted to 5% and 10% respectively.
 - c. Maximum voltage drop limits under steady state for feeder (i.e. outgoing feeders being fed from 415V switchgear) restricted to 3%.



- d. For cables to motors and feeders protected by MCCBs the cross section will be chosen according to the tripping time of MCCBs.

ii. Derating Factors

Derating factors for various conditions of installations including the following shall be considered while selecting the cable sizes:

- a. Variation in ambient temperature for cables laid in air.
 - b. Grouping of cables.
 - c. Variation in ground temperature and soil resistivity for buried cables.
- iii. Cable lengths shall be considered in such ways that straight through cable joints are avoided.
- iv. Cables shall be armoured type if laid in switchyard area, coal handling area or directly buried. All LV power cables except trailing cables shall be XLPE insulated FRLS.
- v. All control cables shall be 2.5 Sq. mm copper cable.
- vi. Multicore control cables will generally have spare conductor (s) in accordance with the following chart and cores of a single cable will not be split for different auxiliary/equipment:

Conductors	Required Cables
1 or 2	: 1-3/C
3 or 4	: 1-5/C
5 or 6	: 1-7/C
7 or 8	: 1-10/C
9 or 10	: 1-12/C
11 or 12	: 1-16/C
13 or 14	: 1-18/C
Above 14 core	: Two or more of above cables

1.4 CONTROL CABLES

Sl. No.	Parameter	Value/Requirement
1.	Applicable Standards	IS-1554, IS-5831, IS-8130, IS-10418, IS-10810, VDE-0815, IEC-332, IEC-754, IS-3975 ASTM-D-2843, ASTM-D-2863, SS-4241475

Sl. No.	Parameter	Value/Requirement
2.	Varieties of cable	3 Core, 5 Core, 7 Core, 10 Core, 12 core 16 Core & 18 Core (as applicable)
3.	Voltage grade	V 1100
4.	Temperature Rating & Short circuit withstand Rating	°C 70 160
5.	Conductor:-	
a.	Area of Cross Section	Sq.mm. 1.5
b.	No. of Strands / Strand Dia. (Finished cable) of Strand	No./ mm 7/0.53 (Stranded & Non-compacted)
c.	Material	Annealed, Plain Copper Conductor
d.	Grade / Standard	High Conductivity, Electrolytic grade Copper to IS-8130
6.	Insulation :-	
a.	Material	HR PVC
b.	Type and Standard	Type-A, as per IS-5831
c.	Thickness (Nominal)	mm 0.8
d.	Method of application	Extruded
e.	Core Identification	As per IS-1554
f.	Volume Resistivity as per IS-5831	Ω cm 1×10^{13} @ 27 °C & 1×10^{10} @ 70 °C
7.	Fillers (wherever applicable)	Non-hygroscopic with FRLS property suitable for the operating temperature of the cable. Fillers shall not stick to the insulation and innersheath
8.	Inner Sheath :-	
a.	Material	HR PVC



PROJECT: DN 104

Sl. No.	Parameter		Value/Requirement
b.	Type and Standard		Type-ST1 as per IS-5831
c.	Thickness (minimum)	mm	As per IS-1554
d.	Method of application		Extruded
e.	Colour		BLACK
9.	Armouring :-		
a.	Material		Galvanized Steel
b.	Standard		As per IS-3975 & IS-1554
c.	Direction of lay		Left Hand
d.	Shape and dimension		Single layer round steel wire
10.	Outer Sheath :-		
a.	Material		HR PVC With FRLS Properties
b.	Type and Standard		Type-ST1 as per IS-5831
c.	Method of application		Extruded
d.	Thickness (minimum)	mm	As per IS-1554
e.	Colour		BLACK
11.	Cable Marking on Outer sheath		"Manufacturer's name, Year of manufacture, Type of Insulation, No. of cores & Conductor size, Voltage rating, Type of Cable, FRLS" embossed @ 1 metre interval.
12.	Sequential marking on Outer sheath		Every 1 Metre for Progressive Length by printing.
13.	Tolerance on Outer diameter	mm	± 2
14.	Tolerance on Outer diameter for the entire length	mm	1

Sl. No.	Parameter	Value/Requirement
15.	Ovality	mm
16.	Bending Radius	minimum
17.	Standard Packing Length	metre
18.	Tolerance on standard packing length	%
19.	Non-standard Length	Last length shall be supplied in single length
20.	Electrical Parameters :-	
a.	Conductor DC Resistance (max.) @ 20° C	Ω/km
b.	Short circuit rating of conductor for 1 second	KA
c.	Insulation Resistance (min.) @20° C	$M\Omega/\text{km}$
d.	Test Voltage - Between Conductor-Conductor	KV/minute
21.	FRLS Properties of Inner & Outer Sheath :-	
a.	Oxygen Index @ ambient temp. As per ASTM-D-2863	%
b.	Temperature Index @ oxygen index 21 As per ASTM-D-2863	° C
c.	Smoke density rating As per ASTM-D-2843	%
d.	Acid gas generation As per IEC 754-Part 1	%
e.	Flammability Tests	
22.	Special Requirements :-	
a.	Outer sheath material shall have	Resistance to water, fungus, rodent and termite attack



1.5 POWER CABLES

Sl. No.	Parameter		Value/Requirement
1.	Applicable Standards		IS-7098, IS-5831, IS-8130, IS-10418, IS-10810, IEC-332, IEC-754, IS-3975, IS-5082, ASTM-D-2843, ASTM-D-2863, SS-4241475 &
2.	Varieties of cable		2 Core, 3 Core, 4 Core
3.	Voltage grade	V	1100
4.	Temperature Rating & Short circuit withstand Rating	°C	90 250
5.	Construction of cable		As per Constructional diagram enclosed with this Data sheet
6.	Conductor:-		
a.	Area of Cross Section	Sq.mm.	2.5 → Copper / 16 sq.mm. → Aluminium (or as applicable)
b.	No. of Strands / Strand Dia. (Finished cable) of Strand	No./ mm	2.5 Sq.mm – 7/0.68
			16 Sq.mm – 7/ 1.71
c.	Material		Annealed, Plain Copper Conductor or Aluminium (As Applicable)
d.	Grade / Standard		High Conductivity, Electrolytic grade Copper to IS-8130, Non-compacted. Multistranded Aluminium to IS-8130 (Class-2), H2 grade, compacted
7.	Insulation :-		
a.	Material		XLPE
b.	Type and Standard		As per IS-7098, part-I
c.	Thickness (Nominal)	mm	0.7mm

Sl. No.	Parameter	Value/Requirement
d.	Method of application	Extruded
e.	Core Identification as per IS-7098	2 Core → Red & Black, 3 Core → Red, Yellow & Blue and 4 Core → Red, Yellow, Blue & Black
f.	Volume Resistivity as per IS-7098	$\Omega \text{ cm}$ $1 \times 10^{14} @ 27^\circ \text{C}$ & $1 \times 10^{12} @ 90^\circ \text{C}$
8.	Fillers (wherever applicable)	Non-hygrosopic with FRLS property suitable for the operating temperature of the cable. Fillers shall not stick to the insulation and inner sheath
9.	Inner Sheath :-	
a.	Material	HR-PVC
b.	Type and Standard	Type-ST2 as per IS-5831
c.	Thickness (minimum)	mm As per IS-7098
d.	Method of application	Extruded
e.	Colour	BLACK
10.	Armouring :-	
a.	Material	Galvanized Steel
b.	Standard	As per IS-3975 & IS-7098
c.	Direction of lay	Left Hand
d.	Shape and dimension	Single layer of round steel wire
11.	Outer Sheath :-	
a.	Material	HR-PVC with FRLS Properties
b.	Type and Standard	Type-ST2 as per IS-5831
c.	Method of application	Extruded
d.	Thickness (minimum)	mm As per IS-7098



Sl. No.	Parameter		Value/Requirement
e.	Colour		BLACK
12.	Cable Marking on Outer sheath		"Manufacturer's name, Voltage grade, Year of manufacture, Type of Insulation, Number of Cores & Size of conductor, FRLS" embossed @ 1 metre interval.
13.	Sequential marking on Outer sheath		Every 1 Metre for Progressive Length by printing.
14.	Tolerance on Outer diameter	mm	± 2
15.	Tolerance on Outer diameter for the entire length	mm	1
16.	Ovality	mm	1
17.	Bending Radius	minimum	12 Times the OD of the Cable
18.	Standard Packing Length	metre	1000/500 as per Purchase Order
19.	Tolerance on standard packing length	%	± 5
20.	Non-standard Length		Last length shall be supplied in single length
21.	Electrical Parameters :-		
a.	Conductor DC Resistance (max.) @ 20° C	Size (Sq.mm)	Value (Ω /km)
		2.5 (Cu)	7.41
		16 (Al)	1.91
b.	Short circuit rating of conductor for 1 second	Size (Sq.mm)	Value (KA)
		2.5 (Cu)	0.36
		16 (Al)	1.51
c.	Insulation Resistance (min.) @ 20° C	M Ω /km	100
d.	Test Voltage - Between Conductor-Conductor as per IS-7098 PART-I	KV/minute	3 KV for 5 Minute

Sl. No.	Parameter	Value/Requirement
22.	FRLS Properties of Outer Sheath :-	
a.	Oxygen Index @ ambient temp. As per ASTM-D-2863	% Not Less than 29
b.	Temperature Index @ oxygen index 21 As per ASTM-D-2863	° C Not Less than 250
c.	Smoke density rating As per ASTM-D-2843	% Shall not be more than 60 (Light Transmission shall be 40% average)
d.	Acid gas generation As per IEC 754-Part 1	% Shall not be more than 20% by weight
e.	Flammability Tests	As per approved Quality plan
23.	Special Requirements:-	
a.	Outer sheath material shall have	Resistance to water, fungus, rodent and termite attack

1.6 CABLE TRAYS, FITTINGS & ACCESSORIES

- Cable trays shall be ladder type as specified complete with matching fittings (like brackets, elbows, bends, reducers, tees, crosses, etc.), accessories (like side coupler plates, etc.) and hardware (like bolts, nuts, washers, G.I. strap, hook etc.) as required. Cable tray shall be ladder type for power & control cables and perforated for instrumentation cables.
- These shall be either prefabricated hot dip galvanized sheet steel trays or site fabricated angle iron trays free from flaws such as laminations, rolling marks, pitting etc. These (including hardware) shall be hot dip galvanized as per relevant IS.
- Cable trays shall have standard width of 150 mm, 300 mm & 600 mm and standard lengths of 2.5 metre. Minimum thickness of mild steel sheets used for fabrication of cable trays and fittings shall be 2 mm. The thickness of side coupler plates shall be minimum 3 mm.
- Cable troughs shall be required for branching out few cables from main cable route. These shall be U-shaped, fabricated of mild steel sheets of minimum thickness 2 mm



and shall be hot dip galvanized as per relevant IS. Troughs shall be standard width of 50 mm & 75 mm with depth of 25 mm.

- v. Prefabricated hot dip galvanized sheet steel cable trays shall be used for maximum support span of 2000 mm unless design is approved for larger span. Cable trays shall be suitable for a cable weight of 100 Kg/meter running length of tray. Minimum thickness of sheet steel/galvanizing shall be 2mm/86 microns respectively. The amount of zinc deposit shall not be less than 610 gm per square meter.
- vi. Cable trays fabricated from standard rolled sections shall be 50x50x6/75x75x6 sections for runners for supporting spans limited to 2000 mm/more than 2000 mm respectively. Cross support shall be 32x6 mm / 50x6 flat for widths up to 500mm/more than 500mm respectively.

1.7 CABLE GLANDS

- i. Cable glands shall conform to BS-6121 and be of robust construction capable of clamping cable and cable armour (for armoured cables) firmly without injury to insulation.
- ii. Cable glands shall be made of heavy duty brass machine finished and nickel chrome plated.
- iii. Thickness of plating shall not be less than 10 micron.
- iv. All washers and hardware shall also be made of brass with nickel chrome plating. Rubber components shall be of neoprene and of tested quality.
- v. Necessary cable dimensions shall be furnished to the successful contractor.
- vi. Cable glands shall be single compression for indoor use, double compression type for outdoor use.
- vii. Glands for classified hazardous areas shall be double compression type.

ANNEXURE-W

SPECIFICATION FOR LOCAL CONTROL PANELS, LIR/LIE, JUNCTION BOX, & ERECTION MATERIALS

1.0 LOCAL CONTROL PANEL

- a. The cabinet mounted equipments shall be fully assembled, installed in mounting racks, wired and fully tested as per specification requirements and Owner approved drawings in the manufacturing works of a qualified manufacturer prior to shipment to the project site. The Bidder shall ensure that the cabinets are complete and ready for installation before dispatch from manufacturing works. The installation work at project site for these cabinets should only involve connections through multi pair cables from marshalling cabinets (wherever provided) to system cabinets and inter-cabinet/cabinet to UCD/UCP/BUP.
- b. The Control cabinets shall house all types of modules / hardware to achieve all functions of Control System including signal conditioning modules, controller modules, I/O modules, communication controller modules, and all other requisite hardware for a complete system.
- c. Local control panel shall be of 2.5 mm steel construction, free standing type, totally enclosed dust and vermin proof with enclosure protection class of IP-55 as per IS: 13947 and colour shall be as per shade no. RAL 7032/7035.
- d. Panel shall be mounted on vibration dampers secured to steel frame on to the floor. Equipment and relays mounted on the panel shall be easily accessible.
- e. The panel shall be supplied completely wired up to terminal blocks for connecting external cables entering the panel from the bottom.
- f. Blank removable gland plate shall be provided with double compression type cable glands/conduits knockout along with the panel.
- g. Terminal block shall be rated 600 volts minimum and shall have strap cage clamp type screw less terminals suitable for connection with 2x2.5 sq. mm copper conductors on each side.
- h. Terminal block shall be provided with white marking strips. Fuses shall not be mounted on terminal blocks. At least 20 percent spare unused terminals fully wired shall be provided on terminal block.
- i. Contactors, Relays, timers and other devices mounted on the panel shall have clearly visible identification marking. Separate contactors shall be provided for start & stop command. Common contactor for start & stop command are not acceptable. All fuses shall be HRC semiconductor type of AC supply. HRC link & fuse shall be of removable type having 45 kA rupturing capacity (min) for protection of various circuits.
- j. The panel shall be provided with a 50x6 mm tinned copper earthing strip running throughout the length of the panel at the bottom.



- k. Panel shall be provided with space heaters with isolating DPN MCB, and thermostats. LED based illuminating lamps, complete with door switches; and 1 no. 6 pin 5/15amps sockets with DPN MCB.
- l. Separate power supply feeder shall be provided for utilities. Panel shall be provided with LED illuminating lamps with door switch and 6 point 5/15A, 240V AC socket with switch for maintenance purposes.
- m. Panel shall have removable lifting eye bolts for safe lifting from top during handling. The panel shall be provided with push buttons, indicating lamps, annunciators, indicating instruments, interlock/ de-interlock switches etc., required for the complete system.
- n. 20% spare relays of each type and rating shall be mounted and wired in relays control panel/Desk. All contacts of relays shall be terminated in terminal blocks of relay control panel/Desk, Additionally in the relay control panel/Desk, 20% spare terminal blocks shall be provided so that additional relays can be mounted and wired.
- o. The annunciation system shall consist of panel mounted audio-visual windows of 50x75 mm provided with plug-in-type solid-state logic 16 nos. high intensity LEDs in parallel. Each relay based control panel shall be provided with 30 nos. min. facial windows. Initiating contacts may be either NO or NC; a jumper or switch shall be provided in each card to make it suitable for either type of contact. A set of acknowledge, reset and test push buttons shall be provided on the panel. All printed circuit boards shall be of epoxy fibre glass construction.

The sequence of annunciation shall be as follows:

S No.	Condition	Visual	Audiable
1	Normal	OFF	OFF
2	Alarm	Flashing	ON
3	Acknowledge	Steady	OFF
	Return to Normal		
4	Before acknowledge	Flashing	ON
5	After acknowledge	Steady	OFF
	Reset		
6	Alarm condition	No change	No change
7	Return to normal	OFF	OFF

2.0 LOCAL INSTRUMENT RACK (LIR) / LOCAL INSTRUMENT ENCLOSURE(LIE)

Transmitters and switches located in the field shall be grouped together and shall be installed in the enclosure (closed transmitter racks) in case of outdoor area such as Boiler area etc. And, in open type Rack in case of covered area. Racks shall be factory prefabricated & painted and complete with internal tubing, manifold valve, isolation valves, integral junction boxes with outside access door, illumination etc. Racks used for furnace, flue gas and air application shall be provided with intermittent & continuous air purging.

2.0.01 Closed Type Instruments / Transmitter Racks

- a. Required number of Instruments / transmitter racks shall be furnished to house transmitters, switches and converters by grouping them suitably, area wise / function wise.
- b. The transmitter enclosure shall be constructed of 3 mm thick steel plate. The enclosures shall preferably be of modular construction and with two end plate assembly bolted to the frame.
- c. The enclosure shall approximately be 1200 millimeters wide, 1000 millimeters deep and 2200 millimeters high to allow easy access to the internals. Racks shall be reinforced as required to ensure true surfaces and to provide adequate support for instruments and equipment mounted therein. Double interlocking doors with three point locking arrangement shall be provided and shall be arranged for maximum possible access to the interior. Centre posts or any member which would reduce access shall not be provided.
- d. Doors shall have concealed quick removal type pinned hinges and locking handles. Doors locks shall accept the same key all over the plant. Neoprene material Gaskets shall be used between all mating sections to achieve dust proof enclosure rating for the modules and an IP-65 waterproof and dust tight rating on the terminal boxes. All Enclosures shall have access doors on front side.
- e. Bulkheads, especially designed to provide isolation from process line vibration shall be installed on modular bulk head plates of the transmitter enclosures to meet the process sensing line connection requirements. Removable top and bottom plates shall be furnished.
- f. All internal wirings and / or data bus connections, if any, between the transmitters and terminal junction box shall run through flexible dust tight conduits connected to the terminal box hub. No exposed wirings within transmitter racks, both open and closed type, is admissible.
- g. All racks shall have a common closed drain trough to connect transmitter drain points to a common header after suitable pressure breaking. Covered funnels shall be used for saturated liquid and steam service, whereas, open funnels may be used for cold liquid services. The trough shall be suitably



- sloped and shall have one end flanged and extending beyond the rack for connection to plant drain header.
- h. Vibration dampeners shall be installed for supporting each enclosure. The loading at each corner of the enclosure shall be determined by actual test weighting when construction is complete to determine the correct length of each dampener for proper loading of the dampener in accordance with owner's recommendations.
 - i. Sufficient spacing among adjacent transmitters shall be maintained to offer easy accessibility and operational convenience. The enclosure shall be designed with sizes to suit the grouping and to completely include all the hardware for hooking up the transmitters to the process on the basis of approved installation diagrams. A maximum of five (5) transmitters are envisaged to be grouped in one enclosure.

2.0.02 Open Type Transmitter Racks

- a. Open type transmitter racks may be provided for mounting Transmitters, switches, gauges, converters and other accessories in rooms, buildings and closed areas like the power house building.
- b. The open type racks may be shop or site fabricated. Transmitters, switches, converters and transducers of enclosure class IP-65 or better can be directly mounted on open racks. However, enclosures not conforming to the above protection standard shall have to be housed in enclosures conforming to IP-65 class prior to mounting them on open structures.
- c. Racks shall be constructed on structural members of adequate strength and rigidity to ensure proper support to the mounted instruments and equipment. Racks shall be of welded construction throughout. Major load-bearing posts shall be suitably supported by gusset plates or moment members. Suitable fenders grill shall be welded to the end-posts of the rack to outline a boundary beyond which no mounted equipment shall project to protect instrument from accidental contact during personnel movement. Each rack shall be provided with a canopy (sheet thickness of 3 mm) to protect the instrument from dripping water or falling objects.
- d. For Operational convenience, the open type racks shall be used for mounting pressure and temperature gauges and switches and the local operating stations for electrical drives in the vicinity. Gauges mounted in racks shall be bottom connected and secured by double lock nuts. All gauges shall be located within 1500 mm from the floor for easy readability.
- e. The structural design shall be such that no item shall interfere with maintenance and removal of instrument, equipment and their accessories.

2.0.03 Service Power and Lighting

- a. Each enclosure/racks shall be provided with universal type power receptacle, light fixture & LED lamps with wire guard and lighting switch etc. Lighting switches shall be door actuated & mounted inside the panel. Outlet box, switch box and device covers shall be of galvanized stamped steel. Light switches and power receptacles shall be installed inside the enclosure on the wall near the latch side of the enclosure door. Light fixtures shall be installed on the ceilings of the enclosures. Power Supplies for miscellaneous devices shall be provided with 2P MCB located within the enclosures/racks. MCB shall be mounted in Fuse blocks. Nameplates shall be furnished above the MCB blocks, identifying the devices being served.
- b. Each rack shall be provided with Universal type power receptacle, LED lamp light fixture with wire guard and lighting switch etc. Outlet box, switch box and device covers shall be galvanized stamped steel. Light fixtures shall be installed on the canopy of the rack.
- c. Power supply for receptacles and lighting shall be arranged. Power supplies for miscellaneous devices shall be provided with 2P MCB located within the rack JB. MCBs shall be mounted in blocks. MCB ratings will give on electrical schematic diagrams. Nameplates shall be furnished above the MCB blocks, identifying the devices being served.

2.0.04 Control Air - A control air supply header shall be furnished in each enclosure/racks having pneumatic devices. The header shall be 25 MM NB brass header stock drilled and tapped for 8 millimetre valves. A valve with double compression end fittings shall be installed in each tap. Not less than three spare connections shall be furnished in each enclosure/rack. The air header shall originate at a bulkhead penetration or fitting located in one of the bulkhead plates. Each pneumatic instrument shall have individual air shut off valve. Pressure reduction shall be achieved by air filter regulator sets. One filter regulator shall be furnished for each group of components making a system.

2.0.05 Service Air - A 15 mm NB service air header shall be furnished in each enclosure/rack housing draft and coal mill instruments. The header shall be furnished complete with a pressure regulating valve, pressure gauge and valve quick disconnect connections. A hose for connecting each header to the draft instrument line four way valve shall be furnished. The hose shall be self-storing nylon tubing having a burst pressure 15 Kg / Sq. cm. The service air header shall originate at a bulkhead penetration or fitting located on one of the bulkhead plates.

2.0.06 Power supplies - Bidder shall supply all required transformers, regulators and other power supply equipment to adapt sources of power to the requirements of the enclosure/rack mounted equipment. This shall include but not be limited to internal instrument illumination transformers. The circuits shall be separately isolated with MCBs.



2.0.07 Equipment Installation - Special attention shall be given in the piping layout to avoid air traps in liquid filled piping, or water pockets in piping.

2.0.08 Impulse piping / tubing

- a. Transmitter enclosures shall be complete with impulse piping & tubing, valves from enclosure bulkhead connection to all instruments and necessary drain / blow down connections. The type, size, material and pressure class of pipes / tubes, fittings, valves etc. Shall be suitable for the intended applications.
- b. Blow down piping / tubing may be shared, but individual instrument piping/tubing and valves shall be furnished. Piping / Tubing material within enclosures/rack shall conform to the application requirements. The final flexible connection to each instrument shall be fabricated with a double offset so that it may readily be disconnected to permit "in situ" calibration of the instrument.
- c. Bulkhead connection shall be used when instrument piping / tubing enters the enclosure/rack. For instruments lines which enter through the bottom of the enclosure/rack, the primary process line from the instrument valve shall be neatly installed, anchored and terminated at approximately 150 Millimeters above the floor of the enclosure/rack. The enclosure shall have a removable, gasketed floor plate to provide an effective seal around the incoming field primary process line. An angle shall be installed 600 Millimeters above the floor, running the length of the enclosure for anchoring of incoming field process lines.
- d. Pulsation dampeners shall be furnished wherever required.
- e. Drain pots shall be furnished for instruments measuring flue gas parameters and vacuum.
- f. All liquid filled blow down lines, except those measuring vacuum shall be connected to a header extended through one end of the enclosure/rack and turned downward for directing the blow down into drain. Gas filled lines and lines equipped with drain pots shall not be connected to the blow down header. The connection between the blow down valve and blow down header shall be constructed so that it can be removed to permit the connection of test instruments to the blow down valves.
- g. The draft instrument line four-way valves shall be installed so that the quick disconnect fitting is readily accessible for connection with the service air hose.
- h. Pipe and stainless steel tube welding shall comply with the provisions of the latest applicable ANSI code for Pressure piping.
- i. Instrument piping and tubing shall be hydrostatically tested at one and one-half times the maximum system pressure for that instrument except for low pressure and vacuum measurement the test pressure will be as per piping standard.



2.0.09 Instrument tubing

- a. Pneumatic tubing shall be installed in a neat workmanlike. It shall be supported frequently enough that it does not shake when subjected to vibration. All tubes which enter or leave the enclosure/rack shall be terminated on bulkhead fittings in the bulkhead plate.
- b. Pneumatic tubing material shall be 6mm OD brass / 316 stainless steel tubing, unless otherwise specified. Flare less tubing fittings shall be used for tubing connections smaller than one inch. Tubing shall be stretched before installation to assure straightness. Special tools shall be used for all bending and forming operations. Tubing shall be carefully handled to avoid flat spots, kinks, and short bends. All piping and tubing shall be air blown after erection and before attachment to equipment at either end.

2.0.10 Wiring of the Racks

- a. A fully enclosed IP 65 type junction box shall be provided in each rack for housing the terminal blocks connectors, power supply fuses and other electrical accessories, as required.
- b. Junction boxes for modular enclosures/racks shall be fabricated externally on one end of each enclosure/rack assembly to accept field wiring / cabling through the top or bottom of the junction box. A hinged door shall give access to the interior of the junction box.
- c. All electrical connections between instruments and the junction box terminal blocks shall be made. In addition all utility wiring for lighting and service power shall be installed.
- d. All wiring used within the enclosures/rack shall conform to NEC / IEC standards. All wiring shall run through flexible or rigid conduits and shall be terminated at suitable terminal blocks. Sufficient clearance shall be provided for all control and instrument leads and all incoming and outgoing leads shall be connected to terminal blocks suitably located for connecting external circuits. High impedance circuits shall be connected using shielded or coaxial wire suitable for the service. Conduits shall be supported properly at regular intervals with suitable conduit clamps. Wire shall be neatly arranged and routed / laid in PVC trough / tray.

3.0 JUNCTION BOX

S No.	FEATURES	ESSENTIAL/MINIMUM REQUIREMENT
1	Type of Enclosure	Flame proof/weather proof IP-65/Explosion Proof as per area classification. Design as per NEC-370 Article 18, 19 & 20.
2	Material	6 mm min. thick FRP with protective Coating.



		3 mm min. thickness Die cast aluminum for Flame proof/Explosion proof area.
3	Mounting	Indoor/Outdoor
4	Cable Entry	Bottom or Side
5	Cable Glands	Double compression type – Nickel plated brass with PVC hoods.
6	Terminals	Phoenix/Wago (screw less cage clamp type spring loaded)
7	No. of Terminals	As required with standardization with 20% spare of each size & type.
8	Grounding	Two terminals for body and shield ground.
9	Gasket	Neoprene/Polyurethane thickness 6.0 mm. Silicon for High Temperature area.
10	Door	Hinged, lockable type.
11	Accessories	Suitable mounting clamps and other accessories shall be in scope of bidder. The brackets, bolts, nuts, screws, glands, lugs required for erection shall be of brass, included in bidder scope of supply. High voltage & insulation resistance test shall also be conducted. M6 Ni plated Brass earthing stud shall be provided (external 2 nos. internal 1 no.)
12	Color	In General same as provided for control panels, and for special services, To be decided during detailed engineering & subject to owner's approval.

4.0 ERECTION MATERIALS - PROCESS CONNECTION AND PIPING

4.0.01 General Requirements

This section covers the material requirement for instrument connection to process, instrument process, piping, tubing, supports and accessories to be furnished under this specification and the requirements of installation and routing. Impulse lines, fittings and other accessories required for the erection of complete Instrumentation and Control System supplied under various packages of this specification shall be supplied on "as required" basis. Bidder shall offer all necessary items for this section based on his experience on similar plants, plant layout diagrams, installation drawings and other applicable sections of this specification. Based on the good engineering practices, Bidder shall furnish installation drawings during the engineering of the system for Owner's review and

approval .The installation of the drawings shall be suitable for his installation of his range of instrumentation. The Bidder shall furnish and test all required erection hardware, which is necessary for proper installation and interconnection of the equipment/systems furnished by the Bidder and their integration with main equipment/systems as per the enclosed installation drawings and other applicable clause.

The Bidder shall furnish all hardware and accessories to ensure that the equipment/systems furnished form a complete and operational system meeting the intent and requirement of this specification. All materials, furnished shall conform to the latest editions of America National Standard Code for Pressure piping, Power piping, ANSI B311.1, ANSI B16.11, ASME Boiler and Pressure Vessel Codes, IBR and other applicable ASME, ANSI and Indian Standards. Schedule numbers, sizes and dimensions of all carbon steel, stainless steel and alloy seamless steel pipe shall confirm to ANSI B.36.10 and of stainless steel pipe shall confirm to ANSI B 36.19 unless otherwise specified. All materials supplied under this section shall be suitable for intended service; process operating conditions and type of instruments used and shall fully conform to the requirements of this specification. The Bidder is responsible for the performance of the equipment furnished on system basis any shortfall in erection material observed during erection stage shall be compensated by the Bidder at no extra cost.

4.1 Guideline for Installation and Routing of Instrument Piping

4.1.01 General Requirements

The following general erection guidelines have been enumerated here to enable the Bidder to estimate the requirement of instrument piping in plant:-

- i. All instrument piping shall be in accordance with good engineering practice. It shall be finalized during engineering stage. Instrument piping shall be complete with fittings, valves and other required accessories.
- ii. Instrument piping shall not be routed:-
 - 1) Across equipment removal areas
 - 2) Below mono-rails and cranes
 - 3) Above or below removable gratings
 - 4) Above or below cable trays.
- iii. Primary Impulse Piping System:
 - 1) The primary impulse piping system shall include the instrument piping and all required accessories from process tap off point (root valves onwards) up to the respective instruments. From the same source, Tee off for instruments are not allowed. Separate tapping shall be provided for each instrument. The Bidder shall provide the necessary fittings and accessories along with impulse pipes for completeness and arrangements as per the finalized Instrument Installation Diagrams. Special accessories such as reservoirs and other devices shall be



installed as required for flow primary element connection as required by the design of instruments, in accordance with the instructions of the instrument manufacturer.

- 2) The Bidder shall prepare impulse pipe routing drawings.
- 3) Impulse piping shall include a blow-down line and shut-off valve adequate for the duty requirements and for withstanding continuous design pressure and temperature of process medium. For process pressure above 40 Kg/Cm²g, double valves shall be used before connecting to the blow-down header (This arrangement shall be provided for installation for the new transmitter if the existing transmitter has the same arrangement.)
- 4) To assure a constant static head the connections from low pressure steam and low pressure liquid filled lines should preferably slope downward continuously towards the instrument as the instrument is mounted below the source point. If downward slope is not feasible or the instrument is mounted above the source point, the line should slope upward continuously and a "pigtail" installed at the instrument to assure a water seal for temperature protection. Upward sloping liquid lines should be used only if the process pressure is sufficient to assure a head of liquid at the instrument. Horizontal runs should have a slope of not less than 40 mm per meter and must be adequately supported to maintain a constant slope. Vacuum connections to the condenser should always slope upward to the instrument.
- 5) Primary process piping for steam flow, liquid flow and manometric level measurement systems should preferably slope downward from the primary element connections to the instrument. Primary piping for flue gas and air flow measurement systems should preferably slope upward from the primary element connections to the instrument. If these requirements cannot be met, special venting or drain provisions will be required. Horizontal runs must have a slope of not less than 40 millimeters per meter and must be adequately supported to maintain a constant slope.
- 6) Primary process piping from the field which enters the instrument enclosure from the bottom shall extend into the enclosure approximately 150 millimeters and be equipped with a socket weld to flare less tubing coupling of stainless steel. This coupling shall be used to connect the field primary process line to the enclosure process line. The field primary process line shall be anchored to the enclosure angle with U-bolts. Holes for supporting U-bolts shall be field or drilled.
- 7) All impulse piping shall be supported rigidly at an interval not exceeding 1.5 meters so as to prevent excessive sag in piping. Process piping shall not be used for supporting impulse piping.
- 8) Impulse piping shall be installed to permit thermal expansion without placing excessive stress on the piping and without affecting the gradient of slope. Long continuous straight runs of piping shall always

be avoided. If required, expansion loops shall be provided at least every 2.5 meters to break the continuity.

- 9) All welded and screwed fittings shall conform to ANSI B16.11. Threads of piping components shall be taper pipe thread in accordance with ANSI B2.1. All threads shall be clean machine cut with all burrs and chips removed. Lubricants shall be of dry film type. Any one of the following compounds may be used as a pipe thread sealer. Bidder shall supply adequate amount of his preferred sealer for erection purpose.

1. Permatex
2. Molycote
3. Neolube

(Teflon tape shall not be used as a pipe thread sealer).

4.1.02 Impulse Piping System

Impulse piping system consists of primary impulse pipes/tubes, valves, fittings, valve manifolds and other accessories between the source connection point (source shut-off valve onwards) and all instruments/devices. Impulse pipe span for supporting clamp shall be 1.5 mtr. This will also include all piping and valves etc. required for instrument drain and vent connections. The Bidder shall furnish and test all items required for completeness of this specification.

4.1.03 Air Supply Piping

The piping for air supply shall be as specified below (However the Bidder shall supply the materials as required basis to complete the system in all respect).

1) Individual Supply Lines and Control Signal Lines:-

Air lines shall be ¼ inch size, connected by brass/SS316 flare less tubing fittings. Copper/SS316 tubing shall be light drawn tempered tubing conforming to ASTM B75 except copper tubing in tubing cables shall be annealed soft temper tubing conforming to ASTM B68 or B75. Fittings on the branch line to facilitate connections to the individual supply line shall be cast brass screwed type.

2) Flexible Hoses

Flexible hoses shall be ¼ inch SS flexible hose pipe and with Buna-N liner steel wire braid reinforcement complete with ¼ inch brass/SS316 fittings and shall have swivel male pipe threads. Each hose shall be done meter in length.

3) Pipe Material Specification:-

The piping material shall be carbon steel hot-dipped galvanized inside and outside as per IS-1239 or the equivalent of these standard heavy quality with screwed ends. The piping threads shall be as per ASA B.2.1.



4) Isolating Valves:-

Gate valves as per ASTM B62 inside screw rising stem screwed female ends as per ASA B.2.1 valve bonnet shall be union type and trim shall be stainless steel body rating 150 pounds ASA. Valves sizes shall be ½ inch to 2 inch.

5) Fittings:-

Forged cast steel A234 Gr. WPM galvanized inside and outside; screwed as per ASA B2.1 dimensions as per ASA B16.11, rating 2000 pounds, elbows and soft seats. The size of the fittings shall be ½ inch through 2 inch.

6) Air Filter Regulator Set:-

An instrument Air Filter Regulator Set with mounting assemblies shall be provided for each pneumatic device requiring air supply.

7) Instrument Air Piping System:-

Instrument Air shall be made available by the bidder at 3.5 to 7.0 Kg/cm² pressure. The instrument air may be arranged as under:-

- i. For the control valves and power cylinders in owner's scope but controlled by bidder's control system, the instrument air requirement for E/P converter shall be tapped from the nearby instrument air header laid by bidder / already laid existing piping with accessories available near the control valves or damper. Complete hardware required for interfacing with Owner system shall be in bidder scope.
- ii. Air supply piping shall be installed at site always with a slope of over 1/100 to prevent accumulation of condensed water within the pipe.
- iii. All joints in the instrument air sub-header shall be of screwed type.
- iv. Instrument airline shall be separate for each individual instrument, equipment & drive with own isolation valve and other required hardware. Tee off of instrument line for two or more same/similar services instrument, equipment & drive are not acceptable.
- v. Instrument air flushing/purging lines shall be provided for Bowl Mill DP, secondary air flow measurement instrument and other all flue gas services instruments etc.

8) Signal / Control Air Tubing System:-

Necessary tubes with fittings and accessories for output signal from pneumatic instruments mounted in the field and control signals to final control elements shall be covered under this tubing system.

4.1.04 Specification for Erection Hardware

The erection hardware shall meet the following specifications:-

a) Impulse Piping

S No	Item	Specification
1	High pressure and high temperature services (Medium: Steam & Water and furnace region)	Seamless Alloy Steel piping to ASTM A335 GR.P91 / 22 (schedule XXS / 160 for high pressure & high temperature)
2	Low pressure and low temperature services (Medium: Steam & Water)	Seamless carbon steel piping to ASTM A106, Gr. C
3	Low pressure and low temperature services (Air, Flue gas)	ERW carbon steel piping to IS 1239:1973 Heavy class System)
4	Steam and water analysis system	Seamless stainless steel piping to ASTM A312 GR. TP-321
5	Seamless copper tubing	ASTM B-75

b) Fittings Double compression type

S No	Item	Specification
1	Material for socket weld fittings	ASTM A105, ASTM A182, Gr. F22 6000/3000 lbs
2	Dimensions of fittings	ANSI B16.11
3	Fittings for steam and water analysis	Gr. F-321

c) Valves

S No	Item	Specification
1	3 - way valve	SS body/forged CS body stellited internals and SW ends as per requirement for 2500 lb/800 lb ASA ratings.
2	5- valve manifolds	FAS body/FCS body 316SS stellited internals with NPT (F) SCRD ends for 3000/2500 lb/1500 lb/800 lb ASA ratings. Construction - Single block (Bar stock)
3	3-valve manifolds	FAS body/FCS body 316SS stellited internals with NPT (F) SCRD ends for 3000/2500 lb/1500 lb/800 lb ASA ratings. Construction - Single block (Bar stock)



4	2-valve manifolds	FCS body, 316SS stellited internals, NPT (F) SCR D ends. Construction – Single block (Bar stock)
5	Isolation and drain valves	Globe valves with FAS body/FCS body, 316SS stellited internals SW ends for 3000/2500 lb/1500 lb/800 ASA ratings.

d) Other Fittings items

S No	Item	Specification
1	Condensation vessels	FAS/FCS body with NPT (F) SCR D connection and vent plugs for 3000/2500/1500/800 lb ASA ratings.
2	Racks and Associated Equipment	ANSI C83.9-1972
3	Code for pressure piping, welding and Hydrostatic testing	ANSI B-31.1
4	Flexible conduits with fittings	Lead coated, paper insulated, heat resistant flexible metallic conduits with necessary fittings.
5	3 Valve manifold shall be used, wherever Diff Pressure transmitter / switch have been used for pressure measurement.	
6	5 Valve manifold shall be used for Diff. Pressure & Flow measurement Transmitters / Switches	
7	2 Valve manifold shall be used for Pressure transmitter/switch/gauge everywhere in the plant, used for pressure measurement.	
8	Double ferruled double compression type fittings shall be used only, wherever required.	

C&I Inputs for Selection of Mechanical Equipments

1. Solenoid valves shall fulfil the following requirements:

- a. Type 2/3/4 way SS 316/Forged Brass (depending on the application subject to Employer's approval during detailed Engg.)
- b. Power supply: 24 V DC + 10%.
- c. Plug and socket electrical connection.
- d. Insulation: Class 'H'

2. All Control valves to be provided with SMART positioner as per the requirements indicated in the Annexure R



Data Sheets

PERFORMANCE DATA - SCR REACTOR			
S.No	Description	Unit	Data to be filled
1.1	General		
1	Unit load range for NOx guarantee		
2	De-NOx efficiency with newly installed catalyst	(%)	
3	De-NOx efficiency at the end of catalyst life	(%)	
4	Activity of newly installed catalyst		
5	Catalyst Activity at the end of catalyst life		
6	Catalyst Pluggage at the end of catalyst life	(%)	
7	Loss of catalyst material at the end of catalyst life	(%)	
1.2	Temperature (deg. C)		
1	Gas temperature at SCR reactor inlet	deg. C	
2	Gas temperature at SCR reactor outlet	deg. C	
3	Temperature of ash collected in SCR reactor ash hopper (if applicable)	deg. C	
4	Temperature of ash collected in duct ash hopper (if applicable)	deg. C	
5	Temperature of ammonia-air mixture at ammonia injection grid inlet	deg. C	
6	Maximum catalyst heating up rate (deg C/min)	deg. C	
7	Maximum catalyst cooling down rate (deg C/min)	deg. C	
8	Minimum flue gas temperature for continuous SCR operation with ammonia injection	deg. C	
1.3	Pressure (mmwc)		
1	Gas pressure at SCR reactor inlet	mmwc	
2	Gas pressure at SCR reactor outlet	mmwc	
1.4	Differential pressure (mmwc)		
1	Gas pressure drop across SCR reactor with new catalyst	mmwc	
2	Gas pressure drop across SCR reactor at end of catalyst life	mmwc	
3	Gas pressure drop from economizer outlet to APH inlet with new catalyst	mmwc	
4	Gas pressure drop from economizer outlet to APH inlet at end of catalyst life	mmwc	



1.5	Flow rate (Nm³/s)		
	Gas flow rate at SCR reactor inlet	Nm ³ /s	
	Gas flow rate at SCR outlet	Nm ³ /s	
1.6	Flue gas constituents		
1	NO _x concentration at SCR reactor outlet	mg/Nm ³ @ 6% O ₂ dry basis	
2	Ammonia Slip at reactor outlet with new catalyst	ppm	
3	Ammonia Slip (ppm) at reactor outlet at end of catalyst life	ppm	
4	SO ₂ to SO ₃ conversion rate in SCR with new catalyst (%)	%	
5	SO ₂ to SO ₃ conversion rate in SCR at end of catalyst life(%)	%	
6	Molar ratio NH ₃ /NO _x at reactor inlet		
7	NH ₃ /Air ratio at Ammonia Injection grid inlet		
8	Conversion of elemental mercury to oxidized mercury (%) (if measured)	%	
1.7	Velocity (m/s)		
1	Gas velocity in SCR reactor inlet duct	m/s	
2	Gas velocity through SCR reactor	m/s	
3	Gas velocity in SCR reactor outlet duct	m/s	
1.8	Supplementary Data for SCR System		
1	Water requirement i) DM water ii) Service Water iii) Potable water		
2	Service air		
3	Instrument air		
4	Super-heated steam		
5	Number and electrical rating of AC power supply feeders for each control instrumentation system in Bidder's scope		
6	Schedule of power consumption		

PERFORMANCE DATA - AMMONIA SYSTEM

S.No	Description	Unit	100% TMCR Design Coal	BMCR Design Coal	HP Out Design Coal	60 TMCR Design Coal	BMCR Worst Coal	TMCR Worst Coal
	Ammonia Handling System							
1.1	Temperature (deg. C)	deg. C						
1	Ammonia forwarding pump suction temperature at minimum ambient temperature	deg. C						
2	Ammonia forwarding pump discharge temperature at minimum ambient temperature	deg. C						
3	Temperature of ammonia at vapouriser inlet	deg. C						
4	Temperature of ammonia at vapouriser outlet	deg. C						
5	Temperature of steam to ammonia vapouriser	deg. C						
6	Temperature of ammonia at air-ammonia mixer inlet	deg. C						
7	Temperature of dilution air at air-ammonia mixer inlet	deg. C						
1.2	Pressure (mmwc)							
1	Ammonia storage tank pressure at minimum ambient temperature	mmwc						
2	Ammonia forwarding pump suction pressure at minimum ambient temperature	mmwc						
3	Ammonia forwarding pump discharge pressure at minimum ambient temperature	mmwc						
4	Pressure of ammonia at vapouriser inlet	mmwc						
5	Pressure of ammonia at vapouriser outlet	mmwc						
6	Pressure of ammonia at air-ammonia mixer inlet	mmwc						
7	Pressure of dilution air at air-ammonia mixer inlet	mmwc						
8	Pressure of ammonia-air mixture at ammonia injection grid inlet	mmwc						
9	Ammonia pressure drop from vapouriser outlet to air-ammonia mixer inlet	mmwc						
1.3	Flow rate (Kg/hr)							
1	Ammonia flow rate at vapouriser outlet	Kg/hr						
2	Ammonia flow rate at air-ammonia mixer inlet with new catalyst	Kg/hr						
3	Ammonia flow rate at air-ammonia mixer inlet at end of catalyst life	Kg/hr						
4	Dilution air flow rate at air-ammonia mixer inlet	Kg/hr						
5	Ammonia-air flow rate through ammonia injection grid	Kg/hr						
1.4	Ammonia Piping							
1	Pipe size							
2	Material							
3	Length							
1.5	Foundation details of Ammonia tanks							



EQUIPMENT DETAILS FOR SELECTIVE CATALYTIC REDUCTION

S.No	Description	Unit	Data to be filled
1.1	General		
1	Manufacturer of SCR System		
2	Manufacturer's model number		
3	No. of SCR reactors per steam generator		
4	Capacity of each SCR reactor (% of BMCR FG flow)		
5	Reactor Width (m)	m	
6	Reactor depth (m)	m	
7	Reactor height (m)	m	
8	Total no. of catalyst layers / reactor		
9	No. of catalyst layers / reactor in service		
10	Height between two adjacent catalyst support levels (m)	m	
11	Height between top edge of catalyst module and bottom edge of the immediately upper catalyst support level (m)	m	
12	Number of catalyst modules and elements per module for each layer		
13	Catalyst pluggage considered for catalyst volume determination		
14	Total Catalyst volume per reactor (m ³)	m ³	
15	Catalyst volume per reactor per layer (m ³)	m ³	
16	Total Catalyst surface area per reactor (m ²)	m ²	
17	Catalyst weight per layer / per reactor (MT)	MT	
18	Percentage of Catalyst pluggage (filled with ash) considered for support structure design (MT)	MT	
19	Space Velocity (m ³ /s/m ³)	m ³ /s/m ³	
20	Area Velocity (m ³ /s/m ²)	m ³ /s/m ²	
21	Type of Static mixer for ammonia and flue gas mixing		
22	No. of nozzles in ammonia Injection Grid		
23	Type and material of nozzle		
24	No. of catalyst de-dusting levels/reactor		
25	Type and number of catalyst de-dusting devices/layer/reactor		
26	Medium and its consumption rate for catalyst de-dusting		
27	Guaranteed power consumption of SCR system for one steam Generator at the guarantee point (KW)	KW	
28	Capacity of Economiser bypass system (if in Vendor scope)		
29	Capacity of SCR bypass system (if in Vendor scope)		
30	Proposed standard for conducting the performance tests		
31	Type of catalyst handling device		
32	Capacity of catalyst handling device (MT)	MT	
1.2	SCR reactor casing		
1	Material		
2	Casing wall thickness (mm)	mm	
3	Design pressure (mmwc) (+ve & -ve)	mmwc	
4	Design temperature (deg C)	deg C	
5	Max. pressure withstand capacity		
6	Max. temperature withstand capacity and duration		
7	No. of catalyst support levels		
8	Maximum load bearing capacity of each catalyst support layer(MT)	MT	
9	Number of inspection doors/layer		
10	Dimensions of access openings of inspection doors (mm x mm)	mm x mm	
1.3	Catalyst		
1	Supplier name		
2	Type of catalyst		
3	Catalyst material chemical composition		
4	Dimension of each catalyst module and element (L x W x H) (mm)	mm	
5	No. of catalyst element per module		
6	No. of plates in each element box for plate type catalyst		
7	No. of catalyst sub-layer per module		
8	Catalyst pitch (mm)	mm	
9	Catalyst plate thickness (mm)	mm	
10	Catalyst Substrate material		
11	Substrate thickness (mm)	mm	
12	Catalyst plate dimension for plate type catalyst (HXW) (mm)	mm	
13	Catalyst Porosity (%)	%	
14	Specific surface area (m ² /m ³)	m ² /m ³	
15	Specific Weight (Kg/m ³)	Kg/m ³	
16	Whether module contains a removable sample element		
17	Maximum Continuous Operating Temperature (deg C)	deg C	
18	Minimum Continuous Operating Temperature (deg C)	deg C	



19	Heating up rate (max.)(oC/min)	oC/min	
20	Cooling down rate (max.)(oC/min)	oC/min	
21	Type of catalyst erosion protection (if applicable)		
22	Minimum chemical life (months)	months	
23	Minimum mechanical life (months)	months	
24	Total Number of sample catalyst for two Reactor		
25	Space velocity (m ³ /h/m ³)	m ³ /h/m ³	
26	Area velocity (m ³ /h/m ²)	m ³ /h/m ²	
27	Physical properties of Catalyst		
	Geometry		
	Pitch		
	Plate thickness		
	Compressive Strength		
	Bend Strength		
	Bond Strength		
	Abrasion Resistance		
	Surface Area (m ² /m ³)	m ² /m ³	
	Pore Volume (m ² /g)	m ² /g	
1.4	Ammonia Injection Grid		
1	Type of Ammonia Injection grid		
2	Control of ammonia Injection (Zonal / overall)		
3	No. of nozzles		
4	Material of the nozzle		
5	Material of the ammonia pipes/manifold		
6	Nozzle size (mm)	mm	
7	Nozzle pitch (mm)	mm	
8	Nozzle spray direction		
9	Velocity at nozzle outlet (m/s)	m/s	
10	Size and weight of pipe frames (diameter and schedule) Vertical frames and Cross frames		
11	Drawing reference No		
1.5	Catalyst De-dusting System		
1	Type Sonic Horn/ Air Cannon/Soot Blower		
2	Manufacturer		
3	Location (Outdoor)		
4	Cleaning medium		
5	Parameters of cleaning medium		
	Pressure	(Kg/cm ²) (abs)	
	Temperature (deg.C)	deg C	
	Flow rate (m ³ /s)	m ³ /s	
6	Source of cleaning medium		
7	De-dusting Frequency per day		
8	Number of De-dusting device/layer		
9	Total time required for one complete cycle of De-dusting operation (min)	min	
10	Depth of penetration (mm)	mm	
11	Cleaning radius/angle		
12	Effective area cleaned by one De-dusting device (m ²)	m ²	
13	Reduction in flue gas pressure drop across SCR reactor after each de-dusting cycle (mmwc)	mmwc	



1.6	For Sonic Horn(if applicable)		
1	Horn Material		
2	Diaphragm Material		
3	Diaphragm Life (yrs)	years	
4	Output power level (dB) and frequency (Hz)	Hz	
5	Maximum operating temperature (oC)	deg C	
6	Weight of each sonic horn (Kg)	kg	
1.7	For Air Cannon(if applicable)		
1	Nozzle Material		
2	Compressed air storage tank Material		
3	No. of ports		
4	No. of compressed air storage tanks/layer		
5	Capacity of each compressed air storage tank (Nm3)	Nm3	
1.8	For Soot Blower		
1	Type of Electric Drive Dual/Single Electric Drive		
2	Material		
	Lance / Swivel tube		
	Nozzle		
3	Motor rating (kW)	KW	
4	Location drawing of De-dusting devices		
5	Description of panels & system equipment offered		
6	Reference drawing Nos.		
1.8	Dilution Air System		
1.8	Dilution Air Fan		
1	Manufacturer		
2	Type Dual/Single Electric Drive		
3	Number and configuration of dilution air fan per steam generator		
	Capacity Max Flow (m3/sec)Head (mmwc)		
	Associated temp. (deg C)		
	Density (Kg/m3)		
4			
5	Source of air supply		
6	Max speed of fan (rpm)	rpm	
7	Fan efficiency at 100% TMCR	%	
8	Auxiliary power consumption at 100% TMCR (kW)	KW	
9	Overall dimensions		
10	Motor rating (KW)	KW	
11	Total weight of fan and motor (tonnes)	tonnes	
12	Method of lubrication		
	For fans		
	For motors		
13	Mode of air flow control adjustment		
14	Impeller diameter (mm)	mm	
15	Shaft diameter (mm)	mm	
16	Material of construction		
	Casing		
	Impeller blades		
	Shaft		
1.9	Dilution Air Heater (if applicable)		
1	Manufacturer		
2	Type		
3	Number and configuration per steam generator		
4	Auxiliary power consumption at 100% TMCR (kW)	KW	
5	Heater rating (KW)	KW	
6	Voltage level (V)	V	
7	Estimated life of heating element (years)	years	
1.10	Ash Hoppers		
	For SCR Reactor (if applicable)		
1	No. per SCR reactor		
2	Material		
3	Plate thickness (mm)	mm	
4	Side angle	degrees	
5	Valley angle	degrees	
6	Storage capacity of each hopper (hours)	hours	
7	Volumetric storage capacity of each hopper (m3)	m3	
8	No. of access doors per hopper		
9	Access door dimensions (mm x mm)	mmxmm	
10	Hopper dust level detectors		
	a) Number per hopper		
	b) Type		
11	Ash collection rate (Kg/hr)	kg/hr	

1.11	Ammonia Unloading, Storage and Forwarding System			
1	Name of overall system designer			
2	Design codes and standard			
1.12	Truck Tank Unloading Station			
1	Manufacturer			
2	Type of connections			
3	Hose Material			
1.13	Ammonia storage Tank			
1	Type of Ammonia storage tanks Horizontal			
2	No. and configuration of ammonia storage tanks			
3	Design code			
4	Storage capacity (days)	days		
5	Operating pressure	(Kg/cm2) (abs)		
6	Design pressure (Kg/cm2) (abs) (+ve & -ve) vii Operating Temperature (deg. C)	deg C		
7	Design Temperature (deg. C)	deg C		
8	Tank Volume (m3)	deg C		
9	Maximum storage volume (m3)	m3		
10	Vapour space in tank (%)	%		
11	Hydraulic test pressure (if required)	(Kg/cm2) (abs)		
12	Shell thickness (mm)	mm		
13	Corrosion allowance			
14	Tank diameter (mm)	mm		
15	Tank length (mm)	mm		
16	Weight when empty (Kg)	kg		
17	Material			
	Shell and head			
	Nozzle necks			
	Nozzle flanges			
	Manhole nozzle			
	Manhole flange			
	Supports and structural attachments			
18	Reference drawing Nos			



1.14	Ammonia Unloading Compressor		
1	Manufacturer		
2	Type		
3	No. and configuration		
4	No. of stages		
5	No. of cylinders		
6	Cylinder bore (mm)	mm	
7	Stroke (mm)	mm	
8	Rated Capacity (Nm ³ /s)	Nm ³ /s	
9	Design temperature (°C)	deg C	
10	Design pressure	(Kg/cm ²) (abs)	
11	Maximum Discharge pressure	(Kg/cm ²) (abs)	
12	Maximum Compression ratio		
13	Speed of the compressor (rpm)	rpm	
14	Efficiency (%)	%	
15	Motor rating and speed	(KW, rpm)	
16	Construction features		
	Built in relief valve Yes/No	Yes/No	
	Relief valve set pressure adjustable Yes/No	Yes/No	
	Common base plate for compressor & motor Yes/No	Yes/No	
17	Material of construction		
	Cylinder		
	Piston		
	Piston Rod		
	Crank Shaft		
	Connecting rod		
	Bearing		
18	Noise Level (dB)	dB	
19	Dimension (LxWxH)(mm)	mm	
20	Reference drawing Nos.		
21	Codes and Standards applicable		
1.15	Ammonia Forwarding Pump (if applicable)		
1	Manufacturer		
2	Type		
3	No. and configuration		
4	No. of stages		
5	Rated Capacity (M ³ /hr)	m ³ /hr	
6	Design temperature (°C)	deg C	
7	Design pressure	(Kg/cm ²) (abs)	
8	Minimum temperature ammonia pump can handle (°C)	deg C	
9	Specific gravity of ammonia at above temperature		
10	Maximum Discharge pressure	(Kg/cm ²) (abs)	
11	Maximum differential pressure between suction and discharge pump can handle	(Kg/cm ²) (abs)	
12	Speed of the pump (rpm)	rpm	
13	Efficiency (%)	%	
14	Maximum entrained vapour pump can handle (%)	%	
15	Motor rating and speed (kw, rpm)	kw, rpm	
16	Minimum allowable suction pressure (mmwc)	mmwc	
17	Construction features		
	Built in relief valve Yes/No	Yes/No	
	Relief valve set pressure adjustable Yes/No	Yes/No	
	Magnetic coupling drive Yes/No	Yes/No	
	Common base plate for pump & motor Yes/No	Yes/No	
18	Material of construction		
	Casing		
	Rotor		
	Shaft		
	Shaft sleeves		
	Base plate		
	Wearing rings (if required)		
	Bearing		
19	Dimension (LxWxH)(mm)	mm	
20	Reference drawing Nos.		
21	Codes and Standards applicable		

1.16	Ammonia Vaporization system			
1	Manufacturer			
2	Type			
3	No. and configuration			
4	Steam source			
1.17	Ammonia Accumulator			
1	Number			
2	Type of accumulator Cylindrical & Vertical			
3	Net capacity of each accumulator (m3)	m3		
4	Design temperature (oC)	deg C		
5	Design pressure (Kg/cm2) (abs)	abs		
6	Inner diameter of accumulator (mm)	mm		
7	Height of accumulator (mm)	mm		
8	Corrosion Allowance (mm)	mm		
9	Material/Thickness(mm)			
	Shell			
	Head			
	Nozzle			
	Codes and Standards applicable			
1.18	Waste Ammonia Dilution Tank			
1	No. and configuration			
2	Storage Capacity of each tank (m3)			
3	Diameter of each tank (m)	m3		
4	Height of each tank (m)	m		
5	Maximum storage volume (m3)	m		
6	Tank Material/Thickness(mm)	m3		
	a) Side Wall	mm		
	b) Bottom	mm		
	c) Roof	mm		
7	Design Pressure (Pa) / Temperature (oC)	deg C		
8	Codes and Standards applicable			
1.19	Waste Water Collection System			
1	Dimension of dyked area			
2	Storage capacity of dyked area (m3)	m3		
3	No. of waste water retaining basin			
4	Storage capacity of retaining basin (m3)	m3		
5	Dyke and retaining basin material			
6	No. and configuration of waste water disposal pump			
7	Design capacity of waste water disposal pump (m3/s)	m3/s		
8	Design pressure of waste water disposal pump (bar)	bar		
9	Design pressure of waste water disposal pump (oC)	deg C		
10	Pump material			
1.20	Water Spray Devices			
1	Location			
2	Type of spray device			
3	Material of nozzle			
4	Spray Water flow rate (m3/s)	m3/s		
5	Spray Water pressure (bar)	bar		



1.21	Chemical dosing system for waste ammonia neutralization		
1	Type of chemical for dosing		
2	Pump capacity		
1.22	POWER CONSUMPTION (kW) FOR SCR SYSTEM OF ONE BOILER Normal Maximum		
1	Ammonia unloading compressor	KW	
2	Ammonia forwarding pump (if applicable)	KW	
3	Ammonia vaporizer	KW	
4	Dilution air fan	KW	
5	Dilution air heater (if applicable)	KW	
6	Any other load	KW	
7	Total	KW	
1.23	Thermal Insulation		
1	Type of insulating material (s)		
2	Manufacturer's name		
3	Maximum hot face temp. (deg. C) the insulating material can withstand	deg C	
4	Bulk Density of insulating material (Kg./m3)	Kg./m3	
5	Area to be insulated and insulation thickness		
	SCR reactor Casing		
	SCR inlet duct		
	SCR outlet duct		
	SCR bypass duct		
	Economiser bypass duct		
6	Ash hopper		
	SCR Reactor (if applicable)		
	Duct (if applicable)		
7	Ammonia pipelines		
8	Ammonia Vapouriser		
9	Any other		
10	Total		
11	Insulation material standard		
1.24	EQUIPMENT WEIGHT (TOTAL)		
1	Structural Steel	ton	
2	SCR reactor including catalyst	ton	
3	SCR inlet duct including Ammonia injection grid, static mixer, Guide vanes, flow splitters etc	ton	
4	SCR outlet duct	ton	
5	SCR bypass duct	ton	
6	Economiser bypass duct(if in Vendor scope)	ton	
7	Platforms, Walkways stairways	ton	
8	Insulation and cladding	ton	
9	Control and Instrumentation	ton	
10	Others	ton	
11	Total estimated weight (Per Steam Generator)	ton	
	Excluding dust	ton	
	Including dust	ton	

GENERAL TECHNICAL INFORMATION / DRAWINGS FOR SELECTIVE CATALYTIC REDUCTION SYSTEM
(After Award of the Contract)

1.1	Characteristic/Correction Curves for SCR System	
1	Gas flow rate vs DeNOx efficiency	
2	Gas temperature vs DeNOx efficiency	
3	Inlet NOx concentration vs DeNOx efficiency	
4	Catalyst deactivation (Relative activity& Ammonia slip V/s operating time	
5	Gas flow rate vs pressure drop across SCR reactor	
6	Pressure drop vs Aux Power Consumption (KW)	
7	Combined effect of gas flow rate and NOx concentration vs Ammonia consumption	
8	Gas velocity vs catalyst life	
9	Gas inlet dust concentration vs catalyst life	
10	Nox/ ammonia molar ratio V/s outlet Nox concentration	
11	Ammonia slip & SO3 concentration Vs Ammonium bi-sulphate formation Temperature	
12	Ammonia slip & SO3 concentration Vs Ammonium bi-sulphate formation rate	



LIST OF MANDATORY SPARES FOR SCR SYSTEM

Sl. No.	ITEM DESCRIPTION	QUANTITY
1	Catalyst ##	
1.1	Catalyst Module (to be supplied in a suitable packing so that it is not affected by outside environmental conditions during storage)	Total no equivalent to 1 Layer for each unit and to be supplied matching 75% guaranteed life of running catalyst.
2	Catalyst Module Seals ##	100% for each unit
3	Soot Blower/ Sonic Horn Assy	
3.1	Complete Assembly	2 no. per Unit
4	Dilution Air Blower	
4.1	Complete Impeller Assembly	1 no. of each type
4.2	Bearing	1 set of each type
4.3	Motor	1 no. of each type
5	Ammonia injection Nozzles, if applicable ##	25% for each unit
6	Injection Grid assembly pipes	10 % quantity of each type and size for each unit
7	Valves	10% of each type and size (minimum 1 no of each type and size)
8	Ammonia unloading System	
8.1	Complete compressor assembly	1 no
8.2	Complete vaporizer assembly	1 no
8.3	Disposal pump assembly	1 no
9	Ammonia Forwarding Pump	
9.1	Complete Impeller Assembly	1 no. of each type
9.2	Casing Liners	1 set of each type
9.3	Bearing	1 set of each type
9.4	Motor	1 no. of each type
9.5	Pump discharge valve assembly	1 no. of each type
10	Flow guide vanes/straightener/splitters	10% quantity of each shape and size for each unit
11	Static Flow Mixer(Guide vane/splitter/liner)	10% quantity of each shape and size for each unit

Note: (1) Item wise price break up to be furnished

(2) ## - The items under Sl.No. 1, 2 and 5 will be considered for price evaluation.