

TD-106 Rev No. 00	Form No.	 HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD		FP60259 Rev No. 02 Page 1 of 8																																																																																				
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company. <u>MECHANICAL SEALS FOR BOILER FEED PUMP TYPE: MDG366</u> 1.0.0 INTENT OF SPECIFICATION : This specification is intended to cover the technical requirements of the shaft seals (Mechanical seals) for Boiler Feed Pumps type MDG366 Coupling side (DE) and End side (NDE). 2.0.0 SCOPE OF SUPPLY: 2.1.0 The scope of supply shall include Design, Engineering and Manufacturing, Inspection, Testing, Packing and forwarding the Mechanical seals. 3.0.0 TECHNICAL REQUIREMENTS: 3.1.0 <u>Technical Data:</u> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 40%;">Seal type</td> <td style="width: 10%;">:</td> <td style="width: 50%;">Cartridge design, stationary flexible element</td> </tr> <tr> <td>Flushing</td> <td>:</td> <td>Self-flushing (API682 Plan 23)</td> </tr> <tr> <td>Quenching</td> <td>:</td> <td>N/A</td> </tr> <tr> <td>Auxiliary glands</td> <td>:</td> <td>Bush (Bronze cast)</td> </tr> <tr> <td>Dimensions</td> <td>:</td> <td>As per coordination diagram in another page</td> </tr> <tr><td colspan="3"> </td></tr> <tr> <td>Fluid</td> <td>:</td> <td>Boiler feed water</td> </tr> <tr> <td>Fluid temperature</td> <td>:</td> <td>4 / 186.5 / 215 deg.C (Min / Rated / Max)</td> </tr> <tr> <td>Specific gravity</td> <td>:</td> <td>0.880 (Rated)</td> </tr> <tr> <td>Pump Suct. Pressure</td> <td>:</td> <td>Max. 3.24 / 6.54 MPaG (Rated/Max.)</td> </tr> <tr> <td>Pump Gland pressure</td> <td>:</td> <td>Max. 1.51 MPaG</td> </tr> <tr> <td>Design condition</td> <td>:</td> <td>6.54 MPaG x 215 deg.C (as pressure casing)</td> </tr> <tr> <td>Rotational speed</td> <td>:</td> <td>0 to 5428 rpm (rated rotational speed is 5270 min⁻¹)</td> </tr> <tr> <td>Balance ratio</td> <td>:</td> <td>(*) to be indicated by manufacturer</td> </tr> <tr> <td>Contact pressure</td> <td>:</td> <td>(*) MPaG, to be indicated by manufacturer</td> </tr> <tr> <td>PV value</td> <td>:</td> <td>(*) MPaG.m/sec, to be indicated by manufacturer</td> </tr> <tr><td colspan="3"> </td></tr> <tr> <td>Face material</td> <td>:</td> <td>Manufacturer's proposal</td> </tr> <tr> <td>Couple driving ring</td> <td>:</td> <td>Manufacturer's proposal</td> </tr> <tr> <td>Seal cover</td> <td>:</td> <td>Manufacturer's proposal</td> </tr> <tr> <td>Shaft sleeve</td> <td>:</td> <td>SUS403Q</td> </tr> <tr><td colspan="3"> </td></tr> <tr> <td>CW temperature</td> <td>:</td> <td>38 deg.C</td> </tr> <tr> <td>Design temp rise</td> <td>:</td> <td>3 deg.C</td> </tr> <tr> <td>CW supply pressure</td> <td>:</td> <td>Min 0.4 MPaG, Nor 0.5 MPaG, Max 0.6 MPaG</td> </tr> <tr> <td>CW line design</td> <td>:</td> <td>1.0 MPaG x 50deg.C</td> </tr> <tr> <td>Design pressure drop</td> <td>:</td> <td>less than 0.2 MPa.</td> </tr> <tr> <td>CW flow rate/cooler</td> <td>:</td> <td>(*) to be indicated by manufacturer</td> </tr> </table>						Seal type	:	Cartridge design, stationary flexible element	Flushing	:	Self-flushing (API682 Plan 23)	Quenching	:	N/A	Auxiliary glands	:	Bush (Bronze cast)	Dimensions	:	As per coordination diagram in another page				Fluid	:	Boiler feed water	Fluid temperature	:	4 / 186.5 / 215 deg.C (Min / Rated / Max)	Specific gravity	:	0.880 (Rated)	Pump Suct. Pressure	:	Max. 3.24 / 6.54 MPaG (Rated/Max.)	Pump Gland pressure	:	Max. 1.51 MPaG	Design condition	:	6.54 MPaG x 215 deg.C (as pressure casing)	Rotational speed	:	0 to 5428 rpm (rated rotational speed is 5270 min ⁻¹)	Balance ratio	:	(*) to be indicated by manufacturer	Contact pressure	:	(*) MPaG, to be indicated by manufacturer	PV value	:	(*) MPaG.m/sec, to be indicated by manufacturer				Face material	:	Manufacturer's proposal	Couple driving ring	:	Manufacturer's proposal	Seal cover	:	Manufacturer's proposal	Shaft sleeve	:	SUS403Q				CW temperature	:	38 deg.C	Design temp rise	:	3 deg.C	CW supply pressure	:	Min 0.4 MPaG, Nor 0.5 MPaG, Max 0.6 MPaG	CW line design	:	1.0 MPaG x 50deg.C	Design pressure drop	:	less than 0.2 MPa.	CW flow rate/cooler	:	(*) to be indicated by manufacturer
Seal type	:	Cartridge design, stationary flexible element																																																																																							
Flushing	:	Self-flushing (API682 Plan 23)																																																																																							
Quenching	:	N/A																																																																																							
Auxiliary glands	:	Bush (Bronze cast)																																																																																							
Dimensions	:	As per coordination diagram in another page																																																																																							
Fluid	:	Boiler feed water																																																																																							
Fluid temperature	:	4 / 186.5 / 215 deg.C (Min / Rated / Max)																																																																																							
Specific gravity	:	0.880 (Rated)																																																																																							
Pump Suct. Pressure	:	Max. 3.24 / 6.54 MPaG (Rated/Max.)																																																																																							
Pump Gland pressure	:	Max. 1.51 MPaG																																																																																							
Design condition	:	6.54 MPaG x 215 deg.C (as pressure casing)																																																																																							
Rotational speed	:	0 to 5428 rpm (rated rotational speed is 5270 min ⁻¹)																																																																																							
Balance ratio	:	(*) to be indicated by manufacturer																																																																																							
Contact pressure	:	(*) MPaG, to be indicated by manufacturer																																																																																							
PV value	:	(*) MPaG.m/sec, to be indicated by manufacturer																																																																																							
Face material	:	Manufacturer's proposal																																																																																							
Couple driving ring	:	Manufacturer's proposal																																																																																							
Seal cover	:	Manufacturer's proposal																																																																																							
Shaft sleeve	:	SUS403Q																																																																																							
CW temperature	:	38 deg.C																																																																																							
Design temp rise	:	3 deg.C																																																																																							
CW supply pressure	:	Min 0.4 MPaG, Nor 0.5 MPaG, Max 0.6 MPaG																																																																																							
CW line design	:	1.0 MPaG x 50deg.C																																																																																							
Design pressure drop	:	less than 0.2 MPa.																																																																																							
CW flow rate/cooler	:	(*) to be indicated by manufacturer																																																																																							

TD-106 Rev No. 00		Form No.	बी एच ई एल  HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD	FP60259 Rev No. 02 Page 2 of 8									
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED . It must not be used directly or indirectly in any way detrimental to the interest of the company.			Ref. Doc	3.1.1 WATER CHEMISTRY: Dosing systems are provided to maintain the chemistry of the boiler feed water and also to comply with different modes of operation i.e. CWT, "Combined Water Treatment mode" during continuous plant operation and "Ammoniacal mode or All volatile treatment (Oxygenated) AVT (O) mode" during start-up & shutdown conditions. The following philosophy of chemical feed system is considered: Start-up sequence: • Ammonia is dosed a pH of 9.2-9.5. • Cation conductivity reaches below 0.15 $\mu\text{s}/\text{cm}$ (at 25°C) and the trend is downwards. • Oxygen feed is manually started from DCS. During normal operation: • pH is maintained at 8.2-8.5 by dosing aqueous ammonia solution. Oxygen dosing rate can be adjusted in the range of 30-150 ppb from DDCMIS. • The oxygen dosing shall automatically turn off by closing the pneumatic control valve (PCV) if Cation conductivity in the cycle goes above 0.3 us/cm. Shut down sequence: • Oxygen feed needs to be stopped one hour before shut down and deaerator and LP heater vents needs to be opened. • Ammonia dosing rate needs to be increased to achieve pH in the range of 9.2-9.5.	3.2.0 The seals shall be capable of performing even in the event of complete loss of feed water due to incidents, such as inadvertent closure of suction valve. In such an event the pump needs to be safely brought down to rest and seals shall withstand the same.	3.3.0 The mechanical seals shall be of fully cartridge type. The seal shall be of proven design with reliable operating experience for at least a period of 3 years under similar conditions in at least 3 pumps.	3.4.0 The mechanical seals shall be designed for a guaranteed operating life of 20,000 hours.	3.5.0 The seals offered shall be suitable to be accommodated in the stuffing box space available in the pumps.	3.6.0 The seals shall be designed to have minimum number of 'O' rings and shall be designed to withstand maximum temperature encountered by the system.	3.7.0 Mechanical seal offered shall have sealing faces not inferior to stationary carbon / rotating silicon carbide combination.	3.8.0 The seals shall be balanced type and sufficient margin shall be provided between the maximum operating PV and the design PV. Bidder shall furnish the calculation for the PV value and shall indicate the margins provided.	3.9.0 The mechanical seals shall be designed for zero visible leakage.	3.10.0 During a complete AC Power supply failure, it would not be possible to supply any cooling water. All necessary protections shall be provided to prevent seal damage due to operation at high temperature.	3.11.0 The mounting arrangement of the seal, orientation of cooling water and flushing water connections shall be as per the coordination diagram shown in another page.

TD-106 Rev No. 00		Form No.	बी एच ई एल  HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD	FP60259 Rev No. 02 Page 3 of 8
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED . It must not be used directly or indirectly in any way detrimental to the interest of the company.			Ref Doc	3.12.0 <u>Reference drawings of pump for seal mounting dimensions</u> : -NA-	
				3.13.0 Independent cooling circuits are provided for coupling side and end side mechanical seals. 2x100% coolers and 2x100% magnetic filters of each mechanical seal along with all the required accessories in cooling circuits & seal circuits are mounted on a single skid. The complete skid assembly per pump is procured against spec no. FP60260. 3.14.0 Although the mechanical properties of SUS403Q can be determined from a test piece taken from the same charge, the actual products shall be subjected to same heat treatment as the test piece and submit the heat treatment record and hardness record. 3.15.0 Design the capability of pumping ring without fail considering the pressure drop in the flushing water line. Bidder shall furnish the characteristic curve of the pumping ring along with the offer. 3.16.0 Apply the appropriate materials confirming to the water treatment as indicated in 3.1.1. 3.17.0 All materials shall be free of asbestos and all wetted surfaces other than sleeve, in contact with flushing water shall be SS316. 3.18.0 If supplier cannot satisfy this specification, the supplier shall offer deviation and clarification in writing and shall get approval in advance. Deviation/Clarification shall be submitted even if there is no deviation. 4.0.0 <u>DRAWINGS & DATA TO BE FURNISHED:</u> 4.1.0 <u>Drawings to be furnished along with offer:</u> - Cross sectional drawing of seal indicating all the dimensions, bill of materials with positions nos., the schematic diagram showing all the connections sizes. - Pumping ring characteristic curve. - Part drawing of Shaft sleeve & Nut - Description of Mechanical Seal structure. - Mechanical seal data sheet as per attached format. - Operating Manual - List of recommended spares along with offer. - Quality plan 4.2.0 <u>Data to be furnished along with offer:</u> - PV value of the face combination materials. - Wear ratio. - Balance ratio & contact pressure - Roughness value. - Leakage rate. - Power consumption. - PV calculation sheet. - Estimated Heat generated in seal. - Reference list. - Quality assurance plan for the seal	

TD-106 Rev No. 00	Form No.	 HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD	FP60259 Rev No. 02 Page 4 of 8
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED . It must not be used directly or indirectly in any way detrimental to the interest of the company.		Ref Doc 5.0.0 INFORMATION TO BE FURNISHED AFTER AWARD OF CONTRACT 5.1.0 Detailed cross-sectional assembly of the seal with all parts identified on it along with their materials of construction (ASTM designation) and over all dimensions shall be submitted for BHEL approval. 5.2.0 Final quality assurance plan of the seal in five copies. 5.3.0 Soft copy of instruction manuals giving the details of installation, operation and maintenance instruction shall be furnished within four weeks of placement of purchase order. 6.0.0 TESTS & GUARANTEE CERTIFICATES 6.1.0 All the seal units shall be tested for leak tightness and dynamic performance in a suitable test rig at vendor works. <u>Details of test procedure and test rig facility available shall be furnished for approval prior to the test.</u> 6.2.0 Type test on one mechanical seal of each type per Purchase Order shall be carried out at supplier's works to prove its dry running capability followed by dynamic performance test. Seal unit assembly shall be completely strip down after the performance test and any visible damage is not acceptable. The type test and the strip down examination shall be witnessed by BHEL representative. 6.3.0 The compliance certificates shall be furnished for mechanical seal, cooler and magnetic filter. 6.4.0 A guarantee certificate shall be furnished for trouble free operation of the seal for a period of 24 months from the date of commissioning, 7.0.0 PACKING: Mechanical seals shall be separately packed to ensure its capability to withstand transit risks without damage. 8.0.0 MARKING: 8.1.0 A tag bearing relevant 12 digit material code of BHEL shall be attached to each seal consignment. 8.2.0 Following details shall be marked on the packing case. a) Name of manufacturer b) BHEL Purchase order number. 8.3.0 Direction of rotation shall be clearly engraved (or) a suitable marked-up plate shall be riveted on the seal plate of mechanical seals. 8.4.0 A name plate containing following details shall be riveted or fixed by screws on top of seal plate and shall be clearly visible. Mechanical seals received without these details will be rejected during inspection at our stores. i) Name of manufacturer ii) Month & year of supply iii) Direction of rotation and application of seal		

TD-106 Rev No. 00	Form No.	 HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD	FP60259												
				Rev No. 02												
				Page 5 of 8												
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED . It must not be used directly or indirectly in any way detrimental to the interest of the company. Ref Doc 9.0.0 <u>VARIANT TABLE:</u> <table><tr><th>VAR. NO.</th><th>DESCRIPTION & MAKE OF SEAL</th><th>MATERIAL CODE</th></tr><tr><td>01</td><td>Mechanical seal Coup. Side for MDBFP MDG366</td><td>FP9760259010</td></tr><tr><td>02</td><td>Mechanical seal End Side for MDBFP MDG366</td><td>FP9760259028</td></tr><tr><td></td><td></td><td></td></tr></table>					VAR. NO.	DESCRIPTION & MAKE OF SEAL	MATERIAL CODE	01	Mechanical seal Coup. Side for MDBFP MDG366	FP9760259010	02	Mechanical seal End Side for MDBFP MDG366	FP9760259028			
VAR. NO.	DESCRIPTION & MAKE OF SEAL	MATERIAL CODE														
01	Mechanical seal Coup. Side for MDBFP MDG366	FP9760259010														
02	Mechanical seal End Side for MDBFP MDG366	FP9760259028														



TD-106 Rev No. 00 Form No.	 HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD		FP60259	
				Rev No. 02	
				Page 6 of 8	


COPYRIGHT AND CONFIDENTIAL
 The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED .
 It must not be used directly or indirectly in any way detrimental to the interest of the company.

Ref Doc

MECHANICAL SEAL DATA SHEET						
				Date		
PUMP MODEL				OEM		
PURCHASE ORDER				END USER		
DRAWING NUMBER				SEAL ARRANGEMENT		
MEDIA				SEAL TYPE		
PARAMETER			UNIT		VALUE	
Specific gravity	P		kg/dm ³			
Specific heat	c		kcal/kg.deg.C			
Box / vessel temperature	D		deg.C			
Box / vessel pressure	P1		kg/cm ² G			
Flush flow rate	F		Lpm			
Shaft speed	N		rpm			
Balance diameter	D		mm			
Outside diameter	Do		mm			
Inside diameter	Di		mm			
Spring load	W		kg			
Reduction constant	K					
Co-efficient of friction	H					
Contact face area	A		cm ²			
Balance value			%			
Spring contact face pressure	Ps		kg/cm ²			
Face velocity	V		m/s			
PV value			kg/cm ² .m/s			
Torque	T		kg.m			
Power loss	H		KW			
Heat generation	Q		kcal/hr			
Temperature rise	DT		deg.C			
Calculated by				Approved by		

COPY RIGHT AND CONFIDENTIAL

The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company.



COORDINATION DIAGRAM
FOR SHAFT SEAL
MDG366 BFP

DIMENSIONS MARKED * SHALL BE MAINTAINED

TD-106-3 Rev No. 5 Form No.	 HYDERABAD	PRODUCT STANDARD PUMPS HYDERABAD			FP60259																																																																																																									
					Rev No. 02																																																																																																									
					Page 8 of 8																																																																																																									
RECORD OF REVISIONS																																																																																																														
<table border="1"> <thead> <tr> <th>Rev. No.</th> <th>Date</th> <th>Revision Details</th> <th>Revised By</th> <th>Approved By</th> </tr> </thead> <tbody> <tr> <td>01</td> <td>06.04.2016</td> <td>Revised to incorporate technical requirements in line with MHI purchase specification.</td> <td>KKC</td> <td>ASK</td> </tr> <tr> <td>02</td> <td>17.04.19</td> <td>Revised clause 6.0.0 for better clarity.</td> <td>ASK</td> <td>MSR</td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>						Rev. No.	Date	Revision Details	Revised By	Approved By	01	06.04.2016	Revised to incorporate technical requirements in line with MHI purchase specification.	KKC	ASK	02	17.04.19	Revised clause 6.0.0 for better clarity.	ASK	MSR																																																																																										
Rev. No.	Date	Revision Details	Revised By	Approved By																																																																																																										
01	06.04.2016	Revised to incorporate technical requirements in line with MHI purchase specification.	KKC	ASK																																																																																																										
02	17.04.19	Revised clause 6.0.0 for better clarity.	ASK	MSR																																																																																																										

COPYRIGHT AND CONFIDENTIAL
 The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED,
 It must not be used directly or indirectly in any way detrimental to the interest of the company.

