

Bid Document

Bid Details	
Bid End Date/Time	26-08-2020 12:00:00
Bid Opening Date/Time	26-08-2020 12:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	30 (Days)
Ministry/State Name	Ministry Of Heavy Industries And Public Enterprises
Department Name	Department Of Heavy Industry
Organisation Name	Bharat Heavy Electricals Limited (bhel)
Office Name	10120029-herp, Varanasi
Total Quantity	1500
Item Category	power cable for direct burial xlpe ugac cable
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Bid to RA enabled	No
Primary product category	power cable for direct burial xlpe ugac cable
Inspection Required	No

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

Power Cable For Direct Burial Xlpe Ugac Cable (500 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	10.0	10.0
	Number of cores (nos)	4	3.5, 4
	Cable Type	Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005	Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005, PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised steel Strip armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Solid	Solid
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable,	yes	*

	Type of the cable and Drum Number shall be embossed on every metre of the cable		
	standard cable length on a drum	500 meter for cable size up to and including 185 sqmm.	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
	Quantity supplied shall not be more than the ordered quantity.	yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Shadab Alam	221003,Tarna, Shivpur	500	30

Power Cable For Direct Burial Xlpe Ugac Cable (500 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in	16.0	16.0

	Sq.mm)		
	Number of cores (nos)	4	3.5, 4
	Cable Type	Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005	Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005, PVC outer Sheathed FR of Type ST-2 cable FR Grade C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised steel Strip armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded and Shaped	Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	500 meter for cable size up to and including 185 sqmm.	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*

	Quantity supplied shall not be more than the ordered quantity.	yes	*
CERTIFICATIONS	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*
	Name of Lab	-	*
	Address of Lab	-	*
	Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Shadab Alam	221003,Tarna, Shivpur	500	30

Power Cable For Direct Burial Xlpe Ugac Cable (500 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Values	Bid Requirement (Allowed Values)
GENERIC	Mode of Buying	Through bidding only	*
	Size of Cable (in Sq.mm)	50.0	50.0
	Number of cores (nos)	4	3.5, 4
	Cable Type	Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005	Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with amendment number 1 and 2 and 3 Reaffirmed 2005, PVC outer Sheathed FR of Type ST-2 cable FR Grade

			C1 Category having heat resisting insulation of PVC compound type C with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 1554 Part-1 1988 reaffirmed 2005
	BIS marked	yes	*
	BIS certificate number	-	*
	Armouring	Galvanised steel Strip armoured	Galvanised round steel wire armoured, Galvanised steel Strip armoured
	Armouring Type	single wire or strip armouring	single wire or strip armouring
	shape of conductor	Stranded and Shaped	Stranded and Shaped
CONSTRUCTIONAL	Number of armouring strip/wire for each size of cable	-	*
	size of armouring strip/wire for each size of cable	-	*
	Material of conductor	Aluminium EC Grade	*
	Weight of finished cable per meter	-	*
	In addition to marking requirements as per relevant specification, sequential marking for length, Size of the cable, Type of the cable and Drum Number shall be embossed on every metre of the cable	yes	*
	standard cable length on a drum	500 meter for cable size up to and including 185 sqmm.	*
	Part length which can be supplied by seller (meter)	-	*
	cable to be supplied on wooden drums conforming to IS: 10418/82 with latest amendments.	yes	*
CERTIFICATIONS	Quantity supplied shall not be more than the ordered quantity.	yes	*
	Availability of Type test report from Central government/NABL/ILAC accredited laboratory to prove conformity to the specification for minimum and maximum ratings.	yes	*
	Type Test Certificate No.	-	*
	Type Test Certificate date	-	*

Name of Lab	-	*
Address of Lab	-	*
Test Report to be furnished to the buyer on demand	yes	*

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Documents

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Shadab Alam	221003,Tarna, Shivpur	500	30

Special terms and conditions for category power cable for direct burial xlpe ugac cable

1.Specification for Cross linked Polyethylene insulated thermoplastic sheathed cables" is as per IS:7098 (Part 1):1988 with latest amendments including amendment no.5. Manufacturer shall furnish calculation sheet as per Appendix-C of IS:7098 (Part 1):1988 amdt., no.5 to buyer/consignee on demand. (Gem Category: Cross linked polyethylene and XLPE insulated PVC outer sheathed cable with aluminum conductor suitable for rated voltage at 1100 volts grade and conforming to IS: 7098 Part-1 1988 with latest amendment including amendment no.5)

Bid Specific Additional Terms and Conditions

1.Scope of supply (Bid price to include all cost components) : Only supply of Goods

[This Bid is also governed by the General Terms and Conditions](#)

---Thank You---