

Bid Document

Bid Details	
Bid End Date/Time	04-01-2021 15:00:00
Bid Opening Date/Time	04-01-2021 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	70 (Days)
Ministry/State Name	Ministry Of Heavy Industries And Public Enterprises
Department Name	Department Of Heavy Industry
Organisation Name	Bharat Heavy Electricals Limited (bhel)
Office Name	10250020-pem, Noida
Total Quantity	20400
Item Category	PVC Copper Cable, Single Core, Unsheathed cables with Flexible conductor-For Working Voltages Up to
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Experience Criteria,Past Performance,Certificate (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Past Performance	80 %
Bid to RA enabled	No
Primary product category	PVC Copper Cable, Single Core, Unsheathed cables with Flexible conductor-For Working Voltages Up to
Inspection Required	Yes
Inspection to be carried out by Buyers own empanelled agency	Yes
Type Of Inspection	Pre Dispatch
Name of the Empanelled Inspection Agency/ Authority	Board of Officers
Quality Assurance Plan document	1608549331.pdf
Estimated Bid Value	243670
Evaluation Method	Total value wise evaluation

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

1. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 80% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

PVC Copper Cable, Single Core, Unsheathed Cables With Flexible Conductor-For Working Voltages Up To (4000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type D
	Conductor material as per Cl.4.1 of IS:694:2010 (Complying with IS:8130:1984 latest)	Plain Copper
	Nominal Cross Sectional Area of Conductor (in Sq.mm)	1.5

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Parameters - PVC Copper Cable, Single Core, Unsheathed Cables With Flexible Conductor-For Working Voltages Up To (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
CONDUCTOR CLASS	Class-2 as per IS: 8130
MIN. NO. OF STRANDS & MAX. RESISTANCE OF CONDUCTOR	As per IS 8130 table-2
STANDARD BUNDLE LENGTH	90-100 meters
THE COLOUR WISE QUANTITY (MTR) OF PVC WIRES SHALL BE	For 1.5 sq mm: BLACK: 2000 RED: 800 YELLOW: 600 BLUE: 600

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting	Address	Quantity	Delivery Days
-------	---------------------	---------	----------	---------------

	Officer			
1	Alok Kumar Chaturvedi	248125,Construction Manager, BHEL C/o Executive Engineer, UJVNL E&M -II, Vyasi HEP, Hathiyari, District Dehradun Pincode -248125	4000	90

PVC Copper Cable, Single Core, Unsheathed Cables With Flexible Conductor-For Working Voltages Up To (12400 meter)

Technical Specifications

* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type D
	Conductor material as per Cl.4.1 of IS:694:2010 (Complying with IS:8130:1984 latest)	Plain Copper
	Nominal Cross Sectional Area of Conductor (in Sq.mm)	2.5

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Parameters - PVC Copper Cable, Single Core, Unsheathed Cables With Flexible Conductor-For Working Voltages Up To (12400 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
CONDUCTOR CLASS	Class-2 as per IS: 8130
MIN. NO. OF STRANDS & MAX. RESISTANCE OF CONDUCTOR	As per IS 8130 table-2
STANDARD BUNDLE LENGTH	90-100 meters
THE COLOUR WISE QUANTITY (MTR) OF PVC WIRES SHALL BE:	For 2.5 sq mm: BLACK: 6200 RED: 2200 YELLOW: 2000 BLUE: 2000

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Alok Kumar Chaturvedi	248125,Construction Manager, BHEL C/o Executive Engineer, UJVNL E&M -II, Vyasi HEP, Hathiyari, District Dehradun Pincode -248125	12400	90

PVC Copper Cable, Single Core, Unsheathed Cables With Flexible Conductor-For Working Voltages Up To (4000 meter)

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Category of Cable	FR
	Type of Insulation (shall conforming to IS:5831:1984 latest)	Type D
	Conductor material as per Cl.4.1 of IS:694:2010 (Complying with IS:8130:1984 latest)	Plain Copper
	Nominal Cross Sectional Area of Conductor (in Sq.mm)	4.0

* Specifications highlighted in bold are the Golden Parameters.

* Bidders may note that In respect of non-golden Parameters, the specifications 'Values' chosen by Buyer will generally be preferred over 'Bid requirement (allowed Values) by the Buyer.

Additional Specification Parameters - PVC Copper Cable, Single Core, Unsheathed Cables With Flexible Conductor-For Working Voltages Up To (4000 meter)

Specification Parameter Name	Bid Requirement (Allowed Values)
CONDUCTOR CLASS	Class-2 as per IS: 8130
MIN. NO. OF STRANDS & MAX. RESISTANCE OF CONDUCTOR	As per IS 8130 table-2
STANDARD BUNDLE LENGTH	90-100 meters
THE COLOUR WISE QUANTITY (MTR) OF PVC WIRES SHALL BE:	For 4.0 sq mm: BLACK: 2000 RED: 700 YELLOW: 700 BLUE: 600

* Bidders offering must also comply with the additional specification parameters mentioned above.

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Alok Kumar Chaturvedi	248125,Construction Manager, BHEL C/o Executive Engineer, UJVNL E&M -II, Vyasi HEP, Hathiyari, District Dehradun Pincode -248125	4000	90

Bid Specific Additional Terms and Conditions

- 1.Scope of supply (Bid price to include all cost components) : Only supply of Goods
- 2.After award of contract – Successful Bidder shall have to get Detailed Design Drawings approved from buyer before starting fabrication. Successful Bidder shall submit Detailed Design Drawings for Buyer's approval, within 7 days of award of contract. Buyer shall, either approve the drawings or will provide complete list of modification required in the drawings within 7 days. Seller shall be required to ensure supply as per approved Drawings with modifications as communicated by Buyer. If there is delay from buyer side in approval of drawing- the delivery period shall be refixed without LD for the period of delay in approval of Drawing.
- 3.**Nominated Inspection Agency:** On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:
Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC): Through Nominated TPIA
Post Receipt Inspection at consignee site before acceptance of stores: Not Applicable

4. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.
5. Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.
6. **OPTION CLAUSE:** The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.
7. Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.
8. The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.
9. While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.
10. **Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER):** Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.
When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---