

Ref Enquiry No. PE/PG/BLI/E-6503/2020, dt. 31/08/2020 GUARANTEED POWER CONSUMPTION FORMAT				Doc No:		PE-WC-468-571-A102	
				Rev No:		0	
				Date of issue:		15 May 2020	
NAME OF PROJECT:				2x250 MW NSPCL BHILAI EXPANSION POWER PROJECT			
NAME OF PACKAGE:				LIME FEEDING / DOSING SYSTEM			
TECHNICAL SPECIFICATION:				PE-TS-468-571-A102			
Sl.No.	Description / Item	Working	Standby	Power Consumption (KW) (at motor input terminal)	Duty Factor	Power Consumption (KW)	
1	2	3	4	5	6	7 = 3 x 5 x 6	
a.	Bucket Elevator	1	1		0.1		
b.	Fan/Blower for Bag Filter	1	1		0.1		
c.	Rotary Feeder	1	1		1		
d.	Screw Feeder	1	1		1		
e.	Agitator	1	1		1		
f.	Dosing pumps	1	1		1		
				Total Guaranteed power (KW)			
Notes							
1	Power consumption (KW) of motors shall be measured at motor input terminals when the system operating at the rated capacity. For this purpose, the drives of standby equipment shall not be considered.						
2	The minimum value of the total guaranteed power consumption quoted amongst techno commercially qualified bidders shall be taken as the guaranteed base power for the bid evaluation.						
3	The total guaranteed power consumption quoted by the bidders at column no. (7) shall be loaded at the rate of Rs.1,36,930 per KW for the differential power quoted over the guaranteed base power arrived as mentioned at S.N. 2 above.						
4	Power quoted by bidder shall be termed as 'Guaranteed Power consumption' (GPC) and bidder shall be liable to demonstrate compliance to GPC value during PG test/ Demonstration test at site. If the actual power consumption exceeds the guaranteed power consumption, liquidated damages shall be payable by the successful bidder at the rate of Rs.1,36,930 per KW excess power consumption, over the guaranteed power consumption indicated by bidder in his bid. Such liquidated damages may be recovered by the BHEL by deduction from the contract price or by enforcing the contract performance guarantee or in any other manner deemed fit by the BHEL.						
5	Completely filled in Guaranteed Power Consumption in this Format shall be submitted as a part of technical bid.						