

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

पावर सेक्टर – पच्छिम क्षेत्र
श्रीमोहिनी कॉम्प्लेक्स, 345 – किंग्सवे
नागपुर – 440 001



Bharat Heavy Electricals Limited

Power Sector – Western Region
Shreemohini Complex, 345 – Kingsway
Nagpur – 440 001

फॅक्स / FAX: 0712 – 3048605 वेब साईट / WEB SITE: www.bhelpswr.co.in

Page 1 of 2

Ref: BHE / PW / PUR / DBBDT-STR / 861-862/CLA-01

DT:30/06/2011

To

ALL BIDDERS

Dear Sir,

SUB : CLARIFICATION ON TENDER SPECIFICATION

NAME OF WORK: SUPPLY (EXCLUDING BHEL SUPPLIED MATERIALS), COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD; TRANSPORTATION TO FABRICATION YARD/ SITE; FABRICATION, ERECTION, ALIGNMENT, BOLTING/ WELDING/ FASTENING, GROUTING, TESTING AND HANDING OVER OF BUNKER STRUCTURES AND RAW COAL BUNKERS IN UNIT-1 & 2 OF 2X600 MW DBPL (DAINIK BHASKAR POWER LIMITED) PROJECT AT BARADARHA IN JANJGIR - CHAMPA DISTRICT IN CHHATTISGARH STATE

TENDER SPECIFICATION No: BHE/PW/PUR/DBBDT-STR/861-862

Query-01: Kindly delete the word “MS Grating” as separate item no ST 2307 is present in BOQ.

Reply-01: Ms grating mentioned in ST.No. 2301 is site fabricated and to be used at remote place to suit the site condition. However, quantity of such item is very nominal and will form a part of ST.NO.2301.

ST.NO.2307 refers only factory made electro forged galvanized grating which is different from ST.NO.2301.

Query-02: Sl.no. ST no. 2302,2303,2305,2306,2308,2310,2316,2317,2319 & 2323 are missing in rate schedule.kindly clarify.

Reply-02: ST.NO. mentioned in rate schedule are correct and they are drawn from standard BOQ of BHEL. Intermediate items which are not appearing are not applicable for this project.

Query-03: Kindly clarify the approximate distance from fabrication yard to erection site.

Reply-03: Distance of fabrication yard from erection site will be approx 500 m to 1 KM.

Query-04: Kindly confirm whether two locations for provision of construction power in fabrication yard and construction/erection site shall be provided or not.

Reply-04: Construction power shall be provided at single location. The location shall be decided by site as per the availability.

Query-05: Kindly refer ST no 2301 of rate schedule, “Handrail” word shall be deleted from item description as separate item no 2320 is appeared in BOQ

Reply-05: “Handrail” word considered to be deleted from ST.No. 2301.

Ref: BHE / PW / PUR / DBBDT-STR / 861-862/CLA-01

DT:30/06/2011

Query-06: Kindly confirm whether the supply of 4.6 grade erection MS Bolts is in bidder's scope or not.

Reply-06: It is in bidder's scope and within the quoted rate.

Query-07: Kindly confirm whether any type of blasting is not required for surface preparation and quantity for item no 2309 for extra over 2301 shall be 5500 MT instead of 3 MT.

Reply-07: a) For ST. No. 2301:- Any type of blasting (sand & shot) is not required and surface is to be cleared by means of manual or mechanical power tools only, for which rates are included in ST.No.2301 .

b) **ST.No. 2309 :-** Blasting may or may not be operative. However in safer side this item is included in BOQ to take care of galvanizing of certain small items like Ms Grating etc as per actual requirement. However for such items surface preparation by blasting shall be inclusive in 2309.

Query-08: Single point source distance estimated 500 Mtrs and may vary to an unspecified extent or limit for construction purpose and office. Please specify.

Reply-08: Bidder shall be abided by the contract condition. No deviation shall be acceptable. Bidders are requested to visit the site to make them fully acquainted with the actual site condition before submission of offer.

Query-09: Kindly specify the capacity of gantry crane for fabrication yard

Reply-09: Gantry Crane should be of minimum 100T capacity.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this clarification duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this clarification.

Thanking you,

Yours faithfully,

DY. GENERAL MANAGER (PUR)