

BHEL	PURCHASE SPECIFICATION		TC 5 4248
HYDERABAD			REV NO: 00
			PAGE 2 OF 4
3.0 <u>TECHNICAL REQUIREMENTS:</u> 3.1 Flow : As per enquiry 3.2 Design pressure : As per enquiry 3.3 Design Temperature : 100 °C 3.4 Operating Temperature : 60 °C 3.5 Pressure drop for complete unit : 0.35 Kg/cm² clean at design condition of at 40°C (46CST) (DP across complete unit including filter elements, filter body & 3-way transflow valve shall not exceed 0.35 bar during starting). 1.5 Kg/cm² Dirty condition (Element to be changed). Collapsible min. pr. 10 Kg/cm² (g). 3.6 Design : As per API 614, 5th Edition Clause 4.6 & ASME Sec VIII Div. I. The design shall be at 40 °C (46CST) 3.7 Fluid handled : Turbine Oil type ISO VG46 3.8 Kinematic Viscosity : 18 CST at 65°C (operating) 46 CST at 40 °C (Design) 3.9 Specific Gravity : 0.88 3.10 Filtration : β 10 = 200, 10 Microns (absolute) or as specified in variant table. ISO 4406 grade 17/14 or NAS 8. 3.11 Cleanliness Level Requirement : ISO 4406 grade 17/14 or NAS 8. 3.12 Filtration Area Requirement in CM² : Vendor has to specify 3.13 Inlet / outlet connections : Raised face Flanged ends (With 150/300 class rated flanges as per ANSI) Required with valve NPT ¾” screwed. 3.14 Vent connections : Required with valve NPT ¾” screwed.			
FORMAT TD-202 REV-00	COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHEL. It must not be used directly or indirectly in any way detrimental to the interest of the company		

BHEL	PURCHASE SPECIFICATION	TC 5 4248
HYDERABAD		REV NO: 00
		PAGE 3 OF 4
3.15 Drain connections : Required with valve NPT ¾” screwed. (Clean- and dirty-side valved drain connections. The dirty side connections shall be located lower in the housing than the filter elements or cartridge support bases to allow complete drainage of the dirty side.) 3.16 Leakage : Not allowed during operation when one half is closed. 3.17 Pressure equalization line with valve : Required. 3.18 Differential Pressure indicator : Required. 3.19 Magnet : Required to collect the solid contamination. 3.20 Inlet / outlet connections : Raised face Flanged ends (With 150/300 class rated flanges as per ANSI), Inlet and Outlet shall be 2”-150 class. 3.22 Terminal points : All terminal points shall be flanged ANSI B 16.5, RF smooth finish. 3.23 Material : Carbon steel for Filter housing and valve body. Casted body filters are not acceptable. Trans flow valve internals shall be stainless steel(SS) 3.24 Hydro static test pressure : 1.5 times of design pressure or as specified in ASME Section VIII Div 1 3.25 Filter element material : Disposable Type, Resin impregnated fiber. (Free water resistance organic paper) Vendor to provide standard (similar) size filter element for all the models offered. The no of filter elements may vary from one capacity to another 3.26 Performance curves required : Vendors shall provide the following 1. Flow Vs Pr. drop curves for housings & 2. Elements.		
FORMAT TD-202 REV-00	COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHEL. It must not be used directly or indirectly in any way detrimental to the interest of the company	

BHEL	PURCHASE SPECIFICATION	TC 5 4248
HYDERABAD		REV NO: 00
		PAGE 4 OF 4
3. Actual area of filtering media 4. Dirt retention capacity. 5. Number of elements per housing. 4.0 <u>SCOPE OF SUPPLY</u> 1 Duplex filter with 3-way transflow type change over valve in C.S construction. The valve internals shall be in S.S construction. R01 2 One set of S.S 40 microns filter element for flushing. 3 1 set of 5 microns filter element other than elements fitted in the filter. The material shall be Fiber glass pleating material with S.S support 4 One set of gaskets & “O” rings duplex filter. The material shall be r asbestos type. 5 One set of foundation bolts & nuts. Note: One set means number of elements for both filter housings 5.0 <u>QUALITY REQUIREMENTS</u> : 1 Material test certificates 2 Hydrostatic Test 3 Design calculations as per ASME Sec VIII Div. I 4 Performance Test & type test certificates of similar model shall be submitted. 5 Quality plan followed during manufacturing shall be provided to BHEL for review and approval. Inspection and testing as per Standard. Quality plan to be submitted along with offer and the same to be approved by BHEL. M/s Lloyds is the approved Inspection agency, if the item is procuring from imported organization. The Inspection charges shall be included in main equipment price.		
REV-00 FORMAT TD-202	COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHEL. It must not be used directly or indirectly in any way detrimental to the interest of the company	