

Annexure-A.

Mandatory spares of MOV actuators for Control Dampers.

Vendor to work out quantity of spare as per logic specified by customer below. Duplicate items should not be quoted as mandatory spare.

1. Position transmitter - 10% of each type or 1 no minimum
2. Power supply unit - 10% of each type or 1 no minimum
3. Logic board - 10% of each type or 1 no minimum
4. Local control board assembly - 10% of each type or 1 no minimum
5. Switch gear assembly - 10% of each type or 1 no minimum
6. Main PCB board/module - 1 no of each type.