



REF: MISTEL:BHILAI

TECHNICAL INFORMATION OF MIST ELIMINATOR FOR NSPCL BHILAI 2X250 MW

A. TECHNICAL INFORMATION

Sl. No.	Description	Requirement
1.	End Customer	NSPCL (NTPC-SAIL Power Corporation Limited)
2.	Project Name	Bhilai 2X250 MW
3.	Location	District Durg, Bhilai (East) , Chattisgarh State, India
4.	Type	Three stage chevron type (First Stage shall be Flat or Roof Type, Second and Third stages shall be Diamond/Roof type)
5.	Material of construction of Mist Eliminator	
i.	ME Panel	Polysulfone (Or) Super austenitic stainless steel (254 SMO)
ii.	Washing Pipe	FRP with corrosion and erosion resistant in the inner and outer side (Silicon Carbide coating on FRP surface exposed to slurry)
iii.	Wash Pipe Supports	Shall be lined with min 2mm thk Alloy 59/C276 or entire Material in Alloy 59/C276
iv.	Washing Nozzles	PVDF or PP as per bidder's proven practice
v.	Hardware inside absorber	a) Alloy 59/ C276 for load bearing applications b) All metallic fasteners provided shall be of Alloy 59/C276 c) For pipe clamps, C276 Bolt, C276 Nut, C276 washer and C276 spring washer to be provided
vi.	Enclosure Plate	Same as that of ME Panel if it is part of Mist Eliminator (or) C276 material.
v.	ME Panel	Polysulfone (Or) Super austenitic stainless steel (254 SMO)
6.	Quantity	
i.	Quantity of Mist Eliminators for Unit-1,2	2 sets (1 set for each unit) 1 set means Complete Mist Eliminators, Washing systems and accessories
7.	Parameters	
vi.	Gas flow	Vertical
vii.	Casing Dimension	Length : 7900 mm Width : 13900 mm
viii.	Design Pressure of Mist Eliminator Panel	660 mmH ₂ O (G)
ix.	Max Allowable Pressure drop across Mist Eliminator element	20 mmH ₂ O (G) at Design point
x.	Design Temperature	70 Deg C (Continuous) 80 – 90 Deg C (30 minutes) 90 – 100 Deg C (5 min)

Sheet 1 of 6

Customer / Plant: NTPC BHILAI (2x250MW)

Cont. No. : G211, G212	Rev. 00		Rev. 01		Rev. 02		Rev. 03	
	Sign	Date	Sign	Date	Sign	Date	Sign	Date
Engineer : VV	-sd-	20.03.20						
Reviewer : PNR/ACR	-sd-	20.03.20						
Approver : RSB	-sd-	20.03.20						



REF: MISTEL:BHILAI

**TECHNICAL INFORMATION OF MIST ELIMINATOR FOR
NSPCL BHILAI 2X250 MW**

Sl. No.	Description	Requirement	
8.	Gas condition at ME Inlet	Guarantee Point	Design Point
i.	Gas Flow Rate (Nm ³ /s-wet)	308	352
ii.	Gas Flow Rate (m ³ /s-wet)	371	429
iii.	Gas Temperature (Deg C)	57.2	61.1
iv.	Density (kg/m ³)	1.044	1.018
v.	Operating Pressure at Mist Eliminator inlet (mm H ₂ O (G))	48	60
vi.	Gas Flow Distribution	+ or - 20%	
9.	Gas Composition at ME Inlet		
i.	SO ₂ (Vol%-wet)	0.0071	0.0069
ii.	H ₂ O (Vol%-wet)	17.08	20.47
iii.	O ₂ (Vol%-wet)	5.72	5.48
iv.	CO ₂ (Vol%-wet)	10.19	9.78
v.	N ₂ (Vol%-wet)	67.0	64.26
vi.	HCl (ppm-wet)	<3	<3
vii.	HF (ppm-wet)	<1	<1
viii.	Dust (mg/Nm ³ -wet)	<50	<200
10.	Gypsum Slurry Density(t/m ³)	1213	1213
11.	Entrained Mist Condition:		
i.	Mist Concentration at Inlet –at Guarantee & Design Point	200 g/Nm ³ -dry	
ii.	Mist Concentration at Outlet –at Guarantee & Design Point	≤20 mg/Nm ³	

12.	Mist Composition		
i.	Solid	30 wt. %	
ii.	Cl ⁻	19000 ppm	
iii.	Mg ²⁺	7570 ppm	
iv.	Ca ²⁺	1170 ppm	
v.	Na ⁺	1240 ppm	
vi.	SO ₄ ²⁻	8055 ppm	

Sheet 2 of 6

Customer / Plant: NTPC BHILAI (2x250MW)								
Cont. No. : G211, G212	Rev. 00		Rev. 01		Rev. 02		Rev. 03	
	Sign	Date	Sign	Date	Sign	Date	Sign	Date
Engineer : VV	-sd-	20.03.20						
Reviewer : PNR/ACR	-sd-	20.03.20						
Approver : RSB	-sd-	20.03.20						



REF: MISTEL:BHILAI

TECHNICAL INFORMATION OF MIST ELIMINATOR FOR NSPCL BHILAI 2X250 MW

B. WASHING ARRANGEMENT

1.1 Washing water condition		
a.	Flow rate - Average	13.77 m ³ /hr *1)
b.	Flow rate at M/E Inlet – Instantaneous Allowable Max	96 m ³ /hr
c.	Flow rate at M/E Inlet – Instantaneous Min	80 m ³ /hr
d.	Feed Pressure (at inlet flange of ME Wash header)	0.2 MPa (Max)
e.	Spray Nozzle –Top washing	90 °, Full Cone(vendor shall decide based on proven practice)
f.	Spray Nozzle –Bottom washing	120 °, Full Cone(vendor shall decide based on proven practice)
g.	Spray pipe level from ME Panel	< 700 mm

*1) Vendor shall decide

Sheet 3 of 6

Customer / Plant: NTPC BHILAI (2x250MW)								
Cont. No. : G211, G212	Rev. 00		Rev. 01		Rev. 02		Rev. 03	
	Sign	Date	Sign	Date	Sign	Date	Sign	Date
Engineer : VV	-sd-	20.03.20						
Reviewer : PNR/ACR	-sd-	20.03.20						
Approver : RSB	-sd-	20.03.20						



REF: MISTEL:BHILAI

TECHNICAL INFORMATION OF MIST ELIMINATOR FOR NSPCL BHILAI 2X250 MW

C. WATER ANALYSIS

Process water is envisaged for Mist Eliminator washing. Process water analysis is provided below.

S.no	Constituents	Unit	PROCESS WATER
1.	Calcium as CaCO_3	ppm	190
2.	Magnesium as CaCO_3	ppm	121
3.	Chlorides as CaCO_3	ppm	110
4.	Sulphate as CaCO_3	ppm	93.5
5.	Alkalinity as CaCO_3	Ppm	297
6.	Iron as fe	ppm	0.55
7.	Total silica	ppm	38.5
8.	pH		7.5
9.	Turbidity	NTU	11

Sheet 4 of 6

Customer / Plant: NTPC BHILAI (2x250MW)								
Cont. No. : G211, G212	Rev. 00		Rev. 01		Rev. 02		Rev. 03	
	Sign	Date	Sign	Date	Sign	Date	Sign	Date
Engineer : VV	-sd-	20.03.20						
Reviewer : PNR/ACR	-sd-	20.03.20						
Approver : RSB	-sd-	20.03.20						



REF: MISTEL:BHILAI


TECHNICAL INFORMATION OF MIST ELIMINATOR FOR NSPCL BHILAI 2X250 MW

D. MIST PARTICLE SIZE DISTRIBUTION

- Bidder shall note there is a tie beam located at the centre line of Absorber (Bidder shall refer to Note 01 :B in the typical drawing enclosed). This tie beam has to be used as Mist Eliminator beam.
- Overall wash arrangement shall be as per the drawing (typical) enclosed.

The Mist Particle Size Distribution shall be as per below fig

Fig. 2 Mist Particle Size Distribution(EXPECTED VALUE)



Sheet 5 of 6

Customer / Plant: NTPC BHILAI (2x250MW)								
Cont. No. : G211, G212	Rev. 00		Rev. 01		Rev. 02		Rev. 03	
	Sign	Date	Sign	Date	Sign	Date	Sign	Date
Engineer : VV	-sd-	20.03.20						
Reviewer : PNR/ACR	-sd-	20.03.20						
Approver : RSB	-sd-	20.03.20						

