


THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY.



## DEVELOPMENT VIEW OF IT. 001

UNSPECIFIED TOLERANCES "MEDIUM" AA 0230208.

VAR	REMARKS	VAR NO.	ITEM NCL.	DESCRIPTION	DRAWING NO.	IT.NO.	MATERIAL CODE	A	LINS	UNIT WT.
						VAR	MATL. SPON.	C	[QTY]	
BP9609437842	002	16TK. x 78 x 175 LG. H. COPPER BAR					AA 12023			1.716 001
BP9609437834	001	16TK. x 78 x 175 LG. H. COPPER BAR					AA 12023			1.716 001

TOOL NO.: - 1564071 (92° CHECKING GAUGE)  
HARDNESS :- 80 HV MINIMUM

FINISH: – SILVER PLATE TO PR.S. AA 0673613 (0.005TK. MIN.)  
AREA OF SILVER PLATING – 415.52 SQ. CM. FOR IT. 001  
415.52 SQ. CM. FOR IT. 002

INSPECTION NOTE: -  
GROOVE DEPTH 4.2/4.3 AND 2.8/2.9 IS IMPORTANT.

[illegible]

SDIS FN: -