



CUSTOMER :											
RAMAGUNDAM FERTILIZERS AND CHEMICALS LIMITED RAMAGUNDAM, TELANGANA											
PROJECT :											
CAPTIVE POWER PLANT, RAMAGUNDAM											
CONSULTANT :											
ENGINEERS INDIA LTD 1, BHIKAJI CAMA PLACE, NEW DELHI - 110 066											
BHARAT HEAVY ELECTRICALS LTD. HYDERABAD											
						NAME		SIGN.		DATE	
				DRN.		SESHU KIRAN		-Sd-		13.03.17	
				CHD.		SESHU KIRAN		-Sd-		13.03.17	
				APPD.		J.K.PATTANAIK		-Sd-		13.03.17	
DEPT. PED.		UNTOL. DIMS. GR.		SCALE		WEIGHT (KG)		REF. TO ASSY. DRG.		ITEM NO.	
CODE 450		9/M/f		N.T.S				N.A.		N.A.	
TITLE				CARD CODE				CUSTOMER DRG NO.			
KEY SLD WITH SPG PACKAGE				NA				SHEET			
								PY-DL-1-M095-1101-01			
SCOPE DEMARCATION				NA				REV.			
								03			
				SHT. No				NO. OF SHT.			
10				11				12			

BHEL's Replies to EIL Comments on Rev-02 Key SLD

PROJECT: Revival of Ramagundam Fertilizer Complex
NAME OF PACKAGE: Steam & Power Generation

CLIENT: M/s RFCL
CONTRACTOR: M/s BHEL

DOC. NO.	A747		-
	JOB NO.	TR. NO.	S.NO

SL. NO.	COMMENT/ OBSERVATION	RESOLUTION / ACTION
1.	DRAWING / DOCUMENT TITLE : Key Single Line Diagram Code: R	
1.1	6.6kV Cable size shall be 240 sq mm.	Noted & Incorporated in revised SLD.
1.2	415V PCC-1 incomer rating shall be 3000A	Noted & Incorporated in revised SLD.
1.3	Please shift 415V UB & HRSG PMCC EMG feeder to Bus-B of 415V EPMCC	As per telecon had with EIL Electrical team on 02/05/2017, 415V GT PMCC & UB PMCC Emergency incomers are shifted to Bus-B of EPMCC.

Replied By: (SIGN/ DATE): 02/05/2017.

Department: Electrical

Name: G.Seshu Kiran/J.K Pattanaik

BHARAT HEAVY ELECTRICAL LIMITED