

TTTD-106-1 Rev No. 5 Form No.		PROJECT ENGINEERING & SYSTEM DIVISION BHEL, HYDERABAD –32.			PY51389					
					Rev No. 01					
					Page 1 of 5					
<u>TECHNICAL SPECIFICATION</u> <u>FOR QUARTZOID BULB DETECTOR</u>										
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company.										
						Revisions :	Prepared by:	Checked by:	Approved By:	Date
						00	Sumant	Amit/PCS	MNSR	26.07.18

TD-106-2 Rev.No. 5 Form No.		PROJECT ENGINEERING & SYSTEM DIVISION BHEL, HYDERABAD –32.	PY51389																																													
			Rev No. 01																																													
			Page 2 of 5																																													
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. It must not be used directly or indirectly in any way detrimental to the interest of the company.	1. SCOPE/INTENT:																																															
	1.1. This specification covers the technical requirements of constructional features, accessories, inspection, tests, test certificates, documentation, preservation, packing and forwarding of Quartzoid Bulb Detector. 1.2. Scope of supply shall include design, manufacture, inspection, shop testing, shop painting, packing and delivery. 1.3. The supplier shall strictly comply with this standard in all respects. No deviation shall be allowed. However, bidder can raise technical queries on the specification during pre-bid stage and clarifications may be sought from BHEL before the bid submission. APPLICATION: These items suitable for fire protection systems (Water based protection system).																																															
2. VARIANT TABLE:		<table border="1"> <thead> <tr> <th>Var. No.</th> <th>Description</th> <th>Material Code</th> </tr> </thead> <tbody> <tr> <td>01</td> <td>Quartzoid bulb detector (Bronze)</td> <td>PY9751389011</td> </tr> </tbody> </table> Note: Bidder to quote as per Material Code as mentioned in the Enquiry		Var. No.	Description	Material Code	01	Quartzoid bulb detector (Bronze)	PY9751389011																																							
Var. No.	Description	Material Code																																														
01	Quartzoid bulb detector (Bronze)	PY9751389011																																														
3. TECHNICAL REQUIREMENTS:		<table border="1"> <thead> <tr> <th>Sl. No.</th> <th>Requirements</th> <th>Compliance</th> </tr> </thead> <tbody> <tr> <td>2.1</td> <td>Type</td> <td>Frangible bulb type</td> </tr> <tr> <td>2.2</td> <td>Operating temperature *</td> <td>79° / 93°</td> </tr> <tr> <td>2.3</td> <td>Material of Construction</td> <td></td> </tr> <tr> <td>2.3.1</td> <td>Frame</td> <td>Bronze (ASTM B 145) Class-5A Leaded gun metal, Chrome plated</td> </tr> <tr> <td>2.3.2</td> <td>Bulb</td> <td>Glass filled with heat sensitivity liquid (colored)</td> </tr> <tr> <td>2.3.3</td> <td>Deflector</td> <td>Brass</td> </tr> <tr> <td>2.3.4</td> <td>Cap</td> <td>Copper</td> </tr> <tr> <td>2.4</td> <td>Working pressure</td> <td>3.5 Kg/cm² (g) minimum</td> </tr> <tr> <td>2.5</td> <td>Detector approved</td> <td>UL listed</td> </tr> <tr> <td>2.6</td> <td>End Connection</td> <td>1/2" NPT</td> </tr> <tr> <td>2.7</td> <td>Max. Working Pressure</td> <td>12 kg/cm²(g)</td> </tr> <tr> <td>2.8</td> <td>Hydro Test Pressure</td> <td>30 kg/cm²(g)</td> </tr> <tr> <td>2.9</td> <td>Finish</td> <td>Chrome Plated</td> </tr> <tr> <td>2.10</td> <td>Marking on Equipment</td> <td>Mfg. Trade Name, Operating Temp,</td> </tr> </tbody> </table>		Sl. No.	Requirements	Compliance	2.1	Type	Frangible bulb type	2.2	Operating temperature *	79° / 93°	2.3	Material of Construction		2.3.1	Frame	Bronze (ASTM B 145) Class-5A Leaded gun metal, Chrome plated	2.3.2	Bulb	Glass filled with heat sensitivity liquid (colored)	2.3.3	Deflector	Brass	2.3.4	Cap	Copper	2.4	Working pressure	3.5 Kg/cm ² (g) minimum	2.5	Detector approved	UL listed	2.6	End Connection	1/2" NPT	2.7	Max. Working Pressure	12 kg/cm ² (g)	2.8	Hydro Test Pressure	30 kg/cm ² (g)	2.9	Finish	Chrome Plated	2.10	Marking on Equipment	Mfg. Trade Name, Operating Temp,
Sl. No.	Requirements	Compliance																																														
2.1	Type	Frangible bulb type																																														
2.2	Operating temperature *	79° / 93°																																														
2.3	Material of Construction																																															
2.3.1	Frame	Bronze (ASTM B 145) Class-5A Leaded gun metal, Chrome plated																																														
2.3.2	Bulb	Glass filled with heat sensitivity liquid (colored)																																														
2.3.3	Deflector	Brass																																														
2.3.4	Cap	Copper																																														
2.4	Working pressure	3.5 Kg/cm ² (g) minimum																																														
2.5	Detector approved	UL listed																																														
2.6	End Connection	1/2" NPT																																														
2.7	Max. Working Pressure	12 kg/cm ² (g)																																														
2.8	Hydro Test Pressure	30 kg/cm ² (g)																																														
2.9	Finish	Chrome Plated																																														
2.10	Marking on Equipment	Mfg. Trade Name, Operating Temp,																																														
Ref. Doc																																																

TD-106-2 Rev.No. 5 Form No.		PROJECT ENGINEERING & SYSTEM DIVISION BHEL, HYDERABAD –32.	PY51389												
			Rev No. 01												
			Page 3 of 5												
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. It must not be used directly or indirectly in any way detrimental to the interest of the company.	<table border="1"> <tr> <td></td> <td></td> <td>Model, 'UL' Listed Mark</td> </tr> </table> *Quantity of 79 Deg C and 93 Deg C QBD shall be decided after post order. 4. PAINTING Finish shall be Chrome plated. 5. INSPECTION AND TESTING As per BHEL QAP (Refer attached Annexure) 6. DOCUMENTATION: 6.1. Along with the offer: Signed and stamped copy of this specification as token of acceptance of the specification for execution in the event of Order. 6.2. After PO Placement: Two copies each of the following documents shall be submitted for approval. • G.A. Drawings with weights and dimensions • Technical Data sheets, Catalogue • Material specification details • Tests to be conducted • O&M manuals • Storage/Preservation instructions for at least three years. Final documentation consisting of above documents shall be submitted in requisite sets (to be decided post order) of hard and soft copies. Schedule for document submissions: <table border="1"> <thead> <tr> <th>S.no</th> <th>Description</th> <th>Schedule</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>Submission of GA drawing & Technical Datasheet by vendor</td> <td>7 days from the date of P.O.</td> </tr> <tr> <td>2</td> <td>Approval GA drawing & Technical Datasheet by BHEL</td> <td>14 days from receipt of the document*</td> </tr> </tbody> </table> * The GA drawing & Technical Datasheet submitted by vendor shall be strictly in compliance to all applicable standards and specification.					Model, 'UL' Listed Mark	S.no	Description	Schedule	1	Submission of GA drawing & Technical Datasheet by vendor	7 days from the date of P.O.	2	Approval GA drawing & Technical Datasheet by BHEL	14 days from receipt of the document*
			Model, 'UL' Listed Mark												
S.no	Description	Schedule													
1	Submission of GA drawing & Technical Datasheet by vendor	7 days from the date of P.O.													
2	Approval GA drawing & Technical Datasheet by BHEL	14 days from receipt of the document*													
Ref. Doc															

TD-106-2 Rev.No. 5	Form No.		PROJECT ENGINEERING & SYSTEM DIVISION BHEL, HYDERABAD –32.	PY51389
				Rev No. 01
				Page 4 of 5
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. It must not be used directly or indirectly in any way detrimental to the interest of the company.		7. PRESERVATION, PACKING & MARKING OR PACKING CASE: 7.1. A suitable temporary rust preventive with minimum life of two years shall be applied inside the item/equipment body in order to prevent corrosion. 7.2. All the item / equipment shall be packed suitably in closed wooden cases in order to avoid damage during transit and storage at BHEL. Suitable supports shall be provided inside the cases in order to avoid internal movement. In case of exported consignments, the packing shall be seaworthy (Refer enclosed Annexure for Export Packing guidelines, AA 0490009, Rev-01). Each item / equipment after end protection should be wrapped in polythene sheet before packing in the cases. Each packing case must contain two copies of the shipping list giving details of all the contents of the case. 7.3. The following marking shall be done on each packing case minimum on two sides and at the top. (a) Complete address of the consignee and destination as per BHEL Purchase Order. (b) BHEL Purchase order Number (c) BHEL item Material Code (d) Number of pieces in each packing case (e) Net Weight (f) Gross Weight (g) Packing case number and total number of packing (h) Arrow indicating top of the packing case.		
Ref.	Doc			

TD-106-3 Rev.No. 5 Form No.		PRODUCT STANDARD BHEL, HYDERABAD –32. PROJECT ENGINEERING & SYSTEM DIVISION				PY51389
						Rev No. 01
						Page 5 of 5
COPYRIGHT AND CONFIDENTIAL The information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED, It must not be used directly or indirectly in any way detrimental to the interest of the company.	RECORD OF REVISIONS					
	Rev. No.	Date	Revision Details	Revised By	Checked By	Approved By
	00	26.07.2018	First Issue	-SD-	-SD-	-SD-
	01	24.02.2020	End connection updated	Sumant/ Harish	Amit / Kamaluddin	PCS
	Ref. Doc.					