



TITLE:
TECHNICAL SPECIFICATION FOR
SEWAGE TREATMENT PLANT
3X800 MW PATRATU STPP EXT.PH-I

BHEL DOCUMENTS NO.: PE-TS-434-673A-A001

VOLUME III

SECTION-

REV. NO. 00

DATE:

COMPLIANCE CUM CONFIRMATION CERTIFICATE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnishing same with the offer:

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions/ deviations with regard to same.
2. QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein.
3. QP will be subject to BHEL/Customer approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. The charges for 3rd party inspection (Lloyds, TUV or equivalent) for imported components shall be included in the base price of the equipment by the bidder.
4. All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/Customer review/ approval. GA drawings, as submitted with offer at tender stage are for reference purpose only and shall be subject to approval during contract stage.
5. There are no other deviations with respect to specification other than those furnished in the 'Schedule of Deviations'.
6. The offered materials shall be either equivalent or superior to those specified. Also for components where material is not specified it shall be suitable for intended duty, materials shall be subject to approval in the event of order.
7. The commissioning spares (if any) are supplied on 'As Required Basis' & prices for same included in the base price (If bidders reply to this is "No commissioning spares are required" and if some spares are actually required during commissioning same shall be supplied by bidder without any cost to BHEL and Customer).
8. All sub vendors shall be subject to BHEL/CUSTOMER approval.
9. Any special tools & tackles, if required, shall be in bidder's scope.
10. Performance guarantee test parameters shall stand valid till the satisfactory completion of Performance guarantee test and its acceptance by BHEL and Customer.



TITLE:
TECHNICAL SPECIFICATION FOR
SEWAGE TREATMENT PLANT
3X800 MW PATRATU STPP EXT.PH-I

BHEL DOCUMENTS NO.: PE-TS-434-673A-A001

VOLUME III

SECTION-

REV. NO. 00

DATE:

PRE BID CLARIFICATION SCHEDULE

All clarification from the Technical Specification shall be filled in by the BIDDER clause by clause in this format only.

VOLUME	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	REASONS FOR CLARIFICATION

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME DESIGNATED	ON	SIGNATURE	DATE	COMPANY SEAL



TITLE:
TECHNICAL SPECIFICATION FOR
SEWAGE TREATMENT PLANT
3X800 MW PATRATU STPP EXT.PH-I

BHEL DOCUMENTS NO.: PE-TS-434-673A-A001

VOLUME III

SECTION-

REV. NO. 00

DATE:

SCHEDULE OF DECLARATION

Icertify that all the technical data and information pertaining to this specification are correct and are true representation of the equipment/system covered by our format proposal number Dated and there is no deviation to the specification.

I hereby certify that I am duly authorized representative of the Bidder's company whose name appears above my signature.

Bidders Company Name

Authorized Representative's
Signature

Name

Bidder's Name

The bidder hereby agrees to fully comply with the requirements and intent of this specification for the price indicated.

**SCHEDULE OF DEVIATIONS WITH COST OF WITHDRAWAL****PROJECT:- 3X800 MW PATRATU STPP EXT.PH-I****SEWAGE TREATMENT PLANT****TENDER ENQUIRY REFERENCE:-****NAME OF VENDOR:-**

SL NO	VOULME/ SECTION	PAGE NO.	CLAUSE NO.	TECHNICAL SPECIFICATION/ TENDER DOCUMENT	COMPLETE DESCRIPTION OF DEVIATION	COST OF withdrawal OF DEVIATION	REFERENCE OF PRICE SCHEDULE ON WHICH COST OF withdrawal OF DEVIATION IS APPLICABLE	NATURE OF COST OF withdrawal OF DEVIATION (POSITIVE/ NEGATIVE)	REASON FOR QUOTING DEVIATION
-------	-----------------	----------	------------	--	-----------------------------------	---------------------------------	--	--	------------------------------

TECHNICAL DEVIATIONS

COMMERCIAL DEVIATIONS

PARTICULARS OF BIDDERS/ AUTHORISED REPRESENTATIVE

NAME	DESIGNATIONS	SIGN & DATE

NOTES:

1. For self manufactured items of bidder, cost of withdrawal of deviation will be applicable on the basic price (i.e. excluding taxes, duties & freight) only.
2. For directly dispatchable items, cost of withdrawal of deviation will be applicable on the basic price including taxes, duties & freight.
3. All the bidders have to list out all their Technical & Commercial Deviations (if any) in detail in the above format.
4. Any deviation not mentioned above and shown separately or found hidden in offer, will not be taken cognizance of.
5. Bidder shall submit duly filled unpriced copy of above format indicating "quoted" in "cost of withdrawal of deviation" column of the schedule above along with their Techno-commercial offer, wherever applicable.
6. Bidder shall furnish price copy of above format along with price bid.
7. The final decision of acceptance/ rejection of the deviations quoted by the bidder shall be at discretion of the Purchaser.
8. Bidders to note that any deviation (technical/commercial) not listed in above and asked after Part-I opening shall not be considered.
9. For deviations w.r.t. Payment terms, Liquidated damages, Firm prices and submission of E1/ E2 forms before claiming 10% payment, if a bidder chooses not to give any cost of withdrawal of deviation loading as per Annexure-VIII of GCC, Rev-06 will apply. For any other deviation mentioned in un-priced copy of this format submitted with Part-I bid but not mentioned in priced copy of this format submitted with Priced bid, the cost of withdrawal of deviation shall be taken as NIL.
10. Any deviation mentioned in priced copy of this format, but not mentioned in the un-priced copy, shall not be accepted.
11. All techno-commercial terms and conditions of NIT shall be deemed to have been accepted by the bidder, other than those listed in unpriced copy of this format.
12. Cost of withdrawal is to be given separately for each deviation. In no event bidder should club cost of withdrawal of more than one deviation else cost of withdrawal of such deviations which have been clubbed together shall be considered as NIL.
13. In case nature of cost of withdrawal (positive/negative) is not specified it shall be assumed as positive.
14. In case of discrepancy in the nature of impact (positive/ negative), positive will be considered for evaluation and negative for ordering.



TITLE:

**TECHNICAL SPECIFICATION FOR
SEWAGE TREATMENT PLANT
3X800 MW PATRATU STPP EXT.PH-I**

BHEL DOCUMENTS NO.: PE-TS-434-673A-A001

VOLUME III

SECTION –

REV. NO. 00

DATE:

**FORMAT FOR GUARANTEED AUXILIARY POWER CONSUMPTION FIGURES
(TO BE FILLED BY THE BIDDER)**

S.NO.	DESCRIPTION OF EQUIPMENT	NO OF EQUIPMENT		TOTAL ESTIMATED AUXILIARY POWER CONSUMPTION FOR WORKING DRIVES AT MOTOR INPUT TERMINAL (IN KW) (For Complete sewage treatment plant)
		WORKING	STANDBY	
1	Complete Sewage treatment plant (Considering all working drives as per technical specification)	56		56
				Total (Kw)

Note-Estimated power consumption (EPC) figure for the system (for working drives only) has been as **56 KW**. So long bidder's quoted guaranteed power consumption (GPC) above remains within this EPC, there will be no technical loading of bid on power consumption for evaluation. However, if bidder's quoted GPC exceeds EPC, there shall be technical loading of bid for evaluation @ US\$ 2179 (US Dollar Two Thousand One Hundred Seventy Nine only) per KW of additional power over EPC.

Bidder's guaranteed power consumption as furnished in relevant schedule shall be demonstrated by the successful bidder during performance testing at works/ site. In case power consumption is noted higher than EPC/ bidder's quoted GPC whichever is higher, during inspection/ PG test, penalty @ US\$ 3025 (US Dollar Three Thousand Twenty Five only) per additional KW shall be levied on vendor. (+) 1.0% of the guaranteed Auxiliary Power Consumption shall be acceptable shortfall with LD.

DOLLAR RATE SHALL BE APPLICABLE AS PER ORDER RECEIVED DATE FROM NTPC (I.E. 08.03.2018).