

**TANGEDCO
2x660 MW UDANGUDI STPP STG I**

**TECHNICAL SPECIFICATION
FOR
MISCELLANEOUS PUMPS (HORIZONTAL)**

Specification No. : PE-TS-435-100-N001 (REV. 0)



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
PPEI BUILDING, SECTOR 16 A
NOIDA - 201301**



TITLE: TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS SPECIFIC TECHNICAL REQUIREMENTS	SPEC. NO.: PE-TS-435-100-N001		
	SECTION:		
	SUB-SECTION:		
	REV. NO. 00	DATE	27.09.2019
	SHEET 1	OF	1

INDEX

THIS TECHNICAL SPECIFICATION CONSISTS OF FOLLOWING SECTIONS:

CONTENTS

SECTION	TITLE
I	Specific Technical Requirements
IA	Specific Technical Requirements (Mechanical)
IB	Specific Technical Requirements (Elec.)
IC	Specific Technical Requirements (C&I)
ID	Data Sheet – A
II	Standard Technical Specifications
IIA	Standard Technical Specifications (Mechanical)
IIB	Standard Technical Specifications (Elec.)
III	Documents to be submitted by Bidder
IIIA	Guarantee Schedule (To be submitted along with the Bid by all Bidders)
IIIB	Compliance Certificate (To be submitted along with the Bid by all Bidders)
IIIC	Deviation schedule (To be submitted along with the Bid by all Bidders)
IIID	Data Sheet – B and Other documents (To be submitted by successful Bidder after award of Contract)

Notes:

1) For detailed list of documents to be submitted by bidder in their technical offer, please refer cl. no. 15.00.00 of Section-IIA.

2) For detailed list of documents to be submitted by vendor after award of contract, please refer Datasheet-C of Section-IIA.

3) In case there is conflict in different clauses of specification, most stringent clause (as decided by BHEL / end customer) shall be followed, if no specific deviation is taken by bidder and accepted by BHEL during tender stage in that regard.



TITLE:
**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

SPECIFIC TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION:

SUB-SECTION:

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SECTION - I

SPECIFIC TECHNICAL REQUIREMENTS

- SUB-SECTION IA** - Specific Technical Requirements (Mech.)
- SUB-SECTION IB** - Specific Technical Requirements (Electrical)
- SUB-SECTION IC** - Specific Technical Requirements (C & I)
- SUB-SECTION ID** – Datasheet-A



TITLE:
**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

SPECIFIC TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **I**

SUB-SECTION: **IA**

REV. NO. **00** DATE **27.09.2019**

SHEET **1** OF **1**

SUB-SECTION – IA

SPECIFIC TECHNICAL REQUIREMENTS (MECHANICAL)

	TECHNICAL SPECIFICATIONS		Specification No. : PE-TS-435-100-N001, Rev0	
	MISCELLANEOUS PUMPS		SECTION: IA	
	SPECIFIC TECHNICAL REQUIREMENTS		REV. NO. 0	DATE: 27.09.2019

1.0 SCOPE

1.1 This enquiry covers the design, manufacture, assembly, inspection and testing at manufacturer's and/or his sub-contractors works, proper packing for delivery and installation checks and supervision of replacement of gland packing with Mechanical Seal arrangement (if applicable) at site and PG Test at site for Miscellaneous Pumps (Horizontal) along with mandatory spares complete with all accessories as per the requirements specified in this specification and any other services, etc. if called for in the succeeding sections of the specification for following project:

A. 2X660 MW UDANGUDI STPP STG I (TANGEDCO)

The above project is referred as '2X660 MW UDANGUDI' elsewhere in the Specification for ease of reference.

NOTE:-

1. The bidder shall include complete supplies for Pumps as covered in this Technical Specification. Part supplies offered for the Pumps shall disqualify the bidder's offer.

2. Pump details shall be as per Data Sheet-A at Section-ID.

1.3 The miscellaneous pumps and drives covered under this specification for various projects are as per Annexure-1 of this section. HT drives, wherever applicable and irrespective of motor ratings, shall be issued free of cost by BHEL. The details of pumps with HT drives shall be as per Annexure-2 of this section.

1.4 The Capacity, Head, Materials of construction, Mandatory spares and other particulars of these pumps, are detailed in Data Sheet-A at Section-ID of the specification.

1.5 For detailed scope of supply & services for Horizontal pumps, refer Standard technical Specification for Horizontal Centrifugal pumps specified under Section-II of this specification.

1.6 Electrical scope between BHEL and Vendor for Miscellaneous pumps and drives of this specification shall be as per Annexure-1 of Section-IB of this specification.

LT drives shall be energy efficient as per subsequent clauses mentioned elsewhere in the specification. **However wherever IE2 compliant motors are applicable same shall be provided with IE3 compliance only.**

1.7 **DELIVERY:**
Delivery of miscellaneous pumps shall be as per NIT requirement.

1.8 Evaluation and LD criterion w.r.t. Auxiliary Power is defined at clause 4.0 of Section IIA of this specification. In case bidder quotes Aux. power less than Benchmark Auxiliary Power, then quoted Aux. power shall be replaced with Benchmark Auxiliary Power for both evaluation as well as LD purposes.

2.0 Additional requirements for Pumps:

2.1 End Customer specific requirements are indicated as Annexure-3 In this section, same are also to be complied. In case of any contradiction with other clauses of Section-IA, the stringentmost requirement is to be complied.

2.2 For Horizontal Pmps:

2.2.1 For Horizontal Pumps, in case, shaft sleeve is threaded, a water slinger shall be provided on the Pump Shaft to avoid ingress of leaked water (if any due to failure of sealing arrangement for shaft sleeve) to Bearing.

2.2.2 In case of axial split casing Multistage pumps, minimum factor of safety of '2' times shall be considered for Pump bearing capacity selection and pump design.

2.2.3 All the Pumps with HT Drives only shall be provided with RTDs for each Pump bearing temperature monitoring / tripping. Specification for RTD are attached at Section-1C.

3.0 Vibration, Noise and Parallel run test (as applicable) for all pumps shall also be conducted by bidder at site as per approved PG Test Procedure, inline with Cl no. 3.04 of Secton-IIA of this specification. Mechanical run test along with Performance test shall be carried out on all pumps to determine the vibration levels, noise levels etc. at Vendor works. However, test value at site shall be used for the acceptance of the equipment. Pump vendor shall bring necessary instruments for conductance of site performance test. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, without any commercial implication to BHEL.

4.0 Additional Dispatch Requirements:

MDCC after final inspection shall be provided to vendor on the basis of following:-

4.1 List of items packed in each box with description & quantity.

4.2 Photograph of each box in open & closed condition.

4.3 Bidder to include handling instructions in engineering drg/doc and packing to be done in such a way to avoid damage of items in transit and long storage at site and same shall be approved in Contract stage by BHEL/Customer

	TECHNICAL SPECIFICATIONS		Specification No. : PE-TS-435-100-N001, Rev0	
	MISCELLANEOUS PUMPS		SECTION: IA	
	SPECIFIC TECHNICAL REQUIREMENTS		REV. NO. 0	DATE: 27.09.2019
5.0 <u>Drawing/Document Submission Schedule:</u>				
MISC. PUMPS (HORIZONTAL)	Primary Documents			
	PE-V7-435-100-N001	TDS AND PERFORMACE CURVES- MISC. PUMPS	R-0 within 20 days from LOI/PO & subsequent revisions within 10 days of comments received from BHEL.	
	PE-V7-435-100-N002	GENERAL ARRANGEMENT AND CROSS SECTIONAL-PUMPS		
	PE-V7-435-100-N003	TDS AND CURVES OF MOTORS FOR MISC. PUMPS		
	PE-V7-435-100-N004	QP-MISC PUMPS		
	PE-V7-435-100-N005	QP- MOTORS		
	Secondary Documents			
	PE-V7-435-100-N006	MOTOR TYPE TEST DOC (if applicable)	R-0 within 20 days of Cat-I(or)II approval on motor document.	
	PE-V7-435-100-N007	O& M MANUAL -HORZ. PUMPS	Within 30 days from MDCC	
	PE-V7-435-100-N008	PG TEST PROCEDURE -HOR. PUMPS	R-0 within 20 days of Cat-I(or)II approval on pump document.	



TECHNICAL SPECIFICATIONS		Specification No. : PE-TS-435-100-N001, Rev0	
MISCELLANEOUS PUMPS		SECTION: IA	
SPECIFIC TECHNICAL REQUIREMENTS	REV. NO.	0	DATE: 27.09.2019

Annexure-1

List of Miscellaneous Pumps and drives for :

A. 2X660 MW UDANGUDI STPP STG I (TANGEDCO)

Sl. No.	Pump Description	Total Qty.	Type of Pumps
	Horizontal Pumps		
1	DMCW PUMPS FOR TG & STATION AUXILIARIES	6 nos.	Horizontal
2	DMCW PUMPS FOR SG AUXILIARIES	4 nos.	Horizontal
3	AHP & CHP MAKEUP PUMPS	2 nos.	Horizontal
4	POTABLE WATER PUMPS	2 nos.	Horizontal
5	SERVICE WATER PUMPS	2 nos.	Horizontal
6	HVAC MUP PUMPS	2 nos.	Horizontal
7	APH/ESP WASH PUMPS	2 nos.	Horizontal
8	HOTWELL MAKEUP PUMPS	4 nos.	Horizontal
9	DM MAKEUP PUMPS	3 nos.	Horizontal
10	BOILER FILL PUMPS	4 nos.	Horizontal



TECHNICAL SPECIFICATIONS		Specification No. : PE-TS-435-100-N001, Rev0	
MISCELLANEOUS PUMPS		SECTION: IA	
SPECIFIC TECHNICAL REQUIREMENTS		REV. NO. 0	DATE: 27.09.2019

Annexure-2

Following HT drives for 2X660 MW UDANGUDI (TANGEDCO), irrespective of Motor ratings shall be issue free, by BHEL:

Horizontal Pumps:

- 1 DMCW PUMPS FOR TG & STATION AUXILIARIES**
- 2 APH/ESP WASH PUMPS**



5.0.0 CONSTRUCTIONAL REQUIREMENTS

5.1.0 Pumps

General design and construction DMCW/CCCW pumps shall be as per HI standard.

Pumps shall be identical in construction and similar parts of the pumps shall be interchangeable.

Continuous motor rating at high ambient for all pumps shall be at least 10% above the maximum power requirement at any condition of entire characteristic curve of the pump.

Casing shall be provided with a drain & vent connection comprising of an isolation valve and blind flange (with fasteners and gaskets) terminated at the edge of the base plate. The minimum size of any connection or piping shall be 1/2 inch nominal pipe size.

Each pump and its components shall be designed to facilitate installation and removal. Components requiring periodic inspections or maintenance shall be easily accessible.

Suction and discharge nozzles shall be flanged and shall conform to ASME standard.

Shaft sealing shall be by mechanical seal.

Sound power level shall not exceed 85 dBA at one (1) meter from the equipment.

The casing shall be designed to withstand the maximum shut-off pressure or 150% of maximum pressure under which the pump can operate at design fluid temperature, whichever is higher. Each pump shall preferably be of such construction that it is possible to service the internals of the pump without disturbing suction and discharge piping connections. Casings shall be of such thickness as well be suitable for maximum discharge and hydrostatic testing pressure and pumping temperature, with a 3 mm minimum corrosion allowance.

Impeller shall be of shrouded type. Impeller shall be of single piece casting (fabricated impellers not acceptable), smooth finished and dynamically balanced along with shaft on proper balancing equipment so as not to cause any vibration.

Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing. A suitable method of locking the wearing ring shall be used, such as by the use of grub screws. Wearing rings shall have a close tolerance fit to permit only a minimum of recirculation flow. Impeller wearing rings shall have surfaces harder than surfaces of opposed casing wearing or shall be made of non-galling material to suit the pump medium.

Bearings shall be of antifriction grease/oil lubricated heavy duty ball or roller bearings capable of carrying heavy loads in either direction of rotation for continuous operation. The bearing shall be designed for a minimum life of 40,000 hrs in continuous operation at rated pump conditions. Hydrodynamics radial and/or thrust bearings shall be provided if required. Bearing housings shall preferably be arranged so that bearings can be replaced without disturbing pump drives or mountings. The housing shall be effectively protected against the ingress of water, pumped fluid and dust. When oil lubrication is provided all bearing oil wells shall be fitted with visual oil level indicators. Non-pressure oil lubricated bearings shall be equipped with constant level oilers. Means of draining bearing housings shall be provided.

Proper lubricating may be by oil/ grease. In case of Oil lubricated bearings, the type shall be of the ring oil/Flooded type, incorporating an ample oil reservoir and fitted with an oil level sight glass/indicator and thermometer. Free access to all lubrication ports shall be incorporated in the pump design. Means of draining bearing housings shall be provided.



TITLE:
**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

SPECIFIC TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **I**

SUB-SECTION: **IB**

REV. NO. **00** DATE **27.09.2019**

SHEET **1** OF **1**

SUB-SECTION – IB

SPECIFIC TECHNICAL REQUIREMENTS (ELECTRICAL)

	TITLE: ELECTRICAL EQUIPMENT SPECIFICATION FOR MISC PUMP 2 X 660 MW UDANGUDI STPP STAGE-I	SPECIFICATION NO.
		VOLUME NO. : II-B
		SECTION: C
		REV NO. : 00 DATE: 30/07/2019
		SHEET: OF

SPECIFIC TECHNICAL REQUIREMENTS:

1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:

The equipment and services to be provided by bidder under this specification shall be as detailed here below but shall not be limited to the following:

- a) Services and Equipment as per "Electrical Scope between BHEL and Vendor".
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The bidder without any extra charge shall provide the same.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Electrical load requirement for Misc Pumps package.
- e) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- f) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer / BHEL approval without any commercial and delivery implications to BHEL.
- g) Various drawings including GA drg, data sheet as per required format, quality plans, calculations, test reports, test certificates, operation and maintenance manuals, characteristic curves, wiring diagrams/schemes etc. shall be furnished as specified at contract stage. All documents shall be subject to customer / BHEL approval without any commercial implications to BHEL.
- h) The sub-vendor list for various electrical items is subject to BHEL/Customer approval without any commercial implications.
- i) Motors shall meet minimum requirement of Electric motor specification.
- j) Purchaser will furnish data sheets to the vendor after award of contract. Vendor shall furnish filled in data sheets meeting the specification requirements.
- k) Vendor to clearly indicate equipment locations and local routing lengths in their cable listing furnished to BHEL.
- l) Cable BOQ worked out based on routing of cable listing provided by the vendor for "both end equipment in vendor's scope" shall be binding to the vendor with +10 % margin to take care of slight variation in routing length & wastages.

2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:

Refer "Electrical Scope between BHEL and Vendor".

3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID

बी एच ई एल 	TITLE: ELECTRICAL EQUIPMENT SPECIFICATION FOR MISC PUMP 2 X 660 MW UDANGUDI STPP STAGE-I	SPECIFICATION NO.
		VOLUME NO. : II-B
		SECTION: C
		REV NO. : 00 DATE: 30/07/2019
		SHEET: OF
3.1	Bidder shall confirm total compliance to the electrical specification without any deviation from the technical / quality assurance requirements stipulated. In line with this, the bidder as technical offer shall furnish two signed and stamped copies of the following: a) A copy of this sheet “Electrical Equipment Specification for Misc Pump package and sheet “Electrical Scope between BHEL and Vendor” with bidder’s signature and company stamp. b) Electrical load requirement.	
3.2	No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.	
4.0	LIST OF ENCLOSURES 4.1 Electrical scope between BHEL & vendor 4.2 Technical specification – Specification for Electric Motors/Actuators 4.3 Standard Technical specification – LV Motors 4.4 Datasheets & quality plan for motors. 4.5 Load Data Format. (Annexure –II) 4.6 BHEL Cable listing format (Annexure –III)	

STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR (FOR EPC PROJECTS)**PACKAGE: MISC. PUMP (Supply Package)****PROJECT:**

<u>S.NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&C</u>	<u>REMARKS</u>
1	415 V MCC	BHEL	BHEL	240 V AC (supply feeder) / 415 V AC (3 PHASE 4 WIRE) supply shall be provided by BHEL based on load data provided by vendor at contract stage for all equipment supplied by vendor as part of contract. Any other voltage level (AC/DC) required will be derived by the vendor.
2	Local Push Button Station (for motors)	BHEL	BHEL	Located near the motors.
3	Power cables, control cables and screened control cables	BHEL	BHEL	Incoming cable from BHEL supplied MCC will be informed by BHEL. Screened control cable between DCS & field equipment will also be informed by BHEL. Vendor shall provide lugs & glands accordingly.
4	Cable trays, accessories & cable trays supporting system	BHEL	BHEL	
5	Cable glands and lugs for equipments supplied by Vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power and control cables.
6	Conduit and conduit accessories for cabling between equipments supplied by vendor	BHEL	BHEL	
7	Equipment grounding & lightning protection	BHEL	BHEL	
8	Below grade grounding	BHEL	BHEL	
9	LT Motors with base plate and foundation hardware	Vendor	BHEL	Makes shall be subject to BHEL approval at contract stage.
10	Mandatory spares	Vendor	-	Vendor to quote as per specification.
11	Recommended O & M spares	Vendor	-	As per specification
12	Any other equipment/material/service required for completeness of system but not specified above (to ensure trouble free and efficient operation of the system).	Vendor	BHEL	
13	Electrical equipment GA drawing	Vendor	-	For necessary interface review.

NOTES:

1. Make of all electrical equipments/items supplied shall be reputed make & shall be subject to approval of BHEL after award of contract.
2. All QPs shall be subject to approval of BHEL after award of contract without any commercial implication.



SECTION-3.16: MOTORS

1.0.0 INTENT OF SPECIFICATION

This section covers the technical requirements of HT motors, LT Motors and DC motors.

2.0.0 CODES AND STANDARDS

The equipment to be furnished under this specification shall be in accordance with the applicable section of the latest edition (including amendments) of the following Indian Standards (IS), IEC publications and other codes except where modified and /or supplemented by this specification.

- | | |
|-----------------|--|
| a) IS: 325 | Three phase induction motors |
| b) IS: 12615 | Energy efficient induction motors |
| c) IS: 900 | Code of practice for installation and maintenance of induction motors |
| d) IS: 996 | Single-phase AC induction motor for general purpose |
| e) IS: 1231 | Dimensions of three-phase foot-mounted induction motors |
| f) IS: 2223 | Dimensions of flange mounted AC induction motors |
| g) IS: 4029 | Guide for testing three-phase induction motors |
| h) IS: 8789 | Values of performance characteristics for three-phase induction motors |
| i) IS: 13555 | Guide for selection and application of 3-phase AC induction motors for different types of driven equipment |
| j) IS: 5571 | Guide for selection of electrical equipment for hazardous areas |
| k) IS: 12065 | Permissible limits of noise level for rotating electrical machines |
| l) IS: 12075 | Mechanical vibration of rotating electrical machines |
| m) IS 60034-5 | Degree of protection provided by Integral design of rotating electrical machines |
| n) IS 60034-8 | Terminal marking and direction of rotation |
| o) IS 60079-1 | Equipment protection by flame proof enclosure |
| p) IS 60034-1 | Rotating electrical machines. |
| q) IS 60079 | Explosive atmospheres |
| r) IS/IEC 60529 | Degrees of protection provided by enclosures (IP code) |
| s) IEC 60034 | Rotating electrical machines. |
| t) IS 3177 | Code of practice for Design, Manufacture, Erection and testing of Cranes and Hoists |

3.0.0 TECHNICAL REQUIREMENTS

3.1.0 Design ambient temperature

Motors shall be suitable for an ambient temperature of 50 degree C and relative humidity of 95% and shall deliver the rated output without exceeding its guaranteed temperature limits.

3.2.0 Supply voltage

Motors rated up to and including 415 V are termed as LT motors and the motors rated higher than 415 V are termed as HT motors.

Motors shall be capable of delivering the rated output under following voltage and frequency variations without exceeding its guaranteed temperature limits.



- Frequency variation : (+) 3% and (-) 5%
- Voltage variation for LT motors : ($\pm$) 10%
- Voltage variation for HT motors : ($\pm$) 6%
- Combined variation of voltage and frequency : 10% (absolute sum)

All the motors shall be so designed that maximum inrush currents, locked rotor torque and pullout torque developed at extreme voltage and frequency variations do not endanger the motor and the driven equipment.

3.3.0 System Parameters

Sl. No.	Description	11 kV and 6.6 kV System	LT System
1.	Voltage level	6.6 kV : Above 200 kW and upto 2000 kW 11 kV: Above 2000 kW	240 V : up to 0.2 kW 415 V: >0.2 kW and up to 200 kW.
2.	System earthing	Earthed through resistance, limiting earth fault current to 300 Amps	415 V system solidly grounded.
3.	Fault withstand rating of motor terminal box (Breaker operated)	50 kA for 0.2 sec for 11 kV and 31.5 kA for 0.2 sec for 6.6 kV	415 V system : 50/65 kA for 0.2 second

3.4.0 Type

AC Motors shall be squirrel cage induction type unless otherwise it is specified.

3.5.0 Duty

- All AC motors shall be squirrel cage three phase/single phase induction motors. All the motor shall be designed for bi-directional rotation.
- All the motors shall be rated for S1 duty for continuous operation. Motors of crane and hoist application shall be intermittent duty.
- DC motor shall generally be of shunt wound type rated for 220 V DC.
- Motors shall be suitable for installation in hot, humid and tropical atmosphere and polluted at places with coal ash and or fly ash.
- The motors shall be suitable for bus transfer schemes provided on the 11 kV/6.6 kV/415 V systems without any injurious effect on its life.

3.6.0 Design margin

Whenever the basis for motor rating are not specified in the corresponding mechanical specification section maximum continuous motor rating shall be atleast 10% above the maximum load derived of the driven equipment under entire operating range including voltage & frequency variation.

The motor characteristics shall match the requirements of the driven equipment so that adequate starting, accelerating; pull up, breakdown and full load torques are available for the intended service.

Service shall be considered as 1.0 only.



3.7.0 Method of Starting

- All the motors shall be suitable for direct on-line starting on full load. Where variable voltage and variable frequency (VVFD) operation is envisaged through VVFD drives, motors shall be specially designed for such application.
- LT motors rated up to 125 kW shall be controlled through MPCB/MCCB and contactor. LT motors rated more than 125 kW shall be controlled through air circuit breaker.
- HT Motors shall be controlled through vacuum circuit breaker.

3.8.0 Efficiency

All the duty motors shall be energy efficient type. For HT and LT motors, it shall be IE3 class as per IS 12615. For VFD controlled HT and LT motors, it shall be IE2 class as per IS 12615.

3.9.0 Temperature rise

- Winding Insulation shall be Class F.
- Temperature rise of air cooled motors shall not exceed 70°C over air temperature of 50°C by resistance method, while delivering its maximum rated output.
- Temperature rise of water cooled motors shall not exceed 80°C over inlet cooling water temperature by resistance method, while delivering its maximum rated output.

3.10.0 Starting voltage

- a) Motors shall be capable of starting and accelerating the load at following starting voltage, with direct on-line starting, without exceeding specified winding temperatures.
 - HT Motors (up to 1000 kW) : 85% of rated voltage
 - HT Motors (> 1000 kW up to 4000 kW) : 80% of rated voltage
 - HT Motors (> 4000 kW) : 75% of rated voltage
 - LT motors : 80% of rated voltage
- b) During fast changeover of power supply source, vector difference between the motor residual voltage and the incoming supply voltage shall be about 150% of the rated voltage and the motors shall withstand voltage stress and torque stress developed during that time, which may last for a period of one (1) second.
- c) The motor shall be capable of operating at full load at a supply voltage of 75% of the rated voltage for 5 minutes.

3.11.0 No. of Starts

Continuous duty motors shall be suitable for the following starting requirements under the specified conditions of load, torque and inertia.

- No. of consecutive hot starts shall be 2 (with initial temperature of the motor at full load operating level).
- No. of consecutive cold starts shall be 3 (with initial temperature of the motor at ambient temperature).
- For conveyor motors, no. of consecutive hot starts shall be 3 (with initial temperature of the motor at full load operating level).



3.12.0 Starting current

- Locked rotor current of HT motors for applications other than listed below shall be limited to 600% of the full load current, and is subject to IS tolerance.
- For energy efficient LT motors, locked rotor current shall be as per IS: 12615.
- Locked rotor current of the VFD controlled AC motors shall be limited to 300% of the full load current, and is subject to IS tolerance.
- Locked rotor current of the BFP motors shall be limited to 450% of the full load current of the motor, and is subject to IS tolerance.

3.13.0 Locked rotor withstand time

- The locked rotor withstand time for HT motors under hot conditions at 110% rated voltage shall be more than the starting time at minimum permissible voltage specified above by atleast three seconds or 15% of the accelerating time whichever is greater. Provision of speed switch shall be avoided to the extent possible. In case the speed switch is required, it shall be indicated by the bidder in his offer
- For the LT motors having starting time up to 20 seconds at minimum permissible voltage, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 2.5 seconds more than the starting time.
- For the motors having starting time more than 20 seconds and up to 45 seconds at minimum permissible voltage, the locked rotor withstand time under hot condition at highest voltage limit shall be at least 5 seconds more than the starting time.
- For motors having starting time more than 45 seconds at minimum permissible voltage, the locked rotor withstand time under hot condition at highest voltage limit shall be more than starting time by at least 10% of the starting time.
- Speed switches mounted on the motor shaft shall be provided in cases where above requirements are not met.
- When a speed switch is mounted on the motor shaft, the same shall remain closed for speeds lower than 20% and open for speeds above 20% of the rated speed. The speed switch shall be capable of withstanding 120% over speed in either direction of rotation.

3.14.0 Torque Requirements

- Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% motor full load torque.
- Pull out torque at rated voltage shall not be less than 205% of full load torque.
- Motors subjected to reverse rotation shall be designed to withstand the stresses encountered when starting with non-energized shaft rotating at 125% of rated speed in reverse direction.

3.15.0 Enclosure

- a) Motors shall have IP 55 degree of protection.
- b) For hazardous location, the enclosure of motors shall following have flame proof construction conforming to applicable standard.
 - Fuel oil area Group – IIB
 - Hydrogen generation plant area : Group – IIC)



3.16.0 Cooling

- LT motors shall be totally enclosed fan cooled (TEFC), type IC411. The cooling shall be effected by self-driven bi-directional centrifugal fan protected by fan cover.
- HT motors can be totally enclosed fan cooled (TEFC) or totally enclosed tube ventilated (TETV) or closed air circuit air cooled (CACA-IC6A1A1) type.
- Motors rated >3000 kW can be closed air circuit water cooled (CACW).
- Motors with CACA/CACW heat exchangers shall have dial type thermometer with adjustable alarm contacts to indicate the following:
 - Hot and cold air temperatures of the closed air circuit for CACA motors.
 - Hot and cold, air and water temperatures for CACW motors.
- The Alarm switch contact rating shall be minimum 0.5 A at 220 V DC and 10 A at 230 V AC.

3.17.0 Winding

- Winding shall be class F insulation with temperature limited to class B. Insulation shall be Non-hygroscopic, oil resistant, and flame resistant. Winding, fittings and hardware shall be corrosion resistant. Winding shall be tropicalized and suitably varnished, baked and treated for operating satisfactorily in humid and corrosive atmosphere.
- For the VFD operated drives, insulation shall be designed to take care of stresses due to high DV/DT. Motors shall be wound with dual coated winding wires and impregnated with VPI process. Further for such application, insulated bearings shall be provided to avoid circulating current caused by shaft induced voltages.
- Space heaters rated for 240 V AC, 50 Hz supply shall be provided for motors rated 30 kW and above to maintain windings in dry condition when motor is standstill.
- For HT motors, insulation shall be Vacuum Impregnated (VPI).
- HT motors shall withstand one minute power frequency voltage test or 1.2/50 micro sec lightning impulse Voltage wave of $4U+5$ kV (U =Line voltage in kV) test on main insulation as per IEC 60034-15. The coil inter-turn insulation shall withstand steep front impulse withstand voltage as per IEC 60034-15.
- For HT motors, 12 nos. simplex or 6 nos. duplex RTDs (two per phase), each having D.C. resistance of 100 ohms at 0°C, embedded in the stator winding at locations where highest temperatures may be expected, shall be provided. The material of the ETD's shall be platinum.

3.18.0 Bearings

- Motor shall be provided with antifriction bearings, unless sleeve bearings are required by the motor application. Bearings shall be provided with seals to prevent leakage of lubricant or entrance of foreign matters like dirt, water etc. into the bearing area.
- Sleeve bearings shall be split type, ring oiled with permanently aligned, close running shaft sleeves. Grease lubricated bearings shall be pre-lubricated and shall have provisions for in-service positive lubrication with grease nipple and relief holes. For sleeve bearings, the bearing housing shall be preferably in end shield itself.
- Vertical shaft motors shall be provided with thrust and guide bearings. Thrust bearing of tilting pad type is preferred. However, if anti-friction bearings can take vertical thrust, thrust and guide bearings are not required.



- Lubricant shall not deteriorate under all service conditions. The lubricants shall be limited to normally available types. For motors rated 30 kW and above re-lubrication facility shall be provided.
- For motor with forced lubrication, a shaft driven oil pump shall be provided along with an electrical auxiliary pump. Alternatively, two motor driven pumps may be provided, one working and one standby. All necessary auxiliaries and accessories shall be provided to complete the system. A pressure gauge and pressure switch for low oil pressure warning and to start the standby oil pump automatically shall also be provided. A motor driven jacking oil pump may be provided, for heavy shaft loads.
- Flow switches shall be provided for monitoring oil flow of forced lubrication bearings, if used. Alarm switch contact rating shall be minimum 0.5 A at 220 V DC and 10 A at 230 V AC.
- For bearing temperature measurement, duplex RTDs shall be provided for each bearing and shall be wired up to the terminal box.
- Each bearing shall be provided with dial type thermometer.
- For all VFD operated motors shall have insulated bearings to prevent flow of shaft currents.
- For motors rated above 1000 KW having shaft length more than 1.5 M shall have insulated bearings to prevent flow of shaft currents.
- All the motors rated <15 kW shall be provided with sealed ZZ bearings.
- Lub oil pressure transmitters shall be provided to DCS for remote monitoring. Lub oil pressure very low trip to HT equipment shall be 2 out of 3 logic.

3.19.0 Terminal Boxes

- Separate terminal boxes of IP 55 degree of protection shall be provided for stator leads. For single core cables, gland plate shall be non-magnetic material. Terminal box of HT motors shall be capable of being turned 360° in steps of 180°. Terminal box of LT motors shall be capable of being turned 360° in steps of 90°. The terminal boxes shall be split type with removable cover with access to connections.
- Terminals for motors shall be stud type, thoroughly insulated from the frame. The terminals shall be clearly identified by phase markings, with corresponding direction of rotation marked on the non-driving end of the motor.
- The terminal box shall be capable of withstanding maximum system fault current for 0.2 sec for all breaker operated motors and shall be provided with explosion vent.
- For contactor operated LT motors, the terminal box shall be capable of withstanding the fault current for 0.2 sec minimum and operating time of MPCB/MCCB.
- Removable gland plates of thickness not less than 2.5 mm sheet steel or 3 mm aluminium (for single core cables) shall be provided for cable boxes.
- Cable spreader box shall be provided for larger cable sizes.
- Cable boxes of HT motors shall be phase segregated type. The terminals of three phases shall be segregated by barriers of metal or fiber glass. For HT motors, cable box design shall be suitable for accommodating cable termination kits.
- Separate terminal box for space heaters shall be provided.
- A separate terminal box of IP 55 degree of protection shall be provided for temperature detectors.
- Motors rated >1000 kW shall be provided with neutral current transformers of PS class on each phase for differential protection in neutral side terminal box. The three phases shall be connected to form the star point after passing through the CTs. The CT details shall be



finalized during detail engineering. Neutral terminal box shall have IP 55 degree of protection.

- The secondary leads of CT shall be wired to separate auxiliary terminal box of IP 55 degree of protection
- All the accessory terminal boxes shall be located on the same side of the main (power) terminal box.
- For LT motors, terminal box shall be located on top, unless otherwise specified.

3.20.0 Earthing Terminals

The frame of each motor shall be provided with two separate and distinct grounding pads complete with tapped hole, GI bolts and washer. The terminal box shall have a separate grounding terminal.

3.21.0 Noise and Vibration

- Motors shall be selected with low noise levels in accordance with IS 12065.
- The peak amplitude of the vibration shall also be within the specified limits of IS: 12075.
- All HT motors shall be provided with vibration pads for mounting vibration detectors.

3.22.0 Name Plates

Motor shall have stainless steel nameplate(s) showing diagram of connections, all particulars as per IS: 325 / IS: 12615 and shall also have 'BEE' marking.

In addition to the minimum information required by IEC/IS, the following information shall be shown on motor rating plate:

- Temperature rise in °C under rated condition and method of measurement.
- Degree of protection.
- Bearing identification no. and recommended lubricant.
- Location of insulated bearings.

3.23.0 Canopy

Canopy shall be provided for all the motors located outdoor. For details, please refer Civil section.

4.0.0 DC MOTORS

DC motors shall be provided where specified/required. DC Motors shall be sized for operation with fixed resistance starting for reliability. DC motors shall be shunt wound type. Motors shall be capable of delivering the rated output at 220 V DC with (+) 10% and (-) 15% variations without exceeding its guaranteed temperature limits. 220 V DC system shall be unearthed. Starting current of the DC motors shall be limited to 200% of the full load current of the motor, and is subject to IS tolerance. DC Motors shall be similar to AC Motors with respect to other features like enclosure type, cooling and class of insulation.

5.0.0 INSTALLATION

Installation shall be carried out as per IS: 900.

6.0.0 PAINTING

Painting shall be carried out by an approved process. Pretreatment shall conform to applicable standard. The equipment shall be subject to a coat of red oxide primer paint. All inside and



outside surface shall be painted with epoxy based paint. The final thickness of paint film on steel shall not be less than 100 microns. Finish shade shall be 631 of IS: 5 (smoke grey).

7.0.0 TESTING AND INSPECTION

7.1.0 Equipment offered shall be of type tested and proven type. Type test certificates for test conducted earlier on similar rating shall be furnished for the motors rated 30 kW and above.

7.2.0 The following type tests shall be conducted on LT motors.

- Measurement of resistance of windings of stator and wound rotor.
- No load test at rated voltage to determine input current power and speed
- Full load test to determine efficiency power factor and slip.
- Temperature rise test.
- Momentary excess torque test.
- High voltage test.
- Test for vibration severity of motor.
- Test for noise levels of motor
- Test for degree of protection
- Over speed test.

7.3.0 The following additional type tests shall be conducted on HT motors.

- No load saturation and loss curves up to approximately 115% of rated voltage
- Measurement of noise at no load.
- Momentary excess torque test
- Full load test
- Temperature rise test at rated conditions.
- Lightning Impulse withstand test on the sample coil shall be as per IEC-60034, part-15
- Surge-withstand test on interturn insulation shall be as per clause no. 5.1.2 of IEC 60034, part-15
- Degree of protection test for the enclosure followed by IR, HV and no load run test.
- Terminal box-fault level withstand test for each type of terminal box.

7.4.0 The following routine tests shall be carried out for the motors as per applicable standards.

- IR of Winding before and after HV tests
- HV test on main winding space heater, RTD, BTD
- Resistance measurement
- No load run test Major Electrical
- Phase sequence and direction of rotation
- Vibration check Major Electrical
- Reduced voltage running test
- Locked rotor test at reduced voltage
- Record of RTD & BTD resistance at the end of no load test
- Test on space heater & RTD
- Visual Control of terminal box and verification of construction with respect to short tested terminal box

7.5.0 The following minimum tests/ checks shall be conducted at site. Any other tests/ checks as per the manufacturer's recommendation shall also be carried out

- Measurement of vibration.
- Measurement of insulation resistance and polarization index.
- Measurement of full load current.
- Test running of the motors, checking the temperature rise and identifying the hot spot etc.



8.0.0 DRAWINGS & DOCUMENTS

The following drawings and documents shall be submitted for approval during detail engineering stage.

- Motor sizing calculation
- Technical particulars
- General arrangement drawings
- Performance curves (Efficiency, power factor, starting current)
- Characteristic curves (Speed torque, Hot/cold with stand time, Negative sequence current)
- Terminal box details
- Test reports
- Sub-vendor list
- Manufacturing quality plan
- Field quality plan



SECTION-3.17: ELECTRICAL ACTUATORS

1.0.0 INTENT OF SPECIFICATION

This section covers the requirements of motor operated electrical actuators.

2.0.0 CODES AND STANDARDS

The equipment to be furnished under this specification shall be in accordance with the applicable section of the latest edition (including amendments) of the applicable Indian Standards (IS), IEC publications and other codes except where modified and /or supplemented by this specification.

3.0.0 TECHNICAL REQUIREMENTS

- 3.1.0 Electric actuators shall be provided as specified in Mechanical and C&I section. It shall be equipped with 3 phase induction motor, rated for S2-15 minutes duty for ON/OFF valve and intermittent duty for inching duty
- 3.2.0 Motor shall be class F insulated with temperature rise limited to class B. Motor shall be of class H insulation with temperature limited to class B used for high pressure and high temperature valves.
- 3.3.0 Motor shall be surface cooled designed for enclosure protection class of IP 67. Motor shall be suitable for starting direct on-line.
- 3.4.0 For installation in potentially hazardous areas, the actuators shall have suitable explosion proof / flame proof type enclosure.
- 3.5.0 Actuators shall be suitable for operation at an ambient temperature of 50 degree C and relative humidity of 95%.
- 3.6.0 Maximum continuous motor rating shall be atleast 10% above the maximum load derived of the driven equipment under entire operating range including voltage & frequency variation.
- 3.7.0 Motors shall be capable of operating under following supply variations without exceeding its guaranteed temperature limits.
- Frequency variation : (+) 3% and (-) 5% of 50 Hz
 - Voltage variation for LT motors : ($\pm$) 10% of 415 V
 - Combined variation of voltage and frequency: 10% (absolute sum)
- 3.8.0 All actuators shall be of integral type. Duty cycle of actuators shall suit the system requirement. The actuators shall be capable of giving the required torque at the output shaft. The actuators shall be designed to take the full thrust.
- 3.9.0 Electrical Actuators of Inching type position transmitters of non contact type shall be interfaced to DCS.
- 3.10.0 Actuators shall be of totally enclosed weather proof and dust proof construction with NEMA-6/IP 65 enclosure and shall be suitable for outdoor application without the necessity for a canopy. The actuator shall be suitable for mounting directly on the valve. The actuator shall be capable of giving the required torque, rpm and thrust without the help of any spur gear arrangement. The actuator shall be suitable for mounting in any position. Actuators shall be provided with integral starters.



- 3.11.0 The actuator shall be complete with motor, reduction gears, change gears, terminal compartment, switch compartment with limit switches and torque switches, local position indicator, position transmitter for remote position indicator, thermistor, space heaters, cable glands, mechanical position indicator, hand wheel for manual operation, valve attachment etc.
- 3.12.0 Each actuator shall have a hand wheel fitted on it for emergency operation. The hand wheel shall be designed such that it is declutched automatically when the power supply to the motor is restored. The material of the hand wheel shall be either malleable iron or steel. The hand wheel shall have adequate clearance from housing for each gripping and operation. Actuators offered shall be with self-locking worm.
- 3.13.0 Two number adjustable torque switches (one for open and one for close) each with 2 NO and 2 NC potential free contacts shall be provided. It is required to have calibration for the torque switches so that the switches can be easily set to any value desired.
- 3.14.0 Two numbers of position limit switches (one for open and one for close) each with 2 NO and 2 NC potential free contacts shall be provided. Two auxiliary limit switches (one for open and one for close) with 2 NO and 2 NC potential free contacts shall also be provided. The limit switches shall be of independently adjustable type. Limit switches and actuating mechanism shall be rust proof suitable for damp atmospheres. Limit switch compartment shall be weather proof and spacious enough for easy setting. The limit switches shall be suitable for the following ratings, both 240 Volts AC, 10 A and 220 V DC, 0.5 Amps.
- 3.15.0 Each actuator shall have a space heater in the limit switch compartment suitable for 240 V AC 50 Hz single phase supply.
- 3.16.0 The wiring from the limit switches, torque switches etc. shall be brought out in a separate terminal box of adequate size, so as to easily terminate the control cables.
- 3.17.0 Actuators shall be supplied with integral starter which shall have sophisticated electronic controls with field programming feature. It shall be designed for remote control from DCS/Respective control system. Required interposing relays for receiving open/close/stop command from DCS/Respective control system shall be provided. Potential free contacts and transducers shall be provided to provide status indication at remote DCS/Respective control system..
- 3.18.0 A three position selector switch (marked as LOCAL-OFF-REMOTE) and push buttons OPEN-STOP-CLOSE (for local operation) with indication lamps for running OPEN and running CLOSE shall be provided.
- 3.19.0 The Remote command signal (OPEN-STOP-CLOSE) from DCS/Respective control system/Control panel shall be isolated from control electronics through opto-isolator.
- 3.20.0 The following individual sStatus annunciation LED's and fault annunciation LED's shall be provided locally (Integral to actuator) to annunciate the following for easy local monitoring.
- Actuator in local mode
 - Actuator in remote mode
 - Actuator running in OPEN direction
 - Actuator running in CLOSE direction
 - Actuator in inching mode.
 - Actuator in self-retaining mode
 - Limit switch OPEN trip
 - Limit switch CLOSE trip
 - Control voltage availability
- 3.21.0 The following individual fault annunciation LED's (Colour-Red) shall be provided locally. (Integral to Actuator)



- Torque switch OPEN
- Torque switch CLOSE
- Thermo switch trip
- Electronic overload relay trip
- Motor single phasing
- Common fault (Inclusive of any one or combination of above fault)

3.22.0 View port shall be provided on integral starter unit to monitor the above status annunciation and fault annunciation.

3.23.0 Electronic Overload relay shall be provided to trip actuator in case of overload. Plug in connections/design shall be provided between:-

- Integral starter unit and basic actuator
- Between external customer connections and actuator.

3.24.0 OPEN-CLOSE indication /LED shall be provided for indication of full open/close position.

3.25.0 Automatic phase correction facility and potential free contact for annunciation of power failure shall be provided.

3.26.0 The following individual potential free relay contacts shall be provided in the actuator for remote annunciation to facilitate continuous monitoring of the actuator.

- Actuator (valve) running in OPEN direction.
- Actuator (valve) running in CLOSE direction.
- Actuator in remote mode.
- Actuator in local mode.
- Actuator power switched off /single phasing.
- Torque switch trip, thermo switch trip and overload relay trip

4.0.0 TESTING AND INSPECTION

Equipment offered shall be of type tested and proven type. Routine tests shall be carried out for all the equipment as per applicable standards. Copies of certified reports of all tests carried out at the works shall be furnished.

The following minimum tests/ checks shall be conducted at site. Any other tests/ checks as per the manufacturer's recommendation shall also be carried out.

- Measurement of insulation resistance.
- Measurement of full load current.
- Test running of the motors.

5.0.0 DRAWINGS & DOCUMENTS

The following drawings and documents shall be submitted for approval during detail engineering stage.

- Integral starter details
- Technical particulars of actuator
- Wiring diagram
- General arrangement drawings
- Test reports
- Manufacturing quality plan
- Field quality plan

DATA SHEET-A		
SL NO.	DESCRIPTION	2X660 MW UDANGUDI SUPERCRITICAL STPP
A	General	
1	Manufacturer & country of origin	
2	Motor type	Squirrel cage induction AC motors
3	Efficiency class	For all LT motors, it shall be IE3 class as per IS 12615 except for VFD controlled LT motors, it shall be IE2 class as per IS 12615
4	Type of starting	DOL
5	Maximum acceptable kW rating of LV motor	>0.2 kW and up to 200 kW. LT motors rated up to 125 kW shall be controlled through MPCB/MCCB and contactor. LT motors rated more than 125 kW shall be controlled through air circuit breaker.
6	Rating up to which Single phase motors permitted.	up to 0.2 Kw
7	Installation (Indoors/ Outdoors)	indoor/outdoor
8	Degree Of Protection	IP 55
9	Name of the equipment driven by motor & Quantity	
10	Maximum Power requirement of driven equipment	
11	Rated speed of Driven Equipment	As per system requirement
12	Design ambient temperature	50 deg C
B	Design and Performance Data	
1	Frame size & type designation	DURING DETAILED ENGINEERING
2	Type of duty	All the motors shall be rated for S1 duty for continuous operation. Motors of crane and hoist application shall be intermittent duty. The motors shall be suitable for bus transfer schemes provided on the 11 kV/6.6 kV/415 V systems without any injurious effect on its life.
3	Rated Voltage	240/415 V
4	Rated Frequency	50 Hz
5	System fault level at rated voltage	50 kA for 1 sec.
6	LV System grounding	solidly grounded
7	Permissible variation for	
a	Voltage	±10%
b	Frequency	+3% to -5%
c	Combined voltage & frequency	10%
8	Rated output at design ambient temp (by resistance method)	As per system requirement
9	Synchronous speed & Rated slip	As per system requirement
10	Minimum permissible starting voltage	80% of rated voltage During fast changeover of power supply source, vector difference between the motor residual voltage and the incoming supply voltage shall be about 150% of the rated voltage and the motors shall withstand voltage stress and torque stress developed during that time, which may last for a period of one (1) second. c) The motor shall be capable of operating at full load at a supply voltage of 75% of the rated voltage for 5 minutes.

11	TYPE OF STARTER PROVIDED IN MCC	DOL
12	Starting time in sec with mechanism coupled	
a	At rated voltage	As per manufacturers standard
b	At min starting voltage	
13	Locked rotor current as percentage of FLC (including IS tolerance)	For energy efficient LT motors, locked rotor current shall be as per IS: 12615. Locked rotor current of the VFD controlled AC motors shall be limited to 300% of the full load current, and is subject to IS tolerance
14	Torque	
a	Starting	
b	Maximum	
15	Permissible temp rise at rated output over ambient temp & method	Winding shall be class F insulation with temperature limited to class B
16	Noise level at 1.0 m (dB)	Motors shall be selected with low noise levels in accordance with IS 12065.
17	Amplitude of vibration	The peak amplitude of the vibration shall also be within the specified limits of IS: 12075.
18	Efficiency & P.F. at rated voltage & frequency	
a	At 100% load	Premium efficiency (IE3) IS: 12615 .
b	At 75% load	
c	At starting	
C	Constructional Features	
1	Method of connection of motor driven equipment	As per system requirement
2	Applicable Standard	as per relevant standard
3	DOP of Enclosure	IP55
4	Method of cooling	LT motors shall be totally enclosed fan cooled (TEFC), type IC411. The cooling shall be effected by self-driven bi-directional centrifugal fan protected by fan cover. The Alarm switch contact rating shall be minimum 0.5 A at 220 V DC and 10 A at 230 V AC.
5	Class of insulation	All motors shall have class F insulation but limited to class B temperature rise
6	Main terminal box	

a	Type	Separate terminal boxes of IP 55 degree of protection shall be provided for stator leads. For single core cables, gland plate shall be non-magnetic material. Terminal box of LT motors shall be capable of being turned 360° in steps of 90°. The terminal boxes shall be split type with removable cover with access to connections.
b	Power Cable details (Conductor, size, armour/unarmour)	DURING DETAILED ENGINEERING
c	Cable Gland & lugs details (Size, type & material)	DURING DETAILED ENGINEERING The frame of each motor shall be provided with two separate and distinct grounding pads complete with tapped hole, GI bolts and washer. The terminal box shall have a separate grounding terminal.
d	Permissible Fault level (kArms & duration in sec)	Fault withstand rating of motor terminal box (Breaker operated): 415 V system : 50/65 kA for 0.2 second
7	Earth Conductor Size & Material	DURING DETAILED ENGINEERING
8	Space heater details (30KW & ABOVE) (Voltage & watts)	Space heaters rated for 240 V AC, 50 Hz supply shall be provided for motors rated 30 kW'and above to maintain windings in dry condition when motor is standstill.
9	Flame proof motor details (if applicable)	For hazardous location: the enclosure of motors shall following have flame proof construction conforming to applicable standard. • Fuel oil area Group – IIB • Hydrogen generation plant area : Group – IIC)
a	Enclosure	
b	suitability for hazardous area	
i	Zone O / I / II	
ii	Group IIA / IIB / IIC	
c	Degree of Protection	
9	No. of Stator winding	As per manufacturers standard
10	Winding connection	As per system requirement
11	Kind of rotor winding	As per manufacturers standard

12	Kind of bearings	Motor shall be provided with antifriction bearings, unless sleeve bearings are required by the motor application. Bearings shall be provided with seals to prevent leakage of lubricant or entrance of foreign matters like dirt, water etc. into the bearing area. • Sleeve bearings shall be split type, ring oiled with permanently aligned, close running shaft sleeves. Grease lubricated bearings shall be pre-lubricated and shall have provisions for inservice positive lubrication with grease nipple and relief holes. For sleeve bearings, the bearing housing shall be preferably in end shield itself. • Vertical shaft motors shall be provided with thrust and guide bearings. Thrust bearing of tilting pad type is preferred. However, if anti-friction bearings can take vertical thrust, thrust and guide bearings are not required. • Lubricant shall not deteriorate under all service conditions. The lubricants shall be limited to normally available types. For motors rated 30 kW and above re-lubrication facility shall be provided. For bearing temperature measurement, duplex RTDs shall be provided for each bearing and shall be wired up to the terminal box. • Each bearing shall be provided with dial type thermometer. • For all VFD operated motors shall have insulated bearings to prevent flow of shaft currents. Lub oil pressure transmitters shall be provided to DCS for remote monitoring. Lub oil pressure very low trip to HT equipment shall be 2 out of 3 logic.
13	Direction of rotation when viewed from NDE	motor shall be bi-directional
14	Paint Shade & type	Painting shall be carried out by an approved process. Pretreatment shall conform to applicable standard. The equipment shall be subject to a coat of red oxide primer paint. All inside and outside surface shall be painted with epoxy based paint. The final thickness of paint film on steel shall not be less than 100 microns. Finish shade shall be 631 of IS: 5 (smoke grey).
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	DURING DETAILED ENGINEERING
D	Characteristic curves/ drawings	
1	(To be enclosed for motors of rating >55KW)	
2	Torque speed characteristic	
3	Thermal withstand characteristic	
4	Current vs time	
5	Speed vs time	
E	Tests on motors	

NOTE:

- 1 Please write "As per manufacturers standard" where data is not defined in the project specification.
- 2 Please mention any project specific requirement if any in the datasheet (Add extra row).
- 3 For details which is not applicable please write "NA"



TITLE:
**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

SPECIFIC TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **I**

SUB-SECTION: **ID**

REV. NO. **00** DATE **27.09.2019**

SHEET **1** OF **1**

SUB-SECTION – IC

SPECIFIC TECHNICAL REQUIREMENTS (C&I)

**2. Resistance Temperature Detector**

- | | | |
|------------------------|---|---|
| 01. Type | : | Platinum (Duplex), ungrounded class 'A' |
| 02. Resistance | : | 100 ohm at 0 °C |
| 03. Base | : | Wound on ceramic (anti-inductive) |
| 04. Wiring | : | 3 Wire |
| 05. Protecting Tube :- | | |
| i) O.D. | : | 8 mm (approx). |
| ii) Material | : | SS-316, Seamless |
| iii) Filling | : | Magnesium oxide (Purity above 99.4%). |
| iv) Length | : | As per application |
| 06. Response time | : | a) 1 to 2 seconds |
| 07. Head: | | |
| i) Type | : | IP-65 universal screwed type. (Explosion proof for NEC Class-1, Division 1 area) |
| ii) Material | : | Die cast aluminum or better |
| iii) Terminal blocks | : | Nickel plated Brass-screw type / silver plated |
| iv) Cable connection | : | 3/4" ET gland and grommet. |
| v) Others | : | Terminal head cover with SS chain and suitable gasket |
| 08. Accessories | : | a) Adjustable nipple-union-nipple with thermowell connection
b) Compression fittings/unions
c) Flanges etc. (for flanged connections only)
d) SS 316 forged thermowell as per ASME PTC code. |
| 09. Nameplate | : | Tag number, service engraved in stainless steel tag plate |
| 10. Standard | : | Standard DIN 43760 |
| 11. Limit of error | : | @ 0 Deg C ± 0.06 Ohm
@ 100 Deg C + 0.13 Ohm
@ 200 Deg C ± 0.20 Ohm
@ 300 Deg C ± 0.27 Ohm |

3. Field Mounted Temperature Transmitters

- | | | |
|---------------------------------|---|--|
| 01. Working Principle | : | Smart |
| 02. Type | : | Two wire |
| 03. Input | : | Universal (T/C of different types, PT 100 RTD and other RTDs) |
| 03. Output Signal | : | Simultaneous transmission of digital and 4-20 mA DC signal with HART. |
| 04. Signal Processing Circuitry | : | Microprocessor based Solid State Electronic |
| 05. Span and Zero | : | Adjustable in field, Non-interacting facility for elevation and suppression of zero. |
| 06. Enclosure Class | : | IP-65 (Explosion proof for NEC Class-1, Division 1 area) |
| 07. Output Indicator | : | LCD type |



- | | | | |
|-----|---------------------------------|---|--|
| 08. | Span Adjustability | : | Yes |
| 09. | Nameplate | : | Tag number to be engraved on metallic tag plate rigidly fixed to the body. |
| 10. | Body | : | Die Cast aluminum |
| 11. | Operating Voltage | : | 18-36 V DC |
| 12. | Load | : | 600 Ohms at 24V DC (Min.) |
| 13. | Performance | : | |
| | i) Accuracy | : | 0.2% of span |
| | ii) Repeatability | : | ±0.05% of span |
| | iii) Cold Junction Compensation | : | Built-in |
| | iv) Calibration | : | As per N.I.S.T Monograph 125 for T/C and European Curve Alpha = 0.00385 for RTD |
| 14. | Accessories | : | a) Universal mounting bracket suitable for pipe and surface mounting.
b) Hi-tensile Carbon Steel U-bolts. |

4. Thermo Well

Thermo wells Pipe/equipment mounted temperature test wells of 316 SS with a process connection of M33x2 thread or 150 RF flanged and instrument connection of ½" NPT (F) in general or 150 RF flanged.. Accessories like name plate, plug with chain, etc. shall be provided. Material of accessories shall be SS. Thermowell shall be hex head of barstock assembly. In case flanged wells are required for any specific application, the same shall be supplied as required. The thermo well construction shall meet the ANSI 19.3 (latest) requirements. Thermo well shall be designed such that the resonant frequency is above the exciting frequencies generated by vortex shedding in the process fluid. All Test thermo well shall have the plug of SS316.

For measurement of pulveriser outlet temperature tungsten carbide block thermowells abrasion resistant not tungsten carbide coated thermowell shall be used. Also the terminals of Thermocouple shall not be at the top of Mills itself. The thermocouple wires are to be laid up to JB through SS tubing of required diameter and the head shall be placed nearer to the JB. Compensating cable exposed to atmosphere in the conventional method melts away due to high temperature at the top of Mill.

For measurement of sea water temperature SS with titanium sleeve thermo wells or better, shall be used.

5. Temperature Switch

- | | | | |
|-----|--------------------------|---|--|
| 01. | Type | : | Mercury filled-in |
| 02. | Sensing Element Material | : | Bellow / Bourdon AISI SS-316 |
| 03. | Bulb Material | : | AISI SS-316 |
| 04. | Capillary | : | Stainless steel armored |
| 05. | Movement Material | : | AISI SS-304 |
| 06. | Case material | : | Epoxy coated steel plate or die-cast aluminum alloy with neoprene gasket and clear glass where applicable cover conforming to IP-65. (Explosion proof for NEC Class-1, Division 1 area). |
| 07. | Scale | : | Black lettering on white background |
| 08. | Over range Protection | : | 120 % |
| 09. | Instrument connection | : | Bottom |
| 10. | Switch configuration | : | Two SPDT |
- Lead wires (3+3 Nos.) are to be brought externally to the male connector wherein the female pug connector will be inserted to connect the control room cables for easy removal & re - calibration



- | | | | |
|-----|--------------------|---|---|
| 11. | Switch rating | : | 240V, 5A AC/220V, 0.5A DC |
| 12. | Switch type | : | Snap acting, shock and vibration-proof. |
| 13. | Adjustability | : | a) Internal Set point adjustable over span range
b) Differential adjustable by 10% of span (minimum) |
| 14. | Cable connection | : | 3/4" ET compression gland. |
| 15. | Compensation | : | a) Capillary compensation with invar wire throughout the capillary length.
b) Case compensation |
| 16. | Performance: | | |
| | i) Scale Accuracy | : | ±1.0 % of full scale |
| | ii) Repeatability | : | < 0.5 % of full range |
| | iii) Response time | : | Less than 40 seconds with thermowell |
| 17. | Capillary length | : | 5 meters (minimum) for local mounting/15 meters for local panel mounting. |
| 18. | Nameplate | : | Tag number, service engraved in stainless steel tag plate |
| 19. | Accessories | : | Mounting accessories, 3/4"ET cable gland |

6. Temperature Gauge

- | | | | |
|-----|--------------------------|---|--|
| 01. | Type | : | Mercury filled-in remote mounting system
Capillary armoured / rigid system type (backward entry / bottom entry) |
| 02. | Sensing Element Material | : | Bourdon - AISI-316 SS |
| 03. | Capillary Armoring | : | Stainless steel flexible |
| 04. | Movement Material | : | AISI 304 SS / Direct Bourdon tip connection to pointer spindle |
| 05. | Bulb Diameter and Length | : | As required |
| 06. | Bulb Material | : | AISI 316 |
| 07. | Capillary | : | Stainless Steel |
| 08. | Thermometer | : | M 20 x 1.5 Male adjustable gland on stem to suit associated Thermowell |
| 09. | Case Material | : | Stainless steel bayonet type with clear glass cover conforming to IP-65. |
| 10. | Dial Size | : | 150 mm in general (100 mm for SWAS gauges) |
| 11. | Scale | : | Black lettering on white background in 270 Deg. arc. |
| 12. | Mounting | : | Surface/Panel |
| 13. | Over range Protection | : | 125 % of range or more |
| 14. | Instrument connection | : | Bottom connection for local mounting and back connection for panel mounting. |
| 15. | Range | : | 50% ~ 70% range of operating temperature of application approximately. |
| 16. | Compensation | : | Case compensation |
| 17. | Zero adjuster | : | Micrometer screw adjustable from front. |
| 18. | Window | : | Shatterproof toughened glass. |
| 19. | Performance | : | Accuracy of ± 1 % of full-scale deflection or better. |
| 20. | Enclosure Class | : | IP-65 |
| 21. | Capillary | : | 5 meters (local)/15.0 meters (local panel) - armored stainless steel |
| 22. | Preferred Feature | : | Capillary Compensation |
| 23. | Accessories | : | a) Forged SS 316 thermowell weldable or screwed as per ASME PTC code
b) Installation accessories as required. |
| 24. | Nameplate | : | Tag number, service engraved in stainless steel tag plate |
| 25. | Immersion length | : | Adjustable up to 300 mm including bulb length or as per application |



1.1.2 Temperature Instrumentation

- a) For temperature up to 300°C 3-wire RTD duplex type, PT 100 type shall be used. For temperature beyond 300°C thermocouples shall be used. Thermocouples shall be manufactured in accordance with the ISA Standard MC96.1, Temperature Measurement Thermocouples. All thermocouples shall be Chromel Alumel (Type K) for $300^{\circ}\text{C} \leq T < 850^{\circ}\text{C}$. R or S type for $T > 850^{\circ}\text{C}$.



- b) The Mv signal of thermocouple shall be used as input to the DCS. Cold junction compensation shall be achieved in the DCS
- c) Thermocouples shall have duplex elements and ungrounded measuring junction.
- d) An extension nipple / union / nipple of sufficient length to extend beyond lagging and connection head shall be furnished for each thermocouple assembly. Terminal blocks shall be marked with polarity and connectors shall be resistant to heat, vibration and galling. The cap shall provide a weather tight enclosure and a chain shall be provided to prevent loss of cap. The cap shall be made of cast aluminium.
- e) RTDs of Duplex type furnished by the Supplier shall be of the three-wire type made with 100 ohm platinum resistance elements. They shall be certified to meet the requirements of the International Temperature Scale, calibrated to the IEC-751 standard ($\alpha = 0.00385 \text{ Ohms/Ohm/}^{\circ}\text{C}$). The RTDs shall be contained in an insulated material and a sheath or sleeve of stainless steel SS-316 and shall be so mounted that they can withstand the greatest shocks and vibrations that can be imposed upon them in the system piping without deterioration. Specific information shall be furnished concerning type and accuracy of bridge circuits to be used with the RTDs. RTDs shall be directly connected to DCS without any transmitters
- f) Unless specified otherwise, each temperature element and thermometer shall be provided with a 1" socket weld type, 316 stainless steel tapered thermowell suitable for the requirements of the given application. Temperature element process connection shall be $\frac{1}{2}$ NPTM.
- g) Temperature transmitters of SMART type are to be provided for all temperature measurements that are used in any CLCS. For thermocouple, cold junction compensation shall be implemented within the transmitter.
- h) Thermocouples will be of duplex MI type in ISA, K(chromel-Alumel), Platinum-Rhodium/Platinum with sheath OD 6 mm. RTD will be Duplex, Pt 100 ohm, 3 wire type as per DIN standard 43760 or equivalent. Thermo wells will be ASME PTC 19.3 latest revision with process connection M 33x2 for threaded connection and flanged connection for Air and Gas system & tanks.
- i) Thermowell immersion length will generally be between $\frac{1}{3}$ and $\frac{1}{2}$ the distance to the center of the pipe. Where thermo wells are installed in lines smaller than 4 inches, the piping shall be expanded to 4 inch size to accommodate the thermo well. Thermowell shall be drilled from solid bar stock.
- j) All thermo well in a high velocity line or duct shall have an ASME PTC 19.3 calculation for determination of the wells resonant frequency. Thermo wells that do not meet the acceptance criteria shall be resized or relocated as necessary.
- k) Thermocouple extension wire is to be solid, shielded, twisted pairs.
- l) If intermediate terminal blocks are required in a thermocouple measuring circuit, they need not be the same material as the thermocouple.
- m) Dial thermometers shall be bimetallic, minimum 150mm dial, every angle form, hermetically sealed with external recalibration adjustment, $\frac{1}{4}$ " OD SS stem, $\frac{1}{2}$ " NPT connection and SS case.
- n) Temperature switches shall be actuated by filled bulb-type elements equipped with standard-length armored capillary tubing. All the switches are internally connected and brought to the surface with Amphenol male/female connection.
- o) Temperature gauges shall have $\pm 1\%$ accuracy and overage protection of 125%.



TITLE:
**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

SPECIFIC TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **I**

SUB-SECTION: **ID**

REV. NO. **00** DATE 27.09.2019

SHEET **2** OF **1**

SUB-SECTION – ID

DATASHEET-A



DATA SHEET - A										SPECIFICATION NO.:	PE-TS-435-100-N001
MISCELLANEOUS PUMPS (HORIZONTAL)										REV. NO.: 00	DATE : 27/09/2019
2X660 MW UDANGUDI STPP STG I										SECTION:	ID
Sl. No.	DESCRIPTION	DMCW PUMPS FOR TO & STATION AUXILIARIES	DMCW PUMPS FOR SG AUXILIARIES	AHP & CHP MAKEUP PUMPS	POTABLE WATER PUMPS	SERVICE WATER PUMPS	HVAC MUP PUMPS	APH/ESP WASH PUMPS	HOTWELL MAKE UP PUMPS	DM MAKEUP PUMPS	BOILER FILL PUMPS
1.0	SERVICE										
1.1	Total no. of pumps for Project	6	4	2	2	2	2	2	4	3	4
1.2	No. of working & standby pumps	(2W+1S) per unit	(1W+1S) per unit	1W+1S for Station	1W+1S for Station	1W+1S for Station	1W+1S for Station	1W+1S for Station	2W+2S	2W+1S	2W+2S
1.3	Liquid Handled (ref. water analysis enclosed herein)	pH corrected DM Water	pH corrected DM Water	Desalinated Water	Desalinated Water	Desalinated Water	Desalinated Water	Desalinated Water	DM Water	DM Water	DM Water
1.4	Location (Indoor / Outdoor)	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor	Indoor
1.5	Duty	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Continuous	Intermittent
1.6	No. of pumps working in parallel	2	-	-	-	-	-	-	2	2	2
1.7	Specific gravity	1	1	1	1	1	1	1	1	1	1
1.8	System design pressure (kg/sqcm), g	10	12	10	10	10	10	12	-	-	-
2.0	DESIGN PARAMETERS										
2.1	Design capacity each, M ³ /hr	1500	500	370	50	100	110	750	270	30	150
2.2	Total dynamic head (MWC)	44.5	58	62	72	64	60	86	50	60	130
2.3	Suction Pressure(MWC)	26.5	26.5	Flooded Suction	Flooded Suction	Flooded Suction	Flooded Suction	Flooded Suction	Flooded Suction	Flooded Suction	Flooded Suction
2.4	Design Temperature (°C)	60	60	60	60	60	60	60	60	60	60
2.5	Maximum permissible speed of pump (RPM)	1500	1500	1500	1500	1500	1500	1500	1500	1500	1500
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 51.5 Hz	About 15% more than Total Dynamic Head	About 15% more than Total Dynamic Head	Not to exceed 90 MWC	Not to exceed 92 MWC	Not to exceed 90 MWC	Not to exceed 90 MWC	Not to exceed 112 MWC	-	-	-
2.7	Operating range	-----30-130% of design duty point flow-----									
2.8	Motor rating	Drive Motor shall be rated, at an ambient temp. of 50 Deg C, with a margin of at least 15 % over the shaft requirement at the duty condition 'or' 10 % above the maximum load demand in the operating range whichever is higher including voltage and frequency variation.									
2.9	Permissible tolerance in rated capacity & TDH	no negative tolerance									
2.10	Permissible tolerance in efficiency at rated capacity(%)	no negative tolerance									
2.11	Performance/Design Standard	HIS									
3.0	CONSTRUCTION FEATURES										
3.1	Pump type	Horizontal centrifugal between bearing Pump	Horizontal centrifugal between bearing Pump	Horizontal centrifugal Pump	Horizontal centrifugal Pump	Horizontal centrifugal Pump	Horizontal centrifugal Pump	Horizontal centrifugal between bearing Pump	Horizontal centrifugal Pump	Horizontal centrifugal Pump	Horizontal centrifugal between bearing Pump
3.2	Impeller type	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed	Closed
3.3	Casing type	Horizontal split type	Horizontal split type	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	To be decided by Bidder	Horizontal split type	To be decided by Bidder	To be decided by Bidder	Axial split type / radially split type / Multistage Type
3.4	Coupling type	Flexible Spacer type	Flexible Spacer type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type	Flexible type
3.5	Sealing arrangement	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning	Gland packing	Gland packing	Gland packing	Gland packing	Gland packing	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning	Gland packing initially & Mechanical seal finally after commissioning
3.6	Type of Lubrication	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid	Grease /Self-liquid
3.7	Pump characteristics	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable	Non Overloading type & stable
3.8	Drain Plugs, vent with valve, lifting lugs, priming connection	YES									
4.0	MATERIALS OF CONSTRUCTION										
4.1	Casing	ASTM-A-351 CF8M	ASTM-A-351 CF8M	2% Ni Cl IS: 210 Gr 260	ASTM-A-351 CF8M	2% Ni Cl IS: 210 Gr 260	2% Ni Cl IS: 210 Gr 260	2% Ni Cl IS: 210 Gr 260	ASTM A CF 8M	ASTM A CF 8M	ASTM A CF 8M
4.2	Impeller	ASTM-A-351 CF8M	ASTM-A-351 CF8M	SS 304	ASTM-A-351 CF8M	SS 304	SS 304	SS 304	ASTM A CF 8M	ASTM A CF 8M	ASTM A CF 8M
4.3	Shaft	SS 316	SS 316	SS 304	SS 304	SS 304	SS 304	SS 304	SS 316	SS 316	SS 316
4.4	Shaft Sleeves	SS-410	SS-410	SS 304	SS 304	SS 304	SS 304	SS 304	SS-410	SS-410	SS-410
4.5	Impeller Wearing rings (If applicable)	SS 316	SS 316	SS 304	SS 304	SS 304	SS 304	SS 304	SS 316	SS 316	SS 316
4.6	Bolts & Nuts / FASTENERS	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304
4.7	Gland / Seal Cover	SS 316	SS 316	SS 304	SS 304	SS 304	SS 304	SS 304	SS 316	SS 316	SS 316
4.8	Lantern Ring	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer	As per Manufacturer
4.9	Mech. seal	As per Manufacturer standard	As per Manufacturer standard	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE	NOT APPLICABLE	As per Manufacturer standard	As per Manufacturer standard	As per Manufacturer standard
4.10	Gland Packing	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)	Braided Impregnated Teflon (Asbestos Free)
4.11	Base Plate	MS fabricated IS-2062 (min. thk.-10 mm) Epoxy Coated									
4.12	Stuffing Box	ASTM-A-351 CF8M	ASTM-A-351 CF8M	2% Ni Cl IS: 210 Gr 260	ASTM-A-351 CF8M	2% Ni Cl IS: 210 Gr 260	2% Ni Cl IS: 210 Gr 260	2% Ni Cl IS: 210 Gr 260	ASTM A CF 8M	ASTM A CF 8M	ASTM A CF 8M
4.13	Casing Wearing rings (If applicable)	SS 316	SS 316	SS 304	SS 304	SS 304	SS 304	SS 304	SS 316	SS 316	SS 316
4.14	Coupling	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304	SS 304
4.15	Connecting Pipe material (for deciding counterflange material)	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589 / IS1239	ASTM A312 TP 316L	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589 / IS1239	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589 / IS1239	Carbon Steel as per IS:2062, Plates rolled & welded as per IS 3589 / IS1239	ASTM A312 TP 316L	ASTM A312 TP 316L	ASTM A312 TP 316L
5.0	MANDATORY SPARES FOR PUMP-MOTOR SET										
5.1	Spares for Pumps										
5.1.1	IMPELLER WEARING RINGS	1 SET of each type & size	1 SET of each type & size	NA	NA	NA	NA	NA	NA	NA	NA
5.1.2	PUMP BEARINGS	1 SET of each type & size	1 SET of each type & size	2 SETS of each type & size	2 SETS of each type & size	2 SETS of each type & size	2 SETS of each type & size	2 SETS of each type & size	2 SETS of each type & size	2 SETS of each type & size	2 SETS of each type & size
5.1.3	PUMP SHAFT	1 SET of each type & size	1 SET of each type & size	NA	NA	NA	NA	NA	NA	NA	NA
5.1.4	MECHANICAL SEAL	1 SET of each type & size	1 SET of each type & size	NA	NA	NA	NA	NA	NA	NA	NA
5.1.5	SHAFT SLEEVES	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size
5.1.6	NUT & BOLTS / FASTENERS	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump	1 set reqd for assembling one pump
5.1.7	THRUST PAD	NA	NA	1 Set of each type & size	1 Set of each type & size	1 Set of each type & size	1 Set of each type & size	1 Set of each type & size	1 Set of each type & size	1 Set of each type & size	1 Set of each type & size
5.2	Spares for Pump Motors										
5.2.1	Driving end bearing	NA	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	NA	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size
5.2.2	Non driving end bearing	NA	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size	NA	1 SET of each type & size	1 SET of each type & size	1 SET of each type & size
5.2.3	Terminal block for motors up to 30 Kw each rating	NA	10 Nos.	10 Nos.	10 Nos.	10 Nos.	10 Nos.	NA	10 Nos.	10 Nos.	10 Nos.
5.2.4	Terminal block for motors above 30 Kw each rating	NA	5 Nos.	5 Nos.	5 Nos.	5 Nos.	5 Nos.	NA	5 Nos.	5 Nos.	5 Nos.
5.2.5	Motors of each type & rating	NA	1 No.	1 No.	1 No.	1 No.	1 No.	NA	1 No.	1 No.	1 No.
	Mandatory Spare Note: 1. Wherever quantity has been specified as percentage (%), it shall mean percentage (%) of the total population of the item in the station (project), unless specified otherwise and the fraction will be rounded off to the next higher whole number. 2. Wherever the quantities have been indicated for each type, size, thickness, material, radius, range etc. these shall cover all the items supplied and installed and the break up for these shall be furnished in the bid. 3. In case spares indicated in the list are not applicable to the particular design offered by the bidder, the bidder should offer spares applicable to offered design with quantities generally in line with the approach followed as above. 4. Each spare shall be clearly marked and labeled on the outside of the packing with its description. When more than one spare part is packed in single case, a general description of the contents shall be shown on the outside of such case and a detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purpose of identification. 5. 1 Set means required for assembling of One(1) Pump, unless specified otherwise.										
6.0	BID EVALUATION RATE										
6.1	Bid evaluation rate	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW	Rs.3.56 Lacs/KW
6.2	Maximum permissible efficiency for Bid evaluation										
6.2.1	Pump Efficiency	86	84	75	68	69	70	80	77	65	75
6.2.2	Motor Efficiency	95	95	94.9	91.8	93.3	93.3	95	94.5	90.5	94.7
Notes :											
1	Material of construction for other components not specified above shall be simiilarly selected in line with the above for the duty intended and subject to approval.										
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.										
3	For all HT motor driven pumps (wherever applicable), bidder shall provide flat surface with dimensions 60 MM x60 MM on bearing Housing for mounting vibration measuring block and a key slots of dimensions 30MM (L) X 15 MM (W) X 3 MM (D) on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL for Phase Marker.										
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.										



TECHNICAL SPECIFICATIONS

Specification No. : PE-TS-435-100-N001, Rev0

MISCELLANEOUS PUMPS

VOLUME:	IIB	SECTION:	D1
REV. NO.	0	DATE:	27.09.2019

A. DM WATER ANALYSIS:

Conductivity:	Less than 0.1 microS/cm
Total silica:	Less than 0.02 ppm
pH:	Less than 7

A. PASSIVATED DM WATER ANALYSIS:

Conductivity:	Less than 0.1 microS/cm
Total silica:	Less than 0.02 ppm
pH:	8.5 to 9.5

C. DESALINATED WATER

pH:	6.5 to 8.5
TDS:	<= 600 mg/l
Quality will confirm to WHO/ IS10500 stds.	



TITLE: TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS SPECIFIC TECHNICAL REQUIREMENTS	SPEC. NO.: PE-TS-435-100-N001	
	SECTION: II	
	SUB-SECTION: IIA	
	REV. NO. 00	DATE 27.09.2019
	SHEET 1	OF 1

SUB-SECTION - IIA

STANDARD TECHNICAL SPECIFICATION (MECHANICAL)

- **STANDARD TECHNICAL SPECIFICATION FOR MISC. PUMPS (HORIZONTAL) INCLUDING DATASHEET-C**
- **STANDARD QUALITY PLANS**

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 1 of 16	

1.00.00	GENERAL INFORMATION
1.01.0	The general guidelines as illustrated in the subsequent clauses of this section shall be applicable for horizontal centrifugal pumps to be procured under the scope of this package.
1.02.0	It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.
1.03.0	The omission of specific reference to any component/accessory necessary for the proper performance of Miscellaneous Pumps and drives shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of equipment at quoted prices.
1.04.0	BHEL's / Customer's representative shall be given full access to the shop in which the equipment are being manufactured or tested and all test records shall be made available to him.
1.05.0	The equipment covered under this specification shall not be dispatched unless the same have been finally inspected, accepted and shipping release issued by BHEL/Customer.
2.00.00	CODES AND STANDARDS
2.01.00	In addition to the requirements spelt out elsewhere in the specification, the equipment to be provided under this section shall specifically conform to the following codes, standards, specifications and regulations, as applicable, including all the latest amendments subsequent to the year of publication as mentioned below.
2.01.01	IS-1520/1980: Horizontal Centrifugal pumps for clear, cold and fresh water.
2.01.02	IS-5120/1977: Technical requirements for Rotodynamic special Purpose pumps.
2.01.03	IS-5639/1970: Pumps for handling chemicals & corrosive liquids.
2.01.04	IS-5659/1970: Pumps for process water.
2.01.05	IS-6536/1972: Pumps for handling volatile liquids.
2.01.06	IS-9137/1978: Code for acceptance tests for centrifugal, mixed flow and axial flow pumps- Class 'C'.

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS		SPECIFICATION NO. PES-179-06	
			VOLUME:	
			SECTION: IIA	
			REV. NO. 04	DATE: 01/07/2016
			SHEET 2 Of 16	
2.01.07	ISO 3555/1977: BS 5316/1977 Part 2	Acceptance test for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.		
2.01.08	ISO 2548/1973: BS 5316/1976 Part 1	- Do - Class 'C' tests.		
2.01.09	API-610/1989:	Centrifugal pumps for general refinery services.		
2.01.10	HIS	Hydraulic Institute Standards, USA		
2.01.11	PTC 8.2/1965:	Power Test Codes - Centrifugal pumps.		
2.01.12	ASTM-1-165-55	Standard Methods for Liquid Penetration Inspection.		
2.02.00	In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding on the bidder.			
3.00.00	SCOPE OF SUPPLY & SERVICES:			
3.01.00	The miscellaneous pumps and drives scope shall be as specified in Data Sheet A /Section IA.			
3.02.00	The Capacity, Head, Materials of construction and other particulars of pumps are detailed in Data Sheet A of the specification.			
3.03.00	Accessories:			
	All the pumps under this specification shall be complete with following standard/special accessories.			
3.03.01	Standard accessories:			
	a)	LT Electric drives/motors (as applicable) with cable gland and lugs at motor end. (The bare HT drive motors and LT motors not in bidder's scope of supply, wherever required supplied as free issue by BHEL refer Cl. 5.08.00).		
	b)	Pump motor coupling along with coupling guard.		
	c)	Common base plate for pumps and motor.		
	d)	Self contained lubrication system along with all internal piping, valves, fittings, specialties etc. as required.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 3 of 16	
	e)	Counter flanges for suction/ discharge nozzles along with fixing nuts, bolts and gaskets.	
	f)	Anchor bolts, nuts, seating steel works, shims etc. as necessary for mounting the pump-motor unit on civil foundations.	
	g)	Suitable vent (with valves)/ lifting/ handling attachments for the pump/ motor/ accessories.	
	h)	Suitable drain connections with isolating valves as applicable.	
	i)	Supply of first fill of lubricants with topping requirements for one year of operation after commissioning and handing over of equipment.	
	j)	Set of “Special” Tools & Tackles for Pumps and motors, if any.	
	k)	Erection and commissioning spares, “on as required” basis.	
	l)	Bidder shall provide various drawings, data, calculations, test reports/ certificates, operation and maintenance manuals, As-built drawings, etc. as specified and as necessary.	
	m)	Mandatory spares as specified in respective Data Sheet-A of this section.	
3.04.00	Services included in Bidder’s Scope:		
3.04.01	The pumps shall be guaranteed to meet the performance requirements specified vide Data Sheet -A and also for trouble free operation after commissioning. Schedule of performance guarantees (Section-IIIA) duly filled and signed shall be furnished with the bid.		
3.04.02	Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. Shaft sleeve and any other item required for satisfactory operation of Mechanical seal after replacement at site shall be provided by the pump supplier without any cost implication to BHEL.		
3.04.03	The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning.		
3.04.04	After commissioning of pumps at site, site performance test for Noise, vibration and parallel running of pumps of all pumps for each unit/project shall be conducted by pump vendor at project site to ensure that the pumps meet the specified requirements. Pump vendor shall bring necessary instruments for conductance of site performance test.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 4 Of 16	
If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, without any commercial implication to BHEL Note: Applicability of conducting PG test at site by vendor as per above clause shall be applicable if indicated in Section-1A. If conductance of PG test of pumps at site for Noise, vibration and parallel running of pumps of all pumps for each unit/project is not in bidders scope and same is conducted by BHEL/ customer. In such cases also, if the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, without any commercial implication to BHEL.			
3.04.05	Performance Guarantees for pumps shall stand valid till the satisfactory completion of performance testing by BHEL and its acceptance by purchaser / customer.		
3.05.00	Works excluded from Bidder's Scope:		
	a) All HT motors and those LT Motors which are specifically excluded. b) Civil foundation c) Suction/ discharge pipe works d) MCC/ Switchgear/Power supply e) Power and Control Cables, unless specifically specified in Electrical/ Systems portion of the specification. f) Erection of equipments.		
4.00.00	BID EVALUATION CRITERIA & LIQUIDATED DAMAGES FOR SHORTFALL:		
4.01.00	The bids received shall be evaluated for power consumption at inlet to the motors, in respect of pumps specified in Data Sheet-A (working pump only viz. not the standby), for the purpose of price comparisons as briefed below: The bid evaluation shall be done at the rate as specified in Data Sheet A per one (1) KW Power consumption, per working pump as follows. KW = Q X H X S P x M x 367.2 Where Q = Rated capacity M³/hr H = Rated TDH, MWC P = Pump Efficiency M = Motor Efficiency. S = Specific Gravity of fluid handled		
4.02.00	The efficiencies for pumps and motors for arriving at benchmark power for Bid Evaluation shall be as indicated in Data Sheet A for various pumps.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 5 of 16	
No advantage shall be given to the bidder for Aux. Power quoted lower than the Bench mark values calculated with KW calculation formula at Cl. 4.01.00 above, <i>considering the bid evaluation efficiencies for pump and motor as indicated in Data Sheet-A</i>. However the bids shall be evaluated as above if the Aux. Power quoted are higher than Bench mark values. NOTE: 1. Efficiencies for HT motors and LT motors not in bidder's scope, for bid evaluation purpose shall be taken based on the maximum value as furnished in Data Sheet A. 2. During contract stage the Guaranteed power consumption of Pumps with BHEL supplied drives (HT/LT) for successful bidder shall be reworked by BHEL as below: Revised guarantee power consumption shall be as per KW calculation formula at Cl. 4.01.00 above, where P = pump efficiency guaranteed by bidder and M = motor efficiency as per approved datasheet of the supplied HT/LT motor. 4.03.00 Liquidated damages for shortfall in Guaranteed KW The above guaranteed power consumption shall be demonstrated by the successful bidder during performance testing at works/ site. For pumps with BHEL supplied drives, the power consumption shall be compared with the reworked guarantee power consumption, defined as per note no. 2 of Cl. 4.02.00 above for the purpose of shortfall. The liquated damages @ twice the bid evaluation rate as above per KW per working pump shall be levied in the event of failure of bidder to demonstrate the guaranteed power consumption. 5.00.00 TECHNICAL REQUIREMENTS: 5.01.00 The pumps shall meet the technical requirements of Section-I as well as Section-II. In the event of any contradiction of Section-II with Section-I, the Section-I will prevail. 5.02.00 The pumps shall be Electric motor driven. 5.03.00 The Pumps shall conform to HIS. It is bare minimum requirement, however, any other equivalent or stringent standard is also acceptable, if, all the requirements of HIS are also met. 5.04.00 The horizontal pumps shall be Horizontal split casing type with speeds not exceeding 1500 RPM or as indicated in Data Sheet-A. 5.05.00 No negative tolerance shall be permitted in rated capacity & TDH. 5.06.00 No negative tolerance shall be permitted in efficiency at rated capacity.			

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 6 Of 16	
5.07.00	The shut off head of pumps shall be more than pump rated TDH and percentage variation may vary depending on the specific speed of the pump as under: i. 10-15% for pumps of specific speed up to 1000 US units, ii. 15-20% for pumps of specific speed in the range of 1000 to 2000 US units, iii. 20-40% for pumps of specific speed in the range of 2000 to 4000 US units, iv. Above 50% for pumps of specific speed in the range of 4000 to 7000 US units.		
5.08.00	All HT motors and those LT motors which are not in bidder's scope of supply: bare motors only, shall be supplied as free issue by BHEL through BHEL, based on ratings and TS (Torque - Speed) curve selected and furnished by the bidders along with their un-priced bid. The responsibility for satisfactory operation for combined performance of pumps & motors shall rest with the bidder only as if, the drive motors also have been supplied by the bidder. Couplings, base plate, foundation bolts, any other fittings, etc. as required shall be supplied by the bidders only. BHEL shall supply one number of each type of drive motors (where drive motor is not in bidder's scope of supply) for shop testing of pumps with job motors. All other motors shall be dispatched by BHEL directly to project sites.		
5.09.00	For all HT motor driven pumps, BHEL has envisaged vibration-monitoring system in their own scope. The bidder shall make provisions for mounting following on the pump/ pump shaft: • Purchaser's probes in both DE/NDE bearings of pumps • Key slots on pump shaft and flat surface on bearing housing for mounting vibration measuring block with dimensions as specified in Data Sheet A. • Other components as finalized during detailing. • For mounting of above on the HT motors & specifically excluded LT motors, same shall be taken care by BHEL.		
5.10.00	The pumps shall be capable of developing the required total head at rated capacity for continuous operation. The pumps shall operate satisfactorily at any point on the Q-H characteristic curve over a range of 0% to 130% capacity and shall be suitable for continuous operation between 30% to 130% capacity.		
5.11.00	Selection of the pumps shall be such that the design point shall be met even with negative manufacturing tolerance.		
5.12.00	The total head capacity curve shall be continuously rising towards the shut off, the pumps shall preferably be non-overloading type and stable.		
5.13.00	The pumps shall be capable of running over the entire range of NPSH conditions required without any noise, vibration or cavitations. The prevailing suction pressures for various pumps are indicated in Data Sheet-A for suitable mechanical design of pumps.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 7 of 16	
5.14.00	The pumps shall be of stiff shaft design. The minimum internal clearances should be sufficiently more than the maximum static deflection of the shaft. Shaft size selected must take into consideration the critical speed as specified in API-610.		
5.15.00	Pumps and motors shall run smooth without undue noise and vibration. The vibration shall be within vibration norms for testing as per American National Standard for 'Rotodynamics Pump' for Vibration Measurement and allowable values, Doc. ANSI/ HIS 9.6.4-2009. The applicable vibration limits for each pump, shall be indicated in the Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO. The noise level shall be limited to 85 dB at distance of 1.0M.		
5.16.00	Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.		
5.17.00	After installation, the guaranteed values of noise, vibration and parallel operation of pumps shall be tested and verified. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.		
5.18.00	High reliability of the pumps is an essential requirement and therefore it gets weightage over its efficiency. It is therefore essential that the bidder choose a standard proven model from the range of pumps manufactured.		
5.19.00	The offered pumps shall be of proven design meeting the experience-qualifying requirement of their operation at two sites for a minimum period of one year or as specified in technical PQR. Any deviation to this criterion shall be suitably highlighted in the deviations schedule.		
5.20.00	The bearings shall be self-water lubricated, no external water supply shall be available. The cooling/ lubrication water for bearings, etc. shall be tapped from the pump discharge and supplied thru' bidder's integral pipe work. If water handled by pump is dirty/ not suitable for lubrication/ cooling, the bidder shall provide requisite strainer/ filters, tanks, motorized valves, etc. after the tap off for the required service, the arrangement provided shall be subject to Purchaser's approval.		
6.00.00	MANDATORY SPARES:		
6.01.00	Bidder to provide the Mandatory spares listed vide Data Sheet-A. Unit price of mandatory spares shall be furnished in price Schedule.		
6.02.00	Bidder shall include the cost of Mandatory Spares, unless specified otherwise in Sec-IA of the specification or NIT.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 8 of 16	
7.00.00	OTHER REQUIREMENTS:		
7.01.00	The quality of water handled by various pumps shall be as per Data Sheet-A.		
7.02.00	The materials of construction for various components specified are the minimum requirements and materials of construction for other components not specified shall be similarly selected by the bidder for the intended duty.		
7.03.00	The makes of various bought out items of bidder (i.e. motor, bearings, mechanical seal etc.) shall be subject to purchaser’s approval in the event of order.		
7.04.00	Painting for Pumps		
	a) The surface of SS, Gun metal, brass, bronze and non-metallic component shall not be applied with any painting.		
	b) The Steel surface to be applied with painting shall be thoroughly cleaned before applying painting by brushing, shop blasting etc. as per the agreed procedure.		
	c) For all the steel surfaces inside the (indoor installation) building, a coat of red oxide primes of min. thickness DFT of 50 microns followed up with under coat of Synthetic Enamel paint of min. thickness DFT of 50 microns shall be applied. The top coat shall consist of two coats each of min. thickness DFT of 50 microns of synthetic enamel paint and thus total DFT shall be min. 200 microns.		
	d) For all the steel surfaces exposed to (outdoor installation) atmosphere, a coat of chlorinated rubber based zinc phosphate primer of min. thickness DFT of 50 microns followed up with under coat of chlorinated rubber paint of min. thickness DFT of 50 microns shall be applied. Then, intermediate coat consisting of one coat of chlorinated rubber based paint pigmented with Titanium di-oxide with min. thickness DFT of 50 microns and top coat shall consist of two coats each of min. thickness DFT of 50 microns of chlorinated rubber paint shall be provided. Total DFT of paint system shall be min. 200 microns.		
7.05.00	It is mandatory for the bidder to submit along with the bid, the deviations if any – whether major or minor in the schedule of deviations only. In the absence of deviations listed in the “Schedule of deviations, the offer shall be deemed to be full conformity with the specification, “notwithstanding” anything else stated elsewhere in bidder’s offer. The implied/indirect deviations shall not be binding on the purchaser.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 9 Of 16	
8.00.00	PERFORMANCE REQUIREMENTS		
8.01.00	Performance requirements for the pumps shall be as guided in Data sheet - A enclosed with Section-I.		
8.02.00	Pump(s) shall preferably be designed to have the best efficiency at flow within ± 10% of the specified duty point flow. The pumps shall be suitable for continuous operation at any point within the “Range of Operation” as stipulated in the Data Sheet - A attached with Section-I.		
8.03.00	Pump(s) shall preferably have a continuously rising head-capacity characteristics from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation. Under all circumstances, the ‘range of operation’ of the pumps shall exclude any unstable operating zone of the head-capacity curve.		
8.04.00	Wherever specified in the Data Sheet - A, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.		
8.05.00	The pump set along with drive motor shall run smooth without undue noise and vibration. Acceptable vibration limits shall be guided by the HIS of USA. Refer clause 5.15.00 above for permissible limits.		
9.00.00	DESIGN AND CONSTRUCTION		
9.01.00	Pump Casing		
9.01.01	Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves. It shall be provided with a connection for suction and discharge pressure gauge as standard feature.		
9.01.02	Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.		
9.01.03	In case where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.		
9.02.00	Impeller		
9.02.01	The Impeller assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 10 Of 16	
9.03.00	Wearing Rings		
9.03.01	Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.		
9.04.00	Shaft		
9.04.01	Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall be at least 30% higher than the rated speed.		
9.05.00	Shaft Sleeves		
9.05.01	Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past Shaft and shaft sleeve and that past the seals/glands.		
9.05.02	Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft sleeve assembly should ensure concentric rotation.		
9.06.00	Bearings		
9.06.01	Bearings shall be easily accessible without disturbing the pump assembly. A drain shall be provided at the bottom of each bearing housing.		
9.06.02	Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.		
9.06.03	In case of sleeve type radial, axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.		
9.06.04	Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation. Life of the bearings shall be guided by the design standard of the pump. Antifriction bearings of standard type, if provided, shall be selected for a minimum life 20,000 hrs. of continuous operation at maximum axial and radial loads at rated speed. Thrust bearing shall be capable of running continuously at maximum load.		
9.06.05	The bearing shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete with all accessories like pump, filters, piping, fittings, valves, interlocking and supervising instruments etc. as necessary. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.		
9.06.06	Bearing housing for HT motor driven pumps shall have provision for mounting temperature measuring device.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 11 Of 16	

9.06.07	Bearings of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.
9.07.00	Stuffing Boxes
9.07.01	Stuffing box design shall permit replacement of packing without removing any part other than the gland.
9.07.02	Stuffing boxes shall be sealed/cooled by the fluid being pumped/external clear water, as specified in the Annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the Annexure shall be included in the scope of supply.
9.08.00	Mechanical Seals
9.08.01	Mechanical seals (cartridge type) shall be provided if specified in the Data Sheet-A of this section. The pump supplier shall co-ordinate with the seal maker in establishing the direct circulation rate for maintaining a stable film at the seal in the chamber. The seal piping system shall form an integral part of the pump assembly.
9.08.02	When handling liquids near boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.
9.08.03	For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.
9.08.04	Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. The special tools (if any) required for above shall be arranged by bidder.
9.08.05	Mechanical seals of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.
9.09.00	Drive Unit
9.09.01	The pumps shall be driven by electric motor directly coupled as specified in the Data Sheet-A of this section. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit.
9.09.02	Unless otherwise specified in Data Sheet-A of this section, drive unit power rating shall be the maximum of the following requirements.

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 12 Of 16	
a) 16% margin over the pump shaft input power at the rated duty point. b) 10% margin over the maximum pump shaft input power required within the ‘Range of Operation’. c) Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.			
9.10.00	Coupling for pump & Motor Shaft		
9.10.01	The pump and motor shafts shall be connected with adequately sized flexible coupling of proven design with spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guard shall be provided.		
9.10.02	No. of coupling holes for joining coupling hubs shall be even in number and preferably in multiples of four.		
10.00.00	INSPECTION AND TESTING		
10.01.00	The Quality Plans enclosed in the specification are for bidder’s guidance only. The bidder shall comply with these and other minimum requirements specified in the specification and shall furnish his own quality plan in the event of order based on the guidance given as above, for approval by BHEL/Customer.		
10.02.00	The Bidder shall carry out the following specific tests inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.		
a) Identification and Testing i) All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standard and test certificates shall be made available to the Owner. ii) 100% PMI (Process Material Identification) inspection for material grade of pump casing, shaft and impeller shall be done by vendor & certification shall be submitted for review of BHEL. Further BHEL reserves the right to conduct random & independent PMI inspection on pump casing, shaft and impeller to ascertain the grade of material during inspection at vendor works. iii) Tests for each pump included under this section shall include but not be limited to the following:			



TITLE:

**STANDARD TECHNICAL SPECIFICATION
HORIZONTAL PUMPS**

SPECIFICATION NO. PES-179-06

VOLUME:

SECTION: IIA

REV. NO. 04

DATE: 01/07/2016

SHEET 13 of 16

- The entire surface of the impeller / casing / diffuser castings shall be subjected to Dye Penetration Test as per ASTM Specification no.:1-165-65.
- Shaft coupling & other active components shall be subjected to Dye Penetration and Ultrasonic Tests.
- Wearing rings, shaft sleeves shall be subjected to Dye Penetration Test.
- Fabricated components of pumps shall be subjected to Dye Penetration test on weld.
- Verification of material, witnessing of pouring, casting and inspection of finished fabricated/castings.
- Inspection of finished castings for impeller and verification of materials.
- Inspection of pump shaft and verification of material.
- Witnessing of NDT/review of NDT reports.
- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940 to grade 6.3 or better.
- Complete Inspection of assembled pump.

b) Hydraulic Testing

The pump casing shall be hydrostatically tested at maximum of the following:

- i. 2 times the TDH (Total Dynamic Head) at rated capacity (or)
- ii. 1.5 times the shut-off pressure (or)
- iii. System Design pressure indicated in Data Sheet-A of Section-I.

The HT pressure shall be maintained for a period of not less than 30 minutes. During testing there should not be any pressure drop & leakage.

c) Performance Test at Shop

- i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard.
- ii) Performance tests are to be conducted to cover the entire range of operation of the pumps at rated speed. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 14 Of 16	
head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals. iii) Tests shall be conducted with actual drive motors being furnished. iv) NPSH tests are to be conducted for each type at 3% head drop conditions, if specified in the pump approved QP. v) All rotating components of the pumps shall be subjected to static and dynamic balancing tests. The assembled rotor will be subjected to dynamic balancing tests. vi) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment. 10.03.00 Inspection of Mandatory/ Recommended spares shall be in line with approved QP for main supply. 11.00.00 DRAWINGS/ DOCUMENTS DISTRIBUTION SCHEDULE 11.01.00 After award of LOI, the successful bidder shall submit drawings/documents as per Data Sheet-C. 11.02.00 The no. of drawings/documents to be submitted shall be as per Data Sheet-C. 12.00.00 The various Sections-I's & II's along with Data Sheets attached in this specification together with the specification for Miscellaneous Pumps shall be complied with by the bidders. 13.00.00 Bidder to submit all drawing/ documents in soft as well as hard copy in the event of order as per schedule indicated in section-IA. Within one (1) week of receipt of BHEL comments a technical representative from Bidder's works shall come for meeting with BHEL along with revised documents to resolve all issues and incorporate all comments in the soft copy here only for further submission to customer. Further on receipt of customer's comments on the documents a technical representative from Bidder's works shall come for meeting with Customer to resolve all issues and incorporate all comments in the soft copy here only and further resubmission of same to Customer. The representative shall be available here till Category-I approval of all the drawings and documents.			

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 15 of 16	
14.00.00	Guarantee for all pumps shall at least remain valid for 18 months from the Unit commissioning date or as specified in NIT.		
15.00.00	The following documents only shall be furnished by the bidder with his offer: a) Compliance certificate duly signed and stamped (enclosed at Section-IIIB). b) GA drawings of pumps and motors with following: (shall be only for reference purpose, same shall not be reviewed/commented by purchaser at this stage and shall be subject to approval only during contract). • Civil static & dynamic loads. • Foundation details. c) Guarantee Schedule duly signed and stamped (enclosed at Section-IIIA). d) Technical deviation schedule (if reqd.) (enclosed at Section-IIIC). e) Data for drive Motor (HT/LT- which is not in bidder's scope of supply - as applicable): Load torque speed curves of the pumps, selected motor rating, rpm, GD² of driven equipment. f) Unpriced copy of the price bid shall be furnished along with the technical bid. Apart from above no other Drgs./Docs./Data sheets etc. are required to be submitted at bid stage and even if furnished shall not be taken cognizance of. In case of any deviation from this technical specification, the same shall be indicated in the schedule of deviations as per Section-IIIC or NIT. In the absence of duly filled schedules it will be assumed that the bid strictly conforms to the specification.		

	TITLE: STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS	SPECIFICATION NO. PES-179-06	
		VOLUME:	
		SECTION: IIA	
		REV. NO. 04	DATE: 01/07/2016
		SHEET 16 Of 16	

DATA SHEET – C

Drawings / documents distribution schedule to be followed by successful Bidder:

- 1.0** Drawings/documents submission schedule, shall be as per Section-IA.
The successful bidder shall submit at least following drawings/ documents:
 - 1.1** Fully dimensioned outline general arrangement drawings of the pump and motor assembly. This drawing should include foundation base plate/sole plate details as applicable, civil foundation, anchor bolt details, loading data (Static and Dynamic), points of connections of external piping, cables and mounting of devices furnished by the supplier and details for Gap between Coupling Shafts, Float & details for axial/radial tolerance allowed etc. which are required for erecting agency during erection of pump.
 - 1.2** Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction with standard applicable codes.
 - 1.3** Technical datasheet as per Datasheet-B (Section-IIID) including characteristic curves of pumps showing the following:
 - a) Flow Vs Head
 - b) Flow Vs Power
 - c) Flow Vs Efficiency
 - d) Flow Vs NPSHR/ minimum submergence
 - 1.4** QAP for pump and QAP for motors (if applicable).
 - 1.5** GA, Datasheet, Curves etc. for drive motor (as applicable).
 - 1.6** Operation and maintenance manual.
 - 1.7** Lubrication arrangement drawings for external lubrication (if applicable).
 - 1.8** PG test procedure as per clause 3.04.04 (if applicable).
 - 1.9** Motor type test document (if applicable).
 - 2.0** Within the stipulated time period as per vendor's drawings/ documents schedule as per NIT, the O&M Manual comprising of minimum following shall be submitted:
 - a) Drawings of components & details as deemed necessary.
 - b) Instruction manual for erection, operation & maintenance.
 - c) Storage instruction.
 - 3.0** Before dispatch of the equipment the bidder shall furnish the following.
 - a) Material test certificates.
 - b) Shop test reports & certificates.
 - c) Fulfilment of packing instructions as indicated in Section-IA of this specification.
 - 4.0** Distribution of drawings / documents for all projects:

The no. of copies of drawing/ documents to be submitted by the successful bidder, after the award of the contract shall be as per Section-IA or as specified in NIT.



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS

CUSTOMER

PROJECT TITLE

BIDDER/VENDOR

QUALITY PLAN NUMBER

PE-QP-999-100-N004 (For Hor. Pumps)
 PE-QP-999-100-N004 (For Ver. Pumps)

SHEET 1 OF 6

SYSTEM

ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)

S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1	MATERIALS CONTROL											
1.1	CASINGS (INCLUDING BOWLS,DIFFUSERS, STAGE BODIES, DISCH HEAD (IF CAST)), ETC. - (AS APPLICABLE) AND IMPELLER	MECHANICAL AND CHEMICAL PROPS	CR	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.		2,1	
1.2	STUFFING BOX, SUCTION BELL, WEARING RINGS,NECK RINGS, SHAFT SLEEVES	DO-	MA	MECHANICAL AND CHEM. ANALYSIS	ONE/HEAT/BATCH	APPROVED CS DRAWING/DATA	RELEVANT MATERIAL SPECN.	LAB REPORT/ MTC	3/2.		2,1	
		HARDNESS DIFFERENCE BETWEEN CASING / IMPELLER AND WEARING RING	MA	LAB. TEST	100%	APPROVED CS DRAWING/ DATA SHEET	50 BHN MIN.	LAB. REPORT	3/2.		2,1	
1.3	BARS/FORGINGS FOR SHAFTS, LINE SHAFTS	1.PHYSICAL & CHEMICAL PROPS	CR	1.MECHANICAL & CHEMICAL ANALYSIS.	1/CAST OR 1/BARS	APPROVED CS DRAWING/DATA SHEET	RELEVANT MATERIAL SPECN.	MILL T.C. OR LAB.REPORT	3/2.		2,1	CORRELATION REQUIRED, IDENTIFICATION AS PER TC
		2.DIMENSIONS	CR	2.MEASURMENT	100%	MFR. DRAWING	MFR. DRAWING	INSP.REPORT	3/2.		2,1	
		3.INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS.	CR	3.ULTRA SONIC TEST	100%	ASTMA388 BACK WALL ECHO 100%	DEFECT ECHO MAX 20% OF B.W.E. LOSS OF BACK WALL ECHO 20% MAX	NDT CERTIFICATE	3/2.		2,1	
1.4	STRESS RELIEVING/ HEAT TREATMENT OF CASTING OF ALL ABOVE (IF APPLICABLE) / SOLUTION ANNEALING OF SS CASTING	1. VARIFICATION OF HT CHART	MA	VERIFICATION OF SR/HT CHART	ALL BATCHES	RELEVANT MATERIAL SPECN.	DO-	CORRELATED SR/HT.CHARTS	3/2.		2,1	
		2. IGC TEST FOR SS CASTING	MA	LAB. TEST	ONE SAMPLE/ HT BATCH	ASTM A 262	ASTM A 262 Gr A	LAB. REPORT	3/2.		2,1	
1.5	SHAFT ENCLOSING TUBES, COLUMN PIPES & DISCHARGE ELBOW	1. MECHANICAL & CHEMICAL PROPS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/BATCH 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./MAFG./ APPROVED DOCS	MFR T.C OR LAB. REPORT	3/2.		2,1	
BHEL				PARTICULARS			BIDDER / VENDOR					
				NAME								
				SIGNATURE								
				DATE						BIDDER/VENDOR SEAL		

NAME
SIGN.
DATE

Prepared By
AJAY JAIN
Ajay
23-07-2012

Reviewed By
ASHWANI KHANNA
Ashwani
23-07-2012

Approved By
I. J. SINGH
I. J. Singh
23-07-2012



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS				CUSTOMER		PROJECT TITLE						
				BIDDER/VENDOR		QUALITY PLAN NUMBER						
SHEET 2 OF 6				SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECKED	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.6	PLATE FLANGE, C/FLANGE	1. MECHANICAL & CHEMICAL PROS. 2. DIMENSIONS. 3. SURFACE FINISH	MA	1. MECH & CHEM TEST 2. MEASUREMENT 3. VISUAL EXAM	1/CAST 100% 100%	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	CORRELATION REQ. FOR MAT OTHER THAN IS 2062
1.7	SUCTION STRAINER (IF APPLICABLE)	MECHANICAL & CHEMICAL PROS.	MI	MECH. & CHEMICAL TEST	1/HEAT	APPROVED GA DRG./DATA SHEET	RELEVANT MATERIAL SPECN./ MFR. DRG./ APPROVED DOC	MILL TC/ LAB REPORT	3/2.		2,1	
1.8	MECHANICAL SEAL (IF APPLICABLE)	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET / GA MECH. SEAL	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
1.9	PUMP BEARINGS	TYPE, SIZE, MFRS, NO., MAKE	MA	VISUAL EXAM	100%	APPROVED DATASHEET	APPROVED DATASHEET		3/2.		2,1	COMPLIANCE TC FOR APPROVED MAKE
2.0 IN PROCESS CONTROL												
2.1	ALL COMPONENTS UNDER 1.00 ABOVE	VISUAL DEFECTS, DIMENSIONS	MA	VISUAL EXAM, MEASUREMENT	100%	MFG. DRAWING	MFG. DRAWING	COMPLIANCE TC	3/2.		2,1	
2.2	IMPELLER	CLEANING AND DEBURRING	MA	VISUAL	100%	MFG. DRAWING	MFG. DRAWING		3/2.		2,1	
	IMPELLER	DYNAMIC BALANCING	CR	DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2,1		WITNESSING ONLY FOR SIZE GREATER THAN 10KW
2.3	IMPELLER-ALL ACCESSIBLE SURFACES, DIFFUSERS	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VERIFICATION BY CUSTOMER
2.4	WEARING RING, SHAFT SLEEVES, CASING	DP TEST	MA	DP TEST ON M/CED AREA	100%	APPENDIX 8 OF ASME SEC. VIII DIV. 1		NDT CERTIFICATE	3/2.		2,1	
2.5	SHAFT	DP TEST	MA	DP TEST ON M/CED AREA	100%	ASTM E 165	NO RELEVANT INDICATION ALLOWED	NDT CERTIFICATE	3/2.	2,1		WITNESS BY BHEL & VERIFICATION BY CUSTOMER
2.6	CASINGS/ BOWLS, STAGE BODIES, DISCHARGE HEAD (IF CAST), SUCTION HOUSING, COLUMN PIPE DISCHARGE PIPE ETC	LEAK TIGHTNESS	CR	VISUAL	100%	TECHNICAL DATA SHEET AND NOTE 2	NO LEAKAGE FOR TEST DURATION OF 30 MIN.	HT CERTIFICATE	3/2.	2,1		HAMMERING OF CASTINGS WITH WOODEN/ RUBBER MALLET BEFORE HYDRO TEST
BHEL				PARTICULARS		BIDDER / VENDOR						
				NAME								
				SIGNATURE								
				DATE								
									BIDDER/VENDOR SEAL			

NAME SIGN. DATE	Prepared By AJAY JAIN 23-07-2012	Reviewed By ASHWANI KHANNA 23-07-2012
NAME SIGN. DATE	Approved By I. J. SINGH 23-07-2012	



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS				CUSTOMER		PROJECT TITLE						
				BIDDER/VENDOR		QUALITY PLAN NUMBER						
SHEET 3 OF 6				SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7	FABRICATED COMPONENTS											WELDING PROCEDURE APPROVAL BY BHEL ALT. 3RD PARTY (LLYODS, BVQI OR EQ.) IS ACCEPTABLE.
2.7.1	WELDING PROCEDURE SPECIFICATION	CORRECTNESS	MA	EXAM.	100%	ASME SEC.IX	ASME SEC.IX	QW 482 OF ASME SEC.IX	3/2.		2,1	
2.7.2	WELDING PROCEDURE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 483 OF ASME SEC.IX	3/2.		2,1	
2.7.3	WELDER PERFORMANCE QUALIFICATION	WELD SOUNDNESS	MA	VISUAL,PHYS. TESTS RT (AS APPLICABLE)	100%	ASME SEC.IX	ASME SEC.IX	QW 484 OF ASME SEC.IX	3/2.		2,1	
2.7.4	WELD FIT-UPS	DIMENSION & ALIGNMENT	MA	MEAS.VISUAL EXAM	100%	WPS, MFG . DRAWING	WPS, MFG . DRAWING	IR/LOGBOOK	3/2.			
2.7.5	ROOT RUNS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	NO SURFACE DEFECT	DO.	3/2.		2, 1	
2.7.6	WELDMENTS	SURFACE DEFECTS	MA	PENETRANT TEST	100%	ASTM E 165	ASME-VIII,DIV I	INSPN REPORT	3/2.		2,1	
BHEL				PARTICULARS		BIDDER / VENDOR						
				NAME								
				SIGNATURE								
				DATE								
BIDDER/VENDOR SEAL												

NAME	Prepared By AJAY JAIN <i>Ajay</i>	Reviewed By ASHWANI KHANNA <i>Ashwani</i>	Approved By I. J. SINGH <i>I. J. Singh</i>
SIGN.			
DATE	23-07-2012	23-07-2012	23-07-2012



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS				CUSTOMER		PROJECT TITLE						
				BIDDER/VENDOR		QUALITY PLAN NUMBER						
SHEET 4 OF 6				SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.7.7	BUTT WELDS	INTERNAL DEFECT	MA	UT/RT	100%			IR	3/2.		2.1	
2.7.8	DICHARGE HEAD, COLUMN PIPE, DISCHARGE PIPE, ETC.	1. LEAK TIGHTNESS 2. DIMENSION	CR	1. HYDROTEST 2. MEASUREMENT	100%	TECHNICAL SPEC/ DATA SHEET, MFR DRAWING	1. NO LEAKAGE 2. MFR. DRAWING	IR	3/2.	2.1		
3.0	SUB-ASSEMBLY CONTROL											
3.1	ROTOR ASSEMBLY	ECCENTRICITY	MA	MEASUREMENT	100%	MFR.DRAWING	MFR.DRAWING	IR/LOG BOOK	3/2.		1	
3.2	ROTOR ASSEMBLY RESIDUAL UNBALANCE	STATIC & DYNAMIC	CR	STATIC & DYNAMIC BALANCING	100%	ISO 1940	ISO1940 Gr 6.3	BALANCING CERTIFICATE	3/2.	2.1		WTNESSING ONLY FOR SIZE GREATER THAN 10KW
3.3	COMPLETE PUMP ASSEMBLY	COMPLETENESS, CORRECTNESS, CLEANLINESS, CLEARANCES, FREENESS, ALIGNMENT	MA	VISUAL EXAM MEASUREMENT	100%	APPROVED DRG & MFG STANDARDS	APPROVED DRG & MFG STANDARDS	I.R. & CHECK LISTS	3/2.		2.1	
BHEL				PARTICULARS		BIDDER / VENDOR						
				NAME								
				SIGNATURE								
				DATE					BIDDER/VENDOR SEAL			

NAME	Prepared By AJAY JAIN 	Reviewed By ASHWANI KHANNA 	Approved By I. J. SINGH
SIGN.			
DATE	23-07-2012	23-07-2012	23-07-2012



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS				CUSTOMER		PROJECT TITLE						
				BIDDER/VENDOR		QUALITY PLAN NUMBER						
SHEET 5 OF 6				SYSTEM		ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)						
S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4	FINAL INSPECTION, TESTS & PACKING DESPATCH CONTROL											
4.1	PUMP WITH JOB/SHOP MOTOR ASSEMBLED ON INDIVIDUAL BASE FRAME	1. Q V/S HEAD, 2. Q V/S POWER, 3. Q V/S PUMP EFF. 4. VIBRATION 5. NOISE 6. BEARING TEMP. 7. LEAKAGES	CR	PERFORMANCE TEST	100%	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES FOR VIBRATIONS - AS PER ANSI/HIS 9.6.4-2009 (VALUES AS PER APPROVED DATA SHEET) FOR BEARING TEMP - BEARING HOUSING SHOULD NOT BE UNTOUCHABLY HOT. FOR LEAKAGE - MINOR LEAKAGE (DROP BY DROP) IN CASE OF GLAND PACKING ARRANGEMENT.	I.R., PERF. TEST RECORD, PLOTTED CURVES	3/2.	2,1.			* MINIMUM 7 POINTS FROM SHUT-OFF TO MAX. OPERATING FLOW COVERING ENTIRE OPERATION RANGE OF PUMP SHALL BE TAKEN.
		NPSH/ MIN. SUBMERGENCE REQUIRED	CR	NPSH TEST	1/MODEL	DO.	IR. NPSH/MIN. SUBMERGENCE TEST RECORD, PLOTTED CURVES	3/2.	2,1.			IF SPECIFIED or INSISTED BY CUSTOMER.
4.2	STRIP DOWN AFTER PERFORMANCE TEST	1. UNDUE WEAR TEAR AND RUBBING	MA	VISUAL EXAM AFTER STRIPPING	1/MODEL	NO UNDUE WEAR TEAR & RUBBING ON IMPELLER & WEAR RING	INSP. REPORT	3/2.	1			WITNESS REQUIRED ONLY WHEN ABNORMAL SOUND OBSERVED DURING PERFORMING TEST.
4.3	COMPLETE PUMP WITH UNIT MOTOR BASE FRAME, COUNTER FLANGES ETC. INCLUDING ALL ACCESSORIES AS PER SECTION C OF SPECN.	COMPLETENESS, CLEANLINESS, OVERALL DIMENSIONS ORIENTATION, WORKMANSHIP AND FINISH	MA	VISUAL EXAM MEASUREMENT	100%	APPD. G.A DRAWING	APPD. G.A DRAWING	INSP. REPORT	3/2.	1		
BHEL				PARTICULARS		BIDDER / VENDOR						
				NAME								
				SIGNATURE								
				DATE					BIDDER/VENDOR SEAL			

NAME	Prepared By	Reviewed By
SIGN.	AJAY JAIN	ASHWANI KHANNA
DATE	23-07-2012	23-07-2012
		Approved By
		I. J. SINGH
		23-07-2012



BHARAT HEAVY ELECTRICALS LIMITED
PROJECT ENGINEERING MANAGEMENT
STANDARD QUALITY PLAN

Rev-01

QUALITY PLAN FOR MISCELLANEOUS PUMPS

CUSTOMER

PROJECT TITLE

BIDDER/VENDOR

QUALITY PLAN NUMBER

SHEET 6 OF 6

SYSTEM

ITEM - CENTRIFUGAL PUMPS (HORIZONTAL / VERTICAL)

S. No.	COMPONENT / OPERATION	CHARACTERISTIC CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
4.4	COMPLETION OF ALL STAGES	1.COMPLETION	MA	VERIFICATION OF IR/T.C.ETC.	100%	MFG. DRG./TECHNICAL DOCS.	APPD. MFG. DRG./TECHNICAL DOCS	IR.	3/2.	2,1		WITNESSING ONLY BY BHEL, CUSTOMER VERIFICATION ONLY BUT CHP
4.5	PAINTING	1.SURFACE FINISH, DFT, MARKINGS ETC.	MA	VISUAL EXAM MEASUREMENT AESTHETIC	100%	APPD.DRG.	APPD.DOCS	IR.	3/2.		2	
4.6	PACKING, MARKING	SOUNDNESS OF PACKING	MI	VISUAL AESTHETIC	100%	MFG. STANDARD	MFG. STANDARD		3/2.		2	

MTC -Mill Test Certificate, MA-Major, MI-Minor, TC-Test Certificate, CR-Critical, IGC- Inter Granular Corrosion

- 1.AS CAST HEAT MARKS SHALL BE PROVIDED ON CI CASTING LIKE TOP & BOTTOM CASING.
2. HYDRO TEST PRESSURE SHALL BE AT LEAST 2(TWO) TIMES THE DUTY POINT (OR) 1.5 TIMES OF SHUT OFF HEAD (OR) SYSTEM DESIGN PRESSURE, WHICHEVER IS HIGHER.
3. THIS QAP IS ALSO APPLICABLE FOR SPARES.
4. NO WELD REPAIRS PERMISSIBLE ON CI CASTING.
5. MATERIAL SHALL BE AS PER APPROVED CROSS SECTION DRG./ DATA SHEET.
6. STRIP TEST- INCASE OF ABNORMAL NOISE OBSERVED DURING PERF. TEST, THOSE PUMP WILL BE STRIPPED DOWN FOR VISUAL INSPECTION OF IMPELLER & WEAR SHALL BE OFFERED FOR VISUAL INSPECTION FOR WEAR /RUBBING MARKS.
7. PUMPS WITH MECHANICAL SEAL ARRANGEMENT TO BE TESTED AND SUPPLIED WITH GLAND PACKING ARRANGEMENT. HOWEVER MANUFACTURER TO ENSURE DIMENTIONAL MATCHING OF MECHANICAL SEAL WITH PUMP GA DRAWING.

LEGEND : 1- BHEL OR BHEL NOMINATED THIRD PARTY /END CUSTOMER OF BHEL,
2- VENDOR,
3-SUB-VENDOR

P- PERFORM, W- WITNESS, V-VERIFICATION

BHEL	PARTICULARS	BIDDER / VENDOR	
	NAME		
	SIGNATURE		
	DATE		BIDDER/VENDOR SEAL

NAME
SIGN.
DATE

Prepared By
AJAY JAIN

23-07-2012

Reviewed By
ASHWANI KHANNA

23-07-2012

Approved By
I. J. SINGH

23-07-2012



TITLE:

**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

STANDARD TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **II**

SUB-SECTION: **IIB**

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SUB-SECTION - IIB

STANDARD TECHNICAL SPECIFICATION (ELECTRICAL)



TITLE :
GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO. PE-SS-999-506-E101
VOLUME NO. : II-B
SECTION : D
REV NO. : 00 DATE : 29/08/2005
SHEET : 1 OF 1

GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00

	TITLE : GENERAL TECHNICAL REQUIREMENTS FOR LV MOTORS	SPECIFICATION NO. PE-SS-999-506-E101
		VOLUME NO. : II-B
		SECTION : D
		REV NO. : 00 DATE : 29/08/2005
		SHEET : 1 OF 4

1.0

INTENT OF SPECIFIATION

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer’s work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

2.0

CODES AND STANDARDS

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

IS:325	Three phase Induction motors
IS : 900	Code of practice for installation and maintenance of induction motors
IS: 996	Single phase small AC and universal motors
IS: 4722	Rotating Electrical machines
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines
IS: 4728	Terminal marking and direction of rotation rotating electrical machines
IS: 1231	Dimensions of three phase foot mounted induction motors
IS: 8789	Values of performance characteristics for three phase induction motors
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
IS: 2148	Flame proof enclosures for electrical appliance
IS: 5571	Guide for selection of electrical equipment for hazardous areas
IS: 12824	Type of duty and classes of rating assigned
IS: 12802	Temperature rise measurement for rotating electrical machnines
IS: 12065	Permissible limits of noise level for rotating electrical machines
IS: 12075	Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

3.0

DESIGN REQUIREMENTS

3.1

Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2

Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information
Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

3.3

Starting Requirements

3.3.1

Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2

Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.

	TITLE : GENERAL TECHNICAL REQUIREMENTS FOR LV MOTORS	SPECIFICATION NO. PE-SS-999-506-E101
		VOLUME NO. : II-B
		SECTION : D
		REV NO. : 00 DATE : 29/08/2005
		SHEET : 2 OF 4
The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.		
3.3.3 The following frequency of starts shall apply i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature. ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour) iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor		
3.4 Running Requirements		
3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.		
3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.		
3.5 Stress During bus Transfer		
3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.		
3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.		
3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.		
3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.		
4.0 CONSTRUCTIONAL FEATURES		
4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy		
4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.		
Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled		
4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.		

	TITLE : GENERAL TECHNICAL REQUIREMENTS FOR LV MOTORS	SPECIFICATION NO. PE-SS-999-506-E101
		VOLUME NO. : II-B
		SECTION : D
		REV NO. : 00 DATE : 29/08/2005
		SHEET : 3 OF 4
4.4.	Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.	
4.5	Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.	
4.6	In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation. In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.	
4.7	Terminals and Terminal Boxes	
4.7.1	Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A. Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".	
4.7.2	unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.	
4.7.3	Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or U W & V respectively.	
4.7.4	Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.	
4.7.5	Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.	
4.7.6	Degree of protection for terminal boxes shall be IP 55 as per IS 4691.	
4.7.7	Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.	
4.7.8.	Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.	
4.7.9	Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.	
4.8	Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.	
4.9	General	

	TITLE : GENERAL TECHNICAL REQUIREMENTS FOR LV MOTORS	SPECIFICATION NO. PE-SS-999-506-E101
		VOLUME NO. : II-B
		SECTION : D
		REV NO. : 00 DATE : 29/08/2005
		SHEET : 4 OF 4
4.9.1 Motors provided for similar drives shall be interchangeable. 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors. 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above. 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956. 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz. 4.9.6 Name plate with all particulars as per IS: 325 shall be provided 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions. 5.0 INSPECTION AND TESTING 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied. 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser. 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan. 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A. 6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT a) OGA drawing showing the position of terminal boxes, earthing connections etc. b) Arrangement drawing of terminal boxes. c) Characteristic curves: (To be given for motor above 55 kW unless otherwise specified in Data Sheet). i) Current vs. time at rated voltage and minimum starting voltage. ii) Speed vs. time at rated voltage and minimum starting voltage. iii) Torque vs. speed at rated voltage and minimum voltage. For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling. iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.		

		QUALITY PLAN		CUSTOMER :		PROJECT		SPECIFICATION :				
				BIDDER/ VENDOR :		TITLE		NUMBER :				
		SHEET 1 OF 2		SYSTEM		QUALITY PLAN NUMBER PED-506-00-Q-006, REV-01		SPECIFICATION TITLE				
				ITEM AC ELECT. MOTORS BELOW 55KW (LV)		SECTION		VOLUME III				
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.0	ASSEMBLY	1.WORKMANSHIP	MA	VISUAL	100%	MANUF'S SPEC	MANUF'S SPEC	-DO-	2	-	-	
		2.DIMENSIONS	MA	-DO-	-DO-	MFG. DRG./ MFG. SPEC.	MFG. DRG./ MFG. SPEC.	-DO-	2	-	-	
		3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/COLOUR CODE	MA	VISUAL	100%	MFG.SPEC./ RELEVANT IS	MFG.SPEC. RELEVANT IS	-DO-	2	-	-	
2.0	PAINTING	1.SHADE	MA	VISUAL	SAMPLE	MANUFR'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	NOTE -1 & NOTE-3
3.0	TESTS	1.ROUTINE TEST INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	IS-325/ BHEL SPEC./ DATA SHEET	SAME AS COL.7	TEST REPORT	2	1		NOTE -1 & NOTE-3
		2.OVERALL DIMENSIONS & ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPN. REPORT	2	1	-	NOTE -1 & NOTE-3
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									

		QUALITY PLAN		CUSTOMER :		PROJECT			SPECIFICATION :			
				BIDDER/ :		TITLE			NUMBER :			
		SHEET 2 OF 2		VENDOR		NUMBER PED-506-00-Q-006, REV-01			SPECIFICATION :			
		SYSTEM		ITEM AC ELECT. MOTORS BELOW 55KW (LV)			TITLE :			SECTION VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTICS CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
	NOTES: 1. ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON 2. WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER. 3. FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.	3.NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT	2	1	-	
		<u>Legends for Inspection agency</u> 1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER) P. PERFORM W. WITNESS V. VERIFY										
BHEL		PARTICULARS		BIDDER/VENDOR								
		NAME										
		SIGNATURE										
		DATE					BIDDER'S/VENDORS COMPANY SEAL					

		QUALITY PLAN		CUSTOMER :			PROJECT TITLE		SPECIFICATION : NUMBER :			
				BIDDER/ VENDOR :			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03		SPECIFICATION : TITLE			
		SHEET 1 OF 9		SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION		VOLUME III	
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6	7	8	9	P	W	V	11
1.0	RAW MATERIAL & BOUGHT OUT CONTROL											
1.1	SHEET STEEL, PLATES, SECTION, EYEBOLTS	1.SURFACE CONDITION	MA	VISUAL	100%	-	FREE FROM BLINKS, CRACKS, WAVINESS ETC	LOG BOOK	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	-DO-	3	-	-	
		3.PROOF LOAD TEST (EYE BOLT)	MA	MECH. TEST	-DO-	-DO-	-DO-	INSPEC. REPORT	3	-	2	
1.2	HARDWARES	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, UN-EVENNESS ETC.	-DO-	3	-	-	
		2.PROPERTY CLASS	MA	VISUAL	SAMPLES	MANFR'S DRG./SPEC BOOK	RELEVANT IS/SPEC.	SUPPLIERS TC & LOG	3	-	2	PROPERTY CLASS MARKING SHALL BE CHECKED BY THE VENDOR
1.3	CASTING	1.SURFACE CONDITION	MA	VISUAL	100%		FREE FROM CRACKS, BLOW HOLES ETC.	LOG BOOK	3	-	2	
		2.CHEM. & PHY. PROP.	MA	CHEM & MECH TEST	1/HEAT NO.	MANFR'S DRG./SPEC	RELEVANT IS/	SUPPLIER'S TC	3	-	2	HEAT NO. SHALL BE VERIFIED
		3.DIMENSIONS	MA	MEASUREMENT	100%	MANUFR'S DRG.	MANUFR'S DRG.	LOG BOOK	3	-	2	
1.4	PAINT & VARNISH	1.MAKE, SHADE, SHELF LIFE & TYPE	MA	VISUAL	100% CONTINUOUS	MANFR'S DRG./SPEC	MANFR'S DRG./SPEC	LOG BOOK	3	-	2	
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN		CUSTOMER :		PROJECT			SPECIFICATION :				
				BIDDER/ :		TITLE			NUMBER :				
				VENDOR		QUALITY PLAN			SPECIFICATION :				
SHEET 2 OF 9		SYSTEM		NUMBER PED-506-00-Q-007, REV-03			TITLE			SECTION			
ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		VOLUME III											
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
									P	W	V		
1	2	3	4	5	6	7	8	9	10			11	
1.5	SHAFT (FORGED OR ROLLED)	1. SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	VENDOR'S APPROVAL IDENTIFICATION SHALL BE MAINTAINED	
		2. CHEM. & PHYSICAL PROPERTIES	MA	CHEM. & PHYSICAL TESTS	1/HEAT NO. OR HEAT TREATMENT BATCH NO	MFG. DRG. SPEC.	RELEVANT IS	SUPPLIER'S TC	3	-	2		
		3. DIMENSIONS	MA	MEASUREMENT	100%	-DO-	MANUFR'S DRG.	LOG BOOK	3	-	2		
		4.INTERNAL FLAWS	CR	UT	-DO-	ASTM-A388	MANUFR'S SPEC. BHEL SPEC.	-DO-	3	2	1		
1.6	SPACE HEATERS, CONNEC- TORS, TERMINAL BLOCKS, CABLES, CABLE LUGS, CARBON BRUSH TEMP. DETECTORS, RTD, BTD'S	1. MAKE & RATING	MA	VISUAL	-DO-	MANUFR'S DRG. SPEC.	MANUFR'S DRG. SPEC.	-DO-	3	-	2	FOR DIA OF 55 MM & ABOVE	
		2. PHYSICAL COND.	MA	-DO-	-DO-	-	NO PHYS. DAMAGE, NO ELECTRICAL DISCONTINUITY	-DO-	3	-	2		
		3.DIMENSIONS (WHEREVER APPLICABLE)	MA	MEASUREMENT	SAMPLE	MANUFR'S DRG./ SPEC.	MANUFR'S DRG. / SPEC.	-DO-	3	-	2		
		4.PERFORMANCE/ CALIBRATION	MA	TEST	100%	-DO-	-DO-	INSP. REPORT	3	-	2		
BHEL			PARTICULARS		BIDDER/VENDOR								
			NAME										
			SIGNATURE										
			DATE					BIDDER'S/VENDORS COMPANY SEAL					

		QUALITY PLAN	CUSTOMER :			PROJECT			SPECIFICATION :			
			BIDDER/ :			TITLE			NUMBER :			
			VENDOR			QUALITY PLAN			SPECIFICATION :			
SHEET 3 OF 9			SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION		VOLUME III	
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
1.7	OTHER INSULATING MATERIALS LIKE SLEEVES, BINDINGS CORDS, PAPERS, PRESS BOARDS ETC.	1. SURFACE COND. ETC.	MA	VISUAL	100%	-	NO VISUAL DEFECTS	INSPT. REPORT	3	-	2	FOR MV MOTOR INSULATION/VARNISH THICKNESS SHALL BE MORE THAN THE BURS HEIGHT
		2. OTHER CHARACTERISTICS	MA	TEST	SAMPLE	MANUF'S SPEC.	MANUF'S SPEC.	LOG BOOK AND OR SUPPLIER'S TC	3	-	2	
1.8		SHEET STAMPING (PUNCHED)	1. SURFACE COND.	MA	VISUAL	100%	-	NO VISUAL DEFECTS (FREE FROM BURS)	LOG BOOK	3	-	
		2.DIMENSIONS INCLUDING BURS HEIGHT	MA	MEASUREMENT	SAMPLE	MANUFR'S DRG. .	MANUFR'S DRG.	-DO-	3	-	2	
		3. ACCEPTANCE TESTS	MA	ELECT. & MECH TESTS	-DO-	MANUF'S SPEC./ RELEVANT IS	RELEVANT IS	SUPPLIER'S TC	3	-	2	
1.9	CONDUCTORS	1. SURFACE FINISH	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	LOG BOOK	3*	-	2*	* MOTOR MANUFACTURER TO CONDUCT VISUAL CHECK FOR SURFACE FINISH ON RANDOM BASIS (10% SAMPLE) AT HIS WORKS AND MAINTAIN RECORD FOR VERIFICATION BY BHEL/CUSTOMER.
		2.ELECT. PROP. & MECH. PROP	MA	ELECT. & MECH.TEST	SAMPLES	RELEVANT IS/ BS OR OTHER STANDARDS	RELEVANT IS/ BS OR OTHER STANDARDS	SUPPLIERS TC & VENDOR'S INSPN. REPORTS	3	-	2	
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE									
									BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN		CUSTOMER :		PROJECT TITLE			SPECIFICATION : NUMBER :			
				BIDDER/ VENDOR :		QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE			
		SHEET 4 OF 9		SYSTEM		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION		VOLUME III	
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6	7	8	9	10			11
1.10	BEARINGS	3.DIMENSIONS	MA	MEASUREMENT	-DO-	-DO-	-DO-	Log Book	3	-	2	
		1.MAKE & TYPE	MA	VISUAL	100%	MANFR'S DRG./ APPROVED DATASHEET	MANFR'S DRG./ APPROVED DATASHEET	-DO-	3	-	2	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	BHEL DATA SHEET	BHEL DATA SHEET BEARING MANUF'S CATALOGUES	-DO-	3	-	2	
		3.SURFACE FINISH	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	2	
1.11	SLIP RING (WHEREVER APPLICABLE)	1.SURFACE COND.	MA	VISUAL	100%	-	-DO-	-DO-	3	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
		3.TEMP.WITH-STAND CAPACITY	MA	ELECT.TEST	-DO-	MANUF'S SPEC./ BHEL SPEC.	MANUF'S SPEC./ BHEL SPEC.	-DO-	3	-	2	
		4.HV/IR	MA	-DO-	100%	-DO-	-DO-	-DO-	3	-	2	
1.12	OIL SEALS & GASKETS	1.MATERIAL OF GASKET	MA	VISUAL	100%	MANUF'S DRG/SPECS	MANUF'S DRG./ SPECS.	-DO-	3	-	-	
		2.SURFACE COND.	MA	VISUAL	100%	-	FREE FROM VISUAL DEFECTS	-DO-	3	-	-	
		3.DIMENSIONS	MA	MEASUREMENT	SAMPLE	MANUF'S DRG	MANUF'S DRG	-DO-	3	-	-	
BHEL			PARTICULARS		BIDDER/VENDOR							
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN		CUSTOMER :		PROJECT			SPECIFICATION :			
				BIDDER/ :		TITLE			NUMBER :			
		SHEET 5 OF 9		VENDOR		QUALITY PLAN			SPECIFICATION :			
		SYSTEM		NUMBER PED-506-00-Q-007, REV-03			TITLE					
				ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION		VOLUME III			
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10			11
2.0	IN PROCESS											
2.1	STATOR FRAME WELDING (IN CASE OF FABRICATED STATOR)	1.WORKMANSHIP & CLEANNES	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	3/2	2	-	
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-	
2.2	MACHINING	1.FINISH	MA	VISUAL	100%	-DO-	GOOD FINISH	LOG BOOK	2	-	-	
		2.DIMENSIONS	MA	MEASUREMENT	-DO-	MANUF'S DRG	MANUF'S DRG	-DO-	2	-	-	
		3.SHAFT SURFACE FLOWS	MA	PT	-DO-	RELEVANT SPEC./ASTM-E165	MANUF'S SPEC./BHEL SPEC./	-DO-	2	-	1	
2.3	PAINTING	1.SURFACE PREPARATION	MA	VISUAL	100%	MANFR'S SPEC/BHEL SPEC./RELEVANT STAND	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
		2.PAINT THICKNESS (BOTH PRIMER & FINISH COAT)	MA	MEASUREMENT BY ELCOMETER	SAMPLE	-DO-	-DO-	-DO-	2	-	-	
		3.SHADE	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-	
		4.ADHESION	MA	CROSS CUTTING & TAPE TEST	-DO-	-DO-	-DO-	Log Book	2	-	-	
BHEL			PARTICULARS		BIDDER/VENDOR							
			NAME									
			SIGNATURE									
			DATE						BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN		CUSTOMER :		PROJECT TITLE			SPECIFICATION : NUMBER :				
				BIDDER/ : VENDOR		QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE				
		SHEET 6 OF 9		SYSTEM		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION		VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS	
1	2	3	4	5	6	7	8	9	10	P	W	V	11
2.4	SHEET STACKING	1.COMPLETENESS	MA	MEASUREMENT	SAMPLE	MANUFR'S SPEC.	MANUFR'S SPEC.	Log Book	2	-	-		(FOR MOTORS OF 2MW AND ABOVE) * ON 10% RANDOM SAMPLE
		2.COMPRESSION & TIGHTENING	MA	MEASUREMENT	100%	-DO-	-DO-	Log Book	2	-	-		
		3.CORE LOSS & HOTSPOT	MA	ELECT.TEST	-DO-	-DO-	-DO-	Log Book	2	1*	1		
2.5	WINDING	1.COMPLETENESS	CR	VISUAL	100%	MANUFR'S SPEC./BHEL SPEC.	MANUFR'S SPEC./BHEL SPEC.	Log Book	2	-	-		
		2.CLEANLINESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
		3.IR-HV-IR	CR	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2	-	1		
		4.RESISTANCE	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
		5.INTERTURN INSULATION	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-		
		6.SURGE WITH STAND AND TAN. DELTA TEST	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
2.6	IMPREGNATION	1.VISCOSCITY	MA	PHY. TEST	AT STARTING	-DO-	-DO-	Log Book	2	-	-		FOR MV MOTOR
		2.TEMP. PRESSURE VACCUM	MA	PROCESS CHECK	CONTINUOUS	-DO-	-DO-	Log Book	2	-	-		
		3.NO. OF DIPS	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1		
BHEL			PARTICULARS		BIDDER/VENDOR								
			NAME										
			SIGNATURE										
			DATE						BIDDER'S/VENDORS COMPANY SEAL				

		QUALITY PLAN		CUSTOMER :			PROJECT TITLE		SPECIFICATION : NUMBER :			
				BIDDER/ VENDOR :			QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03		SPECIFICATION : TITLE			
		SHEET 7 OF 9		SYSTEM			ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION		VOLUME III	
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6	7	8	9	10			11
2.7	COMPLETE STATOR ASSEMBLY	4.DURATION	MA	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	1	VERIFICATION FOR MV MOTOR ONLY
2.8	BRAZING/COMPRESSION JOINT	1.COMPACTNESS & CLEANLINESS	MA	VISUAL	100%	-DO-	-DO-	Log Book	2	-	-	
2.9	COMPLETE ROTOR ASSEMBLY	1.COMPLETENESS	CR	-DO-	-DO-	-DO-	-DO-	Log Book	2	-	-	
		2.SOUNDNESS	CR	MALLET TEST & UT	-DO-	-DO-	-DO-	Log Book	2		1	
		3.HV	MA	ELECT. TEST	-DO-	-DO-	-DO-	Log Book	2		1	
2.10	ASSEMBLY	1.RESIDUAL UNBALANCE	CR	DYN. BALANCE	-DO-	MFG SPEC./ ISO 1940	MFG. DWG.	Log Book	2		1	
		2.SOUNDNESS OF DIE CASTING	CR	ELECT. (GROWLER TEST)	-DO-	MFG. SPEC.	MFG. SPEC.	Log Book	2		1	
		1.ALIGNMENT	MA	MEAS.	-DO-	-DO-	-DO-	Log Book	2	-	-	
		2.WORKMANSHIP	MA	VISUAL	-DO-	-DO-	-DO-	Log Book	2	-	-	
		3.AXIAL PLAY	MA	MEAS.	-DO-	-DO-	-DO-	Log Book	2	-	1	
		4.DIMENSIONS	MA	-DO-	-DO-	MFG.DRG./ MFG SPEC.	MFG. DRG/ RELEVANT IS	Log Book	2	-	-	
		5.CORRECTNESS, COMPLETENESS TERMINATIONS/ MARKING/ COLOUR CODE	MA	VISUAL	100%	MFG SPEC. RELEVANT IS	MFG SPEC. RELEVANT IS	Log Book	2	-	-	
		6. RTD, BTD & SPACE HEATER MOUNTING.	MA	VISUAL	100%	MFG SPEC. RELEVANT IS	MFG SPEC. RELEVANT IS	Log Book	2		1	
BHEL			PARTICULARS		BIDDER/VENDOR							
			NAME									
			SIGNATURE									
			DATE									
BIDDER'S/VENDORS COMPANY SEAL												

		QUALITY PLAN		CUSTOMER :		PROJECT TITLE			SPECIFICATION : NUMBER :			
				BIDDER/ : VENDOR		QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03			SPECIFICATION : TITLE			
		SHEET 8 OF 9		SYSTEM		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)			SECTION		VOLUME III	
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
1	2	3	4	5	6	7	8	9	10	11	12	
3.0	TESTS	1.TYPE TESTS INCLUDING SPECIAL TESTS AS PER BHEL SPEC.	MA	ELECT.TEST	1/TYPE/SIZE	IS-325/ BHEL SPEC./ DATA SHEET	IS-325/ BHEL SPEC./ DATA SHEET	TEST REPORT	2	1*	1	* NOTE - 1
		2.ROUTINE TESTS INCLUDING SPECIAL TEST AS PER BHEL SPEC.	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1\$	1	\$ NOTE - 2
		3.VIBRATION & NOISE LEVEL	MA	-DO-	100%	IS-12075 & IS-12065	IS-12075 & IS-12065	-DO-	2	1\$	1	\$ NOTE - 2
		4.OVERALL DIMENSIONS AND ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPC. REPORT	2	1	-	
		5.DEGREE OF PROTECTION	MA	ELECT. & MECH. TEST	1/TYPE/ SIZE	RELEVANT IS	BHEL SPEC. AND DATA SHEET	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		6. MEASUREMENT OF RESISTANCE OF RTD & BTD	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1\$	1	\$ NOTE - 2
		7. MEASUREMENT OF RESISTANCE, IR OF SPACE HEATER	MA	-DO-	100%	-DO-	-DO-	-DO-	2	1\$	1	\$ NOTE - 2
		8. NAMEPLATE DETAILS	MA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPC. REPORT	2	1\$	1	\$ NOTE - 2
		9.EXPLOSION FLAME PROOF NESS (IF SPECIFIED)	MA	EXPLOSION FLAME PROOF TEST	1/TYPE	IS-3682 IS-8239 IS-8240	IS-3682 IS-8239 IS-8240	TC	2	-	1	TC FROM AN INDEPENDENT LABORATORY, REFER NOTE-3
		10. PAINT SHADE, THICKNESS & FINISH	MA	VISUAL & MEASUREMENT BY ELKOMETER	SAMPLE	BHEL SPEC. & DATA SHEET	BHEL SPEC. & DATA SHEET	TC	2	1\$	1	SAMPLING PLAN TO BE DECIDED BY INSPECTION AGENCY \$ NOTE - 2
BHEL			PARTICULARS			BIDDER/VENDOR						
			NAME									
			SIGNATURE									
			DATE									
									BIDDER'S/VENDORS COMPANY SEAL			

		QUALITY PLAN		CUSTOMER :		PROJECT TITLE		SPECIFICATION : NUMBER :				
				BIDDER/ VENDOR		QUALITY PLAN NUMBER PED-506-00-Q-007, REV-03		SPECIFICATION : TITLE				
		SHEET 9 OF 9		SYSTEM		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV & MV)		SECTION		VOLUME III		
SL. NO.	COMPONENT/OPERATION	CHARACTERISTIC CHECK	CAT.	TYPE/ METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	AGENCY			REMARKS
									P	W	V	
1	2	3	4	5	6	7	8	9	10		11	
NOTES: 1 DEPENDING UPON THE SIZE AND CRITICALLY, WITNESSING BY BHEL SHALL BE DECIDED. 2 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON. 3 IN CASE TEST CERTIFICATES FOR THESE TESTS ON SIMILAR TYPE, SIZE AND DESIGN OF MOTOR FROM INDEPENDENT LABORATORY ARE AVAILABLE, THESE TEST MAY NOT BE REPEATED. 4 WHEREVER CUSTOMER IS INVOLVED IN INSPECTION, AGENCY (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER. <u>Legends for Inspection agency</u> 1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER) P. PERFORM W. WITNESS V. VERIFY												
BHEL			PARTICULARS		BIDDER/VENDOR							
			NAME									
			SIGNATURE									
			DATE									
											BIDDER'S/VENDORS COMPANY SEAL	

SUB-VENDOR LIST FOR ELECTRICAL ITEMS

ITEM DESCRIPTION	SL NO.	VENDOR NAME
CABLE GLANDS	1	ALLIED TRADERS & EXPORTERS
	2	ARUP ENGG & FOUNDRY WORKS
	3	BALIGA LIGHTING EQPT.PVT.LTD.
	4	COMMET BRASS PRODUCTS
	5	DOWELLS
	6	ELECTROMAC INDUSTRIES
	7	INCAB
CABLE LUGS	1	DOWELLS
	2	UNIVERSAL MACHINES LTD.
LV MOTORS (NON FLAME PROOF)	1	ABB
	2	BHARAT BIJLEE LTD.
	3	CROMPTON GREAVES
	4	GE-POWER
	5	KIRLOSKAR ELECTRIC CO LTD.
	6	LAXMI HYDRAULICS PVT. LTD
	7	MARATHON
	8	NGEF
	9	RAJINDRA ELECT INDUSTRIES
	10	SIEMENS



TITLE:

**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

STANDARD TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **III**

SUB-SECTION:

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SECTION III

DOCUMENTS TO BE SUBMITTED BY BIDDER



TITLE:

**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

STANDARD TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **IIIA**

SUB-SECTION:

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SECTION IIIA

**GUARANTEE SCHEDULE
(TO BE SUBMITTED ALONG WITH THE BID BY ALL BIDDERS)**

**SCHEDULE OF PERFORMANCE GUARANTEES****2X660 MW UDANGUDI (TANGEDCO)**

SPECN. NO.:

PE-TS-435-100-N001, Rev-00

VOLUME:

--

SECTION:

IIIA Sheet 1 of 1

REV. NO.

00

DATE:

27.09.2019

Following parameters are guaranteed for following pumps

Sl. No.	Pump Description	Guaranteed Capacity	Guaranteed TDH	Guaranteed Pump Eff.	Guaranteed Motor Eff.	Guaranteed Power consumption at inlet to motor terminals	Pump model	Motor Rating	Pump GD ² Value for HT motor only	Pump RPM	T/S Curve attached for HT motor
		(M3/Hr)	(MWC)	%	%	(KW)		(KW)			
	Horizontal pumps (Type-I)										
1	#DMCW PUMPS FOR TG & STATION AUXILIARIES	1500	44.5		95						
2	#DMCW PUMPS FOR SG AUXILIARIES	500	58								
3	#AHP & CHP MAKEUP PUMPS	370	62								
4	#POTABLE WATER PUMPS	50	72								
5	#SERVICE WATER PUMPS	100	64								
6	#HVAC MUP PUMPS	110	60								
7	#APH/ESP WASH PUMPS	750	86		95						
8	#HOTWELL MAKEUP PUMPS	270	50								
9	#DM MAKEUP PUMPS	30	60								
10	#BOILER FILL PUMPS	150	130								

Note: 1 # Bid evaluation and LD is applicable for these pumps only as per clause 4.00.00 of Section-IIA & Data Sheet-A of Section-ID of Technical Specification for pumps.

We the undersigned hereby undertake to meet the performance guarantees as listed in the table above on the conditions as elsewhere specified. Any variation of the specified conditions during official tests will be taken in account by the customer

PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE

NAME

DESIGNATION

SIGNATURE

DATE

COMPANY SEAL



TITLE:

**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

STANDARD TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **IIIB**

SUB-SECTION:

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SECTION IIIB

**COMPLIANCE CERTIFICATE
(TO BE SUBMITTED ALONG WITH THE BID BY ALL BIDDERS)**

	TECHNICAL SPECIFICATIONS	SPECN. NO.: PE-TS-435-100-N001, Rev.0		
	MISCELLANEOUS PUMPS COMPLIANCE CERTIFICATE	VOLUME:	--	SECTION: IIIB
		REV. NO.	0	DATE: 27.09.2019

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnish same with the offer.

- The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions/ deviations with regard to same.
- QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein.

QP will be subject to BHEL/ CONSULTANT/ CUSTOMER approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc.
- All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/ CONSULTANT/ CUSTOMER approval.
- There are no other deviation with respect to specification other than those furnished in the 'Schedule of Deviations'.
- Bidder shall include the cost of Mandatory Spares, unless specified otherwise in Sec-IA of the specification or NIT.

Any mandatory spares stated as not applicable, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.
- The offered materials should be either equivalent or superior to those specified. Also for components where material is not specified it shall be suitable for intended duty. All materials shall be subject to approval in the event of order.
- Prices for recommended spares (if any) for 3 years operation shall be furnished separately & not included in the base price.
- The commissioning spares (if any) are supplied on 'As Required Basis' & prices for same included in the base price (If bidders reply to this is "No commissioning spares are required" and if some spares are actually required during commissioning same shall be supplied by bidder without any cost to BHEL).
- All sub vendors shall be as per BHEL/CONSULTANT/CUSTOMER approved list.
- Tests for noise, vibration, parallel running etc. for pumps shall be conducted at site by Pump Vendor/BHEL as per cl. no. 3.04.00 of Section-IIA and if the site performance is found not meeting the requirements in any respect as specified, than the equipment shall be rectified or replaced by the vendor, at his own cost.
- Any special tools & tackles, if required, shall be in bidder's scope.
- All models offered have been supplied by bidder in the past and are meeting the experience qualifying criteria of BHEL/CONSULTANT/CUSTOMER (viz. offered model is successfully operating in two separate stations for at least one year or as specified in technical PQR). Any deviation to this criteria shall be suitably highlighted in deviation schedule.
- All selected motor ratings have minimum margins as per Datasheet A, Section ID.

We the undersigned hereby undertake to meet the compliance requirements as listed above on the conditions as elsewhere specified.

PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL



TITLE:

**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

STANDARD TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-426 -100-N001**

SECTION: **IIIC**

SUB-SECTION:

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SECTION IIIC

**DEVIATION SCHEDULE
(TO BE SUBMITTED ALONG WITH THE BID BY ALL BIDDERS)**

AS PER NIT FORMAT



TITLE:

**TECHNICAL SPECIFICATION
MISCELLANEOUS PUMPS**

STANDARD TECHNICAL REQUIREMENTS

SPEC. NO.: **PE-TS-435-100-N001**

SECTION: **IIID**

SUB-SECTION:

REV. NO. **00** DATE 27.09.2019

SHEET **1** OF **1**

SECTION IIID

DATA SHEET – B FOR PUMPS

ELECTRICAL LOAD DATA FORMAT

CABLE SCHEDULE

MOTOR DATASHEET-C

**(TO BE SUBMITTED BY SUCCESSFUL BIDDER AFTER AWARD OF
CONTRACT)**

		PROJECT: MISCELLANEOUS PUMPS DATASHEET - B	
SL.	DESCRIPTION	UOM	PUMP DATA
1.0	GENERAL		
1.1	Designation of the Pump		
1.2	Manufacturer		
1.3	Model No.		
1.4	No. of pumps	Nos.	
1.5	System Design Pressure	Kg/cm ²	
1.6	Specific Gravity of fluid to be handled	-	
2.0	PERFORMANCE PARAMETERS		
2.1	Performance standard		
2.2	Rated capacity. (No negative tolerance)	M ³ /hr	
2.3	Total Dynamic Head (TDH) at rated capacity (No negative tolerance)	MWC	
2.4	Shut off head	MWC	
2.5	Range of Operation of the Pump		
	a) Min.Flow	M ³ /hr	
	b) Max.Flow	M ³ /hr	
2.6	The pumps offered have continuously rising head capacity curves from the duty point towards shut off point.		
2.7	The pumps offered have stable rising H-Q curves within the "Range of Operation"		
2.8	Pump rated speed	RPM	
2.9	Vibration measurements (2.9.2 is applicable in addition to 2.9.1 for Pumps with speed less than 600 RPM)		
2.9.1	Max.value of vibration on any pump /motor bearing w.r.t. velocity (Vrms) as per ANSI/ HIS 9.6.4 for speed > 600 RPM		
	a) Guaranteed at manufacturer's works	mm/s	
	b) Guaranteed at site	mm/s	
2.9.2	Max.value of vibration on any pump /motor bearing w.r.t. peak to peak amplitude as per ANSI/ HIS 9.6.4 for speed <= 600 RPM		
	a) Guaranteed at manufacturer's works	microns	
	b) Guaranteed at site	microns	
2.10	Max. noise Level (Guaranteed at site)	dB	
2.11	Guaranteed Pump efficiency at rated head & rated capacity without -ve tolerance	%	
2.12	Power consumption		
	a) Guaranteed pump input power at duty point	KW	
	b) Guaranteed max. Pump input power within range of operation.	KW	
	c) Max. pump input power at shut off	KW	
	d) Guranteed power at motor input	KW	
2.13	NPSH required at rated capacity	MWC	
3.0	DESIGN & CONSTRUCTION FEATURES		
3.1	Type of pump casing		
3.2	Pump duty		
3.3	Type of Impeller		
3.4	Location		
3.5	Pump suitable for parallel operation		
3.6	Torque speed curve of the pump & drive motor furnished for pumps with drive motor rating of 100 KW and above.		
3.7	Pump number of stages		

		PROJECT: MISCELLANEOUS PUMPS DATASHEET - B	
SL.	DESCRIPTION	UOM	PUMP DATA
3.8	Specific speed $N = \frac{\text{RPM} \times (\text{Flow in USGPM})^{1/2}}{(\text{Head in Ft.})^{3/4}}$		
3.9	Minimum suction head required in MLC for pump operation at maximum discharge point within the 'Range of Operation' specified (NPSHR at max. flow).		
3.10	Whether pump is suitable/designed so that pump internals can be attended without disturbing suction and discharge piping.		
3.11	Type of coupling between pump & motor		
3.12	Bearing (DE & NDE)		
	a) Type and manufacturer		
	b) Bearing no.		
	c) Type of lubrication		
	d) Design life (Hrs.)		
3.13	Shaft Sealing arrangement		
	a) Type and manufacturer		
	b) Sealing liquid		
	c) Requirement of external water if any		
	i) Quality		
	ii) Quantity/ Pump	M ³ /hr	
3.14	In case separate oil/grease/water pump or any such equipment required for bearing lubrication/stuffing box gland sealing, furnish full technical details of these equipment and their drive.		
4.0	MATERIAL OF CONSTRUCTION (Indicate applicable code/ standard)		
4.1	Casing		
4.2	Impeller		
4.3	Shaft		
4.4	Shaft sleeves		
4.5	Wear ring		
4.6	fasteners		
4.7	Gland		
4.8	Lantern ring		
4.9	Mechanical seals (faces)/		
	Gland packing		
4.10	Base plate		
5.0	CONNECTIONS AND OTHER DIMENSIONAL DETAILS		
5.1	Impeller diameter	mm	
6.0	DRIVE DATA		
6.1	Drive unit output at 50°C ambient condition	KW/ P	
7.0	INSPECTION & TESTING		
7.1	Material test		
7.2	Hydrostatic test pressure	Kg/cm ²	
7.3	Hydrostatic test duration	Min.	
7.4	Performance test on pump at shop		
7.5	Dyanamic balance test		
8.0	WEIGHT AND LOADING DATA		
8.1	Weight of the pump & drive assembly	Kg	
8.2	Weight of the heaviest piece to be handled	Kg	

		PROJECT: MISCELLANEOUS PUMPS DATASHEET - B		
SL.	DESCRIPTION	UOM	PUMP DATA	
8.3	Size of base plate (length x width)	mm		
9.0	ADDITIONAL INFORMATION FOR VERTICAL PUMPS			
9.1	Type of pump			
9.2	No. of stages for Vertical Turbine Pump	Nos.		
9.3	Bowl Head	MLC		
9.4	Bowl Efficiency	%		
9.5	Setting Length	m		
9.6	Column pipe OD X Thickness	mm X mm		
9.7	No of column pieces	Nos.		
9.8	No of intermediate shafts	Nos.		
9.9	No of bearings	Nos.		
9.10	Type & make of Bearing			
9.11	Sealing/lubrication arrangement of bearings			
9.12	Capacity of overhead forced lubrication tank	m ³		
9.13	Nos of forced lubrication pumps	Nos.		
9.14	Capacity of forced lubrication pumps	m ³ /Hr		
9.15	TDH of forced lubrication pumps	MLC		

[illegible]

ANNEXURE III

[illegible]

Explanatory notes for filling up cable list for routing through WinPath, the cable routing program (developed by Corporate R&D) being used in PEM.

1. For the purpose of clarity, it may please be noted that the information given in regard to the cables to be routed through WinPath as per the system elaborated below is called "Cable List", while the term "Cable Schedule" applies to the cable list with routing information added after routing has been carried out.
2. The cable list shall be entered as an MS Excel file in the format as per enclosed template EXT_CAB_SCH_FORMAT.XLS. No blank lines, special characters, header, footer, lines, etc. shall be introduced in the file. No changes shall be made in the title line (first line) of the template.
3. The field properties shall be as under:
 - a. UNITCABLENO: A/N, up to sixteen (16) characters; each cable shall have its own unique, unduplicated cable number. In case this rule is violated, the cable cannot be taken up for routing.
 - b. FROM: A/N, up to sixty (60) characters; the "From" end equipment/ device description and location to be specified here. Information in excess of 60 characters will be truncated after 60 characters.
 - c. TO: A/N, up to sixty (60) characters; the "To" end equipment/ device description and location to be specified here. Information in excess of 60 characters will be truncated after 60 characters.
 - d. PURPOSE: A/N, up to sixty (60) characters; the purpose (i.e. power cable/ indication/ measurement, etc.) to be specified here. Information in excess of 60 characters will be truncated after 60 characters.
 - e. REMARKS: A/N, up to forty (40) characters; Any information pertinent to routing to be specified here (e.g., cable number of the cable redundant to the cable number being entered). Information in excess of 40 characters will be truncated after 40 characters.
 - f. CABLESIZE: A/N, 7 characters exactly as per the codes indicated below shall be specified here. The program cannot route cables described in any other way/ format.
 - g. PATHCABLENO: Field reserved for utilization by the program. User shall not enter any information here.
4. One list shall be prepared for each system/ equipment (i.e., separate and unique cable lists shall be prepared for each system).
5. The cables shall be described as per the scheme listed below:

A	NN	A	NNN
Cable	No. of cores	Cable code	Cable size
Voltage	(e.g. 01,03,3H, 07)	(See C below)	(e.g. 035,185,2.5, 0.5)
Code (see B below)			

(A) SYSTEM VOLTAGE CODES:

(ac) A = 11KV, B = 6.6KV, C = 3.3KV, D = 415V, E = 240V, F = 110V
 (dc) G = 220V, H = 110V, J = 48V, K = +24V, L = -24V

(B) CABLE VOLTAGE CODES:

A = 11KV (Power cables)

Explanatory notes for filling up cable list for routing through WinPath, the cable routing program (developed by Corporate R&D) being used in PEM.

B = 6.6KV (Power cables)
C = 3.3KV (Power cables)
D = 1.1KV (LV & DC system power & control cables)
E = 0.6KV (0.5 sq. mm. Control cables)

(C) CABLE CODES

PVC Copper

A = Armoured FRLS	B = Armoured Non-FRLS
C = unarmoured FRLS	D = Unarmoured Non-FRLS

PVC Aluminium

E = Armoured FRLS	F = Armoured Non-FRLS
G = unarmoured FRLS	H = Unarmoured Non-FRLS

XLPE Copper

J = Armoured FRLS	K = Armoured Non-FRLS
L = unarmoured FRLS	M = Unarmoured Non-FRLS

XLPE Aluminium

N = Armoured FRLS	P = Armoured Non-FRLS
Q = unarmoured FRLS	R = Unarmoured Non-FRLS

S = FIRE SURVIVAL CABLES
T = TOUGH RUBBER SHEATH
U = OVERALL SCREENED
V = PAIRED OVERALL SCREENED
W = PAIRED INDIVIDUAL SCREENED
Y = COMPENSATING CABLES
I = PRE-FABRICATED CABLES
Z = JELLY FILLED CABLES

	TITLE MOTORS DATA SHEET – C 2 x 660MW UDANGUDI STPP	SPECIFICATION NO.
		VOLUME II B
		SECTION D
		REV NO. 00 DATE 21.05.18
		SHEET 1 OF 2

S. No.	Description		Data to be filled by successful bidder
A.	General		
1	Manufacturer & country of origin		
2	Motor type		
3	Type of starting		
4	Name of the equipment driven by motor & Quantity		
5	Maximum Power requirement of driven equipment		
6	Rated speed of Driven Equipment		
7	Design ambient temperature		
B.	Design and Performance Data		
1	Frame size & type designation		
2	Type of duty		
3	Rated Voltage		
4	Permissible variation for		
5	a	Voltage	
6	b	Frequency	
7	c)	Combined voltage & frequency	
8	Rated output at design ambient temp (by resistance method)		
9	Synchronous speed & Rated slip		
10	Minimum permissible starting voltage		
11	Starting time in sec with mechanism coupled		
12	a)	At rated voltage	
13	b)	At min starting voltage	
14	Locked rotor current as percentage of FLC (including IS tolerance)		
15	Torque		
	a)	Starting	
	b)	Maximum	
16	Permissible temp rise at rated output over ambient temp & method		
17	Noise level at 1.0 m (dB		
18	Amplitude of vibration		
19	Efficiency & P.F. at rated voltage & frequency		
	a)	At 100% load	
	c)	At 75% load	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

	TITLE MOTORS DATA SHEET – C 2 x 660MW UDANGUDI STPP	SPECIFICATION NO.
		VOLUME II B
		SECTION D
		REV NO. 00 DATE 21.05.18
		SHEET 2 OF 2

S. No.	Description	Data to be filled by successful bidder
	c) At starting	
C.	Constructional Features	
1	Method of connection of motor driven equipment	
2	Applicable Standard	
3	DOP of Enclosure	
4	Method of cooling	
5	Class of insulation	
6	Main terminal box	
	a) Type	
	b) Power Cable details (Conductor, size, armour/unarmour)	
	c) Cable Gland & lugs details (Size, type & material)	
	d) Permissible Fault level (kArms & duration in sec)	
7	Space heater details (Voltage & watts)	
8	Flame proof motor details (if applicable)	
	a) Enclosure	
	b) suitability for hazardous area	
	i Zone	O / I / II
	ii Group	IIA / IIB / IIC
9	No. of Stator winding	
10	Winding connection	
11	Kind of rotor winding	
12	Kind of bearings	
13	Direction of rotation when viewed from NDE	
14	Paint Shade & type	
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	
D.	Characteristic curves/ drawings (To be enclosed for motors of rating $\geq 55\text{KW}$)	
	a) Torque speed characteristic	
	b) Thermal withstand characteristic	
	c) Current vs time	
	d) Speed vs time	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			